

# EntelliGuard<sup>®</sup> Digital Test Kit

## User's Guide



imagination at work

# DEH-4568

## WARNINGS, CAUTIONS, AND NOTES AS USED IN THIS PUBLICATION



### WARNINGS

Warning notices are used in this publication to emphasize that hazardous voltage, currents, or other conditions that could cause personal injury are present in this equipment or may be associated with its use.

Warning notices are also used for situations in which inattention or lack of equipment knowledge could cause either personal injury or damage to equipment.



### CAUTIONS

Caution notices are used for situations in which equipment might be damaged if care is not taken.



### NOTES

Notes call attention to information that is especially significant to understanding and operating the equipment.

---

This document is based on information available at the time of publication. While efforts have been made to ensure accuracy, the information contained herein does not cover all details or variations in hardware and software, nor does it provide for every possible contingency in connection with installation, operation, and maintenance. Features may be described herein that are not present in all hardware and software systems. GE Consumer & Industrial assumes no obligation of notice to holders of this document with respect to changes subsequently made.

GE Consumer & Industrial makes no representation or warranty, expressed, implied, or statutory, with respect to, and assumes no responsibility for the accuracy, completeness, sufficiency, or usefulness of the information contained herein. No warranties of merchantability or fitness for purpose shall apply.

EntelliGuard is a registered trademark of the General Electric Company.

## 1-1 Description

EntelliGuard® TU Test Kit is a lightweight, portable test instrument designed for field-testing of EntelliGuard TU Trip Units. The Test Kit includes the following features:

- Operation from a 100-240VAC 50/60 Hz Universal plug supply or two 9-volt alkaline batteries (batteries not supplied).
- Provides power to the trip unit for viewing and setting set-points with no load on the breaker
- Verification of metering (phase simulation)
- Trip test
- Temporarily disable the Ground Fault feature during single phase breaker testing

## 1-2 Summary of Operation

The functions of the various switches and LEDs on the panel (see front cover) are as follows:

### Power Switch

Pressing this button will power-up the trip unit. The green Power LED will indicate that power has been provided to the trip unit. A red Battery Low LED indicates that the batteries in the test kit should be replaced.

### Trip Breaker Switch

Pressing this button will cause the breaker to trip. The switch has an associated red LED that indicates the state of the switch. If the LED is illuminated, then switch is ON and firing the flux shifter to trip the breaker.

### Disable Ground Fault

Pressing this button will cause the trip unit GF protection to be temporarily disabled. To enable the GF, the switch and associated red LED must be turned off. The GF switch has an associated red LED that indicates the state of the switch (GF disabled when red LED illuminated).



---

**WARNING:** When using EntelliGuard Digital Test Kit to defeat Ground Fault function of EntelliGuard Trip Units, the ground fault protection of the trip unit will not be active. Power to the breaker should be removed prior to using this feature. Before applying load to the breaker, ensure that the Disable GF LED is OFF or the Test Kit is disconnected from the trip unit.

Failure to follow this procedure can result in deactivation of the Trip Unit GF protection.

### Test Mode Switch

Pressing this button will cause the trip unit to be in a testing mode. Current shall **not** be applied to the breaker at this state. The switch has a red LED that indicates the state of the switch (LED On when switch is ON).



**CAUTION:** With the Test Mode enabled, the EntelliGuard trip unit will not provide correct protection to the system, which may result in a trip below desired levels. Power should be disconnected from the circuit breaker prior to entering Test Mode. Ensure that the Test Mode LED is OFF when in normal operation.

Failure to follow this procedure can result in improper operation of the system.

### Phase Simulation

This switch is enabled only if the trip unit is in the Test Mode condition. By pressing this switch, the EntelliGuard trip unit will display approximately 100A on each current phase. This can be viewed on the trip unit LCD under METER menu. The switch has a red LED that indicates the state of the switch (LED On when Switch is ON).


## 1.3 Specifications

The EntelliGuard Digital Test Kit Catalog Number is GTUTK20. It includes the following components:


- Test kit box
- 24VDC power supply – CUI Inc., Part Number EMS 240075-P5P-SZ or equivalent. Voltage polarity is as follows:



- Serial Communication Test Kit cable (6 ft DB9 (male)/DB9 (female) cable). This cable connects the Test Kit to a PC. Part number 45-0314 from GC Electronics or equivalent. Below is the connection diagram between the test kit and PC.



- EntelliGuard Trip Unit cable (6-ft. SVGA/VGA Monitor Extension Cable HD15M to HD15F). This cable connects the Test Kit to EntelliGuard Trip Unit. Part Number SPC20050 from SPC Technology or equivalent. Below is the connection diagram between the Test Kit and Trip Unit



- Batteries – two 9V alkaline batteries.



Figure 1. EntelliGuard Test Kit Connections

## 1.4 Detailed Operation

**Cables:** The Test Kit is provided with a 15-pin trip unit cable that connects to the side (EntelliGuard trip unit port) of the test kit and to the front of the trip unit. This cable allows the test kit to power the trip unit and to apply signals for the test functions provided below.

In addition, the test kit is provided with a 9-pin cable that connects to the top (serial communication port) of the test kit to support Modbus communication. Modbus communication requires a computer, Modbus software and configuration to be used. See the EntelliGuard Trip Unit Manual (DEH-4567) for Modbus register information. Contact your GE Account Manager for availability of software specifically for use with the EntelliGuard Trip Unit.

**Powering the trip unit:** The test kit can be used to power the trip unit as follows:

- Connect the EntelliGuard Trip Unit cable to the trip unit.
- Press the Power button to power-on the trip unit.

The power on LED will be lit. The trip unit can also be powered by external 24V that is wired to the secondary disconnect of the circuit breaker and is powered when sufficient current is flowing through the circuit breaker. The test kit can be used to power the trip unit in cases where current is flowing through the circuit breaker but the current is insufficient to power the trip unit. Applying power to the trip unit from the test kit while the trip unit is powered from another source will not damage the trip unit.

**Trip Breaker Test:** Pressing the Trip Breaker button signals the trip unit to trip the breaker by firing the flux shifter. This can be used to verify that the flux shifter is connected and installed properly and that the flux shifter trips the breaker mechanism. This test is performed by having the test kit connected and the breaker closed and then pushing the Trip Breaker button. The breaker will then open.

If trip unit fails to trip the breaker in this test, remove the breaker from service and refer the trip unit to an authorized GE service representative.

**Ground Fault Disable:** This feature should only be used when testing the breaker with the breaker disconnected from the source (upstream breaker or switch open or breaker racked out). This test is used when performing primary injection testing of overcurrent or short circuit protection features on 1 phase of the circuit breaker. This single-phase current will appear as a ground fault to the trip unit due to the phase unbalance (only 1 phase current applied). The ground fault disable feature will allow this testing to occur without the unit tripping on ground fault. Pressing the Disable Ground Fault button signals the trip unit to temporarily disable the GF protection.



**WARNING:** When using EntelliGuard Digital Test Kit to defeat Ground Fault function of EntelliGuard Trip Units the ground fault protection of the trip unit will not be active. Power to the breaker should be removed prior to using this feature. Before applying load to the breaker, ensure that the Disable GF LED is OFF or the Test Kit is disconnected from the trip unit.

Failure to follow this procedure can result in deactivation of the Trip Unit GF protection.

**Test Mode:** This feature should only be used when testing the breaker with the breaker disconnected from the source (upstream breaker or switch open or breaker racked out). When in test mode, the Phase Simulation button is used to apply a fixed voltage to the sensing circuitry for each phase. This will test the measurement circuitry of the trip unit. If the unit is working properly then 100A ± 10A will appear for each phase on the trip unit METER display.



**CAUTION:** With the Test Mode enabled, the EntelliGuard trip unit will not provide correct protection to the system, which may result in a trip below desired levels. Power should be disconnected from the circuit breaker prior to entering Test Mode. Ensure that the Test Mode LED is OFF when in normal operation.

Failure to follow this procedure can result in improper operation of the system.

GE  
41 Woodford Avenue, Plainville, CT 06062  
www.geelectrical.com  
© 2008 General Electric Company



imagination at work