





- DEVICE LIST
- TC - SHUNT TRIP COIL
 - o - AUX. SW.-OPEN WHEN BKR. IS OPEN
 - o - AUX. SW.-CLOSED WHEN BKR. IS OPEN
 - AL - ALARM DEVICE
 - UV - UNDERVOLTAGE TRIP DEVICE COIL
 - AS - AUXILIARY SWITCH
 - SD - SECONDARY DISCONNECT
 - CT - TRIPPING TRANSFORMER
 - STD - STATIC TRIP DEVICE

NOTE 1:
CONTACT DESIGNATIONS FOR
WIRES 15 & 16 ARE FOUND
ON TRIP W/D 18-738-600-40




ALL REVISIONS MUST BE MADE ON CAD SYSTEM.

- - SINGLE FASTON TAB.
ONE CONNECTION ONLY
- - MULTIPLE CONNECTIONS POSSIBLE

CLASS 'C' WIRING
#14 WIRE SIS. 00-357-286-341
#10 WIRE SIS. 00-357-286-003



WIRE CHART			
WIRE	TERMINALS		SIZE
1	SD12	AS3	14
2	SD15	AS2	10
2A	AS1	TC2	10
3	SD14	AS7	14
4	SD13	AS8	14
5	SD16	AS4	14
6	SD11	TC1	10
7	SD10	AS5	14
8	SD9	AS6	14
15	SD2	SEE NOTE 1	
16	SD1		



WAS STD4, STD9
ADDED NOTE 1
ECO LV0883-03
03/12/22/88

WIRE TO TC & SW
WIRE #14
02/11/18/02

4 WIRE
AUX SW (1a, 2b)
TRIP COIL
CAD MT
DRAWN RAB
CHECK
APVD

PRODUCT TYPE
RL

Siemens Energy & Automation, Inc.

DWG NAME
MANUALLY OPERATED
AIR CIRCUIT BREAKER
WIRING DIAGRAM

SIZE B	FSCM NO.	DWG NO. 18-738-601-431	ISSUE 03
SCALE: NTS		SHEET 1 OF 1	