



WIRE CHART		
WIRE	TERMINALS	SIZE
15	SD2	SEE NOTE 1
16	SD1	



STD
1 2 3 4 5 6 7 8 9 10

SD
1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16



- DEVICE LIST
- TC - SHUNT TRIP COIL
 - B - AUX. SW. - OPEN WHEN BKR. IS OPEN
 - AL - ALARM DEVICE
 - UV - UNDERVOLTAGE TRIP DEVICE COIL
 - AS - AUXILIARY SWITCH
 - SD - SECONDARY DISCONNECT
 - CT - TRIPPING TRANSFORMER
 - STD - STATIC TRIP DEVICE

ALL REVISIONS MUST BE MADE ON CAD SYSTEM.

NOTE 1: CT DESIGNATIONS FOR WIRING IN THIS WIRE FOUND ON TRIP W/D 18-738-600-400

01	01/28/82	REVISION NOTE
02	05/06/83	WAS STD4, STD9
03	04/22/88	ECO LV8803-B3

CAD	MT
DRAWN	RAB
CHECK	APVD
PRODUCT TYPE	RL

Siemens Energy & Automation, Inc.			
DWG NAME	MANUALLY OPERATED AIRCIRCUIT BREAKER WIRING DIAGRAM		
SIZE	FSCM NO.	DWG NO.	18-738-601-450
B			
SCALE: NTS	WT	SHEET	1 OF 1