

SIPROTEC

Line Differential Protection with Distance Protection 7SD5

V 4.3

Manual

Preface

Introduction

Functions

Mounting and Commissioning

Technical Data

Appendix

Literature

Glossary

Index

1

2

3

4

A

www.ElectricalPartManuals.com

Disclaimer of liability

We have checked the text of this manual against the hardware and software described. However, deviations from the description cannot be completely ruled out, so that no liability can be accepted for any errors or omissions contained in the information given.

The information in this manual is checked periodically, and necessary corrections will be included in future editions. We appreciate any suggested improvements.

We reserve the right to make technical improvements without notice.

Copyright

Copyright © Siemens AG 2004. All rights reserved.

Dissemination or reproduction of this document, or evaluation and communication of its contents, is not authorized except where expressly permitted. Violations are liable for damages. All rights reserved, particularly for the purposes of patent application or trademark registration.

Registered Trademarks

SIPROTEC, SINAUT, SICAM and DIGSI are registered trademarks of SIEMENS AG. Other designations in this manual may be trademarks that if used by third parties for their own purposes may violate the rights of the owner.

4.30.03

www.ElectricalPartManuals.com

Preface

Purpose of this Manual

This manual describes the functions, operation, installation, and commissioning of the device 7SD5. In particular, one will find:

- Descriptions of device functions and settings → Chapter 2;
- Instructions for mounting and commissioning → Chapter 3;
- List of technical data → Chapter 4;
- As well as a compilation of the most significant data for experienced users → Appendix A.

General information about design, configuration, and operation of SIPROTEC® 4 devices are laid down in the SIPROTEC® System Description /1/.

Target Audience

Protection engineers, commissioning engineers, personnel concerned with adjustment, checking, and service of selective protective equipment, automatic and control facilities, and personnel of electrical facilities and power plants.

Applicability of this Manual

This manual is valid for: SIPROTEC® 4 Line Differential Protection with Distance Protection 7SD5; firmware version V 4.3.

Indication of Conformity

	This product complies with the directive of the Council of the European Communities on the approximation of the laws of the Member States relating to electromagnetic compatibility (EMC Council Directive 89/336/EEC) and concerning electrical equipment for use within specified voltage limits (Low-voltage directive 73/23 EEC). This conformity is proved by tests conducted by Siemens AG in accordance with Article 10 of the Council Directive in agreement with the generic standards EN 50081 and EN 61000-6-2 for EMC directive, and with the standard EN 60255-6 for the low-voltage directive. The product conforms with the international standard of the series IEC 60255 and the German standard VDE 0435.

Further Standards

IEEE Std C37.90-*

This product is UL-certified according to the Technical Data:



IND. CONT. EQ.
TYPE 1
69CA



IND. CONT. EQ.
TYPE 1

Additional Support

Should further information on the System SIPROTEC® 4 be desired or should particular problems arise which are not covered sufficiently for the purchaser's purpose, the matter should be referred to the local Siemens representative.

Training Courses

Individual course offerings may be found in our Training Catalogue, or questions may be directed to our training centre in Nuremberg.

Instructions and Warnings

The warnings and notes contained in this manual serve for your own safety and for an appropriate lifetime of the device. Please observe them!

The following indicators and standard definitions are used:

DANGER!

indicates that death, severe personal injury or substantial property damage can result if proper precautions are not taken.

Warning

indicates that death, severe personal injury or substantial property damage can result if proper precautions are not taken.

Caution

indicates that minor personal injury or property damage can result if proper precautions are not taken. This particularly applies to damage on or in the device itself and consequential damage thereof.

Note:

indicates information about the device or respective part of the instruction manual which is essential to highlight.



WARNING!

Hazardous voltages are present in this electrical equipment during operation.

Failure to observe these precautions can result in death, personal injury, or serious material damage.

Only qualified personnel shall work on and in the vicinity of this equipment. The personnel must be thoroughly familiar with all warnings and maintenance procedures of this manual as well as the safety regulations.

Successful and safe operation of the device is dependent on proper transportation, storage, mounting and assembly and the observance of the warnings and instructions of the unit manual.

Of particular importance are the general installation and safety regulations for work in a high-voltage environment (for example, VDE, IEC, EN, DIN, or other national and international regulations). These regulations must be observed.

Definition

QUALIFIED PERSONNEL

Prerequisites to proper and safe operation of this product are proper transport, proper storage, setup, installation, operation, and maintenance of the product, as well as careful operation and servicing of the device within the scope of the warnings and instructions of this manual. Qualifications are:

- Training and Instruction to energize, de-energize, clear, ground and tag circuits and equipment in accordance with established safety practices.
- Training and instruction (or other qualification) for switching, earthing, and designating devices and systems.
- Training in rendering first aid.

Typographic and Graphical Conventions

To designate terms which refer in the text to information of the device or for the device, the following fonts are used:

Parameter names

Designators of configuration or function parameters which may appear word-for-word in the display of the device or on the screen of a personal computer (with operation software DIGSI®), are marked in bold letters of a monospace type style. This also applies to header bars for selection menus.

1234A

Parameter addresses have the same character style as parameter names. Parameter addresses contain the suffix **A** in the overview tables if the parameter can only be set in DIGSI® via the option **Display additional settings**.

Parameter Conditions





Possible settings of text parameters, which may appear word-for-word in the display of the device or on the screen of a personal computer (with operation software DIGSI®), are additionally written in italics. This also applies to header bars for selection menus.

„Annunciations“


Designators for information, which may be output by the relay or required from other devices or from the switch gear, are marked in a monospace type style in quotation marks.

Deviations may be permitted in drawings and tables when the type of designator can be obviously derived from the illustration.


The following symbols are used in drawings:

	Device-internal logical input signal
	Device-internal (logical) output signal
	Internal input signal of an analog quantity
	External binary input signal with number (binary input, input indication)
	External binary output signal with number (device indication)
	External binary output signal with number (device indication) used as input signal
	Example of a parameter switch designated FUNCTION with the address 1234 and the possible settings ON and OFF


Besides these, graphical symbols are used according to IEC 60617-12 and IEC 60617-13 or symbols derived from these standards. Some of the most frequently used are listed below:




Input signal of an analog quantity




AND gate




OR gate




Exclusive-OR gate (antivalence): output is active, if only **one** of the inputs is active




Equivalence: output is active, if **both** inputs are active or inactive at the same time




Dynamic inputs (edge-triggered) above with positive, below with negative edge




Formation of one analog output signal from a number of analog input signals




Limit stage with setting address and parameter designator (name)




Timer (pickup delay T, example adjustable) with setting address and parameter designator (name)



Timer (dropout delay T, example non-adjustable)



Dynamic triggered pulse timer T (monoflop)



Static memory (RS-flipflop) with setting input (S), resetting input (R), output (Q) and inverted output ($\bar{Q}$)



Contents

1	Introduction	19
1.1	Overall Operation	20
1.2	Application Scope	23
1.3	Characteristics	27
2	Functions	35
2.1	General	37
2.1.1	Functional Scope	37
2.1.1.1	Configuration of the Scope of Functions	37
2.1.1.2	Control of the Main Protection Functions	38
2.1.1.3	Setting Notes	38
2.1.1.4	Settings	43
2.1.2	General Power System Data (Power System Data 1)	45
2.1.2.1	Setting Notes	45
2.1.2.2	Settings	54
2.1.3	Change Group	55
2.1.3.1	Purpose of the Setting Groups	55
2.1.3.2	Setting Notes	55
2.1.3.3	Settings	56
2.1.3.4	Information List	56
2.1.4	General Protection Data (Power System Data 2)	56
2.1.4.1	Setting Notes	56
2.1.4.2	Settings	68
2.1.4.3	Information List	71
2.2	Protection Data Interfaces and Protection Data Topology	74
2.2.1	Functional Description	74
2.2.1.1	Protection Data Topology / Protection Data Communication	74
2.2.2	Protection Data Interfaces	81
2.2.2.1	Setting Notes	81
2.2.2.2	Settings	83
2.2.2.3	Information List	84
2.2.3	Differential Protection Topology	85
2.2.3.1	Setting Notes	85
2.2.3.2	Settings	87
2.2.3.3	Information List	87

2.3	Differential Protection	89
2.3.1	Functional Description	89
2.3.2	Setting Notes	99
2.3.3	Settings	103
2.3.4	Information List	104
2.4	Breaker Intertrip and Remote Tripping	106
2.4.1	Functional Description	106
2.4.2	Setting Notes	108
2.4.3	Settings	108
2.4.4	Information List	108
2.5	Distance Protection	110
2.5.1	Distance Protection, General Settings	110
2.5.1.1	Earth Fault Detection	110
2.5.1.2	Fault Detection (optional)	113
2.5.1.3	Calculation of the Impedances	118
2.5.1.4	Setting Notes	125
2.5.1.5	Settings	132
2.5.1.6	Information List	135
2.5.2	Distance Protection with Quadrilateral Characteristic (optional)	137
2.5.2.1	Method of Operation	137
2.5.2.2	Setting Notes	143
2.5.2.3	Settings	147
2.5.3	Distance Protection with MHO Characteristic (optional)	150
2.5.3.1	Functional Description	150
2.5.3.2	Setting Notes	157
2.5.3.3	Settings	160
2.5.4	Tripping Logic of the Distance Protection	162
2.5.4.1	Method of Operation	162
2.5.4.2	Setting Notes	167
2.6	Power Swing Detection (optional)	168
2.6.1	Method of Operation	168
2.6.2	Setting Notes	174
2.6.3	Settings	174
2.6.4	Information List	174

2.7	Teleprotection for Distance Protection (optional)	175
2.7.1	General	175
2.7.2	Method of Operation	176
2.7.3	PUTT (Pickup)	177
2.7.4	Permissive Underreach Transfer Trip with Zone Acceleration Z1B (PUTT)	179
2.7.5	Direct Underreach Transfer Trip	181
2.7.6	Permissive Overreach Transfer Trip (POTT)	182
2.7.7	Directional Comparison Pickup	185
2.7.8	Directional Unblocking Scheme	187
2.7.9	Directional Blocking Scheme	192
2.7.10	Pilot Wire Comparison	195
2.7.11	Reverse Interlocking	197
2.7.12	Transient Blocking	199
2.7.13	Measures for Weak and Zero Infeed	200
2.7.14	Setting Notes	202
2.7.15	Settings	205
2.7.16	Information List	205
2.8	Earth Fault Protection in Earthed Systems (optional)	207
2.8.1	Method of Operation	207
2.8.2	Setting Notes	219
2.8.3	Settings	228
2.8.4	Information List	231
2.9	Teleprotection for Earth Fault Protection (optional)	232
2.9.1	General	232
2.9.2	Directional Comparison Pickup	233
2.9.3	Directional Unblocking Scheme	236
2.9.4	Directional Blocking Scheme	239
2.9.5	Transient Blocking	242
2.9.6	Measures for Weak or Zero Infeed	243
2.9.7	Setting Notes	244
2.9.8	Settings	248
2.9.9	Information List	248
2.10	Weak-infeed Tripping (optional)	250
2.10.1	Classical Tripping	250
2.10.1.1	Method of Operation	250
2.10.1.2	Setting Notes	253
2.10.2	Tripping According to Specification RTE	253
2.10.2.1	Functional Description	253
2.10.2.2	Setting Notes	256
2.10.3	Weak Infeed Tripping (optional)	257
2.10.3.1	Settings	257
2.10.3.2	Information List	258

2.11	Direct Local Trip	260
2.11.1	Functional Description	260
2.11.2	Setting Notes	261
2.11.3	Settings	261
2.11.4	Information List	261
2.12	Direct Remote Trip and Transmission of Binary Information	262
2.12.1	Functional Description	262
2.12.2	Information List	263
2.13	Instantaneous High-Current Switch-onto-Fault Protection (SOTF)	265
2.13.1	Functional Description	265
2.13.2	Setting Notes	266
2.13.3	Settings	267
2.13.4	Information List	268
2.14	Backup Time Overcurrent Protection	269
2.14.1	General	269
2.14.2	Functional Description	269
2.14.3	Setting Notes	275
2.14.4	Settings	281
2.14.5	Information List	282
2.15	Automatic Reclosure Function (optional)	284
2.15.1	Functional Description	285
2.15.2	Setting Notes	301
2.15.3	Settings	309
2.15.4	Information List	312
2.16	Synchronism and Voltage Check (optional)	314
2.16.1	Method of Operation	314
2.16.2	Setting Notes	318
2.16.3	Settings	322
2.16.4	Information List	323
2.17	Undervoltage and Overvoltage Protection (optional)	325
2.17.1	Overvoltage Protection	325
2.17.2	Undervoltage Protection	330
2.17.3	Setting Notes	334
2.17.4	Settings	338
2.17.5	Information List	340
2.18	Frequency Protection (optional)	342
2.18.1	Method of Operation	342
2.18.2	Setting Notes	344
2.18.3	Settings	346
2.18.4	Information List	347

2.19	Fault Locator	348
2.19.1	Functional Description	348
2.19.2	Setting Notes	352
2.19.3	Settings	356
2.19.4	Information List	356
2.20	Circuit Breaker Failure Protection	358
2.20.1	Functional Description	358
2.20.2	Setting Notes	368
2.20.3	Settings	371
2.20.4	Information List	372
2.21	Thermal Overload Protection	373
2.21.1	Method of Operation	373
2.21.2	Setting Notes	374
2.21.3	Settings	376
2.21.4	Information List	376
2.22	Monitoring Functions	378
2.22.1	Measurement Supervision	378
2.22.1.1	Hardware Monitoring Functions	378
2.22.1.2	Software Monitoring	380
2.22.1.3	Measuring Circuit Monitoring	381
2.22.1.4	Malfunction Responses	386
2.22.1.5	Setting Notes	388
2.22.1.6	Settings	390
2.22.1.7	Information List	391
2.22.2	Trip Circuit Supervision	391
2.22.2.1	Functional Description	392
2.22.2.2	Setting Notes	395
2.22.2.3	Settings	395
2.22.2.4	Information List	395
2.23	Function Control and Circuit Breaker Test	396
2.23.1	Function Control	396
2.23.1.1	Line Energization Recognition	396
2.23.1.2	Detection of the Circuit Breaker Position	399
2.23.1.3	Open Pole Detector	402
2.23.1.4	Pickup Logic for the Entire Device	403
2.23.1.5	Tripping Logic of the Entire Device	404
2.23.2	Circuit Breaker Test	409
2.23.2.1	Functional Description	409
2.23.2.2	Information List	410
2.23.3	Device	411
2.23.3.1	Trip-dependent Messages	411
2.23.3.2	Spontaneous Indications on the Display	411
2.23.3.3	Switching Statistics	411
2.23.3.4	Setting Notes	412
2.23.3.5	Settings	412
2.23.3.6	Information List	412

2.24	Ancillary Functions	414
2.24.1	Commissioning Tools	414
2.24.1.1	Functional Description	414
2.24.1.2	Setting Notes	415
2.24.1.3	Settings	416
2.24.2	Processing of Messages	416
2.24.2.1	Functional Description	416
2.24.3	Statistics	421
2.24.3.1	Functional Description	421
2.24.3.2	Information List	421
2.24.4	Measurement During Operation	423
2.24.4.1	Functional Description	423
2.24.4.2	Information List	425
2.24.5	Differential Protection Values	427
2.24.5.1	Measured Values of the Differential Protection	427
2.24.5.2	Information List	427
2.24.6	Remote Measured Values	428
2.24.6.1	Functional Description	428
2.24.7	Measured Values Constellation	429
2.24.7.1	Functional Description	429
2.24.8	Oscillographic Fault Records	429
2.24.8.1	Functional Description	429
2.24.8.2	Settings	430
2.24.8.3	Information List	430
2.24.9	Demand Measurement Setup	431
2.24.9.1	Long-term Average Values	431
2.24.9.2	Settings	431
2.24.9.3	Information List	431
2.24.10	Min/Max Measurement Setup	432
2.24.10.1	Reset	432
2.24.10.2	Settings	432
2.24.10.3	Information List	432
2.24.11	Set Points (Measured Values)	434
2.24.11.1	Limit Value Monitoring	434
2.24.11.2	Information List	434
2.24.12	Energy	435
2.24.12.1	Information List	435
2.25	Command Processing	436
2.25.1	Control Authorization	436
2.25.1.1	Command Types	436
2.25.1.2	Sequence in the Command Path	437
2.25.1.3	Switchgear Interlocking	438
2.25.1.4	Information List	441
2.25.2	Control Device	441
2.25.2.1	Information List	441
2.25.3	Process Data	442
2.25.3.1	Method of Operation	442
2.25.3.2	Information List	442
2.25.4	Protocol	443
2.25.4.1	Information List	443

3	Mounting and Commissioning	445
3.1	Mounting and Connections	446
3.1.1	Configuration Information	446
3.1.2	Hardware Modifications	451
3.1.2.1	General	451
3.1.2.2	Disassembly	453
3.1.2.3	Switching Elements on Printed Circuit Boards	455
3.1.2.4	Interface Modules	462
3.1.2.5	Reassembly	466
3.1.3	Mounting	466
3.1.3.1	Panel Flush Mounting	466
3.1.3.2	Rack Mounting and Cubicle Mounting	468
3.1.3.3	Panel Surface Mounting	470
3.2	Checking Connections	471
3.2.1	Checking Data Connections of Serial Interfaces	471
3.2.2	Checking the Protection Data Communication	473
3.2.3	Power Plant Connections	474
3.3	Commissioning	477
3.3.1	Test Mode / Transmission Block	478
3.3.2	Checking the Time Synchronization Interface	478
3.3.3	Checking the System Interface	479
3.3.4	Checking the States of the Binary Inputs/Outputs	481
3.3.5	Checking the Protection Data Topology	484
3.3.6	Tests for the Circuit Breaker Failure Protection	490
3.3.7	Checking the Instrument Transformer Connections of One Line End	492
3.3.8	Checking the Instrument Transformer Connections of Two Line Ends	494
3.3.9	Checking the Instrument Transformer Connections for More than Two Ends	506
3.3.10	Measuring the Operating Time of the Circuit Breaker	507
3.3.11	Checking the Teleprotection System with Distance Protection	508
3.3.12	Testing the Signal Transmission with Earth Fault Protection	511
3.3.13	Checking the Signal Transmission for Breaker Failure Protection and/or Stub Fault Protection	513
3.3.14	Checking the Signal Transmission for Internal and External Remote Tripping	513
3.3.15	Testing User-Defined Functions	513
3.3.16	Trip and Close Test with the Circuit Breaker	514
3.3.17	Trip/Close Tests for the Configured Operating Devices	514
3.3.18	Triggering Oscillographic Recordings for Test	515
3.4	Final Preparation of the Device	516

4	Technical Data	517
4.1	General	519
4.1.1	Analog Inputs	519
4.1.2	Auxiliary voltage	520
4.1.3	Binary Inputs and Outputs	520
4.1.4	Communications Interfaces	522
4.1.5	Electrical Tests	526
4.1.6	Mechanical Stress Tests	528
4.1.7	Climatic Stress Tests	529
4.1.8	Service Conditions	529
4.1.9	Certifications	530
4.1.10	Mechanical Design	530
4.2	Protection Data Interfaces and Differential Protection Topology	531
4.3	Differential Protection	533
4.4	Breaker Intertrip and Remote Tripping -Direct Local Trip	535
4.5	Distance Protection (optional)	536
4.6	System Power Swing (with impedance) (optional)	539
4.7	Teleprotection for Distance Protection (optional)	540
4.8	Earth Fault Protection in Earthed Systems (optional)	541
4.9	Teleprotection for Earth Fault Protection (optional)	550
4.10	Weak-infeed Tripping (classic/optional)	551
4.11	Weak-infeed Tripping (French specif./optional)	552
4.12	Direct Remote Trip and Transmission of Binary Information	553
4.13	Instantaneous High-Current Switch-onto-Fault Protection (SOTF)	554
4.14	Time Overcurrent Protection	555
4.15	Automatic Reclosure Function (optional)	558
4.16	Synchronism and Voltage Check (optional)	559
4.17	Undervoltage and Overvoltage Protection (optional)	561
4.18	Frequency Protection (optional)	564
4.19	Fault Locator	565
4.20	Circuit Breaker Failure Protection	566
4.21	Thermal Overload Protection	567
4.22	Monitoring Function	569
4.23	User Defined Functions (CFC)	571
4.24	Additional Functions	574

4.25	Dimensions	577
4.25.1	Panel Flush and Cubicle Mounting (Housing Size $1/2$)	577
4.25.2	Panel Flush and Cubicle Mounting (Housing Size $1/4$)	578
4.25.3	Panel Surface Mounting (Housing Size $1/2$)	579
4.25.4	Panel Surface Mounting (Housing Size $1/4$)	579
A	Appendix	581
A.1	Ordering Information and Accessories	582
A.1.1	Ordering Information	582
A.1.1.1	Ordering Code (MLFB)	582
A.1.2	Accessories	586
A.2	Terminal Assignments	590
A.2.1	Panel Flush Mounting or Cubicle Mounting	590
A.2.2	Panel Surface Mounting	595
A.3	Connection Examples	602
A.3.1	Current Transformer Connection Examples	602
A.3.2	Voltage Transformer Connection Examples	606
A.4	Default Settings	609
A.4.1	LEDs	609
A.4.2	Binary Input	610
A.4.3	Binary Output	611
A.4.4	Function Keys	612
A.4.5	Default Display	612
A.4.6	Pre-defined CFC Charts	615
A.5	Protocol-dependent Functions	616
A.6	Functional Scope	617
A.7	Settings	619
A.8	Information List	638
A.9	Group Alarms	673
A.10	Measured Values	674
	Literature	681
	Glossary	683
	Index	691

www.ElectricalPartManuals.com

Introduction

The SIPROTEC® Line Differential Protection with Distance Protection 7SD5 is introduced in this chapter. The 7SD5 is presented in its application, characteristics, and functional scope.

1.1	Overall Operation	20
1.2	Application Scope	23
1.3	Characteristics	27

1.1 Overall Operation

The SIPROTEC® line protection 7SD5 is equipped with a powerful microcomputer system. This provides fully numerical processing of all functions in the device, from the acquisition of the measured values up to the output of commands to the circuit breakers, as well as the exchange of measured data with the other ends of the protected area. Figure 1-1 shows the basic structure of the device.

Analog Inputs

The measuring inputs (MI) convert the currents and voltages coming from the instrument transformers and adapt them to the level appropriate for the internal processing of the device. The device has 4 current and 4 voltage inputs. Three current inputs are provided for measurement of the phase currents, a further measuring input (I_4) may be configured to measure the earth current (residual current from the current transformer star-point or separate earth current transformer), the earth current of a parallel line (for parallel line compensation) or the star-point current of a power transformer (for earth fault direction determination).




Figure 1-1 Hardware structure of the line differential protection 7SD5

A voltage input is provided for each phase-earth voltage. The connection of voltage transformers is not required for differential protection, but for using distance protection

and other ancillary functions. A further voltage input (U_4) may optionally be used to measure either the displacement voltage, for a busbar voltage (for synchronism and voltage check) or any other voltage U_X (for overvoltage protection). The analog signals are then routed to the input amplifier group "IA".

The input amplification IA stage provides high-resistance terminations for the analog input quantities. It contains filters that are optimized with regard to bandwidth and processing speed.

The AD analog digital converter group contains analog/digital converters and memory chips for data transfer to the microcomputer system.

Microcomputer System

Apart from processing the measured values, the microcomputer system also executes the actual protection and control functions. In particular, the following are included:

- Decisions for trip and close commands,
- Continuous supervision of measured signals.
- Monitoring of the pickup conditions of the individual protection functions.
- Formation of the local differential protection values (phasor analysis and charge current computation) and creation of the transmission protocol.
- Decoding of the received transmission protocol, synchronization of differential protection values and summing up of the differential currents and charge currents,
- Monitoring of the communication with the other devices part of the line protection system
- Interrogation of threshold values and time sequences.
- Processing of signals for the logic functions.
- Decisions for trip and close commands
- Storage of messages, fault annunciations as well as fault records for system fault analysis
- Operating system and related function management such as, e.g., data recording, real-time clock, communication, interfaces, etc.

The information is provided via output amplifier OA.

Binary Inputs and Outputs

The microcomputer system obtains external information through binary inputs such as remote resetting or blocking commands for protection functions. The computer system obtains the information from the system (e.g. remote resetting) or the external equipment (e.g. blocking commands). These outputs include, in particular, trip commands to circuit breakers and signals for remote annunciation of important events and conditions.

Front Elements

Light emitting diodes (LEDs) and a display screen (LCD) on the front panel provide information such as measured values, messages related to events or faults, status, and functional status of the device.

Integrated control and numeric keys in conjunction with the LCD facilitate local interaction with the device. All information of the device can be accessed using the integrated control and numeric keys. The information includes protective and control settings, operating and fault messages, and measured values (see also Chapter 2 and SIPROTEC® 4 System Description /1/).

Using integrated switchgear control functions, the control of circuit breakers and other equipment is possible from the device front panel.

Serial Interfaces

Via the serial operator interface in the front panel the communication with a personal computer using the operating program DIGSI® is possible. This permits convenient operation of all functions of the device.

The service interface can also be used for communication with a personal computer using DIGSI®. This port is especially well suited for dedicated connection of the devices to the PC or for operation via a modem.

All device data can be transferred to a central master or main control system through the serial system (SCADA) interface. This interface may be provided with various protocols and physical transmission modes to suit the particular application.

Another interface is provided for the time synchronization of the internal clock via external synchronization sources.

The operator and service interface allow the communication from one PC with the devices at all ends of the protected object during commissioning, checking and also during operation of the device, using a standard browser. A software program named „WEB-Monitor“) supports this function which has been optimized with regard to the line protection system.

Protection Data Interfaces

The protection data interfaces are a particular case. Depending on the model there are one or two protection data interfaces. Via these interfaces the measured value data of each end of the protected object is transmitted to the other ends; during this procedure measured values from the other ends may also be added. Further information such as closing the local circuit breaker, pickup of the inrush restraint as well as other external trip commands coupled via binary inputs or binary information can be transmitted to other ends via the protection data interfaces.

Power Supply

These described functional units are supplied by a current supply PS with the necessary power in the different voltage levels. Brief supply voltage dips which may occur on short circuits in the auxiliary voltage supply of the devices are usually bridged by a capacitor (see also Technical Data, Chapter 4.1).

1.2 Application Scope

The SIPROTEC® line protection 7SD5 is a protection relay that combines differential and distance protection. A multi-end fault locator allows to precisely locate faults in two-ended lines, even with unfavourable operating or fault conditions.

The combined line protection is a selective short-circuit protection for overhead lines and cables with single- and multi-ended infeeds in radial, ring or any type of meshed systems of any transmission level. Measuring data are compared separately for each phase. The network neutral can be earthed, compensated or isolated.

The device incorporates the functions which are normally required for the protection of an overhead line feeder and is therefore capable of universal application. It may also be applied as time graded back-up protection to all types of comparison protection schemes used on lines, transformers, generators, motors and busbars of all voltage levels.

The inrush current restraint allows for the application of the 7SD5 even if a power transformer is situated within the protected zone (ordering option) whose starpoint(s) might also be isolated, earthed or provided with a Petersen coil.

A major advantage of the differential protection principle is the instantaneous tripping in the event of a short-circuit at any point within the entire protected zone. The current transformers limit the protected zone at the ends towards the remaining system. This rigid limit is the reason why the differential protection scheme shows such an ideal selectivity.

The line protection system requires a 7SD5 device as well as a set of current transformers at either end of the protected zone.

If the 7SD5 line protection is to be operated with distance protection as the main or backup protection function, voltage transformers are required. They are also needed for the acquisition and display of measured values (voltages, power, power factor).

The devices located at the ends of the protected zone exchange measuring information via protection data interfaces using dedicated communication links (usually fibre optic cables) or a communication network, provided that they operate with differential protection. The distance protection can exchange measuring information via teleprotection functions with conventional connections (contacts), or transmit it through fast command channels provided on the protection data interfaces (can be configured with DIGSI). Two type 7SD5 devices can be used for an object with two ends to be protected: cables, overhead line or both, with or without unit-connected power transformer (option). Employing type 7SD5*3, objects having 3 (three-terminal lines) or more ends can be protected, besides two-terminal lines, also with or without unit-connected transformers (option). Up to 6 ends can be covered, which means that smaller busbar arrangements can also be protected. For each end a 7SD5*3 is used. Building up a communication chain between 3 or more devices the outermost ends of the chain can be equipped with the 7SD5*2 model. For more information refer to Section 2.2.1.

With two and more devices (= ends of the protected object) the communication can be built up as a ring. This enables a redundant operation in case one communication line fails. The devices will automatically find the remaining healthy communication lines. But even with two ends, communication lines can be doubled to create redundancies.

Since fault-free data transmission is the prerequisite for the proper operation of the differential protection system, it is continuously monitored internally.

In the event of a communication failure, if there is no backup channel available, the devices can automatically be switched to the second main protection function, i.e. dis-

tance protection, or to emergency operation using an integrated time overcurrent protection, until communication is restored again.

The communication link can be used for transmitting further information. Besides measured values, binary commands or other information can be transmitted.

As an alternative, distance protection can be used as backup protection, just as time overcurrent protection is used for emergency protection; both protection functions operate in this case independently and in parallel to differential protection at each end.

Protection Functions

Generally speaking, two basic functions are available in the 7SD5 line protection relay, namely differential and distance protection. One of the protection functions can be configured at a time as the main protection function (Main1). As an alternative, differential protection can be selected as the main protection function, and distance protection as backup protection (Main2).

Recognition of short-circuits in the protection zone only with the measured currents is the basic function of the differential protection. Also high resistive faults with small currents can be recognized. Even complex multiphase faults are precisely detected, as the measured values are evaluated phase segregated. The protection system is restraint against inrush currents of power transformers in the protection zone. When switching onto a fault at any point of a line, an undelayed trip signal can be emitted.

The basic function of the distance protection is the recognition of the distance to the fault with distance protection measurement. In particular for complex multiphase faults, the distance protection has a non-switched 6-impedance-loops design (full scheme). Different pickup schemes enable a good adaption to system conditions and the user philosophy. The network neutral can be isolated, compensated or earthed (with or without earth current limiting). The use on long, high-loaded lines is possible with or without serial compensation. The distance protection may be supplemented by teleprotection using various signal transmission schemes (for fast tripping on 100 % of the line length). In addition, an earth fault protection for high resistance earth faults (ordering option) is available, which may be directional, non-directional and may also be incorporated in signal transmission. On lines with weak or no infeed at one line end, it is possible to achieve fast tripping at both line ends by means of the signal transmission schemes. When switching onto a fault at any point of a line, an undelayed trip signal can be emitted.

The integrated time overcurrent protection function can be configured as a permanent backup protection at all line ends, or as a protection function for emergency operation. Emergency operation is a state in which the differential protection cannot operate, for example because of a communication failure, and in which no distance protection operating in parallel is available (e.g. because of a measuring voltage failure). The time overcurrent protection function has three definite time overcurrent stages and one inverse time (IDMT) stage; a series of characteristics according to various standards is available for the inverse time stage.

Depending on the version ordered, the short-circuit protection functions may also trip single-pole. They may operate in co-operation with an integrated automatic reclosure (available as an option) with which single-pole, three-pole or single- and three-pole rapid automatic reclosure as well as multi-shot automatic reclosure are possible on overhead lines. Before reclosure after three-pole tripping, the validity of the reclosure can be checked by voltage and/or synchronism check by the device (can be ordered optionally). It is possible to connect an external automatic reclosure and/or synchronism check, as well as double protection with one or two automatic reclosure functions.

Other protection functions are possible in addition to the short-circuit protection functions described above. A thermal overload protection has been integrated which pro-

protects in particular cables and power transformers from illegal heating through overload. Other possible functions are multi-stage overvoltage, undervoltage and frequency protection, circuit breaker failure protection and protection against effects of power swings (simultaneously active as power swing blocking for the distance protection). For rapid location of the damage to the line after a short-circuit, a multi-end fault locator is integrated which also may compensate the influence of parallel lines, and of the fault resistances when power is flowing in the line.

Control Functions

Depending on the ordered variant the device provides control functions which can be accomplished for activating and deactivating switchgears via the integrated operator panel, the system interface, binary inputs and a personal computer with the operating software DIGSI®. The status of the primary equipment can be transmitted to the device via auxiliary contacts connected to binary inputs. The current status (or position) of the primary equipment can be read out at the device, and used for interlocking or plausibility monitoring. The number of the operating equipment to be switched is limited by the binary inputs and outputs available in the device or the binary inputs and outputs allocated for the switch position indications. Depending on the equipment used one (single point indication) or two (double point indication) binary inputs may be used. The capability of switching primary equipment can be restricted by a setting associated with the switching authority (remote or local), and by the operating mode (interlocked/non-interlocked, with or without password request). Processing of interlocking conditions for switching (e.g. switching error protection) can be established with the aid of integrated, user-configurable logic functions.

Messages and Measured Values; Fault Recording

The operating messages provide information about conditions in the power system and the device. Measurement quantities and values that are calculated can be displayed locally and communicated via the serial interfaces.

Device messages can be assigned to a number of LEDs on the front panel (allocatable), can be externally processed via output contacts (allocatable), linked with user-definable logic functions and/or issued via serial interfaces (see Communication below).

During a fault (system fault) important events and changes in conditions are saved in fault logs (Event Log or Trip Log). Instantaneous fault values are also saved in the device and may be analysed subsequently.

As a special feature the values are synchronized between the line terminals via the communication link.

Communication

Serial interfaces are available for the communication with operating, control and memory systems.

A 9-pin DSUB socket on the front panel is used for local communication with a personal computer. By means of the SIPROTEC® 4 operating software DIGSI®, all operational and evaluation tasks can be executed via this operator interface, such as specifying and modifying configuration parameters and settings, configuring user-specific logic functions, retrieving operational messages and measured values, inquiring device conditions and measured values, issuing control commands.

To establish an extensive communication with other digital operating, control and memory components the device may be provided with further interfaces depending on the order variant

The service interface can be operated through data lines. Also, a modem can be connected to this interface. For this reason, remote operation is possible via personal

computer and the DIGSI® operating software, e.g. to operate several devices via a central PC.

The system interface is used for central communication between the device and a control centre. The service interface can be operated through data cables or optical fibres. For data transmission there are several standardized protocols available.

Another interface is provided for the time synchronization of the internal clock via external synchronization sources (IRIG-B or DCF77).

Other interfaces provide for communication between the devices at the ends of the protected object. These protection data interfaces have been mentioned above in the protection functions.

The operator and service interface allow to operate the device remotely or locally, using a standard browser. This is possible during commissioning, checking and also during operation of the devices at all ends of the protected object, using a communication network. For this special commissioning tool, the "WEB-Monitor", is provided, which has been optimized for the differential protection system, but upgraded for the needs of the distance protection.

1.3 Characteristics

General Features

- Powerful 32-bit microprocessor system
- Complete digital processing of measured values and control, from the sampling of the analog input values, the processing and organization of the communication between devices up to the closing and tripping commands to the circuit breakers
- Complete galvanic and reliable separation between internal processing circuits from the measurement, control, and power supply circuits by analog input transducers, binary inputs and outputs and the DC/DC or AC/DC converters
- Suited for lines with up to 6 ends, even with transformers in the protected zone (order option)
- Simple device operation using the integrated operator panel or a connected personal computer with operator guidance
- Storage of fault indications as well as instantaneous values for fault recording

Differential Protection

- Differential protection system for up to 6 ends with digital protection data transmission
- Protection for all types of short-circuits in systems with any starpoint conditioning
- Reliable distinction between load and short-circuit conditions, also on high resistant faults with small fault currents
- High sensitivity in the case of a weakly loaded system, extreme stability against load jumps and power swings
- Due to phase segregated measurement the pickup sensitivity is independent of the type of fault
- Suited for transformers in the protected area (order option)
- Detection of high-resistant, weak-current faults due to high sensitivity;
- Insensitive against in-rush and charge currents — also for transformers in the protected area — and against higher-frequency switching transients;
- Charging current compensation; therefore increased pickup sensitivity
- High stability also for different current transformer saturation
- Adaptive restraint that is automatically derived from the measured values and the configured current transformer data
- Fast phase segregated tripping also on weak or zero infeed ends (breaker intertrip)
- Low dependence on frequency due to frequency tracking
- Digital transmission of protection data; communication between devices via dedicated communication connections (in general optical fibre) or a communication system
- Communication possible via ISDN networks or pilot wire connections (up to 30 km, depends on the type of pilot wire);
- Permanent supervision of the protection data transmission concerning disturbance, failure, and transfer time deviation in the transmission network, with automatic transfer time correction
- Automatic changeover of communication paths in case of transmission failure or transmission disturbance is provided (for ring topology with 7SD5*3)

- Phase segregated tripping (in conjunction with single-pole or single- and three-pole auto-reclosure) is possible (order option)

Distance Protection (optional)

- Can be used either to operate in parallel to differential protection, or as the main protection function
- Protection for all types of faults in systems with earthed, compensated or isolated starpoint
- Selectable polygonal tripping characteristic or MHO characteristic
- Possibility to choose between Z pickup, $I>$, U/I or $U/I/\phi$ pickup, enabling the adaption to different system conditions and the user philosophy
- Reliable differentiation between load and fault conditions also on long, high-loaded lines
- High sensitivity in the case of a weakly loaded system, extreme stability against load jumps and power swings
- Optimum adaption to the line parameters by means of the tripping characteristic with diverse configuration parameters and „load trapezoid“ (elimination of the possible load impedances)
- Six measuring systems for each distance zone
- Six distance zones, selectable as forward, reverse or non-directional reaching, one may be used as an overreach zone
- Nine time stages for the distance zones
- Direction determination (with polygon) or polarization (with MHO characteristic) is done with unfaulted loop (quadrature) voltages and voltage memory, thereby achieving unlimited directional sensitivity, and not affected by capacitive voltage transformer transients
- Suitable for lines with serial compensation
- Insensitive to current transformer saturation
- Compensation against the influence of a parallel line
- Shortest command time significantly less than one cycle
- Phase segregated tripping (in conjunction with single-pole or single- and three-pole auto-reclosure)
- Non delayed tripping following switch on to fault is possible
- Two sets of earth impedance compensation

Power Swing Supplement (optional)

- Power swing detection with dZ/dt measurement with three measuring systems
- Power swing detection up to a maximum of 7 Hz swing frequency;
- In service also during single-pole dead times
- Settable power swing programs
- Prevention of undesired tripping by the distance protection during power swings
- Tripping for out-of-step conditions can also be configured

Teleprotection Supplement (optional)

- Different procedures settable
- Permissive Underreach Transfer Trip = PUTT (via a separately settable overreach zone)
- Comparison schemes (Permissive Overreach Transfer Trip = POTT or blocking schemes, with separate overreach zone)
- Pilot wire comparison/reverse interlocking (with DC voltage for local connections or extremely short lines)
- Suitable for lines with two or three ends
- Phase segregated transmission possible in lines with two ends
- Signal exchange between devices via binary outputs and binary inputs, either directly via device contacts or through the protection data interface(s)

Earth Fault Protection (optional)

- Time overcurrent protection with maximally three definite time stages (DT) and one inverse time stage (IDMT) for high resistance earth faults in earthed systems
- For inverse-time overcurrent protection a selection from various characteristics based on several standards is possible
- The inverse time stage can also be set as fourth definite time stage
- High sensitivity (depending on the version from 3 mA)
- Phase current restraint against error currents during current transformer saturation
- Second harmonic inrush restraint
- Optionally earth fault protection with zero sequence voltage tripping time or inverse time tripping
- Each stage can be set to be non-directional or directional in the forward or reverse direction
- Single-pole tripping enabled by integrated phase selector
- Direction determination with zero sequence system quantities (I_0 , U_0), with zero sequence current and transformer star-point current (I_0 , I_Y), with negative sequence system quantities (I_2 , U_2) or with zero sequence power ($3I_0 \cdot 3U_0$)
- One or more stages may function in conjunction with a teleprotection scheme; also suited for lines with three ends
- Instantaneous tripping by any stage when switching onto a fault

Tripping at Line Ends with no or Weak Infeed (optional)

- Possible in conjunction with teleprotection schemes
- Allows fast tripping at both line ends, even if there is no or only weak infeed available at one line end
- Phase segregated tripping and single-pole automatic reclosure (version with single-pole tripping)

External Direct and Remote Tripping

- Tripping at the local line end from an external device via a binary input
- Tripping of the remote line end by internal protection functions or an external device via a binary input (with teleprotection)

Transmission of Information

- Transmission of the measured values from all ends of the protected object with the amount and phase
- Transmission of up to 4 fast commands to all remote ends (order option)
- Transmission of up to 24 additional binary signals to all remote ends (order option)

Time Overcurrent Protection

- Selectable as emergency function during a failure of the main protection function(s) due to a failure of the data communication and/or the measuring voltages, or as backup function;
- Maximally two definite time stages (DT) and one inverse time stage (IDMT), each for phase currents and for earth currents
- For inverse-time overcurrent protection a selection from various characteristics based on several standards is possible
- Blocking capability, e.g. for reverse interlocking with any element
- Instantaneous tripping by any stage when switching onto a fault
- Stub fault protection: fast tripping of faults between the current transformer and line isolator (when the isolator switching status feed back is available); particularly suited to substations with 1¹/₂ circuit breaker arrangements

Instantaneous High-Current Switch-onto-Fault Protection

- Fast tripping for all faults on 100 % line length
- Selectable for manual closure or following each closure of the circuit breaker
- With integrated line energization detection

Automatic Reclosure Function (optional)

- For reclosure after single-pole, three-pole or single-pole and three-pole tripping
- Single or multiple reclosure (up to 8 reclosure attempts)
- With separate action times for every reclosure attempt, optionally without action times
- With separate dead times after single-pole and three-pole tripping, separate for the first four reclosure attempts
- With the option of an adaptive dead time: in this case only **one** device controls the automatic reclosure cycles whilst at the other end(s) the automatic reclosure solely depends on the **one** controlling device. The criteria used are voltage measurement and/or the transmitted CLOSE command (Remote-CLOSE).
- Controlled optionally by protection pickup with separate dead times after single, two-pole and three-pole pickup
- Optionally with adaptive dead time, reduced dead time and dead line check

Synchronism and Voltage Check (optional)

- Verification of the synchronous conditions before reclosing after three-pole tripping
- Fast measuring of voltage difference U_{Diff} of the phase angle difference φ_{Diff} and frequency difference f_{Diff}
- Alternatively, check of the de-energized state before reclosing
- Closing at asynchronous system conditions with prediction of the synchronization time
- Settable minimum and maximum voltage

- Verification of the synchronous conditions or de-energized state also possible before the manual closing of the circuit breaker, with separate limit values
 - Also measurement via transformer
 - Measuring voltages optionally phase-phase or phase-earth
- Voltage Protection (optional)**
- Two overvoltage stages for the phase-earth voltages
 - Two overvoltage stages for the phase-phase voltages
 - Two overvoltage stages for the positive sequence voltage, optionally with compounding
 - Two overvoltage stages for the negative sequence voltage
 - Two overvoltage stages for the zero sequence voltage or any other single-phase voltage
 - Settable dropout to pickup ratios for the overvoltage protection functions
 - Two undervoltage stages for the phase-earth voltages
 - Two undervoltage stages for the phase-phase voltages
 - Two undervoltage stages for the negative sequence voltage;
 - Settable current criterion for undervoltage protection functions
- Frequency Protection (optional)**
- Monitoring for underfrequency ($f <$) and/or overfrequency ($f >$) with 4 frequency limits and delay times that are independently adjustable
 - Particularly insensitive to harmonics and abrupt phase angle changes
 - Large frequency range (approx. 25 Hz to 70 Hz)
- Fault Locator**
- Optionally single-ended (conventional) or double-ended fault location via communication interfaces
 - Initiated by trip command or reset of the fault detection
 - Fault location output in Ohm, kilometers or miles and % of line length
 - Output of the fault location also possible in BCD code
 - Parallel line compensation can be selected
 - Taking into consideration the load current in case of single-phase earth faults fed from both sides (configurable)
 - Possibility to take into account line asymmetry and of different line sections
- Circuit Breaker Failure Protection**
- With definite time current stages for monitoring current flow through every pole of the circuit breaker
 - With definite time monitoring time steps for single-pole and three-pole tripping
 - Start by trip command of every internal protection function
 - Start by external trip functions possible
 - Single-stage or two-stage
 - Short dropout and overshoot times
 - End fault protection and pole discrepancy monitoring possible

Thermal Overload Protection	• Provides thermal replica of the current heat losses of the protected object • R.m.s. measurement of all three phase currents • Adjustable thermal and current-dependent warning stages
User-defined Functions	• Freely programmable combination of internal and external signals for the implementation of user-defined logic functions • All common logic functions • Time delays and set point interrogation
Commissioning, Operation, Maintenance	• Display of magnitude and phase angle of local and remote measured values • Indication of the calculated differential and restraint currents • Display of the measured values of the communication link, such as transmission delay and availability; • Function logout of a device from the line protection system during maintenance work at an end of a power line, test mode and commissioning mode supported
Command Processing	• Switchgear can be switched on and off manually via local control keys, the programmable function keys on the front panel, via the system interface (e.g. by SICAM® or LSA), or via the operator interface (using a personal computer and the operating software DIGSI®); • Feedback on switching states via the circuit breaker auxiliary contacts (for commands with feedback) • Plausibility monitoring of the circuit breaker position and monitoring of interlocking conditions for switching operations
Monitoring Functions	• Increase of the availability of the device by monitoring of the internal measurement circuits, auxiliary power supply, hardware, and software; • Current transformer and voltage transformer secondary circuits are monitored using summation and symmetry check techniques • Monitoring of communication with statistics showing the availability of transmission telegrams • Check of the consistency of protection settings at all line ends: blocking of the differential protection system in case of inconsistent settings which could lead to a malfunction • Trip circuit supervision possible • Check of local and remote measured values and comparison of both • Broken wire supervision for the secondary CT circuits with fast phase segregated blocking of the line protection system in order to avoid malfunction • Supervision of measuring voltage failure using "Fuse Failure Monitor"
Ancillary Functions	• Battery buffered real-time clock, which may be synchronized via a synchronization signal (e.g. DCF77, IRIG B, GPS via satellite receiver), binary input or system interface • Automatic time synchronization between the devices at the ends of the protected object via the protection data transmission

- Continuous calculation and display of measured quantities on the front of the device
Indication of measured quantities of the remote line end(s)
- Fault event memory for the last 8 network faults (faults in the power system), with real time stamps (1 ms resolution)
- Fault recording memory and data transfer for analog and user configurable binary signal traces with a maximum time range of 15 s, synchronized between the devices of the line protection system
- Statistics: counter with the trip commands issued by the device, as well as recording of the fault current data and accumulation of the interrupted fault currents;
- Communication with central control and memory components possible via serial interfaces (depending on the individual ordering variant), optionally via electrical RS485 bus connection, fiber optic cable or a modem connection
- Commissioning aids such as connection and direction checks as well as interface check and circuit breaker test functions
- The „IBS-Tool“ (installed on a PC or a laptop) widely supports the testing and commissioning procedure. The communication topology of the line protection and communication system, phasor diagrams of all currents and (if applicable) voltages at all ends of the line protection system, as well as the differential protection and distance protection characteristics, are displayed as a graph.



www.ElectricalPartManuals.com

Functions

This chapter describes the numerous functions available on the SIPROTEC® 4 7SD5. It shows the setting possibilities for all the functions in maximum configuration. Instructions for deriving setting values and formulae, where required are provided.

Additionally it may be defined which functions are to be used.

2.1	General	37
2.2	Protection Data Interfaces and Protection Data Topology	74
2.3	Differential Protection	89
2.4	Breaker Intertrip and Remote Tripping	106
2.5	Distance Protection	110
2.6	Power Swing Detection (optional)	168
2.7	Teleprotection for Distance Protection (optional)	175
2.8	Earth Fault Protection in Earthed Systems (optional)	207
2.9	Teleprotection for Earth Fault Protection (optional)	232
2.10	Weak-infeed Tripping (optional)	250
2.11	Direct Local Trip	260
2.12	Direct Remote Trip and Transmission of Binary Information	262
2.13	Instantaneous High-Current Switch-onto-Fault Protection (SOTF)	265
2.14	Backup Time Overcurrent Protection	269
2.15	Automatic Reclosure Function (optional)	284
2.16	Synchronism and Voltage Check (optional)	314
2.17	Undervoltage and Overvoltage Protection (optional)	325
2.18	Frequency Protection (optional)	342
2.19	Fault Locator	348
2.20	Circuit Breaker Failure Protection	358
2.21	Thermal Overload Protection	373
2.22	Monitoring Functions	378
2.23	Function Control and Circuit Breaker Test	396

2.24	Ancillary Functions	414
2.25	Command Processing	436

2.1 General

A few seconds after the device is switched on, the initial display appears in the LCD. In the 7SD5 the measured values are displayed.

Configuration of the device functions is made via the DIGSI® software from your PC. The procedure is described in detail in the SIPROTEC® 4 System Description. Entry of password no. 7 (parameter set) is required to modify configuration settings. Without the password, the settings may be read, but cannot be modified and transmitted to the device.

The function parameters, i.e. settings of function options, threshold values, etc., can be entered via the front panel of the device, or by means of a personal computer connected to the operator or service interface of the device utilizing the DIGSI® software package. Password no. 5 (individual parameters) is required.

This general section describes which device settings reflect the interaction between your substation, its measuring locations (current and voltage transformers), the analog device connections and the various protection functions of the device.

In a first step (Section 2.1.1), you have to specify which protection functions you want to use, because not all of the functions integrated in the device are necessary, useful or even possible for your relevant case of application.

After entering some System Data (frequency), you inform the device (Section 2.1.2) of the properties of the main protected object. This comprises e.g. nominal system data, nominal data of instrument transformers, polarity and connection type of measured values

The above information is sufficient to describe the protected object to the device's main protection function, i.e. the differential protection. For the other protection functions (e.g. backup distance protection) you select what measured values will be processed and in which way.

You will be informed how to set the circuit breaker data, and find out about setting groups and how to use them.

Last but not least, you can set general data which are not dependent on any protection functions.

2.1.1 Functional Scope

2.1.1.1 Configuration of the Scope of Functions

The 7SD5 device contains a series of protective and additional functions. The hardware and firmware provided is designed for this scope of functions. In addition, the command functions can be matched to the system conditions. In addition, individual functions may be enabled or disabled during configuration, or interaction between functions may be adjusted.

Example for the configuration of scope of functions:

A substation has feeders with overhead lines and transformers. Fault location is to be performed on the overhead lines only. In the devices for the transformer feeders this function is therefore „Disabled“.

The available protection and supplementary functions can be configured as **Enabled** or **Disabled**. For some functions, a choice may be presented between several options which are explained below.

Functions configured as **Disabled** are not processed by the 7SD5. There are no indications, and corresponding settings (functions, limit values) are not displayed during setting.



Note

The functions and default settings available depend on the order variant of the device.

2.1.1.2 Control of the Main Protection Functions

Differential and Distance Protection

If the order option specifies that the 7SD5 universal line protection includes the distance protection, the device can be operated in three modes:

1. Differential protection with distance protection
2. Differential protection only
3. Distance protection only

In mode 1, the distance protection operates in parallel with the differential protection. In this mode, both protection functions are configured (address 112

DIFF. PROTECTION; address 115 **Phase Distance**, address 116 **Earth Distance** and address 117 **Dis. PICKUP**), and can be switched **ON** or **OFF** with the addresses 1201 **STATE OF DIFF.** and 1501 **FCT Distance**. When the differential protection is switched off or blocked, the distance protection continues to operate without restrictions.

You can also operate the differential protection without distance protection (mode 2, addresses 115, 116 and 117 = **Disabled**). The device behaves in this case like a normal line differential protection relay.

In mode 3, the differential protection is not configured (address 112 **DIFF. PROTECTION = Disabled**); the distance protection operates as the main protection function (if it is activated).

2.1.1.3 Setting Notes

Configuration of Function Scope

Configuration settings can be entered using a PC and the operating software DIGSI® and transferred via the operator interface on the front panel of the device or via the service interface. For more information on working with DIGSI®, please refer to the SIPROTEC®4 System Description /1/.

For changing configuration parameters in the device, password no. 7 is required (for parameter set). Without the password, the settings may be read, but may not be modified and transmitted to the device.

The scope of functions with the available options is set in the **Functional Scope** dialog box to match plant requirements.

Most settings are self-explaining. The special cases are described below.

Differential Protection

The differential protection and the distance protection can each be configured as the main protection function.

If the differential protection is the main protection function of the device, **DIFF . PROTECTION** (address 112) is set to **Enabled**. This also implies the supplementary functions of the differential protection such as breaker intertrip.

For the transmission of the protection signals to one (or two) device(s) each device is equipped with one or two protection data interfaces (order option). The assignment of the protection data interfaces is essential for the line protection system, i.e. the interaction of the devices at the ends of the protected object. Enable protection data interface 1 **P. INTERFACE 1** in address 145, and protection data interface 2 (if available) **P. INTERFACE 2** in address 146, if you want to use them. At least one protection data interface at the is required to make use of the differential protection function. A protected object with two ends requires at least one protection data interface in each device. If there are more ends, it must be guaranteed that all devices that belong together are interconnected directly or indirectly (via other devices). Section 2.2.1 Protection Data Topology provides more information.

The number of relays (address 147 **NUMBER OF RELAY**) must be equal to the number of measuring locations at the ends of the protected object. Please observe that only current transformer sets that limit the protected object are counted. The line in Figure 2-1, for instance, has three ends and three devices. It is limited by three current transformer sets. Two devices would normally be sufficient if current transformers 1 and 2 are connected in parallel at the secondary side and connected to a device. However, in the event of an external fault causing a high short-circuit current to pass through the current transformers 1 and 2, the restraint of the differential protection would be insufficient.



Figure 2-1 Protected object with 3 ends and 3 devices

If the device is connected to voltage transformers, set this condition in address 144 **V - TRANSFORMER**. The voltage dependent functions such as e.g. distance protection can be used if voltage transformers are connected.

If a power transformer is located within the protected zone, set this condition in address 143 **TRANSFORMER** (order option). The actual transformer data will be requested when the general protection data are set (see Section 2.1.4.1 under margin heading „Topological Data for Transformers“ (optional)).

If you want to configure differential protection with charging current compensation, set this condition in address 149 **charge I comp.**.

Distance Protection

Depending on the ordered version, the distance protection of the 7SD5, if configured as the main protection function or in combination with differential protection, features a range of fault detection modes, from which the appropriate type for the particular system conditions can be selected. If the device is equipped with impedance pickup only (7SD5***-*****-**E**** and 7SD5***-*****-**H****), you can select the tripping characteristic to be used by the distance protection; to do so, set address 115 for phase-phase measuring units **Phase Distance** and address 116 for phase-earth measuring units **Earth Distance** accordingly. You can choose between the polygonal tripping characteristic **Quadrilateral** and the MHO characteristic **MHO**. The characteristics and measurement methods are described in detail in Sections 2.5.2 and 2.5.3. You can choose different settings for the two addresses. If the device is to be used only for phase-earth loops or only for phase-phase loops, set the function that is not required to **Disabled**.

Other pickup procedures are available with the variants 7SD5***-*****-**D**** and 7SD5***-*****-**G****. The properties of these procedures are described in detail in Section 2.5.1.

If the fault current magnitude is a reliable criterion for distinction between a fault occurrence and load operation (incl. tolerable overload), set Address 117 **Dis. PICKUP = I> (overcurr.)** (overcurrent pickup). If the voltage surge is required as another pickup criterion, set **U/I** (voltage-dependent current pickup). For heavily loaded high-voltage lines and very-high-voltage lines the setting **U/I / φ** (voltage and phase-angle dependent current pickup) may be required. With setting **Z< (quadrilat.)** (... pickup) the distance zones which are set highest establish the pickup criteria. If you set address 117 **Dis. PICKUP** to **Disabled**, the distance protection function and all associated functions will not be available.

Please note that the power swing supplement (see also Section 2.6) only works together with the **Z< (quadrilat.)** pickup. In all other cases it is ineffective, even though you have set address 120 **Power Swing = Enabled**.

To complement the distance protection function by teleprotection schemes, you can select the desired scheme at address 121 **Teleprot. Dist..** You can select the permissive underreach transfer trip with pickup **PUTT (Pickup)** and with overreach zone **PUTT (Z1B)**, the teleprotection scheme **POTT**, directional comparison pickup **Dir.Comp.Pickup**, unblocking with Z1B **UNBLOCKING**, blocking scheme **BLOCKING**, and the schemes with pilot wire comparison **Pilot wire comp** and **Rev. Interlock** (reverse interlocking). If you do not want to use teleprotection in conjunction with distance protection set **Disabled**.

Other Special Features

If use of the setting group changeover function is desired, address 103 **Grp Chge OPTION** should be set to **Enabled**. In this case, up to four different groups of settings may be changed quickly and easily during device operation (see also Section 2.1.3). With the setting **Disabled** only one parameter group is available.

Address 110 **Trip mode** is only valid for devices that trip single-pole or three-pole. Set **1 - /3pole** to enable also single-pole tripping i.e., if you want to utilize single-pole or single-pole / multi-pole automatic reclosure. This requires an internal automatic reclosing function to be available or an external reclosing device. Furthermore, the circuit breaker must be capable of single pole tripping.

Note

If you have changed address 110, save your changes first via **OK** and reopen the dialog box since the other setting options depend on the selection in address 110.



The Direct Local Trip (address 122 **DTT Direct Trip**) is a command that is initiated from an external device for tripping the local circuit breaker.

With address 125 **Weak Infeed** you can select a supplement to the teleprotection schemes. Set **Enabled** to apply the classical scheme for echo and weak infeed tripping. The setting **Logic no. 2** switches this function to the French specification. This setting is available in the device variants for the region France (only version 7SD5***-**D** or 10th digit of order number = D).

At address 126 **Back-Up 0/C** you can set the characteristic group which the time overcurrent protection uses for operation. In addition to the definite time overcurrent protection, an inverse time overcurrent protection may be configured depending on the ordered version. The latter operates either according to an IEC characteristic (**TOC IEC**) or an ANSI characteristic (**TOC ANSI**). For the characteristics please refer to the Technical Data. You can also disable the time overcurrent protection (**Disabled**).

At address 131 **Earth Fault 0/C** you can set the characteristic group which the earth fault protection uses for operation. In addition to the definite time overcurrent protection, which covers up to three phases, an inverse-time earth fault protection function may be configured depending on the ordered version. The latter operates either according to an IEC characteristic (**TOC IEC**) or an ANSI characteristic (**TOC ANSI**) or according to a logarithmic-inverse characteristic (**TOC Logarithm.**). If an inverse-time characteristic is not required, the stage usually designated „inverse time“ can be used as the fourth definite-time stage (**Definite Time**). Alternatively, you can select an earth fault protection with inverse-time characteristic **U0 inverse** or a zero sequence power protection **Sr inverse**. For the characteristics please refer to the Technical Data. You can also disable the earth fault protection (**Disabled**).

When using the earth fault protection, it can be complemented by teleprotection schemes. Select the desired scheme at address 132 **Teleprot. E/F**. You can select the direction comparison scheme **Dir.Comp.Pickup**, the unblocking scheme **UNBLOCKING** and the blocking scheme **BLOCKING**. The procedures are described in detail in Section 2.9. If you do not want to use teleprotection in conjunction with earth fault protection set **Disabled**.

If the device features an automatic reclosing function, address 133 and 134 are of importance. Automatic reclosure is only allowed in overhead lines. It should not be used in any other case. If the protected object consists of a mixture of overhead lines and other equipment (e.g. overhead line in block with a transformer or overhead line/cable), it must be ensured that reclosure can only be performed in the event of a fault on the overhead line. If no automatic reclosing function is desired for the feeder at which 7SD5 operates, or if an external device is used for reclosure, set address 133 **Auto Reclose** to **Disabled**.

Otherwise set the number of desired reclosing attempts there. You can select **1 AR-cycle** to **8 AR-cycles**. You can also set **ADT** (adaptive dead times). In this case the behaviour of the automatic reclosing function is determined by the cycles of the remote end. The number of cycles must however be configured at least in one of the line ends which must have a reliable infeed. The other end — or other ends, if there are more than two line ends — may operate with adaptive dead time. Section 2.15 provides detailed information on this topic.

The **AR control mode** at address 134 allows a maximum of four options. Firstly, it can be determined whether the auto-reclose cycles are carried out according to the fault type detected by **pickup** of the starting protective function(s) (only three-pole tripping), or according to the type of **trip command**. Secondly, the automatic reclosing function can be operated **with** or **without** action time.

The setting **Trip with T-action / Trip without T-action ...** (default setting = Trip with T-action ...) is preferred if single-pole or single-pole/three-pole auto-

reclose cycles are provided for and possible. In this case different dead times after single-pole tripping on the one hand and after three-pole tripping on the other hand are possible (for every reclose cycle). The protective function that issues the trip command determines the type of trip: single-pole or three-pole. Depending on the latter the dead time is selected.

The setting **Pickup with T-action / Pickup without T-action ...** (Pickup with T-action ...) is only possible and visible if only three-pole tripping is desired. This is the case when either the ordering number of the device model indicates that it is only suited for three-pole tripping, or when three-pole tripping is solely configured (address 110 **Trip mode = 3pole only**, see above). In this case you can set different dead times for the auto-reclose cycles following single-pole, two-pole and three-pole faults. Decisive here is the **pickup** situation of the protective functions at the instant the trip command disappears. This control mode enables also the dead times to be made dependent on the type of fault in the case of three-pole reclosure cycles. Tripping is always three-pole.

The setting **Trip with T-action** provides an action time for each reclose cycle. The action time is started by a general pickup of all protection functions. If no trip command is present before the action time expires, the corresponding reclose cycle is not carried out. Section 2.15 provides detailed information on this topic. This setting is recommended for time-graded protection. If the protection function which is to operate with automatic reclosure, does not have a general pickup signal for starting the action times, select ... **Trip without T-action**.

Address 137 **U/O VOLTAGE** allows to activate the voltage protection function with a variety of undervoltage and overvoltage protection stages. In particular, the overvoltage protection with the positive sequence system of the measuring voltages provides the option to calculate the voltage at the other, remote line end via integrated compounding. This is particularly useful for long transmission lines where no-load or low-load conditions prevail and an overvoltage at the other line end (Ferranti effect) is to cause tripping of the local circuit breaker. In this case set address 137 **U/O VOLTAGE** to **Enabl. w. comp.** (available with compounding). Do not use compounding in lines with series capacitors!

For the fault location you can determine in address 138 **Fault Locator**, **Enabled** and **Disabled** that the fault distance is output in BCD code (4-bit units, 4-bit tens and 1-bit hundreds and 1-bit „data valid“) via binary outputs (**with BCD-output**). A corresponding number of output relays (No. 1143 to 1152) must be made available and allocated for this purpose. For double-ended fault location, address 3807 **two ended** must be set to **ON**. Please note that address 160 **L-sections FL** is used to state the number of sections of which your line length consists (e.g. cable-overhead line).

For the trip circuit supervision set at address 140 **Trip Cir. Sup.** the number of trip circuits to be monitored: **1 trip circuit**, **2 trip circuits** or **3 trip circuits**, unless you omit it (**Disabled**).

2.1.1.4 Settings

Addr.	Parameter	Setting Options	Default Setting	Comments
103	Grp Chge OPTION	Disabled Enabled	Disabled	Setting Group Change Option
110	Trip mode	3pole only 1-/3pole	3pole only	Trip mode
112	DIFF.PROTECTION	Enabled Disabled	Enabled	Differential protection
115	Phase Distance	Quadrilateral MHO Disabled	Quadrilateral	Phase Distance
116	Earth Distance	Quadrilateral MHO Disabled	Quadrilateral	Earth Distance
117	Dis. PICKUP	Z< (quadrilat.) I> (overcurr.) U/I U/I/φ Disabled	Z< (quadrilat.)	Distance protection pickup program
120	Power Swing	Disabled Enabled	Disabled	Power Swing detection
121	Teleprot. Dist.	PUTT (Z1B) PUTT (Pickup) POTT Dir.Comp.Pickup UNBLOCKING BLOCKING Rev. Interlock Pilot wire comp Disabled	Disabled	Teleprotection for Distance prot.
122	DTT Direct Trip	Disabled Enabled	Disabled	DTT Direct Transfer Trip
124	HS/SOTF-O/C	Disabled Enabled	Disabled	Instantaneous HighSpeed/SOTF Overcurrent
125	Weak Infeed	Disabled Enabled Logic no. 2	Disabled	Weak Infeed (Trip and/or Echo)
126	Back-Up O/C	Disabled TOC IEC TOC ANSI	TOC IEC	Backup overcurrent
131	Earth Fault O/C	Disabled TOC IEC TOC ANSI TOC Logarithm. Definite Time U0 inverse Sr inverse	Disabled	Earth fault overcurrent
132	Teleprot. E/F	Dir.Comp.Pickup UNBLOCKING BLOCKING Disabled	Disabled	Teleprotection for Earth fault overcurr.

Addr.	Parameter	Setting Options	Default Setting	Comments
133	Auto Reclose	1 AR-cycle 2 AR-cycles 3 AR-cycles 4 AR-cycles 5 AR-cycles 6 AR-cycles 7 AR-cycles 8 AR-cycles ADT Disabled	Disabled	Auto-Reclose Function
134	AR control mode	Pickup w/ Tact Pickup w/o Tact Trip w/ Tact Trip w/o Tact	Trip w/o Tact	Auto-Reclose control mode
135	Synchro-Check	Disabled Enabled	Disabled	Synchronism and Voltage Check
136	FREQUENCY Prot.	Disabled Enabled	Disabled	Over / Underfrequency Protection
137	U/O VOLTAGE	Disabled Enabled Enabl. w. comp.	Disabled	Under / Overvoltage Protection
138	Fault Locator	Disabled Enabled with BCD-output	Disabled	Fault Locator
139	BREAKER FAILURE	Disabled Enabled	Disabled	Breaker Failure Protection
140	Trip Cir. Sup.	Disabled 1 trip circuit 2 trip circuits 3 trip circuits	Disabled	Trip Circuit Supervision
142	Therm.Overload	Disabled Enabled	Disabled	Thermal Overload Protection
143	TRANSFORMER	NO YES	NO	Transformer inside protection zone
144	V-TRANSFORMER	Not connected connected	connected	Voltage transformers
145	P. INTERFACE 1	Enabled Disabled	Enabled	Protection Interface 1 (Port D)
146	P. INTERFACE 2	Disabled Enabled	Disabled	Protection Interface 2 (Port E)
147	NUMBER OF RELAY	2 relays 3 relays 4 relays 5 relays 6 relays	2 relays	Number of relays
148	GPS-SYNC.	Enabled Disabled	Disabled	GPS synchronization
149	charge I comp.	Enabled Disabled	Disabled	charging current compensation
160	L-sections FL	1 Section 2 Sections 3 Sections	1 Section	Line sections for fault locator

2.1.2 General Power System Data (Power System Data 1)

The device requires certain network and power system data so that it can be adapted to its intended functions in accordance with application. This comprises, e.g., nominal system data, nominal data of transformers, polarity ratios and their physical connections, in certain cases circuit breaker properties, and similar. Furthermore, there are a number of settings associated with all functions rather than a specific protection, control or monitoring function. These data can only be changed from a PC running DIGSI® and are discussed in this section.

2.1.2.1 Setting Notes

Polarity of Current Transformers

In address 201 **CT Starpoint**, the polarity of the wye-connected current transformers is specified (the following figure also goes for only two current transformers). This setting determines the measuring direction of the device (forwards = line direction). A change in this setting also results in a polarity reversal of the earth current inputs I_E or I_{EE} .




Figure 2-2 Polarity of current transformers

Nominal Values of the Transformers

If voltage transformers are connected, the device obtains in addresses 203 **Unom PRIMARY** and 204 **Unom SECONDARY** information on the primary and secondary nominal voltage (phase-to-phase voltage), and in addresses 205 **CT PRIMARY** and 206 **CT SECONDARY** information on the primary and secondary nominal currents of the current transformers (phases).

Address 206 **CT SECONDARY** must correspond to the nominal current of the device, otherwise the processor system cannot be started.

The correct primary data are required for the calculation of the proper primary information of the operational measured values. If the settings of the device are performed with primary values using DIGSI®, these primary data are an indispensable requirement for the fault-free operation of the device.

In principle, the differential protection is designed such that it can operate without measured voltages if it is configured as the main protection function without distance protection function. However, voltages can be connected. These voltages allow to display and log voltages, to calculate various components of power and to locate faults. If nec-

essary, they can also serve for determining the life line condition in case of automatic reclosure. During configuration of the device functions (Section 2.1.1), it has been determined whether the device is to work with or without measured voltages.

Voltage Connection

The device contains four voltage measuring inputs, three of which are connected to the set of voltage transformers. Various possibilities exist for the fourth voltage input U_4 :

- Connection of the U_4 input to the open delta winding e-n of the voltage transformer set:

Address 210 is then set to: **U4 transformer = Udelta transf..**

When connected to the e-n winding of a set of voltage transformers, the voltage transformation ratio of the voltage transformers is usually:

$$\frac{U_{Nprim}}{\sqrt{3}} / \frac{U_{Nsec}}{\sqrt{3}} / \frac{U_{Nsec}}{3}$$

The factor U_{ph}/U_{delta} (secondary voltage, address 211 **Uph / Udelta**) must be set to $3/\sqrt{3} = \sqrt{3} \approx 1.73$. For other transformation ratios, i.e. the formation of the displacement voltage via an interconnected transformer set, the factor must be corrected accordingly. This factor is of importance if the $3U_0$ protective element is used and for the monitoring of the measured values and the scaling of the measurement and disturbance recording signals.

- Connection of the U_4 input to the busbar voltage in order to perform the synchronism check:

Address 210 is then set to: **U4 transformer = Usync transf..**

If the transformation ratio differs from that of the line voltage transformers this can be adapted with the setting in address 215 **U-line / Usync**. In address 212 **Usync connect..**, the type of voltage used by the busbar for synchronism check is configured. The device then selects automatically the appropriate feeder voltage. If the two measuring points used for synchronism check — i.e. feeder voltage transformer and busbar voltage transformer — are not separated by devices that cause a relative phase shift, then the parameter in address 214 ϕ **Usync-Uline** is not required. This parameter can only be altered with DIGSI® under **Additional Settings**. If however a power transformer is switched in between, its vector group must be adapted. The phase angle from U_{Line} to U_{Bus} is evaluated positively.

Example: (see also Figure 2-3)

Busbar 400 kV primary, 110 V secondary,

Feeder 220 kV primary, 100 V secondary,

Transformer 400 kV / 220 kV, vector group Dy(n) 5

The transformer vector group is defined from the high side to the low side. In this example, the feeder voltage is connected to the low voltage side of the transformer. If U_{sync} (busbar or high voltage side) is placed at zero degrees, then U_{line} is at $5 \times 30^\circ$ (according to the vector group) in the clockwise direction, i.e. at -150° . A positive angle is obtained by adding 360° :

Address 214: ϕ **Usync-Uline** = $360^\circ - 150^\circ = 210^\circ$.

The busbar transformers supply 110 V secondary for primary operation at nominal value while the feeder transformer supplies 100 V secondary. Therefore, this difference must be balanced:

Address 215: **U-line / Usync** = $100 \text{ V} / 110 \text{ V} = 0.91$.




Figure 2-3 Busbar voltage measured via transformer

- Connection of the U_4 input to any other voltage signal U_x , which can be processed by the overvoltage protection function:

Address 210 is then set to: **U4 transformer = U_x transformer.**

- If the input U_4 is not required, set:

Address 210 **U4 transformer = Not connected.**

Also in this case the factor **Uph / Udelta** (address 211, see above) is of importance, as it is utilised for the scaling of the measurement and disturbance recording data.

Current Connection

The device features four current measurement inputs, three of which are connected to the set of current transformers. Various possibilities exist for the fourth current input I_4 :

- Connection of the I_4 input to the earth current in the starpoint of the set of current transformers on the protected feeder (normal connection):

Address 220 is then set to: **I4 transformer = In prot. line** and address 221 **I4/Iph CT = 1.**

- Connection of the I_4 input to a separate earth current transformer on the protected feeder (e.g. a summation CT or core balance CT):

Address 220 is then set to: **I4 transformer = In prot. line** and address 221 **I4/Iph CT** is set:

$$I_4 / I_{ph CT} = \frac{\text{Ratio of earth current transformer}}{\text{Ratio of phase current transformers}}$$

This is independent of whether the device has a normal measuring current input for I_4 or a sensitive measuring current input (if necessary with I_E transformer for earth fault protection).

Example:

Phase current transformers 500 A / 5 A

Earth current transformer 60 A / 1 A

$$I_4 / I_{ph CT} = \frac{60 / 1}{500 / 5} = 0.600$$

- Connection of the I_4 input to the earth current of the parallel line (for parallel line compensation of the distance protection and/or fault location):

Address 220 is then set to: **I4 transformer = In paral. line** and usually address 221 **I4/Iph CT** = 1.

If the set of current transformers on the parallel line however has a different transformation ratio to those on the protected line, this must be taken into account in address 221:

Address 220 is then set to: **I4 transformer = In paral. line** and address 221 **I4/Iph CT** = $I_{N \text{ paral. line}} / I_{N \text{ prot. line}}$

Example:

Current transformers on protected line 1200 A

Current transformers on parallel line 1500 A

$$I_4 / I_{ph CT} = \frac{1500}{1200} = 1.250$$

- Connection of the I_4 input to the starpoint current of a transformer; this connection is occasionally used for the polarisation of the directional earth fault protection:

Address 220 is then set to: **I4 transformer = IY starpoint**, and address 221 **I4/Iph CT** is according to transformation ratio of the starpoint transformer to the transformer set of the protected line.

- If the input I_4 is not required, set:

Address 220 **I4 transformer = Not connected**,

Address 221 **I4/Iph CT** is then irrelevant.

In this case, the neutral current is calculated from the sum of the phase currents.

NominalFrequency

The nominal frequency of the system is set in address 230 **Rated Frequency**. The presetting according to the ordering code (MLFB) only needs to be changed if the device is applied in a region different to the one indicated when ordering. You can set **50 Hz** or **60 Hz**.

System Starpoint

If the distance protection has been configured as the main protection function or in combination with differential protection, the manner in which the system starpoint is earthed must be considered for the correct processing of earth faults and double earth faults. Accordingly, set for address 207 **SystemStarpoint** = **Solid Earthed**, **Peterson-Coil** or **Isolated**. For „low-resistant“ earthed systems set **Solid Earthed**.

Distance Unit

Address 236 **Distance Unit** determines the distance unit (**km** or **Miles**) for the fault location indications. If the compounding function of the voltage protection is used, the overall line capacitance is calculated from the line length and the capacitance per unit length. If compounding is not used and fault location is not available, this parameter is of no consequence. Changing the distance unit will not result in an automatic

conversion of the setting values which depend on this distance unit. They have to be re-entered into their corresponding valid addresses.

Mode of Earth Impedance (Residual) Compensation

Matching of the earth to line impedance is an essential prerequisite for the accurate measurement of the fault distance (distance protection, fault locator) during earth faults. In address 237 **Format Z0/Z1** the format for entering the residual compensation is determined. It is possible to either use the ratio **RE/RL**, **XE/XL** or to enter the complex earth (residual) impedance factor **K0**. The setting of the earth (residual) impedance factors is done in the power system data 2 (refer to Section 2.1.4).

Operating Time of the Circuit Breaker

The circuit breaker closing time **T-CB close** at address 239 is required if the device is to close also under asynchronous system conditions, no matter whether for manual closing, for automatic reclosing after three-pole tripping, or both. The device will then calculate the time for the close command such that the voltages are phase-synchronous the instant the breaker poles make contact.

Trip Command Duration

In address 240 the minimum trip command duration **TMin TRIP CMD** is set. This applies to all protection and control functions which may issue a trip command. It also determines the duration of the trip pulse when a circuit breaker trip test is initiated via the device. This parameter can only be altered with DIGSI® under **Additional Settings**.

In address 241 the maximum close command duration **TMax CLOSE CMD** is set. This applies to all close commands issued by the device. It also determines the length of the close command pulse when a circuit breaker test cycle is issued via the device. It must be set long enough to ensure that the circuit breaker has securely closed. There is no risk in setting this time too long, as the close command will in any event be terminated following a new trip command from a protection function. This setting is only possible via DIGSI® at "Additional Settings".

Circuit Breaker Test

7SD5 allows a circuit breaker test during operation by means of a tripping and a closing command entered on the front panel or via DIGSI®. The duration of the trip command is set as explained above. Address 242 **T-CBtest-dead** determines the duration from the end of the trip command until the start of the close command for this test. It should not be less than 0.1s.

Current Transformer Characteristic

The basic principle of the differential protection assumes that all currents flowing into a healthy protected section add up to zero. If the current transformer sets at the line ends have different transformation errors in the overcurrent range, the sum of the secondary currents can reach considerable peaks due to the saturation of the transformers when a short-circuit current flows through the line. These peaks may feign an internal fault. The features included in the 7SD5 to prevent errors in case of current transformer saturation work completely satisfying if the protection knows the response characteristic of the current transformers.

For this, the characteristic data of the current transformers and of their secondary circuits are set (see also Figure 2-19 in Section 2.3). The default setting are adequate in most cases; they correspond to usual current transformers for protection purposes.

The nominal accuracy limit factor n of the current transformers and the nominal power P_N are usually stated on the rating plate of the current transformers. The information stated refers to reference conditions (nominal current, nominal burden). For example (according to VDE 0414 / Part 1 or IEC 60044)

Current transformer 10P10; 30 VA $\rightarrow n = 10$; $P_N = 30$ VA

Current transformer 10P20; 20 VA $\rightarrow n = 20$; $P_N = 20$ VA

The operational accuracy limit factor n' is derived from this nominal data and the actual secondary burden P' :

$$\frac{n'}{n} = \frac{P_N + P_i}{P' + P_i}$$

with

n' =	Operational accuracy limit factor (actual over-current factor)
n =	Nominal accuracy limit factor of CTs (distinctive number behind P)
P_N =	Nominal CT burden [VA] at nominal current
P_i =	Internal CT burden [VA] at rated current
P' =	Actually connected burden (devices + secondary lines) [VA] at nominal current

Usually, the internal burden of current transformers is stated in the test report. If unknown, it can be calculated roughly from the DC resistance R_i of the secondary winding.

$$P_i \approx R_i \cdot I_N^2$$

The ratio between the operational accuracy limit factor and the nominal accuracy limit factor n'/n is set under address 251 **K_ALF/K_ALF_N**.

The CT error at nominal current, plus a safety margin, is set under address 253 **E% ALF/ALF_N**. It is equal to the „current measuring deviation for primary nominal current intensity F1“ according to VDE 0414 / Part 1 or IEC 60044. It is

- 3 % for a CT 5P, and
- 5 % for a CT 10P.

The CT error at nominal accuracy limit factor, plus a safety margin, is set under address 254 **E% K_ALF_N**. It is derived from the number preceding the P of the transformer data.

Table 2-1 illustrates some usual current transformer types with their characteristic data and the recommended settings.

Table 2-1 Recommended settings for current transformer data

CT Class	Standard	Error at Rated Current		Error at Rated Accuracy Limit Factor	Recommended Settings		
		Transformation Ratio	Angle		Address 251	Address 253	Address 254
5P	IEC 60044-1	1.0 %	± 60 min	≤ 5 %	≤ 1.50 ¹⁾	3.0 %	10.0 %
10P		3.0 %	—	≤ 10 %	≤ 1.50 ¹⁾	5.0 %	15.0 %
TPX	IEC 60044-1	0.5 %	± 30 min	ε ≤ 10 %	≤ 1.50 ¹⁾	1.0 %	15.0 %
TPY		1.0 %	± 30 min	ε ≤ 10 %	≤ 1.50 ¹⁾	3.0 %	15.0 %
TPZ		1.0 %	± 180 min ± 18 min	ε ≤ 10 % (only I~)	≤ 1.50 ¹⁾	6.0 %	20.0 %
PX	IEC 60044-1 BS: Class X				≤ 1.50 ¹⁾	3.0 %	10.0 %
C100 to C800	ANSI				≤ 1.50 ¹⁾	5.0 %	15.0 %

¹⁾ If $n'/n \leq 1.50$, setting = calculated ratio; if $n'/n > 1.50$, setting = 1.50

With this data the device establishes an approximate CT error characteristic and calculates the restraint quantity (see also Section 2.3).

Calculation example:

Current transformers 5P10; 20 VA

Transformation 600 A / 5 A

Internal burden 2 VA

Secondary lines 4 mm² CC

Length 20 m

Device 7SD5, $I_N = 5$ A

Burden at 5 A, 0.3 VA

The resistance of secondary lines is (with the resistivity for copper $\rho_{Cu} = 0.0175$ Ωmm²/m)

$$R_l = 2 \cdot 0.0175 \frac{\Omega \text{mm}^2}{\text{m}} \cdot \frac{20 \text{ m}}{4 \text{ mm}^2} = 0.175 \Omega$$

Here, the most unfavourable case is assumed, i.e. the current (as it is the case with single-phase faults) flows back and forth via the secondary lines (factor 2). From that the power for nominal current $I_N = 5$ A is calculated

$$P_l = 0.175 \Omega \cdot (5 \text{ A})^2 = 4.375 \text{ VA}$$

The entire connected burden consists of the burden of the incoming lines and the burden of the device:

$$P' = 4.375 \text{ VA} + 0.3 \text{ VA} = 4.675 \text{ VA}$$

Thus the ratio of the accuracy limit factors is as follows

$$\frac{n'}{n} = \frac{P_N + P_l}{P' + P_l} = \frac{20 \text{ VA} + 2 \text{ VA}}{4.675 \text{ VA} + 2 \text{ VA}} = 3.30$$

According to the above table, address 251 should be set to 1.50 if the calculated ratio is higher than 1.50. This leads to the following setting values:

Address 251 **K_ALF / K_ALF_N = 1.50**

Address 253 **E% ALF / ALF_N = 3.0**

Address 254 **E% K_ALF_N = 10.0**

The presettings correspond to current transformers 10P with nominal burden

Of course, only those settings are reasonable where address 253 **E% ALF / ALF_N** is set lower than address 254 **E% K_ALF_N**.

Power Transformer with Voltage Regulation

If the protected object covers a power transformer with voltage regulation, a differential current may occur even during normal healthy operation under steady-state conditions. This differential current depends on the current intensity as well as on the position of the tap changer of the transformer. Since this differential current is current-proportional it is meaningful to consider it like a current transformer error. You may calculate the maximum differential current at the limits of the tap changer under nominal conditions (referred to the mean current) and add it to the current transformer error as discussed above (addresses 253 and 254). This correction is performed only at that relay facing the regulated winding of the power transformer.

Calculation example:

Transformer YNd5
35 MV
110 kV/25 kV
Y-winding with tap changer $\pm 10\%$

From this resulting:

Nominal current at nominal voltage $I_N = 184\text{ A}$

Nominal current at $U_N + 10\%$ $I_{\min} = 167\text{ A}$

Nominal current at $U_N - 10\%$ $I_{\max} = 202\text{ A}$

$$\text{Medium Current } I_{\text{Mid}} = \frac{I_{\min} + I_{\max}}{2} = \frac{167\text{ A} + 202\text{ A}}{2} = 184.5\text{ A}$$

The maximum deviation from this mean current is

$$\text{Max. Error } \delta_{\text{Max}} = \frac{I_{\max} - I_{\text{Mid}}}{I_{\text{Mid}}} = \frac{202\text{ A} - 184.5\text{ A}}{184.5\text{ A}} = 0.095 = 9.5\%$$

This maximum deviation δ_{max} [in %] has to be added to the current transformer errors as determined above, addresses 253 **E% ALF / ALF_N** and 254 **E% K_ALF_N**.

It must be considered that this deviation is referred to the mean current value between the extrema of the tap changer position at nominal apparent power, not to the current value at nominal voltage and nominal power. This demands a further correction of the data of the protected object as discussed in Section 2.1.4 under margin heading „Topological Data for Transformers (optional)“.

2.1.2.2 Settings

Addresses which have an appended "A" can only be changed with DIGSI, under Additional Settings.

Addr.	Parameter	Setting Options	Default Setting	Comments
201	CT Starpoint	towards Line towards Busbar	towards Line	CT Starpoint
203	Unom PRIMARY	0.4 .. 1200.0 kV	400.0 kV	Rated Primary Voltage
204	Unom SECONDARY	80 .. 125 V	100 V	Rated Secondary Voltage (Ph-Ph)
205	CT PRIMARY	10 .. 5000 A	1000 A	CT Rated Primary Current
206	CT SECONDARY	1A 5A	1A	CT Rated Secondary Current
207	SystemStarpoint	Solid Earthed Peterson-Coil Isolated	Solid Earthed	System Starpoint is
210	U4 transformer	Not connected Udelta transf. Usync transf. Ux transformer	Not connected	U4 voltage transformer is
211	Uph / Udelta	0.10 .. 9.99	1.73	Matching ratio Phase-VT To Open-Delta-VT
212	Usync connect.	L1-E L2-E L3-E L1-L2 L2-L3 L3-L1	L1-E	VT connection for sync. voltage
214A	ϕ Usync-Uline	0 .. 360 °	0 °	Angle adjustment Usync-Uline
215	U-line / Usync	0.50 .. 2.00	1.00	Matching ratio U-line / Usync
220	I4 transformer	Not connected In prot. line In paral. line IY starpoint	In prot. line	I4 current transformer is
221	I4/Iph CT	0.010 .. 5.000	1.000	Matching ratio I4/Iph for CT's
230	Rated Frequency	50 Hz 60 Hz	50 Hz	Rated Frequency
236	Distance Unit	km Miles	km	Distance measurement unit
237	Format Z0/Z1	RE/RL, XE/XL K0	RE/RL, XE/XL	Setting format for zero seq.comp. format
239	T-CB close	0.01 .. 0.60 sec	0.06 sec	Closing (operating) time of CB
240A	TMin TRIP CMD	0.02 .. 30.00 sec	0.10 sec	Minimum TRIP Command Duration
241A	TMax CLOSE CMD	0.01 .. 30.00 sec	1.00 sec	Maximum Close Command Duration
242	T-CBtest-dead	0.00 .. 30.00 sec	0.10 sec	Dead Time for CB test-autoreclosure

Addr.	Parameter	Setting Options	Default Setting	Comments
251	K_ALF/K_ALF_N	1.00 .. 10.00	1.00	k_alf/k_alf nominal
253	E% ALF/ALF_N	0.5 .. 50.0 %	5.0 %	CT Error in % at k_alf/k_alf nominal
254	E% K_ALF_N	0.5 .. 50.0 %	15.0 %	CT Error in % at k_alf nominal

2.1.3 Change Group

2.1.3.1 Purpose of the Setting Groups

Up to four independent setting groups can be created for establishing the device's function settings. During operation, the user can locally switch between setting groups using the operator panel, binary inputs (if so configured), the operator and service interface per PC, or via the system interface. For reasons of safety it is not possible to change between setting groups during a power system fault.

A setting group includes the setting values for all functions that have been selected as **Enabled** during configuration (see Section 2.1.1.3). In 7SD5 devices, four independent setting groups (A to D) are available. Whereas setting values and options may vary, the selected scope of functions is the same for all groups.

Setting groups enable the user to save the corresponding settings for each application. When they are needed, settings may be loaded quickly. All setting groups are stored in the relay. Only one setting group may be active at a given time.

2.1.3.2 Setting Notes

General

If multiple setting groups are not required. Group A is the default selection. Then, the rest of this section is not applicable.

If multiple setting groups are desired, the setting group change option must be set to **Grp Chge OPTION = Enabled** in the relay configuration of the functional scope (Section 2.1.1.3, address 103). For the setting of the function parameters, you can configure each of the required setting groups A to D, one after the other. A maximum of 4 is possible. To find out how to proceed, how to copy and to reset settings groups, and how to switch between setting groups during operation, please refer to the SIPROTEC® 4 System Description.

Two binary inputs enable changing between the 4 setting groups from an external source.

2.1.3.3 Settings

Addr.	Parameter	Setting Options	Default Setting	Comments
301	ACTIVE GROUP	Group A Group B Group C Group D	Group A	Active Setting Group is
302	CHANGE	Group A Group B Group C Group D Binary Input Protocol	Group A	Change to Another Setting Group

2.1.3.4 Information List

No.	Information	Type of Information	Comments
-	Group A	IntSP	Group A
-	Group B	IntSP	Group B
-	Group C	IntSP	Group C
-	Group D	IntSP	Group D
7	>Set Group Bit0	SP	>Setting Group Select Bit 0
8	>Set Group Bit1	SP	>Setting Group Select Bit 1

2.1.4 General Protection Data (Power System Data 2)

The general protection data (**P.System Data 2**) include settings associated with all functions rather than a specific protection, monitoring or control function. In contrast to the **P.System Data 1** as discussed before, these can be changed over with the setting groups and can be configured via the operator panel of the device.

The nominal operating data under **P.System Data 2** should be set to the same values at all ends of the protected object. This ensures uniform measured values displayed during commissioning and operation and sent to a central computer station.

2.1.4.1 Setting Notes

Nominal Values of Protected Lines

The statements under this margin heading refer to protected lines (cables or overhead lines) if no power transformer is situated within the protected zone, i.e. to models without transformer option or if address 143 **TRANSFORMER** has been set to **NO** (see Section 2.1.1.3).

With address 1103 **FullScaleVolt.** you inform the device of the primary nominal voltage (phase-to-phase) of the equipment to be protected (if voltages are applied). This setting influences the displays of the operational measured values in %.

The primary nominal current (address 1104 **FullScaleCurr.**) is that of the protected object. For cables the thermal continuous current-loading capacity can be selected. For overhead lines the nominal current is usually not defined; set the nominal current of the current transformers (as set in address 205 **CT PRIMARY**, Section 2.1.2.1). If

the current transformers have different nominal currents at the ends of the protected object, set the highest nominal current value for all ends.

This setting will not only have an impact on the indication of the operational measured values in per cent, but **must also be exactly the same for each end of the protected object**, since it is the basis for the current comparison at the ends.

Topological Data for Transformers (optional)

The statements under this margin heading apply to cases where the differential protection has been configured as the main protection function and where a power transformer is situated within the protected zone (i.e. to models with transformer option, or if address 143 **TRANSFORMER** has been set to **YES**, see Section 2.1.1.3). If no transformer is part of the protected zone, this paragraph can be passed over.

The topological data make it possible to relate all measured quantities to the nominal data of the power transformer.

With address 1103 **FullScaleVolt.** you inform the device of the primary nominal voltage (phase-to-phase) of the transformer to be protected. This setting is also needed for computing the current reference value of the differential protection. Therefore, **it is important to set the correct nominal voltage for each end of the protected object even if no measured voltages are applied to the relay.**

In general, select the nominal voltage of the transformer winding facing the device. However, if the protected transformer is equipped with a voltage tap changer at one winding, then do not use the nominal voltage of that winding but the voltage that corresponds to the mean value of the currents at the ends of the control range of the tap changer. In this way the fault currents caused by voltage regulation are minimized.

Calculation example:

Transformer YNd5
 35 MVA
 110 kV / 25 kV
 Y-winding with tap changer $\pm 10\%$

This results for the regulated winding (110 kV) in:

maximum voltage $U_{\max} = 121 \text{ kV}$

minimum voltage $U_{\min} = 99 \text{ kV}$

Setting voltage (address 1103)

$$U_{N\text{-Oper Prim}} = \frac{2}{\frac{1}{U_{\max}} + \frac{1}{U_{\min}}} = \frac{2}{\frac{1}{121 \text{ kV}} + \frac{1}{99 \text{ kV}}} = 108.9 \text{ kV}$$

The **OPERATION POWER** (address 1106) is the direct primary nominal apparent power for transformers and other machines. For transformers with more than two windings, state the winding with the highest nominal apparent power. The **same operation power value must be set for each end of the protected object** since it is the basis for the current comparison at the ends.

The power must always be entered as a primary value, even if the device is generally configured in secondary values. The device calculates the nominal current of the protected winding from this power.

The **VECTOR GROUP I** (address 1162) is the vector group of the power transformer, always from the device's perspective. The device which is used for the reference end of the transformer, normally the one at the high voltage side, must keep the numerical

index **0** (default setting). The relevant vector group index must be stated for the other winding(s).

Example:

Transformer **Yy6d5**

For the **Y** end is set: **VECTOR GROUP I = 0**,

For the **y** end is set: **VECTOR GROUP I = 6**,

For the **d** end is set: **VECTOR GROUP I = 5**.

If a different winding is chosen as reference winding, e.g. the d winding, this has to be taken into consideration:

For the **Y** end is set: **VECTOR GROUP I = 7** (12 - 5),

For the **y** end is set: **VECTOR GROUP I = 1** (6 - 5),

For the **d** end is set: **VECTOR GROUP I = 0** (5 - 5 = 0 = reference side).

Address 1161 **VECTOR GROUP U** is normally set to the same value as address 1162 **VECTOR GROUP I**.

If the vector group of the transformer is adapted with external means, e.g. because there are matching transformers in the measuring circuit that are still used, set **VECTOR GROUP I = 0** at all ends. In this case the differential protection operates without proper matching computation. However, the measuring voltages transmitted via the transformer would not be adapted in the device and therefore not be calculated and displayed correctly. Address 1161 **VECTOR GROUP U** serves to remove this disadvantage. Set the correct vector group of the transformer according to the above-mentioned considerations.

Address 1162 **VECTOR GROUP I** is therefore relevant for the differential protection, whereas address 1161 **VECTOR GROUP U** serves as a basis for the computation of measured voltages beyond the transformer.

Address 1163 **TRANS STP IS** is used to set whether the power transformer starpoint facing the device is earthed or not. If the starpoint is earthed, the device will eliminate the zero sequence current of the relevant side, since this zero sequence current may cause a spurious tripping in case of an earth fault outside of the protected zone.

General Line Data of the Distance Protection

The statements under this margin heading apply to cases where the distance protection has been configured as the main or as a backup protection of the differential protection function.

The settings of the line data in this case refers to the common data which is independent of the actual distance protection grading.

The line angle (address 1105 **Line Angle**) may be derived from the line parameters. The following applies:

$$\tan \varphi = \frac{X_L}{R_L} \quad \text{or} \quad \varphi = \arctan\left(\frac{X_L}{R_L}\right)$$

where R_L is being the resistance and X_L the reactance of the protected feeder. The line parameters may either apply to the entire line length, or be per unit of line length as the quotient is independent of length. Furthermore it makes no difference if the quotients are calculated with primary or secondary values.

The line angle is of major importance, e.g. for earth impedance matching according to amount and angle or for compounding in overvoltage protection.

Calculation Example:

110 kV overhead line 150 mm² with the following data:

$$R'_1 = 0.19 \, \Omega/\text{km}$$

$$X'_1 = 0.42 \, \Omega/\text{km}$$

The line angle is computed as follows

$$\tan \varphi = \frac{X'_L}{R'_L} = \frac{X'_1}{R'_1} = \frac{0.42 \, \Omega/\text{km}}{0.19 \, \Omega/\text{km}} = 2.21 \quad \varphi = 65.7^\circ$$

In address 1105 the setting **Line Angle = 66°** is entered.

Address 1540 **Distance Angle** specifies the angle of inclination of the R sections of the distance protection polygons. Usually you can also set the line angle here as in address 1105.

The directional values (power, power factor, work and related min., max., mean and setpoint values), calculated in the operational measured values, are usually defined with positive direction towards the protected object. This requires that the connection polarity for the entire device was configured accordingly in the Power System Data 1 (compare also „Polarity of Current Transformers“, address 201). But it is also possible to define by setting the „forward“ direction for the protection functions and the positive direction for the power etc. differently, e.g. so that the active power flow (from the line to the busbar is indicated in the positive sense. Set under address 1107 **P,Q sign** the option **reversed**. If the setting is **not reversed** (default), the positive direction for the power etc. corresponds to the „forward“ direction for the protection functions.

The reactance value X' of the protected line is entered as reference value x' in address 1111 in Ω/km if the distance unit was set as kilometer (address 236, see Section 2.1.2.1 at „Distance Unit“), or in Ω/mile if mile was selected as distance unit. The corresponding line length is entered in address 1113 **Line Length** in kilometers or in miles. If, after entry of the reactance per unit of line length in address 1111 or of the line length in address 1113, the distance unit is changed in address 236, the line data must be entered again for the revised distance unit.

The capacitance per unit length C' of the protected line is required for load current compensation, for double-ended fault location and for compounding in overvoltage protection. Without compounding it is of no consequence. It is entered as a reference value c' at address 1112 in $\mu\text{F}/\text{km}$ if kilometers was set as the distance unit (address 236, see Section 2.1.2.1 at „Distance Unit“), or in $\mu\text{F}/\text{mile}$ if mile was set as distance unit. If, after entry of the capacitance per unit of line length in address 1112 or of the line length in address 1113, the distance unit is changed in address 236, the line data must be entered again for the revised distance unit.

For calculation of the capacitance of a line system, the entire line length, i.e. the sum of all line sections, must be set in address 1114 **Tot. Line Length**. For lines with more than two ends, this information is required for charging current compensation.

When entering the parameters with a personal computer and DIGSI® the values may optionally also be entered as primary values. If the nominal quantities of the primary transformers (U, I) are set to minimum, primary values allow only a rough setting of the value parameters. In such cases it is preferable to set the parameters in secondary quantities.

For conversion of primary values to secondary values the following applies in general:

$$Z_{\text{sec}} = \frac{\text{Ratio of current transformers}}{\text{Ratio of voltage transformers}} \cdot Z_{\text{prim}}$$

Likewise, the following goes for the reactance setting of a line:

$$X'_{\text{sec}} = \frac{N_{\text{CT}}}{N_{\text{VT}}} \cdot X'_{\text{prim}}$$

where

N_{CT} = Current transformer ratio

N_{VT} = Transformation ratio of voltage transformer

The following applies for the capacitance per distance unit:

$$C'_{\text{sec}} = \frac{N_{\text{VT}}}{N_{\text{CT}}} \cdot C'_{\text{prim}}$$

Calculation Example:

110 kV overhead line 150 mm² as above

$$R'_1 = 0.19 \, \Omega/\text{km}$$

$$X'_1 = 0.42 \, \Omega/\text{km}$$

$$C' = 0.008 \, \mu\text{F}/\text{km}$$

Current Transformer 600 A / 1 A

Voltage transformer 110 kV / 0.1 kV

The secondary per distance unit reactance is therefore:

$$X'_{\text{sec}} = \frac{N_{\text{CT}}}{N_{\text{VT}}} \cdot X'_{\text{prim}} = \frac{600 \, \text{A} / 1 \, \text{A}}{110 \, \text{kV} / 0.1 \, \text{kV}} \cdot 0.42 \, \Omega/\text{km} = 0.229 \, \Omega/\text{km}$$

In address 1111 the setting **x' = 0.229** Ω/km is entered.

The secondary per distance unit capacitance is therefore:

$$C'_{\text{sec}} = \frac{N_{\text{VT}}}{N_{\text{CT}}} \cdot C'_{\text{prim}} = \frac{110 \, \text{kV} / 0.1 \, \text{kV}}{600 \, \text{A} / 1 \, \text{A}} \cdot 0.008 \, \mu\text{F}/\text{km} = 0.015 \, \mu\text{F}/\text{km}$$

In address 1112 the setting **c' = 0.015** μF/km is entered.

Earth Impedance (Residual) Compensation

Matching of the earth to line impedance is an essential prerequisite for the accurate measurement of the fault distance (distance protection, fault locator) during earth faults. This compensation is either achieved by entering the resistance ratio R_E/R_L and the reactance ratio X_E/X_L or by entry of the complex earth (residual) compensation factor K_0 . Which of these two entry options applies was determined by the setting in address 237 **Format Z0/Z1** (refer to Section 2.1.2.1). Only the addresses applicable for this setting will be displayed.

Earth Impedance (Residual) Compensation with Scalar Factors R_E/R_L and X_E/X_L

When entering the resistance ratio R_E/R_L and the reactance ratio X_E/X_L the addresses 1116 to 1119 apply. They are calculated separately, and do not correspond to the real and imaginary components of Z_E/Z_L . A computation with complex numbers is therefore not necessary! The ratios are obtained from system data using the following formulas:

Resistance ratio:	Reactance ratio:
$\frac{R_E}{R_L} = \frac{1}{3} \cdot \left(\frac{R_0}{R_1} - 1 \right)$	$\frac{X_E}{X_L} = \frac{1}{3} \cdot \left(\frac{X_0}{X_1} - 1 \right)$

Where

R_0 = Zero sequence resistance of the line

X_0 = Zero sequence reactance of the line

R_1 = Positive sequence resistance of the line

X_1 = Positive sequence reactance of the line

These values may either apply to the entire line length or be based on a per unit of line length, as the quotients are independent of length. Furthermore it makes no difference if the quotients are calculated with primary or secondary values.

Calculation Example:

110 kV overhead line 150 mm² with the following data:

R_1/s = 0.19 Ω/km positive sequence impedance

X_1/s = 0.42 Ω/km positive sequence impedance

R_0/s = 0.53 Ω/km zero sequence impedance

X_0/s = 1.19 Ω/km zero sequence impedance

(where s = line length)

For earth impedance ratios, the following emerge:

$$\frac{R_E}{R_L} = \frac{1}{3} \cdot \left(\frac{R_0}{R_1} - 1 \right) = \frac{1}{3} \cdot \left(\frac{0.53 \text{ Ω/km}}{0.19 \text{ Ω/km}} - 1 \right) = 0.60$$

$$\frac{X_E}{X_L} = \frac{1}{3} \cdot \left(\frac{X_0}{X_1} - 1 \right) = \frac{1}{3} \cdot \left(\frac{1.19 \text{ Ω/km}}{0.42 \text{ Ω/km}} - 1 \right) = 0.61$$

The earth impedance (residual) compensation factor setting for the first zone Z1 may be different from that of the remaining zones of the distance protection. This allows the setting of the exact values for the protected line, while at the same time the setting for the back-up zones may be a close approximation even when the following lines have substantially different earth impedance ratios (e.g. cable after an overhead line). Accordingly, the settings for the address 1116 **RE/RL(Z1)** and 1117 **XE/XL(Z1)** are determined with the data of the protected line while the addresses 1118

RE/RL(Z1B...Z5) and 1119 **XE/XL(Z1B...Z5)** apply to the remaining zones Z1B and Z2 up to Z5 (as seen from the relay location).

Earth Impedance (Residual) Compensation with Magnitude and Angle (K_0 -Factor)

When the complex earth impedance (residual) compensation factor K_0 is set, the addresses 1120 to 1123 apply. In this case it is important that the line angle is set correctly (address 1105, see margin heading „General Line Data“) as the device needs the line angle to calculate the compensation components from the K_0 . These earth im-

pedance compensation factors are defined with their magnitude and angle which may be calculated with the line data using the following equation:

$$K_0 = \frac{Z_E}{Z_L} = \frac{1}{3} \cdot \left(\frac{Z_0}{Z_1} - 1 \right)$$

Where

Z_0 = (complex) zero sequence impedance of the line

Z_1 = (complex) positive sequence impedance of the line

These values may either apply to the entire line length or be based on a per unit of line length, as the quotients are independent of length. Furthermore it makes no difference if the quotients are calculated with primary or secondary values.

For overhead lines it is generally possible to calculate with scalar quantities as the angle of the zero sequence and positive sequence system only differ by an insignificant amount. With cables however, significant angle differences may exist as illustrated by the following example.

Calculation Example:

110 kV single-conductor oil-filled cable $3 \cdot 185 \text{ mm}^2$ Cu with the following data

Z_1/s = $0.408 \cdot e^{j73^\circ} \Omega/\text{km}$ positive sequence impedance

Z_0/s = $0.632 \cdot e^{j18.4^\circ} \Omega/\text{km}$ zero sequence impedance

(where s = line length)

The calculation of the earth impedance (residual) compensation factor K_0 results in:

$$\frac{Z_0}{Z_1} = \frac{0.632}{0.408} \cdot e^{j(18.4^\circ - 73^\circ)} = 1.55 \cdot e^{-j54.6^\circ} = 1.55 \cdot (0.579 - j0.815) = 0.898 - j1.263$$

$$K_0 = \frac{1}{3} \cdot \left(\frac{Z_0}{Z_1} - 1 \right) = \frac{1}{3} \cdot (0.898 - j1.263 - 1) = \frac{1}{3} \cdot (-0.102 - j1.263)$$

The magnitude of K_0 is therefore

$$K_0 = \frac{1}{3} \cdot \sqrt{(-0.102)^2 + (-1.263)^2} = 0.42$$

When determining the angle, the quadrant of the result must be considered. The following table indicates the quadrant and range of the angle which is determined by the signs of the calculated real and imaginary part of K_0 .

Table 2-2 Quadrants and ranges of the angle K_0

Real part	Imaginary part	$\tan \varphi(K_0)$	Quadrant/range	Calculation
+	+	+	I $0^\circ \dots +90^\circ$	$\arctan (Im / Re)$
+	-	-	IV $-90^\circ \dots 0^\circ$	$-\arctan (Im / Re)$
-	-	+	III $-90^\circ \dots -180^\circ$	$\arctan (Im / Re) - 180^\circ$
-	+	-	II $+90^\circ \dots +180^\circ$	$-\arctan (Im / Re) + 180^\circ$

In this example the following result is obtained:

$$\varphi(K_0) = \arctan\left(\frac{1.263}{0.102}\right) - 180^\circ = -94.6^\circ$$

The magnitude and angle of the earth impedance (residual) compensation factors setting for the first zone Z1 and the remaining zones of the distance protection may be different. This allows the setting of the exact values for the protected line, while at the same time the setting for the back-up zones may be a close approximation even when the following lines have substantially different earth impedance factors (e.g. cable after an overhead line). Accordingly, the settings for the address 1120 **K0 (Z1)** and 1121 **Angle K0(Z1)** are determined with the data of the protected line while the addresses 1122 **K0 (> Z1)** and 1123 **AngleI K0(> Z1)** apply to the remaining zones Z1B and Z2 up to Z5 (as seen from the relay mounting location).



Note

If a combination of values is set which is not recognized by the device, it operates with preset values $K_0 = 1 \cdot e^{0^\circ}$. The information „Dis.ErrorK0(Z1)“ (No. 3654) or „DisErrorK0(>Z1)“ (No. 3655) appears in the event logs.

Level Arrangement

The center phase of a level arrangement is determined in address 1124 **center phase**. The compensation factor parameters **C0/C1** (address 1125) and **center phase** are reserved for the double-ended fault locator. They are used for configuration of a line with different sections (e.g. overhead line-cable). Refer to Section 2.19 for more details.

Parallel Line Mutual Impedance (optional)

If the device is applied to a double circuit line (parallel lines) and parallel line compensation for the distance and/or fault location function is used, the mutual coupling of the two lines must be considered. A prerequisite for this is that the earth (residual) current of the parallel line has been connected to the measuring input I_4 of the device and that this was configured with the power system data (Section 2.1.2.1) by setting the appropriate parameters.

The coupling factors may be determined using the following equations:

Resistance ratio:	Reactance ratio:
$\frac{R_M}{R_L} = \frac{1}{3} \cdot \frac{R_{0M}}{R_1}$	$\frac{X_M}{X_L} = \frac{1}{3} \cdot \frac{X_{0M}}{X_1}$

where

R_{0M}	= Mutual zero sequence resistance (coupling resistance) of the line
X_{0M}	= Mutual zero sequence reactance (coupling reactance) of the line
R_1	= Positive sequence resistance of the line
X_1	= Positive sequence reactance of the line

These values may either apply to the entire double circuit line length or be based on a per unit of line length, as the quotient is independent of length. Furthermore it makes no difference whether the quotients are calculated with primary, or secondary values.

These setting values only apply to the protected line and are entered in the addresses 1126 **RM/RL ParallLine** and 1127 **XM/XL ParallLine**.

For earth faults on the protected feeder there is in theory no additional distance protection or fault locator measuring error when the parallel line compensation is used. The setting in address 1128 **RATIO Par. Comp** is therefore only relevant for earth faults outside the protected feeder. It provides the current ratio I_E/I_{EP} for the earth

current balance of the distance protection (in Figure 2-4 for the device at location II), above which compensation should take place. In general, a presetting of 85 % is sufficient. A more sensitive (larger) setting has no advantage. Only in the case of a severe system asymmetry, or a very small coupling factor (X_M/X_L below approximately 0.4), may a smaller setting be useful. A more detailed explanation of parallel line compensation can be found in Section 2.5.1 under distance protection.




Figure 2-4 Distance with parallel line compensation at II

The current ratio may also be calculated from the desired distance of the parallel line compensation and vice versa. The following applies (refer to Figure 2-4):

$$\frac{I_E}{I_{EP}} = \frac{x/l}{2-x/l} \quad \text{or} \quad \frac{x}{l} = \frac{2}{1 + \frac{I_E}{I_{EP}}}$$

Current Transformer Saturation

7SD5 contains a saturation detector which largely detects the measuring errors resulting from the saturation of the current transformers and initiates a switchover to distance measurement. The threshold above which it picks up can be set in address 1140 **I-CTsat. Thres.**. This is the current level above which saturation may be present. The setting ∞ disables the saturation detector. This parameter can only be altered with DIGSI® under **Additional Settings**. If current transformer saturation is expected, the following equation may be used as a thumb rule for this setting:

$$\text{Setting value I-CTsat. Thres.} = \frac{n'}{5} \cdot I_{nom}$$

$$\text{With } n' = n \cdot \frac{P_N + P_i}{P^* + P_i} = \text{Actual Overcurrent Factor}$$

P_N = Nominal CT burden [VA]

P_i = Nominal CT internal burden [VA]

P^* = Actual connected burden (protection device + connection cable)

Circuit Breaker Status

Information regarding the circuit breaker position is required by various protection and supplementary functions to ensure their optimal functionality. The device has a circuit breaker status recognition which processes the status of the circuit breaker auxiliary contacts and contains also a detection based on the measured currents and voltages for opening and closing (see also Section 2.23.1).

In address 1130 the residual current **PoleOpenCurrent** is set, which will definitely not be exceeded when the circuit breaker pole is open. If parasitic currents (e.g. through induction) can be excluded when the circuit breaker is open, this setting may

be very sensitive. Otherwise this setting must be increased correspondingly. Usually the presetting is sufficient. This parameter can only be altered with DIGSI® under **Additional Settings**.

The residual voltage **PoleOpenVoltage**, which will definitely not be exceeded when the circuit breaker pole is open, is set in address 1131. Voltage transformers are presumed to be on the line side. The setting should not be too sensitive because of possible parasitic voltages (e.g. due to capacitive coupling). It must in any event be set below the smallest phase-earth voltage which may be expected during normal operation. Usually the presetting is sufficient. This parameter can only be altered with DIGSI® under **Additional Settings**.

The seal-in time **SI Time all Cl.** (address 1132) determines the activation period for enabling protection functions following each energization of the line (e.g. fast tripping high-current stage). This time is started by the internal circuit breaker switching detection when it recognizes energization of the line or by the circuit breaker auxiliary contacts, if these are connected to the device via binary input to provide information that the circuit breaker has closed. The time should therefore be set longer than the circuit breaker operating time during closing plus the operating time of this protection function plus the circuit breaker operating time during opening. This parameter can only be altered with DIGSI® under **Additional Settings**.

In address 1134 **Line Closure** the criteria for the internal recognition of line energization are determined. **Only with ManCl** means that only the manual close signal via binary input or the integrated control is evaluated as closure. **I OR U or ManCl** means that additionally the measured currents or voltages are used to determine closure of the circuit breaker, whereas **CB OR I or M/C** implies that either the currents or the states of the circuit breaker auxiliary contacts are used to determine closure of the circuit breaker. If the voltage transformers are not situated on the line side, the setting **CB OR I or M/C** must be used. In the case of **I or Man.Close** only the currents or the manual close signals are used to recognize closing of the circuit breaker.

Address 1135 **Reset Trip CMD** determines under which conditions a trip command is reset. If **CurrentOpenPole** is set, the trip command is reset as soon as the current disappears. It is important that the value set in address 1130 **PoleOpenCurrent** (see above) is undershot. If **Current AND CB** is set, the circuit breaker auxiliary contact must send a message that the circuit breaker is open. It is a prerequisite for this setting that the position of the auxiliary contacts is allocated via a binary input.

While the time **SI Time all Cl.** (address 1132, refer above) is activated following each recognition of line energization, **SI Time Man.Cl** (address 1150) is the time following manual closure during which special influence of the protection functions is activated (e.g. increased reach of the distance protection). This parameter can only be altered with DIGSI® under **Additional Settings**.

Note

For CB Test and automatic reclosure the CB auxiliary contact status derived with the binary inputs >CB1 ... (No. 366 to 371, 410 and 411) are relevant for the circuit breaker test and for the automatic reclosure to indicate the CB switching status. The other binary inputs >CB ... (No. 351 to 353, 379 and 380) are used for detecting the status of the line (address 1134) and for reset of the trip command (address 1135). Address 1135 is also used by other protection functions, e.g. by the echo function, energization in case of overcurrent etc. For use with one circuit breaker only, both binary input functions, e.g. 366 and 351, can be allocated to the same physical input.



For manual closure of the circuit breaker via binary inputs, it can be specified in address 1151 **MAN . CLOSE** whether the integrated manual CLOSE detection checks the synchronism between the busbar voltage and the voltage of the switched feeder. This setting does not apply for a close command via the integrated control functions. If the synchronism check is desired the device must either feature the integrated synchronism check function or an external device for synchronism check must be connected.

In the former case the synchronism check function must be configured as available, a busbar voltage must be connected to the device and this must be correctly parameterized in the power system data (Section 2.1.2.1, address 210 **U4 transformer = Usync transf.**, as well as the the associated factors).

If no synchronism check is to be performed with manual closing, set **MAN . CLOSE = w/o Sync-check**. If a check is desired, set **with Sync-check**. To not use the MANUAL CLOSE function of the device, set **MAN . CLOSE** to **NO**. This may be reasonable if the close command is output to the circuit breaker without involving the 7SD5, and the relay itself is not desired to issue a close command.

For commands via the integrated control (local control, DIGSI, serial interface) address 1152 **Man.Clos. Imp.** determines whether a particular close command via the integrated control function should be treated by the protection (like instantaneous re-opening when switching onto a fault) like a MANUAL CLOSE command via binary input. This address also informs the device for which switchgear this applies. You can select from the switching devices which are available for the integrated control. Choose that circuit breaker which usually operates for manual closure and, if required, for automatic reclosure (usually Q0). If **none** is set here, a CLOSE command via the control will not generate a MANUAL CLOSE impulse for the protection function.

Three-pole Coupling

Three-pole coupling is only relevant if single-pole auto-reclosures are carried out. If not, tripping is always three-pole. The remainder of this margin heading section is then irrelevant.

Address 1155 **3pole coupling** determines whether any multi-phase pickup leads to a three-pole tripping command, or whether only multi-pole tripping decisions result in a three-pole tripping command. This setting is only relevant for versions with single-pole and three-pole tripping and is only available there. It does not have an impact on the differential protection since pickup and tripping are equivalent. The time overcurrent protection function, however, can also pick up in the event of a fault occurred outside the protected object, without tripping.

More information on the functions is also contained in Section 2.23.1 Pickup Logic for the Entire Device.

With the setting **with PICKUP** every fault detection in more than one phase leads to three-pole coupling of the trip outputs, even if only a single-phase earth fault is situated within the protection zone, and further faults (e.g. caused by overcurrent), only affect the higher zones, or are located in the reverse direction (distance protection). Even if a single-phase trip command has already been issued, each further fault detection will lead to three-pole coupling of the trip outputs.

If, on the other hand, this address is set to **with TRIP** (default setting for differential protection), three-pole coupling of the trip output (three-pole tripping) only occurs when more than one pole is tripped. Therefore, if a single-phase fault occurs within the protected zone and a further fault outside of it, single-pole tripping is possible. A further fault during the single-pole tripping will only lead to a three-pole coupling, if it occurs within the protected zone.

This parameter is valid for all protection functions of 7SD5 which are capable of single-pole tripping. The default setting is **with TRIP**.

The difference is noticeable when multiple faults occur, which means faults that occur at nearly the same time at different places in the system.

If, for example, two single-phase ground faults occur on different lines — these may also be parallel lines — (Figure 2-5), the protective relays of all four line ends detect a fault L1-L2-E, i.e. the pickup image is consistent with a two-phase earth fault. If single pole tripping and reclosure is employed, it is therefore desirable that each line only trips and recloses single pole. This is possible with setting 1155 **3pole coupling = with TRIP**. In this manner each of the four relays at the four line ends recognizes that single pole tripping for the fault on the respective line is required.




Figure 2-5 Multiple fault on a double-circuit line

In some cases, however, three-pole tripping would be preferable for this fault scenario, for example in the event that the double-circuit line is located in the vicinity of a large generator unit (Figure 2-6). This is because the generator considers the two single-phase to earth faults as one double-phase earth fault, with correspondingly high dynamic load on the turbine shaft. With the setting 1155 **3pole coupling = with PICKUP**, the two lines are switched off three-pole, since each device picks up as with L1-L2-E, i.e. as with a multi-phase fault.



Figure 2-6 Multiple fault on a double-circuit line next to a generator

Address 1156 **Trip2phFlt** determines that the short-circuit protection functions perform only a single-pole trip in case of isolated two-phase faults (clear of earth), provided that single-pole tripping is possible and permitted. This allows a single-pole automatic reclosure cycle for this kind of fault. Thereby you can specify whether the leading phase (**1pole leading 0**), or the lagging phase (**1pole lagging 0**) is tripped. The parameter is only available in versions with single-pole and three-pole tripping. It can only be altered with DIGSI® under **Additional Settings**. If this possibility is to be used, you have to bear in mind that the phase selection should be the same throughout the entire network and that it must be the same at all ends of one line. More information on the functions is also contained in Section 2.23.1 Pickup Logic for the Entire Device. Usually the presetting **3pole** is used here.

Line Sections

The line section parameters 6001 **S1: Line angle** to 6012 **S1: angle K0**, 6021 **S2: Line angle** to 6032 **S2: angle K0** and 6041 **S3: Line angle** to 6052 **S3: angle K0** are reserved for the double-ended fault locator. They are used for parameterization of a line with different sections (overhead line-cable). Refer to Section 2.19 for more details.

2.1.4.2 Settings

Addresses which have an appended "A" can only be changed with DIGSI, under Additional Settings.

The table indicates region-specific presettings. Column C (configuration) indicates the corresponding secondary nominal current of the current transformer.

Addr.	Parameter	C	Setting Options	Default Setting	Comments
1103	FullScaleVolt.		0.4 .. 1200.0 kV	400.0 kV	Measurement: Full Scale Voltage (100%)
1104	FullScaleCurr.		10 .. 5000 A	1000 A	Measurement: Full Scale Current (100%)
1105	Line Angle		30 .. 89 °	85 °	Line Angle
1106	OPERATION POWER		0.2 .. 5000.0 MVA	692.8 MVA	Operational power of protection zone
1107	P,Q sign		not reversed reversed	not reversed	P,Q operational measured values sign
1111	x'	1A	0.0050 .. 9.5000 Ω/km	0.1500 Ω/km	x' - Line Reactance per length unit
		5A	0.0010 .. 1.9000 Ω/km	0.0300 Ω/km	
1111	x'	1A	0.0050 .. 15.0000 Ω/mi	0.2420 Ω/mi	x' - Line Reactance per length unit
		5A	0.0010 .. 3.0000 Ω/mi	0.0484 Ω/mi	
1112	c'	1A	0.000 .. 100.000 μF/km	0.010 μF/km	c' - capacit. per unit line len. μF/km
		5A	0.000 .. 500.000 μF/km	0.050 μF/km	
1112	c'	1A	0.000 .. 160.000 μF/mi	0.016 μF/mi	c' - capacit. per unit line len. μF/mile
		5A	0.000 .. 800.000 μF/mi	0.080 μF/mi	
1113	Line Length		0.1 .. 1000.0 km	100.0 km	Line Length
1113	Line Length		0.1 .. 650.0 Miles	62.1 Miles	Line Length
1114	Tot.Line Length		0.1 .. 1000.0 km	100.0 km	Total Line Length
1114	Tot.Line Length		0.1 .. 650.0 Miles	62.1 Miles	Total Line Length
1116	RE/RL(Z1)		-0.33 .. 7.00	1.00	Zero seq. comp. factor RE/RL for Z1
1117	XE/XL(Z1)		-0.33 .. 7.00	1.00	Zero seq. comp. factor XE/XL for Z1
1118	RE/RL(Z1B...Z5)		-0.33 .. 7.00	1.00	Zero seq. comp. factor RE/RL for Z1B...Z5
1119	XE/XL(Z1B...Z5)		-0.33 .. 7.00	1.00	Zero seq. comp. factor XE/XL for Z1B...Z5
1120	K0 (Z1)		0.000 .. 4.000	1.000	Zero seq. comp. factor K0 for zone Z1

Addr.	Parameter	C	Setting Options	Default Setting	Comments
1121	Angle K0(Z1)		-135.00 .. 135.00 °	0.00 °	Zero seq. comp. angle for zone Z1
1122	K0 (> Z1)		0.000 .. 4.000	1.000	Zero seq.comp.factor K0, higher zones >Z1
1123	AngleI K0(> Z1)		-135.00 .. 135.00 °	0.00 °	Zero seq. comp. angle, higher zones >Z1
1124	center phase		unknown/sym. Phase 1 Phase 2 Phase 3	unknown/sym.	center phase of feeder
1125	C0/C1		0.01 .. 10.00	0.75	Compensation factor C0/C1
1126	RM/RL ParalLine		0.00 .. 8.00	0.00	Mutual Parallel Line comp. ratio RM/RL
1127	XM/XL ParalLine		0.00 .. 8.00	0.00	Mutual Parallel Line comp. ratio XM/XL
1128	RATIO Par. Comp		50 .. 95 %	85 %	Neutral current RATIO Parallel Line Comp
1130A	PoleOpenCurrent	1A	0.05 .. 1.00 A	0.10 A	Pole Open Current Threshold
		5A	0.25 .. 5.00 A	0.50 A	
1131A	PoleOpenVoltage		2 .. 70 V	30 V	Pole Open Voltage Threshold
1132A	SI Time all Cl.		0.01 .. 30.00 sec	0.10 sec	Seal-in Time after ALL closures
1134	Line Closure		only with ManCl I OR U or ManCl CB OR I or M/C I or Man.Close	I or Man.Close	Recognition of Line Closures with
1135	Reset Trip CMD		CurrentOpenPole Current AND CB	CurrentOpenPole	RESET of Trip Command
1140A	I-CTsat. Thres.	1A	0.2 .. 50.0 A; ∞	20.0 A	CT Saturation Threshold
		5A	1.0 .. 250.0 A; ∞	100.0 A	
1150A	SI Time Man.Cl		0.01 .. 30.00 sec	0.30 sec	Seal-in Time after MANUAL closures
1151	MAN. CLOSE		with Sync-check w/o Sync-check NO	NO	Manual CLOSE COMMAND generation
1152	Man.Clos. Imp.		(Setting options depend on configuration)	None	MANUAL Closure Impulse after CONTROL
1155	3pole coupling		with PICKUP with TRIP	with TRIP	3 pole coupling
1156A	Trip2phFlt		3pole 1pole leading Ø 1pole lagging Ø	3pole	Trip type with 2phase faults
1161	VECTOR GROUP U		0 .. 11	0	Vector group numeral for voltage

Addr.	Parameter	C	Setting Options	Default Setting	Comments
1162	VECTOR GROUP I		0 .. 11	0	Vector group numeral for current
1163	TRANS STP IS		Solid Earthed Not Earthed	Solid Earthed	Transformer starpoint is
1540	Distance Angle		30 .. 90 °	85 °	Angle of inclination, distance charact.
6001	S1: Line angle		30 .. 89 °	85 °	S1: Line angle
6002	S1: x'	1A	0.0050 .. 9.5000 Ω/km	0.1500 Ω/km	S1: feeder reactance per km: x'
		5A	0.0010 .. 1.9000 Ω/km	0.0300 Ω/km	
6002	S1: x'	1A	0.0050 .. 15.0000 Ω/mi	0.2420 Ω/mi	S1: feeder reactance per mile: x'
		5A	0.0010 .. 3.0000 Ω/mi	0.0484 Ω/mi	
6003	S1: c'	1A	0.000 .. 100.000 μF/km	0.010 μF/km	S1: feeder capacitance c' in μF/km
		5A	0.000 .. 500.000 μF/km	0.050 μF/km	
6003	S1: c'	1A	0.000 .. 160.000 μF/mi	0.016 μF/mi	S1: feeder capacitance c' in μF/mile
		5A	0.000 .. 800.000 μF/mi	0.080 μF/mi	
6004	S1: Line length		0.1 .. 1000.0 km	100.0 km	S1: Line length in kilometer
6004	S1: line length		0.1 .. 650.0 Miles	62.1 Miles	S1: Line length in kilometer
6008	S1: center ph.		unknown/sym. Phase 1 Phase 2 Phase 3	unknown/sym.	S1: center phase
6009	S1: XE/XL		-0.33 .. 7.00	1.00	S1: Zero seq. compensating factor XE/XL
6010	S1: RE/RL		-0.33 .. 7.00	1.00	S1: Zero seq. compensating factor RE/RL
6011	S1: K0		0.000 .. 4.000	1.000	S1: Zero seq. compensating factor K0
6012	S1: angle K0		-135.00 .. 135.00 °	0.00 °	S1: Zero seq. compensating angle of K0
6021	S2: Line angle		30 .. 89 °	85 °	S2: Line angle
6022	S2: x'	1A	0.0050 .. 9.5000 Ω/km	0.1500 Ω/km	S2: feeder reactance per km: x'
		5A	0.0010 .. 1.9000 Ω/km	0.0300 Ω/km	
6022	S2: x'	1A	0.0050 .. 15.0000 Ω/mi	0.2420 Ω/mi	S2: feeder reactance per mile: x'
		5A	0.0010 .. 3.0000 Ω/mi	0.0484 Ω/mi	
6023	S2: c'	1A	0.000 .. 100.000 μF/km	0.010 μF/km	S2: feeder capacitance c' in μF/km
		5A	0.000 .. 500.000 μF/km	0.050 μF/km	
6023	S2: c'	1A	0.000 .. 160.000 μF/mi	0.016 μF/mi	S2: feeder capacitance c' in μF/mile
		5A	0.000 .. 800.000 μF/mi	0.080 μF/mi	
6024	S2: Line length		0.1 .. 1000.0 km	100.0 km	S2: Line length in kilometer
6024	S2: line length		0.1 .. 650.0 Miles	62.1 Miles	S2: line length in miles

Addr.	Parameter	C	Setting Options	Default Setting	Comments
6028	S2: center ph.		unknown/sym. Phase 1 Phase 2 Phase 3	unknown/sym.	S2: center phase
6029	S2: XE/XL		-0.33 .. 7.00	1.00	S2: Zero seq. compensating factor XE/XL
6030	S2: RE/RL		-0.33 .. 7.00	1.00	S2: Zero seq. compensating factor RE/RL
6031	S2: K0		0.000 .. 4.000	1.000	S2: Zero seq. compensating factor K0
6032	S2: angle K0		-135.00 .. 135.00 °	0.00 °	S2: Zero seq. compensating angle of K0
6041	S3: Line angle		30 .. 89 °	85 °	S3: Line angle
6042	S3: x'	1A	0.0050 .. 9.5000 Ω/km	0.1500 Ω/km	S3: feeder reactance per km: x'
		5A	0.0010 .. 1.9000 Ω/km	0.0300 Ω/km	
6042	S3: x'	1A	0.0050 .. 15.0000 Ω/mi	0.2420 Ω/mi	S3: feeder reactance per mile: x'
		5A	0.0010 .. 3.0000 Ω/mi	0.0484 Ω/mi	
6043	S3: c'	1A	0.000 .. 100.000 μF/km	0.010 μF/km	S3: feeder capacitance c' in μF/km
		5A	0.000 .. 500.000 μF/km	0.050 μF/km	
6043	S3: c'	1A	0.000 .. 160.000 μF/mi	0.016 μF/mi	S3: feeder capacitance c' in μF/mile
		5A	0.000 .. 800.000 μF/mi	0.080 μF/mi	
6044	S3: Line length		0.1 .. 1000.0 km	100.0 km	S3: Line length in kilometer
6044	S3: line length		0.1 .. 650.0 Miles	62.1 Miles	S3: line length in miles
6048	S3: center ph.		unknown/sym. Phase 1 Phase 2 Phase 3	unknown/sym.	S3: center phase
6049	S3: XE/XL		-0.33 .. 7.00	1.00	S3: Zero seq. compensating factor XE/XL
6050	S3: RE/RL		-0.33 .. 7.00	1.00	S3: Zero seq. compensating factor RE/RL
6051	S3: K0		0.000 .. 4.000	1.000	S3: Zero seq. compensating factor K0
6052	S3: angle K0		-135.00 .. 135.00 °	0.00 °	S3: Zero seq. compensating angle of K0

2.1.4.3 Information List

No.	Information	Type of Information	Comments
301	Pow.Sys.Flt.	VI	Power System fault
302	Fault Event	VI	Fault Event
303	E/F Det.	VI	E/Flt.det. in isol/comp.netw.
351	>CB Aux. L1	SP	>Circuit breaker aux. contact: Pole L1

No.	Information	Type of Information	Comments
352	>CB Aux. L2	SP	>Circuit breaker aux. contact: Pole L2
353	>CB Aux. L3	SP	>Circuit breaker aux. contact: Pole L3
356	>Manual Close	SP	>Manual close signal
357	>CloseCmd.Blo	SP	>Block all close commands from external
361	>FAIL:Feeder VT	SP	>Failure: Feeder VT (MCB tripped)
362	>FAIL:Bus VT	SP	>Failure: Busbar VT (MCB tripped)
366	>CB1 Pole L1	SP	>CB1 Pole L1 (for AR,CB-Test)
367	>CB1 Pole L2	SP	>CB1 Pole L2 (for AR,CB-Test)
368	>CB1 Pole L3	SP	>CB1 Pole L3 (for AR,CB-Test)
371	>CB1 Ready	SP	>CB1 READY (for AR,CB-Test)
378	>CB faulty	SP	>CB faulty
379	>CB 3p Closed	SP	>CB aux. contact 3pole Closed
380	>CB 3p Open	SP	>CB aux. contact 3pole Open
381	>1p Trip Perm	SP	>Single-phase trip permitted from ext.AR
382	>Only 1ph AR	SP	>External AR programmed for 1phase only
383	>Enable ARzones	SP	>Enable all AR Zones / Stages
385	>Lockout SET	SP	>Lockout SET
386	>Lockout RESET	SP	>Lockout RESET
410	>CB1 3p Closed	SP	>CB1 aux. 3p Closed (for AR, CB-Test)
411	>CB1 3p Open	SP	>CB1 aux. 3p Open (for AR, CB-Test)
501	Relay PICKUP	OUT	Relay PICKUP
502	Relay Drop Out	OUT	Relay Drop Out
503	Relay PICKUP L1	OUT	Relay PICKUP Phase L1
504	Relay PICKUP L2	OUT	Relay PICKUP Phase L2
505	Relay PICKUP L3	OUT	Relay PICKUP Phase L3
506	Relay PICKUP E	OUT	Relay PICKUP Earth
507	Relay TRIP L1	OUT	Relay TRIP command Phase L1
508	Relay TRIP L2	OUT	Relay TRIP command Phase L2
509	Relay TRIP L3	OUT	Relay TRIP command Phase L3
510	Relay CLOSE	OUT	General CLOSE of relay
511	Relay TRIP	OUT	Relay GENERAL TRIP command
512	Relay TRIP 1pL1	OUT	Relay TRIP command - Only Phase L1
513	Relay TRIP 1pL2	OUT	Relay TRIP command - Only Phase L2
514	Relay TRIP 1pL3	OUT	Relay TRIP command - Only Phase L3
515	Relay TRIP 3ph.	OUT	Relay TRIP command Phases L123
530	LOCKOUT	IntSP	LOCKOUT is active
533	IL1 =	VI	Primary fault current IL1
534	IL2 =	VI	Primary fault current IL2
535	IL3 =	VI	Primary fault current IL3
536	Final Trip	OUT	Final Trip
545	PU Time	VI	Time from Pickup to drop out
546	TRIP Time	VI	Time from Pickup to TRIP
560	Trip Coupled 3p	OUT	Single-phase trip was coupled 3phase
561	Man.Clos.Detect	OUT	Manual close signal detected
562	Man.Close Cmd	OUT	CB CLOSE command for manual closing
563	CB Alarm Supp	OUT	CB alarm suppressed

No.	Information	Type of Information	Comments
590	Line closure	OUT	Line closure detected
591	1pole open L1	OUT	Single pole open detected in L1
592	1pole open L2	OUT	Single pole open detected in L2
593	1pole open L3	OUT	Single pole open detected in L3

2.2 Protection Data Interfaces and Protection Data Topology

As described in the explanation of the function principle of differential protection (Section 2.3), the devices which belong to the protected object limited by the current transformer sets have to exchange the data of the ends of the protected object. This applies not only for the measured quantities relevant for the differential protection itself, but also for all data which are to be available at the ends. This includes the synchronization and topological data as well as the intertripping, transfer trip, remote annunciation signals and measured values. The topology of the protected object, the allocation of the devices to the ends of the protected object and the allocation of the ways of communication to the devices protection data interfaces form the topology of the protection system and its communication.

2.2.1 Functional Description

2.2.1.1 Protection Data Topology / Protection Data Communication

Protection Data Topology

For a standard layout of lines with two ends, you require one protection data interface for each device. The protection data interface is named PI1 (see also Figure 2-7). The corresponding protection data interface must be configured as **Enabled** during configuration of the functional scope (see Section 2.1.1).

With 7SD5 it is also possible to connect both protection data interfaces with each other provided the two devices have two protection data interfaces each and the relevant means for transmission are available. This provides for 100 % redundancy as far as the transmission is concerned (Figure 2-8). The devices autonomously search for the fastest communication link. If this link is faulty, the devices automatically switch over to the other link which is then used until the faster one is healthy again.




Figure 2-7 Differential protection for two ends with two 7SD5 devices, each of them having one protection data interface (transmitter/receiver)




Figure 2-8 Differential protection for two ends with two 7SD5 each of them having two protection data interfaces (transmitter/receiver)

For more than two ends, a communication chain or a communication ring can be formed. A setup with a maximum of six devices is possible.

Figure 2-9 shows a Communication Chain with four devices. The ends **1** and **2** are derived from the arrangements of the current transformers shown on the left. Although this is actually only **one** line end, it should be treated in terms of differential protection as two ends because the current is measured in two places. This is to make sure that the transformation errors of both transformer sets are considered by the restraint, especially for a high fault current flowing from end **1** to end **2** (external fault).

The communication chain begins at the protection data interface PI 1 of device with the index **1**, continues in the device with index **2** at PI 1, extends from device with index **2** at PI 2 to the device with index **4**, etc. until it reaches the device with index **3** at PI 1. The example shows that the indexing of the devices must not necessarily have to correspond to the sequence of the communication chain. Which protection data interface is connected to which protection data interface does not play a role. One device with one protection data interface at each terminal of the chain is sufficient.




Figure 2-9 Differential protection for four ends with chain topology

Figure 2-10 shows the same line arrangement as Figure 2-9. The communication links, however, have been complemented to form a closed ring. A 7SD5 device with 2 protection data interfaces is necessary for each terminal. This communication ring has the advantage, as compared to the chain shown in Figure 2-9, that the entire communication system works even if one communications link fails. The devices detect the failure and switch automatically over to the remaining paths of communication. In this example PI 1 is always connected to PI 2 of the following device.

By the way, the two above possibilities for two devices can be regarded as special cases of chain and ring. The connection as shown in Figure 2-7 forms a communication chain with only one chain element, and Figure 2-8 shows a ring which is compressed into one two-way connection.




Figure 2-10 Differential protection for four ends with ring topology

Communication Media

The communication is enabled via pilot wire or direct optical fibre connections or via communication networks. Which kind of media is used, depends on the distance and on the communication media available. For shorter distances a direct connection via optical fibres having a transmission rate of 512 kBit/s is possible. Otherwise we recommend communication converters. A transmission via modem and communication networks can also be realized. Please note, however, that the tripping times of the differential protection devices depend on the transmission quality and that they are prolonged in case of a reduced transmission quality and/or an increased transmission time. Figure 2-11 shows some examples for communication connections. In case of a direct connection the distance depends on the type of the optical fibre. Table 2-3 lists the options available. The modules in the device are replaceable. For ordering information see Appendix, under Accessories.

If a communication converter is used, the device and the communication converter are linked with a FO5 module via optical fibres. The converter itself is available in different versions allowing to connect it to communication networks operating with two-wire copper lines or ISDN. The order numbers can be found in the Appendix under Accessories.

Table 2-3 Communication via Direct Connection

Module in the Device	Connector Type	Fibre Type	Optical Wavelength	Perm. Path Attenuation	Distance, Typical
FO5	ST	Multimode 62.5/125 μm	820 nm	8 dB	1.5 km (0.95 miles)
FO6	ST	Multimode 62.5/125 μm	820 nm	16 dB	3.5 km (2.2 miles)
FO7	ST	Monomode 9/125 μm	1300 nm	7 dB	10 km (6.25 miles)
FO8	FC	Monomode 9/125 μm	1300 nm	18 dB	35 km (22 miles)
FO17 ¹⁾	LC	Monomode 9/125 μm	1300 nm	13 dB	24 km (14.9 miles)
FO18 ¹⁾	LC	Monomode 9/125 μm	1300 nm	29 dB	60 km (37.5 miles)
FO19 ¹⁾	LC	Monomode 9/125 μm	1550 nm	29 dB	100 km (62.5 miles)

¹⁾ For direct connection over short distances, a suitable optical attenuator should be used to avoid malfunctions and damage to the device.




Figure 2-11 Examples for communication connections



Note

The redundancy of different communication connections (for ring topology) requires a consequent separation of the devices connected to the communication network. For example, different communication routes should not be conducted via the same multiplexer card, as there is no alternative which could be used if the multiplexer card should fail.

Establishing the Protection Data Communication

When the devices of a differential protection system are linked to each other and switched on, they communicate by themselves. The successful connection is indicated by an annunciation, e.g. with „Re12 Login“, when device 1 has contacted device 2. All devices of a differential protection system inform each device of the successful protection data communication.

Additionally, the protection data interface is indicated via which a healthy link is established.

These are helpful features during commissioning and are described, together with further commissioning tools, in Section „Mounting and Commissioning“. But even during operation, the regular communication of the devices can be checked to each other.

Monitoring of Communication

The communication is permanently monitored by the devices.

Single faulty data telegrams are not a direct risk if they occur only occasionally. They are recognized and counted in the device which detects the disturbance and can be read out per unit of time as statistical information (Annunciation → Statistic).

You can define a limit for the permissible rate of faulty data telegrams. When, during operation, this limit is exceeded, an alarm is given (e.g. „PI1 Error“, No. 3258 if protection data interface 1 is affected). You may use this alarm to block the differential protection, either via binary output and input, or via logical combination by means of the integrated user-definable logic (CFC).

If several faulty telegrams or no data telegrams at all are received, this is regarded as an **Error** as soon as a time delay for data disturbance alarm (default setting 100 ms, can be altered) is exceeded. A corresponding alarm is output („PI1 Data fault“, No. 3229 for interface 1). If the system offers no alternative way of communication (as ring topologies would do), the differential protection will stop operating. All devices are affected by the disturbance, since the formation of differential currents and restraint currents is no longer possible at any of the ends. The distance protection as the second main protection function assumes complete protection over all zones, provided that it is configured, and that time overcurrent protection is configured as well as the emergency function. As soon as data transmission has returned to normal, the devices switch automatically back to differential protection mode or differential and distance protection mode, depending on how they are configured.

If the communication is interrupted for a permanent period (which is longer than a settable time period), this can be regarded as a transmission **Failure** of the communication. A corresponding alarm is output (e.g. „PI1 Datafailure“, No. 3230 for interface 1). Otherwise the same reactions apply as for the data disturbance.

Transmission time jumps that, for example, can occur in case of switchover in the communication network are recognized (e.g. „PI1 jump“, No. 3254 for interface 1) and corrected by the devices. The differential protection system continues to operate without loss of sensitivity. The transmission times are measured again and updated

within less than 2 seconds. If GPS synchronization (with satellite receiver) is used, asymmetric transmission times are recognized and corrected immediately.

The maximum permissible unbalance of the delay times can be set. If the delay time in the transmit and receive path is different, a differential current is calculated by the devices because of this difference. This has a direct influence on the sensitivity of the differential protection system. The automatic self-restraint of the protection adapts the restraint quantities to these differences so that a spurious operation of the differential protection due to these influences is prevented. Thus, higher difference values reduce the sensitivity of the protection, which may be noticeable in case of very low-current faults. With GPS synchronization, transmission time differences do **not** affect the sensitivity of the differential protection as long as GPS synchronization is intact. When the GPS synchronization detects that the permissible time difference is exceeded during operation, the message „PI 1 PD unsym.“ (No. 3250 for interface 1) will be issued.

When a transmission time jump exceeds the maximum permissible transmission delay time, this is annunciated. If transmission time jumps occur frequently the regular operation of the differential protection is no longer ensured. Protection communication via this communication link can be blocked via a setting parameter (e.g. 4515 **PI1 BLOCK UNSYM**). If a chain topology was configured, failure of one transmission link blocks the differential protection. If a ring topology is configured, the system switches to chain topology. A corresponding alarm is output („PI1 unsym.“, No. 3256 for interface 1). This blocking of the link can only be reset via a binary input („>SYNC PI1 RESET“, No. 3252 for interface 1).

Changeover of Operating Mode

During protection test, plant inspection, but also during operational switch-off of a feeder, it is possible to change the operating mode of a device in order to perform such work without effect on running operation.

The following modes are available:

- Log out device: logging out a device from the universal line protection system with the circuit breaker being switched off. The differential protection continues to be active at the other end(s); thus, the other end(s) may remain switched on. As the local circuit breaker is open (as well as the line disconnecter) revision work can be performed at the local feeder without affecting operation at the other end(s).

This mode can be switched on or off in the following ways:

- Using the integrated keypad: Menu Control/Taggings/Set: „Logout“
- Via a binary input (No 3451 „>Logout“), if this has been configured when allocating the binary inputs
- In DIGSI with Control/Taggings: „Logout local device“

- Test mode: When this mode is activated, except for the device where the test mode is activated, the differential protection is blocked for the entire system. All currents from the other devices are set to zero in the local device. The local device only evaluates the locally measured currents but does not transmit them to the other devices; this allows to test the device. Moreover, the test mode prevents in the local device that tripping of the differential protection generates a transfer trip signal.

If the device has been logged out before (see „Logout“), all the other devices can operate normally. Otherwise, the differential protection system is blocked in all linked devices. Depending on the parameter settings, either the distance protection assumes the entire protection function over all zones, or the time overcurrent protection becomes effective as emergency function.

This mode can be switched on or off in the following ways:

- Using the integrated keypad: Menu Control/Taggings/Set: „Test mode“
- Via a binary input (No. 3194 „>Test Diff.“), if this has been configured when allocating the binary inputs. In this case the existing CFC chart for Log out device must be rearranged with the I/O's for Test mode or a new CFC chart has to be created.
- In DIGSI with Control/Taggings: „Diff: Test mode“

- Commissioning mode: The trip commands of the differential protection system are blocked in the commissioning mode. The differential system as an entity can be checked using primary or secondary values; this can be done on the local display, with DIGSI or with the WEB-Monitor. If the WEB-Monitor is used, the current operating point is marked in the differential protection characteristic.

This mode can be switched on or off in the following ways:

- Using the integrated keypad: Menu Control/Taggings/Set: „Commissioning mode“
- Via a binary input (No. 3195 „>Comm. Diff.“), if this has been configured when allocating the binary inputs. In this case the existing CFC chart for Log out device must be rearranged with the I/O's for Test mode or a new CFC chart has to be created.
- In DIGSI with Control/Taggings: „Diff: Commissioning Mode“

2.2.2 Protection Data Interfaces

2.2.2.1 Setting Notes

General Information about Interfaces

The protection data interfaces connect the devices with the communication media. The communication is permanently monitored by the devices. Address 4509 **T-DATA DISTURB** defines after which delay time the user is informed about a faulty or missing telegram. Address 4510 **T-DATAFAIL** is used to set the time after which a transmission failure alarm is output. Address 4512 **Td ResetRemote** determines how long time remote information remains standing after a transmission fault has been cleared.

Protection Data Interface 1

The protection data interface 1 can be turned **ON** or **OFF** in address 4501 **STATE PROT I 1**. If it is switched **OFF**, this corresponds to a transmission failure. In case of a ring topology, the differential protection and all functions which require the transmission of data, can continue their operation, but not in case of a chain topology.

In address 4502 **CONNEC. 1 OVER**, set the transmission media that you want to connect to protection data interface PI 1. The following selection is possible:

F.optic direct, i.e. communication directly by fibre-optic cable with 512 kBit/s;

Com conv 64 kB, i.e. via communication converters with 64 kBit/s (G703.1 or X.21 or S0);

Com conv 128 kB, i.e. via communication converters with 128 kBit/s (X.21, copper cable);

Com conv 512 kB i.e. via communication converter 512 kbit/s (X.21).

The possibilities may vary for the different device versions. The data must be identical at both ends of a communication route.

The setting depends on the features of the communication media. As a general rule, it can be stated that the higher the transmission rate the shorter the tripping time of the differential protection system.

The devices measure and monitor the transmission times. Deviations are corrected, as long as they are within the permissible range. These permissible ranges are set under addresses 4505 and 4506 and can normally be left at their default values.

The maximum permissible transmission time (address 4505 **PROT 1 T-DELAY**) is preset to a value that does not exceed the usual delay of communication networks. This parameter can only be altered with DIGSI® under **Additional Settings**. If it is exceeded during operation (e.g. because of switchover to a different transmission route), the message „PI1 TD alarm“ (No. 3239) will be issued. Increased transmission times only have an impact on the tripping time of the differential protection system.

The maximum **transmission time difference** (outgoing telegram vs. return telegram) can be altered in address 4506 **PROT 1 UNSYM.**. This parameter can only be altered with DIGSI® under **Additional Settings**. With a direct fibre-optic connection, this value can be set to 0. For transmission via communication networks a higher value is needed. The standard value is 100 µs (default setting). The permissible transmission time difference has a direct influence on the sensitivity of the differential protection.

If GPS synchronization is used this value is relevant only in case the GPS signal is missing. As soon as the GPS synchronization is restored, the transmission time differences are compensated again. As long as GPS synchronization is intact, transmission time differences do **not** affect the sensitivity of the protection.

Address 4511 **PI1 SYNCMODE** is only relevant if GPS synchronization (ordering option) is used. It determines the conditions for operation when the protection data communication has been re-established (initially or after transmission failure).

- **PI1 SYNCMODE = TEL or GPS** means that the differential protection will become active as soon as the protection communication has been established (data telegrams are received). Until the GPS synchronization is put into service with the conventional method, the differential protection operates with increased self-restraint determined by the maximum transmission time difference without GPS (address 4506 **PROT 1 UNSYM.**).
- **PI1 SYNCMODE = TEL and GPS** means that the differential protection is active, after reception of proper protection data telegrams, first when GPS synchronization has taken place or if the running time is signalled via an external operation (binary input). If synchronization is established by the operator, the differential protection operates with the configured value under address 4506 **PROT 1 UNSYM.** since transmission time differences are compensated by the GPS synchronization.
- **PI1 SYNCMODE = GPS SYNC OFF** means that no GPS synchronization takes place for this protection data interface. This is meaningful if no transmission time differences are expected (e.g. for fibre-optic direct data link).

You can determine a limit value **PROT1 max ERROR** for the permissible rate of faulty protection data telegrams under address 4513. This parameter can only be altered with DIGSI® under **Additional Settings**. The preset value 1 % means that one faulty telegram per 100 telegrams is permissible. The sum of telegrams in both directions is decisive.

If frequent transmission time jumps occur the regular operation of the differential protection is endangered. Under address 4515 **PI1 BLOCK UNSYM** you can decide whether the differential protection shall be blocked in this case. Normal setting is **YES** (default). If a ring topology is configured, the system switches to chain topology. If a chain topology was configured, failure of one transmission link blocks the differential protection. This parameter can only be altered with DIGSI® under **Additional Settings**.

Protection Data Interface 2

If protection data interface 2 exists and is used, the same possibilities apply as for protection data interface 1. The corresponding parameters are set under addresses 4601 **STATE PROT 1 2 (ON or OFF)**, 4602 **CONN. 2 OVER**, 4605 **PROT 2 T-DELAY** and 4606 **PROT 2 UNSYM.** here again, the two last parameters can only be set with DIGSI® under **Additional Setting**. If GPS synchronization is available, the parameter is to be used under the address 4611 **PI2 SYNCMODE**. The maximum permissible rate of faulty protection data telegrams **PROT2 max ERROR** (address 4613) and the reaction to impermissible transmission time difference **PI2 BLOCK UNSYM** (address 4615) (blocking of the differential protection **YES** or **NO**) can also be changed under **Additional Settings**.

GPS Synchronization (optional)

If GPS synchronization (order option) is used, this synchronization mode can be switched **ON** or **OFF** in address 4801 **GPS-SYNC..**

Address 4803 **TD GPS FAILD** is used to set the delay time after which an alarm is output „GPS loss“ (No 3247) after a GPS failure is detected.

Further parameters concerning GPS synchronization were set for the individual protection data interfaces (see above).

2.2.2.2 Settings

Addresses which have an appended "A" can only be changed with DIGSI, under Additional Settings.

Addr.	Parameter	Setting Options	Default Setting	Comments
4501	STATE PROT I 1	ON OFF	ON	State of protection interface 1
4502	CONNEC. 1 OVER	F.optic direct Com conv 64 kB Com conv 128 kB Com conv 512 kB	F.optic direct	Connection 1 over
4505A	PROT 1 T-DELAY	0.1 .. 30.0 ms	30.0 ms	Prot 1: Maximal permissible delay time
4506A	PROT 1 UNSYM.	0.000 .. 3.000 ms	0.100 ms	Prot 1: Diff. between send and receive delay time
4509	T-DATA DISTURB	0.05 .. 2.00 sec	0.10 sec	Time delay for data disturbance alarm
4510	T-DATAFAIL	0.0 .. 60.0 sec	6.0 sec	Time del for transmission failure alarm
4511	PI1 SYNCMODE	TEL and GPS TEL or GPS GPS SYNC OFF	TEL and GPS	PI1 Synchronizationmode
4512	Td ResetRemote	0.00 .. 300.00 sec; ∞	0.00 sec	Remote signal RESET DELAY for comm.fail
4513A	PROT1 max ERROR	0.5 .. 20.0 %	1.0 %	Prot 1: Maximal permissible error rate
4515A	PI1 BLOCK UNSYM	YES NO	YES	Prot. 1: Block. due to unsym. delay time
4601	STATE PROT I 2	ON OFF	ON	State of protection interface 2
4602	CONNEC. 2 OVER	F.optic direct Com conv 64 kB Com conv 128 kB Com conv 512 kB	F.optic direct	Connection 2 over
4605A	PROT 2 T-DELAY	0.1 .. 30.0 ms	30.0 ms	Prot 2: Maximal permissible delay time
4606A	PROT 2 UNSYM.	0.000 .. 3.000 ms	0.100 ms	Prot 2: Diff. in send and receive time
4611	PI2 SYNCMODE	TEL and GPS TEL or GPS GPS SYNC OFF	TEL and GPS	PI2 Synchronizationmode
4613A	PROT2 max ERROR	0.5 .. 20.0 %	1.0 %	Prot 1: Maximal permissible error rate
4615A	PI2 BLOCK UNSYM	YES NO	YES	Prot. 2: Block. due to unsym. delay time
4801	GPS-SYNC.	ON OFF	OFF	GPS synchronization
4803A	TD GPS FAILD	0.5 .. 60.0 sec	2.1 sec	Delay time for local GPS-pulse loss

2.2.2.3 Information List

No.	Information	Type of Information	Comments
3215	Wrong Firmware	OUT	Incompatible Firmware Versions
3217	PI1 Data reflec	OUT	Prot Int 1: Own Datas received
3218	PI2 Data reflec	OUT	Prot Int 2: Own Datas received
3227	>PI1 light off	SP	>Prot Int 1: Transmitter is switched off
3228	>PI2 light off	SP	>Prot Int 2: Transmitter is switched off
3229	PI1 Data fault	OUT	Prot Int 1: Reception of faulty data
3230	PI1 Datafailure	OUT	Prot Int 1: Total reception failure
3231	PI2 Data fault	OUT	Prot Int 2: Reception of faulty data
3232	PI2 Datafailure	OUT	Prot Int 2: Total reception failure
3233	DT inconsistent	OUT	Device table has inconsistent numbers
3234	DT unequal	OUT	Device tables are unequal
3235	Par. different	OUT	Differences between common parameters
3236	PI1<->PI2 error	OUT	Different PI for transmit and receive
3239	PI1 TD alarm	OUT	Prot Int 1: Transmission delay too high
3240	PI2 TD alarm	OUT	Prot Int 2: Transmission delay too high
3243	PI1 with	VI	Prot Int 1: Connected with relay ID
3244	PI2 with	VI	Prot Int 2: Connected with relay ID
3245	>GPS failure	SP	> GPS failure from external
3247	GPS loss	OUT	GPS: local pulse loss
3248	PI 1 GPS sync.	OUT	GPS: Prot Int 1 is GPS synchronized
3249	PI 2 GPS sync.	OUT	GPS: Prot Int 2 is GPS synchronized
3250	PI 1 PD unsym.	OUT	GPS:PI1 unsym.propagation delay too high
3251	PI 2 PD unsym.	OUT	GPS:PI2 unsym.propagation delay too high
3252	>SYNC PI1 RESET	SP	> PI1 Synchronization RESET
3253	>SYNC PI2 RESET	SP	> PI2 Synchronization RESET
3254	PI1 jump	OUT	Prot.1: Delay time change recognized
3255	PI2 jump	OUT	Prot.2: Delay time change recognized
3256	PI1 unsym.	IntSP	Prot.1: Delay time unsymmetry to large
3257	PI2 unsym.	IntSP	Prot.2: Delay time unsymmetry to large
3258	PI1 Error	OUT	ProtInt1:Permissible error rate exceeded
3259	PI2 Error	OUT	ProtInt2:Permissible error rate exceeded

2.2.3 Differential Protection Topology

2.2.3.1 Setting Notes

Protection Data Topology

First of all, define your protection data communication topology: number the devices consecutively. This numbering is a serial device index that serves for your own overview. It starts for each distance differential protection system (i.e. for each protected object) with 1. For the differential protection system the device with index 1 is always the absolute-chronology master, i.e. the absolute time management of all devices which belong together depends on the absolute time management of this device, if synchronization is set to **Timing-Master**. As a result the time information of all devices is comparable at all times. The device index serves for unique definition of the devices within the differential protection system (i.e. for one protected object).

An ID number is also to be given to each single device (device-ID). The device-ID is used by the communication system to identify each individual device. It must be between 1 and 65534 and must be unique within the communication system. The ID number identifies the devices in the communication system (like a device address) since the exchange of information between several differential protection systems (thus also for several protective relay) can be executed via the same communication system.

Please make sure that the possible communication links and the existing interfaces are in accordance with each other. If not all devices are equipped with **two** protection data interfaces, those with only **one** protection data interface must be located at the ends of the communication chain. A **ring topology** is only possible if **all** devices in a differential protection system are equipped with two protection data interfaces.

If you work with different physical interfaces and communications links, please make sure that every protection data interface corresponds to the projected communication link.

For a protected object with two ends (e.g. a line) the addresses 4701 **ID OF RELAY 1** and 4702 **ID OF RELAY 2** are set, e.g. for device 1 the device-ID **16** and for device 2 the device-ID **17** (Figure 2-12). The indices of the devices and the device-IDs do not have to match here, as mentioned above.




Figure 2-12 Differential protection topology for 2 ends with 2 devices — example

For a protected object with more than two ends (and corresponding number of devices), the further devices are assigned to their device IDs with the parameter addresses **4703 ID OF RELAY 3**, **4704 ID OF RELAY 4**, **4705 ID OF RELAY 5** and **4706 ID OF RELAY 6**. A maximum of 6 ends with 6 devices is possible for a protected object. Figure 2-13 shows an example with 4 relays. During the configuration of the protection functions (Section 2.1.1.3) the number of devices required for the relevant case of application was set in address **147 NUMBER OF RELAY**. Device IDs can be entered for as many devices as were configured under that address, no further IDs are offered during setting.

In address **4710 LOCAL RELAY** you indicate the actual local device. Enter the index for each device (according to the consecutive numbering used). Each index from 1 to the entire number of devices must be used once, but may not be used twice.




Figure 2-13 Differential protection topology for 4 ends with 4 devices — example

Make sure that the parameters of the differential protection topology for the differential protection system are conclusive:

- Each device index can only be used once.
- Each device index must be assigned unambiguously to one device ID.
- Each device index must be the index of a local device once.
- The device with index 1 is the source for the absolute time management (timing master).
- The number of devices must be equal at all devices.

During startup of the protection system, the above listed conditions are checked. If one out of these conditions is still not fulfilled, no differential protection operation is possible.

The device then issues one of the following error messages

- „DT inconsistent“ (Device Table contains two or more identical device identification numbers)
- „DT unequal“ (Different settings of parameters 4701 to 4706)
- „Equal IDs“ (Protection system contains devices with identical settings of parameter 4710)

If the indication „Par. different“ is displayed OFF, the differential protection is blocked as well. In this case the following parameters, which should have identical settings in the devices, have in fact different settings.

- Address 230 **Rated Frequency**
- Address 143 **TRANSFORMER** in the protected zone
- Address 1106 **OPERATION POWER** primary
- Address 112 **DIFF. PROTECTION** exists
- Address 149 **charge I comp.** exists

2.2.3.2 Settings

Addr.	Parameter	Setting Options	Default Setting	Comments
4701	ID OF RELAY 1	1 .. 65534	1	Identification number of relay 1
4702	ID OF RELAY 2	1 .. 65534	2	Identification number of relay 2
4703	ID OF RELAY 3	1 .. 65534	3	Identification number of relay 3
4704	ID OF RELAY 4	1 .. 65534	4	Identification number of relay 4
4705	ID OF RELAY 5	1 .. 65534	5	Identification number of relay 5
4706	ID OF RELAY 6	1 .. 65534	6	Identification number of relay 6
4710	LOCAL RELAY	relay 1 relay 2 relay 3 relay 4 relay 5 relay 6	relay 1	Local relay is

2.2.3.3 Information List

No.	Information	Type of Information	Comments
3451	>Logout	SP	> Logout input signal
3457	Ringtopology	OUT	System operates in a closed Ringtopology
3458	Chaintopology	OUT	System operates in a open Chaintopology
3464	Topol complete	OUT	Communication topology is complete
3475	Rel1Logout	IntSP	Relay 1 in Logout state
3476	Rel2Logout	IntSP	Relay 2 in Logout state
3477	Rel3Logout	IntSP	Relay 3 in Logout state
3478	Rel4Logout	IntSP	Relay 4 in Logout state
3479	Rel5Logout	IntSP	Relay 5 in Logout state
3480	Rel6Logout	IntSP	Relay 6 in Logout state
3484	Logout	IntSP	Local activation of Logout state

No.	Information	Type of Information	Comments
3487	Equal IDs	OUT	Equal IDs in constellation
3491	Rel1 Login	OUT	Relay 1 in Login state
3492	Rel2 Login	OUT	Relay 2 in Login state
3493	Rel3 Login	OUT	Relay 3 in Login state
3494	Rel4 Login	OUT	Relay 4 in Login state
3495	Rel5 Login	OUT	Relay 5 in Login state
3496	Rel6 Login	OUT	Relay 6 in Login state

2.3 Differential Protection

The differential protection represents the main protection function of the device. It is based on current comparison. For this, one device must be installed at each end of the zone to be protected. The devices exchange their measured quantities via communications links and compare the received currents with their own. In case of an internal fault the allocated circuit breaker is tripped.

Depending on the ordered model, the 7SD5 is designed for protected objects with up to 6 ends. Thus, with exception of normal lines, three and multi-branch lines can also be protected with or without connected transformers in block as well as small busbars. The protected zone is selectively limited by the CTs at its ends.

Differential protection can be configured in parallel to distance protection (Main2), or as sole protection function (refer also to Section 2.1.1.3).

2.3.1 Functional Description

Basic Principle with Two Ends

Differential protection is based on current comparison. It makes use of the fact that e.g. a line section L (Figure 2-14) carries always the same current i (dashed line) at its two ends in healthy operation. This current flows into one side of the considered zone and leaves it again on the other side. A difference in current is a clear indication of a fault within this line section. If the actual current transformation ratios are the same, the secondary windings of the current transformers **CT1** and **CT2** at the line ends can be connected to form a closed electric circuit with a secondary current I ; a measuring element **M** which is connected to the electrical balance point remains at zero current in healthy operation.

When a fault occurs in the zone limited by the transformers, a current $i_1 + i_2$ which is proportional to the fault currents $I_1 + I_2$ flowing in from both sides is fed to the measuring element. As a result, the simple circuit shown in Figure 2-14 ensures a reliable tripping of the protection if the fault current flowing into the protected zone during a fault is high enough for the measuring element **M** to respond.




Figure 2-14 Basic principle of the differential protection for a line with two ends

Basic Principle with Multiple Ends

For lines with three or more ends or for busbars, the principle of differential protection is extended in that the total sum of all currents flowing into the protected object is zero in healthy operation, whereas in case of a fault the total sum is equal to the fault current (see Figure 2-15 as an example for four ends).




Figure 2-15 Basic principle of differential protection for four ends (single-line illustration)

Transmission Measured Value

If the entire protected object is located in one place — as is the case with generators, transformers, busbars —, the measured quantities can be processed immediately. This is different for lines where the protected zone spans a certain distance from one substation to the other. To be able to process the measured quantities of all line ends at each line end, these have to be transmitted in a suitable form. In this way, the tripping condition at each line end can be checked and the respective local circuit breaker can be operated if necessary.

7SD5 transmits the measured quantities as digital telegrams via communication channels. For this, each device is equipped with at least one protection data interface.

Figure 2-16 shows this for a line with two ends. Each device measures the local current and sends the information on its intensity and phase relation to the opposite end. The interface for this communication between protection devices is called the protection data interface. As a result, the currents can be added up and processed in each device.




Figure 2-16 Differential protection for a line with two ends

In case of more than two ends, a communication chain is built up by which each device is informed about the total sum of the currents flowing into the protected object. Figure 2-17 shows an example for three ends. Ends 1 and 2 are derived from the arrangements of the current transformers shown on the left. Although this is actually only one line end, it should be treated in terms of differential protection as two ends because the current is measured in two places. Line end 3 is situated on the opposite side.

Each device receives its local currents from the current transformers. Device 1 measures the current i_1 and transmits its data as complex phasor I_1 to device 2. Device 2 adds the share I_2 to its own measured current i_2 and sends this partial sum to device 3. The partial sum $I_1 + I_2$ finally reaches device 3 which then adds its share I_3 . Vice versa, a corresponding chain leads from device 3 via device 2 to device 1. In this way, the total sum of the three currents measured at the measuring points is available to all three devices.

The sequence of the devices in the communication chain need not correspond to the indexation, as shown in Figure 2-17. The allocation is carried out during the parameterization of the topology, as explained in Section 2.2.1.




Figure 2-17 Differential protection for a line with three ends

The communication chain can also be connected to a ring, as shown in dashed lines in Figure 2-17. This provides for redundancy of transmission: even if one communication link fails, the entire differential protection system will be fully operational. The devices detect communication failures and switch automatically to another communication channel. It is also possible to switch off one line end, e.g. for a check or a revision, and put the local protection out of operation. With a communication ring, the rest of the operation can proceed without disturbances.

You will find detailed information on the topology of device communication in Section 2.2.1.

Measured Value Synchronization

The devices measure the local currents in an asynchronous way. This means that each device measures, digitizes and pre-processes the associated currents of the current transformers with its own, random processor pulse. If the currents of two or more line ends are to be compared, it is necessary, however, to process all currents with the same time base.

All devices which belong together exchange their time with each telegram. The device with index 1 functions as a „timing master“ thus determining the time base. The other devices then calculate the time delay from the transmission and processing times related on the „timing master“. With this „rough synchronization“ the equality of the time bases with a precision of ± 0.5 ms is provided.

To reach a sufficiently precise synchronization all current values are marked with a „time stamp“ before they are transmitted from one device to the other as digital telegrams. This time stamp indicates at which point in time the transmitted current data were valid. Therefore, the receiving devices can carry out an optimized synchronization of the current comparisons based on the received time stamp and their own time management, i.e. they can compare the currents which were actually measured at exactly the same time (<5 μ s tolerance).

The transmission periods are permanently monitored by the devices using the time data stamps and considered at the respective receiving end.

The frequency of the measured quantities, which is decisive for the comparison of complex phasors, is also continuously measured and with the calculation, if necessary, corrected to achieve a synchronous comparison of the phasors. If the device is connected to voltage transformers and at least one voltage of a sufficient level is available, the frequency is derived from this voltage. If not, the measured currents are used for the determination of the frequency. The measured frequencies are interchanged between the devices via the communication link. Under these conditions all devices work with the currently valid frequency.

Restraint

The precondition for the basic principle of the differential protection is that the total sum of all currents flowing into the protected object is zero in healthy operation. This precondition is only valid for the primary system and even there only if shunt currents of a kind produced by line capacitances or magnetizing currents of transformers and reactors can be neglected.

The secondary currents which are applied to the devices via the current transformers, are subject to measuring errors caused by the response characteristic of the current transformers and the input circuits of the devices. Transmission errors such as signal jitters can also cause deviations of the measured quantities. As a result of all these influences, the total sum of all currents processed in the devices in healthy operation is not exactly zero. Therefore, the differential protection is restrained against these influences.

Charging Current Compensation

Charging current compensation is an ancillary function of the differential protection. It allows to achieve a higher sensitivity by partially compensating the charging currents caused by the capacitances of the overhead line or cable. Charging currents flow through the capacitance of the line.

Due to the phase-to-earth and phase-to-phase capacitances, charging currents are flowing even in healthy operation and cause a difference of currents at the ends of the protected zone. Especially when cables and long lines have to be protected, the capacitive charging currents can reach considerable magnitude.

If the feeder-side transformer voltages are connected to the devices, the influence of the capacitive charging currents can be compensated to a large extent arithmetically. It is possible to activate a charging current compensation which determines the actual charging current. With two line ends, each device takes over half of the charging current compensation, with M devices each device takes the Mth part. For more simplicity, Figure 2-18 shows a single-phase system.




Figure 2-18 Charging current compensation for a line with two ends (single-phase system)

In healthy operation charging currents can be considered as being almost constant under steady-state conditions, since they are only determined by the voltage and the capacitances of the lines. Without charging current compensation, they must therefore be taken into account when setting the sensitivity of the differential protection (refer also to Section 2.3.2 under „Pickup Value of Differential Current“). With charging current compensation, no charging currents need to be taken into account here. With charging current compensation, the steady-state magnetizing currents across shunt reactances are taken into account as well. The devices have a separate inrush restraint feature for transient inrush currents (see below under the margin heading „Inrush Restraint“).

Current Transformers Errors

To consider the influences of current transformer errors, each device calculates a self-restraining quantity I_{Error} . This is calculated by estimating the possible local transformer errors from the data of the local current transformers and the intensity of the measured currents (see Figure 2-19). The current transformer data have been parameterized under the power system data (cf. Section 2.1.2.1 under margin heading „Current Transformer Characteristics“ and apply to each individual device. Since each device transmits its estimated errors to the other devices, each device is capable to form the total sum of possible errors; this sum is used for restraint.




Figure 2-19 Approximation of the current transformer errors

Further Influences

Further measuring errors which may arise in the device itself by hardware tolerances, calculation tolerances, deviations in time or due to the „quality“ of the measured quantities such as harmonics and deviations in frequency, are also estimated by the device and increase the local self-restraining quantity automatically. Here, the permissible variations in the protection data transmission and processing periods are also considered.

Deviations in time are caused by residual errors during the synchronization of measured quantities, data transmission and operating time variations, and similar events. When GPS synchronization is used, these influences are eliminated and do not increase the self-restraining quantity.

If an influencing parameter cannot be determined — e.g. the frequency, if no sufficient measured quantities are available — the device will assume by definition nominal frequency. In this example, frequency means that if the frequency cannot be determined, because no sufficient measured quantities are available, the device will assume nominal frequency. But since the actual frequency can deviate from the nominal frequency within the permissible range ($\pm 20\%$ of the nominal frequency), the restraint will be increased automatically. As soon as the frequency has been determined (max. 100 ms after reappearance of a suitable measured quantity), the restraint will be decreased correspondingly. This is important during operation if no measured quantities are existing in the protected area before a fault occurs, e.g. if a line with the voltage

transformers on the line side is switched onto a fault. Since the frequency is not yet known at this point of time, an increased restraint will be active until the actual frequency is determined. This may delay the tripping somewhat, but only close to the pickup threshold, i.e. in case of very low-current faults.

These self-restraining quantities are calculated by each device from the total sum of the possible deviations and transmitted to the other devices. In the same way as the total currents (differential currents) are calculated (see above, „Transmission of Measured Values“), each device calculates thus the total sum of the restraining quantities and thereby stabilize the differential currents.

It is due to the self-restraint that the differential protection works with a maximum of sensitivity at all times, since the restraining quantities adapt themselves automatically in a dynamic way to possible errors. In this way, even high-resistance faults, with high load currents at the same time, can be detected effectively. Using GPS synchronization, the self-restraining when using communication networks is minimize once more since differences in the transmission times are compensated automatically. A maximal sensitivity of the differential protection consists of an optical-fibre connection.

Inrush Restraint

If the protected area includes a power transformer, a high inrush current can be expected when connecting the transformer. This inrush current flows into the protected zone but does not leave it again.

The inrush current can amount to a multiple of the nominal current and is characterised by a considerable 2nd harmonic content (double nominal frequency) which is practically absent during a short-circuit. If the second harmonic content in the differential current exceeds a selectable threshold, tripping is blocked.

The inrush restraint has an upper limit: if a certain (adjustable) current value is exceeded, it will not be effective any more, since there must be an internal current-intensive short-circuit.

Figure 2-20 shows a simplified logic diagram. The conditions for the inrush restraint are examined in each device in which this function has been activated. The blocking condition is transmitted to all devices so that it is effective at all ends of the protected object.




Figure 2-20 Logic diagram of the inrush restraint for one phase

Since inrush stabilization operates individually for each phase, the protection is fully operative even when the transformer is switched onto a single-phase fault, whereby an inrush current may possibly flow through one of the undisturbed phases. It is, how-

ever, possible to set the protection in a way that when the permissible harmonic content in the current of only one single phase is exceeded, not only the phase with the inrush current but also the remaining phases of the differential stage are blocked. This cross-block can be limited to a selectable duration. Figure 2-21 shows the logic diagram.

The cross-block function affects all devices as well, since it extends the inrush restraint to all three phases.




Figure 2-21 Logic diagram of the cross-block function for one end

Evaluation of Measurement Quantities

The evaluation of measured values is performed separately for each phase. Additionally, the residual current is evaluated.

Each device calculates a differential current from the total of the current phasors that were formed at each end of the protected zone and transmitted to the other ends. The differential current value is equal to the value of the fault current that is registered („seen“) by the differential protection system. In the ideal case it is equal to the fault current value. In a healthy system the differential current value is low and, in a first approximation, equal to the charging current. With charging current compensation it is very low.

The restraining current counteracts the differential current. It is the total of the maximum measured errors at the ends of the protected object and is calculated from the actual measured values and power system parameters that were set. Therefore the highest possible error value of current transformers within the nominal range and/or the short-circuit current range is multiplied with the current flowing through each end of the protected object. The total value, including the measured internal errors, is then transmitted to the other ends. This is the reason why the restraining current is an image of the greatest possible measurement error of the entire differential protection system.

The pickup characteristic of the differential protection (Figure 2-22) derives from the restraining characteristic $I_{diff} = I_{rest}$ (45°-curve), that is cut below the setting value **I-DIFF**. It complies with the formula

$$I_{rest} = \mathbf{I-DIFF} + \Sigma (\text{errors by CT's and other effects})$$

If the calculated differential current exceeds the pickup limit and the greatest possible measurement error, the fault must be internal (shaded area in Figure 2-22).




Figure 2-22 Differential protection pickup characteristic, $I_{diff} >$ stage

High-Speed Charge Comparison

The charge comparison protection function is a differential stage which is superimposed on the current comparison (the actual differential protection). If a high-current fault occurs, high-speed tripping decision is then possible.

The charge comparison protection function does not sum up the complex current phasors at the ends of the protected object, but the integral of currents calculated according to the following formula:

$$Q = \int_{t_1}^{t_2} i(t) dt$$

It includes the integration interval of t_1 to t_2 , which is selected in the 7SD5 device to the period $1/4$.

The calculated charge Q is a scalar value which is faster to determine and to transmit than a complex phasor.

The charges of all ends of the protected object are added in the same way as done with the current phasors of the differential protection. Thus the total of the charges is available at all ends of the protected zone.

Right after a fault occurrence within the protected zone a charge difference emerges. For high fault currents which can lead to saturation of current transformers, a decision is taken before the saturation begins.

The charge difference of external faults is theoretically equal to zero at the beginning. The charge comparison protection function immediately detects the external fault and blocks its own function. If saturation begins in one or more current transformers which limit the protected zone, the before-mentioned function remains blocked. Thus possible differences resulting from the saturation are excluded. Generally it is assumed that

an initial saturation of current transformers only takes place after the expiration of at least one integration interval ($1/4$ cycle) that commenced with the occurrence of a fault.

When the power line is switched on, the pickup value of the charge comparison is automatically redoubled for a period of approximately 1.5 s. This is to prevent from malfunction caused by transient current in the CT secondary circuit due to remanence of the CTs (e.g. during auto-reclosure). This current would simulate a charge value which is not found in the primary quantities.

Each phase is subject to the charge comparison. Therefore an internal fault (evolving fault) in a different phase after the external fault occurred is registered immediately. The functional limitation of the charge comparison is reached in the less probable case that an internal fault (evolving fault) appears after occurrence of an external fault with considerable current transformer saturation in the same phase. This must then be detected by the actual differential protection.

Furthermore the charge comparison is influenced by charge currents from lines and shunt currents from transformers (steady-state and transient) that also cause a charge difference. Therefore the charge comparison is, as aforesaid, a function suited to complete the differential protection ensuring a fast tripping for high-current short-circuits. Normally, the charge comparison is set higher than the nominal current. For charge comparison, it is irrelevant whether the charging current compensation is activated or not.

Blocking/Inter-blocking

The distance protection, provided that it is available and configured, automatically takes over as protection function if the differential protection is blocked by a binary input signal. The blocking at one end of a protected object affects all ends via the communications link (interblocking). If the distance protection is not available or ineffective, and if overcurrent protection has been configured as emergency function, all devices automatically switch to this emergency mode.

Please keep in mind that the differential protection is phase-selectively blocked at all ends when a wire break is detected at one end of the protected object. The message „Wire break“ appears only on the device in which the wire break has been detected. All other devices show the phase-selective blocking of the differential protection by displaying dashes instead of the differential and restraint current for the failed phase. In the case of a phase-selective blocking of the differential protection due to wire break, the distance protection, even if it is available and configured, does not take over the protection function for the failed phase.

Pickup of the Differential Protection

Figure 2-23 shows the logic diagram for differential protection. The phase-segregated stages are totalled to phase information. Additionally the device provides information of which stage picked up.




Figure 2-23 Pickup logic for the differential protection function

As soon as the differential protection function registers a fault within its tripping zone, the signal „Diff. Gen. Flt.“ (general device pickup of the differential protection) is issued. For the differential protection function itself, this pickup signal is of no concern since the tripping conditions are available at the same time. This signal, however, is necessary for the initiation of internal or external supplementary functions (e.g. fault recording, automatic reclosure).

Tripping Logic of the Differential Protection

The tripping logic of the differential protection combines all decisions of the differential stages and forms output signals which are also influenced by the central tripping logic of the entire device (Figure 2-24).

The pickup signals that identify the concerned stages of the differential protection can be delayed via the time stage **T-DELAY I-DIFF>**. Independently from this condition,

a single-phase pickup can be blocked for a short time in order to bridge the transient oscillations on occurrence of a single earth fault in a resonant-earthed system.

The signals processed in this way are linked by the tripping logic of the device to the output signals „Diff. Gen. TRIP“, „Diff TRIP 1p L1“, „Diff TRIP 1p L2“, „Diff TRIP 1p L3“, „Diff TRIP L123“. The single-pole information implies that tripping will take place single-pole only. The actual generation of the commands for the tripping (output) relay is executed within the tripping logic of the entire device (see Section 2.23.1).




Figure 2-24 Tripping logic of the differential protection

2.3.2 Setting Notes

General

The differential protection can be switched **ON** or **OFF** in address 1201 **STATE OF DIFF.**. If a single device is switched off at any end of a protective object, the calculation of measured values becomes impossible. The entire differential protection of all ends is then blocked; if the distance protection is available and configured, it represents the main protection function.

Pickup Value of the Differential Current

The current sensitivity is set with address 1210 **I-DIFF>**. It is determined by the entire current flowing into a protected zone in case of a fault. This is the total fault current regardless of how it is distributed between the ends of the protected object.

If charging current compensation has been switched **ON** at address 1221 **Ic-comp.** = **ON**, the pickup value **I-DIFF>** can be set to $1 \cdot I_{CN}$. Thus the residual error of the charging current compensation is considered.

Without charging current compensation (address 1221 **Ic-comp.** = **OFF**), this pickup value must be set to a value that is higher than the total steady-state shunt current of the protected object. For cables and long overhead lines, the charging current is to be considered in particular.

The charging current is calculated from the operational capacitance:

$$I_C = 3.63 \cdot 10^{-6} \cdot U_N \cdot f_N \cdot C_B' \cdot s$$

with

I_C	Charging current to be calculated in A primary
U_N	Nominal voltage of the network in kV primary
f_N	Nominal frequency of the network in Hz
C_B'	Per unit line length service capacitance of the line in nF/km or nF/mile
s	Length of the line in km or miles

For lines with multiple ends, the total sum of all line sections is taken as the length.

Considering the variations of voltage and frequency, the value set should be at least 2 to 3 times higher than the calculated charging current. Moreover, the pickup value should not be less than 15% of the operating nominal current. The nominal operating current either derives from the nominal apparent power of a transformer in the protected area (as described in 2.1.4.1 under margin heading „Topological Data for Transformers (optional)“, or from the addresses 1104 **FullScaleCurr.** according to Section 2.1.4.1 under margin heading „Nominal Values of Protected Lines“. It must be equal at all ends of the protected object.

If no voltages are measured, the compensated charging current is taken into account in address 1224 **IcSTAB / IcN**. This ratio is normally 2.5, so that the current set by it is 2 to 3 times, or **IcSTAB / IcN · I-DIFF>**, of the determined charging current.

If setting is performed from a personal computer using DIGSI®, the parameters can be set either as primary or as secondary quantities. If secondary quantities are set, all currents must be converted to the secondary side of the current transformers.

Calculation Example:

110 kV single-conductor oil-filled cable 240 mm² in 50-Hz network with the following data:

s (length) = 16 km

$C_B' = 310$ nF/km

Current transformers 600 A/5 A

From that the steady-state charging current is calculated:

$$I_C = 3.63 \cdot 10^{-6} \cdot U_N \cdot f_N \cdot C_B' \cdot s = 3.63 \cdot 10^{-6} \cdot 110 \cdot 50 \cdot 310 \cdot 16 = 99 \text{ A}$$

For the setting with primary values at least the double value is to be set, i.e.:

Setting value **I-DIFF> = 200**

Setting value with charging current compensation **I-DIFF> = 100 A**

For the setting with secondary values this value has to be converted to secondary quantity:

$$\text{Setting Value} = \frac{200 \text{ A}}{600 \text{ A}} \cdot 5 \text{ A} = 1.67 \text{ A}$$

- If a power transformer with voltage regulation is installed within the protected zone consider that a differential current may be present even during normal operation, dependent on the position of the tap changer. Therefore it is essential to calculate the maximum differential current at the end positions of the tap changer and to add this current to the pickup value setting for **I-DIFF>** (referred to the nominal transformer current).

Pickup Value during Switch-on

When switching on long, unloaded cables, overhead lines and arc-compensated lines, considerable higher-frequency transient reactions may occur. These peaks are considerably damped by means of a digital filter in the differential protection. A pickup value **I-DIF>SWITCH ON** (address 1213) can be sent to reliably prevent single-sided pickup of the protection. This pickup value is always active when a device has recognized the connection of a dead line at its end. For the duration of the seal-in time **SI Time all C1**, which was set with the general protection data under address 1132 (Section 2.1.4.1 all devices are then switched over to this particular pickup value. A setting to three to four times the steady-state charging current ensures usually the stability of the protection during switch-on of the line. For switch-on of a transformer or shunt reactor, an inrush restraint is incorporated (see below under margin heading „Inrush Restraint“).

Final checks will be carried out during commissioning. Further information can be found in chapter Installation and Commissioning.

Time Delays

In special cases of application it may be useful to delay the tripping of the differential protection with an additional timer, e.g. in case of reverse interlocking. The delay time **T-DELAY I-DIFF>** (address 1217) is only started upon detection of an internal fault. This parameter can only be altered with DIGSI® under **Additional Settings**.

If the differential protection is applied to an isolated or resonant-earthed network, it must be ensured that tripping is avoided during the transient oscillations of a single earth fault. With address 1218 **T3I0 1PHAS** the pickup to a single fault is therefore delayed for 0.04 s (presetting). For large resonant-earthed systems the time delay should be increased. By setting the address to ∞ the single-phase tripping is totally suppressed.

Please note that the parameter **T3I0 1PHAS** is also used by the distance protection function. The settings that you make here also affect the distance protection (see Section 2.5.1.4 under margin heading „Earth Fault Detection“).

Pickup Value of Charge Comparison Stage

The pickup threshold of the charge comparison stage is set in address 1233 **I-DIFF>>**. The RMS value of the current is decisive. The conversion into charge value is carried out by the device itself.

Setting near the operational nominal current is adequate in most cases. Please also remember that the setting is related to the operational nominal values that must be equal (primary) at all ends of the protected object.

Since this stage reacts very fast, a pickup of capacitive charging currents (for lines) and inductive magnetizing currents (for transformers or reactors) — also for switch-on condition — must be excluded. This is also true when the charging current compensation is on, since the compensation is not effective for charge comparison.

In resonant-earthed systems the value of the non-compensated system earth fault current should also not be undershot. This value derives from the total capacitive earth fault current without considering the Petersen coil. As the Petersen coil serves to compensate nearly the total earth fault current, its nominal current can be taken as a base.

For transformers set the value $I_{N \text{ Transf}}/U_{k \text{ Transf}}$.

The pickup thresholds are finally checked during commissioning. For further information please refer to the chapter Installation and Commissioning.

Charging Current Compensation

The charging current compensation can only operate if this function has been set during configuration of the functional scope (Section 2.1.2) at address 149 **charge I comp. = Enabled**. Also, the line data must have been configured (Section 2.1.4.1).

With more than two line ends the parameter of address 1114 **Tot.Line Length** is to be considered. If the unit of length in address 236 is changed for the total line length in address 1114, the line data have to be set anew for the unit of length which has been changed. It is possible to enter here unrealistic data (very long line with extremely high capacitance). The charging current compensation is in that case ineffective and provides restraint with a very high restraint current. This can also be seen from the measured restraint values and from the output of an „effective-OFF“ indication.

In address 1221 **Ic-comp.** you can determine whether the charging current compensation is to be switched **ON** or **OFF**. Please note that the parameter **I-DIFF** in address 1210 must absolutely be increased to a value of 2 to 3 times I_{cN} before the compensation is switched **OFF**, because otherwise a spurious trip might be the result.

Note

If the protected line section includes transformers or compensation reactors, the charging current compensation must not be switched on.

In the following cases, an active protection device is not able to assess the charging current (charging current compensation is ineffective):

- No voltage measurement (depends on configuration),
- Fuse Failure, or
- Detection of a ΣU measuring error.

In all these cases the protection device remains active for its assigned line section, but must return to its "classic" restraint strategy, i.e. with I_{cRest} being 2 to 3 times I_{cN} . The calculated charging current is set to zero. The charging current tolerance, however, should be set to $2.5 \cdot I_{cN}$ · line section portion to avoid spurious tripping of the protection. Address 1224 **IcSTAB / IcN** allows you to determine the charging current restraint factor. Since in the latter descriptions the charging current was already considered using setting 1210 **I-DIFF** = $1 \cdot I_{cN}$, the additional restraint value of the device is calculated as follows: $(IcSTAB / IcN - 1) \cdot I-DIFF$ divided by the number of devices. This value is added to the normal restraint in case of a failure of the protective device voltage to be measured.

Inrush Restraint

The inrush restraint of the differential protection is only necessary when the devices are operated on a transformer or on lines which end on transformers. The transformer is inside the differential protection zone. At address 2301 **INRUSH REST.** it can be switched **ON** or **OFF**.

It is based on the evaluation of the second harmonic which exists in the inrush current. Ex-works a ratio of **15 %** of the **2nd HARMONIC** I_{2fN}/I_{fN} is set under address 2302, which can normally be taken over. However the component required for restraint can be parameterized. In order to be able to achieve a higher degree of restraint in case of exceptionally unfavourable inrush conditions, you may also set a smaller value.

However, if the local measured current exceeds a value set in address 2305 **MAX INRUSH PEAK**, there will be no inrush restraint. The peak value is decisive. The set value should be higher than the maximum inrush current peak value that can be expected. For transformers set the value above $\sqrt{2} \cdot I_{NTransf.}/u_{kTransf.}$. If a line ends on a transformer, a smaller value may be selected, considering the damping of the current by the line impedance.

The crossblock function can be activated (**YES** or deactivated (**NO**) in address 2303 **CROSS BLOCK**. The time after exceeding of the current threshold for which this cross-

block is to be activated is set under address 2310 **CROSSB 2HM**. With the setting ∞ the crossblock function is always active until the second harmonic content in all phases has dropped below the set value.

2.3.3 Settings

Addresses which have an appended "A" can only be changed with DIGSI, under Additional Settings.

The table indicates region-specific presettings. Column C (configuration) indicates the corresponding secondary nominal current of the current transformer.

Addr.	Parameter	C	Setting Options	Default Setting	Comments
1201	STATE OF DIFF.		OFF ON	ON	State of differential protection
1210	I-DIFF>	1A	0.10 .. 20.00 A	0.30 A	I-DIFF>: Pickup value
		5A	0.50 .. 100.00 A	1.50 A	
1213	I-DIF>SWITCH ON	1A	0.10 .. 20.00 A	0.30 A	I-DIFF>: Value under switch on condition
		5A	0.50 .. 100.00 A	1.50 A	
1217A	T-DELAY I-DIFF>		0.00 .. 60.00 sec; ∞	0.00 sec	I-DIFF>: Trip time delay
1218	T3I0 1PHAS		0.00 .. 0.50 sec; ∞	0.04 sec	Delay 1ph-faults (comp/isol. star-point)
1221	Ic-comp.		OFF ON	OFF	Charging current compensation
1224	IcSTAB/IcN		2.0 .. 4.0	2.5	Ic Stabilising / Ic Nominal
1233	I-DIFF>>	1A	0.8 .. 100.0 A; ∞	1.2 A	I-DIFF>>: Pickup value
		5A	4.0 .. 500.0 A; ∞	6.0 A	
2301	INRUSH REST.		OFF ON	OFF	Inrush Restraint
2302	2nd HARMONIC		10 .. 45 %	15 %	2nd. harmonic in % of fundamental
2303	CROSS BLOCK		NO YES	NO	Cross Block
2305	MAX INRUSH PEAK	1A	1.1 .. 25.0 A	15.0 A	Maximum inrush-peak value
		5A	5.5 .. 125.0 A	75.0 A	
2310	CROSSB 2HM		0.00 .. 60.00 sec; ∞	0.00 sec	Time for Crossblock with 2nd harmonic

2.3.4 Information List

No.	Information	Type of Information	Comments
3101	IC comp. active	OUT	IC compensation active
3102	2nd Harmonic L1	OUT	Diff: 2nd Harmonic detected in phase L1
3103	2nd Harmonic L2	OUT	Diff: 2nd Harmonic detected in phase L2
3104	2nd Harmonic L3	OUT	Diff: 2nd Harmonic detected in phase L3
3120	Diff active	OUT	Diff: Active
3132	Diff. Gen. Flt.	OUT	Diff: Fault detection
3133	Diff. Flt. L1	OUT	Diff: Fault detection in phase L1
3134	Diff. Flt. L2	OUT	Diff: Fault detection in phase L2
3135	Diff. Flt. L3	OUT	Diff: Fault detection in phase L3
3136	Diff. Flt. E	OUT	Diff: Earth fault detection
3137	I-Diff>> Flt.	OUT	Diff: Fault detection of I-Diff>>
3139	I-Diff> Flt.	OUT	Diff: Fault detection of I-Diff>
3141	Diff. Gen. TRIP	OUT	Diff: General TRIP
3142	Diff TRIP 1p L1	OUT	Diff: TRIP - Only L1
3143	Diff TRIP 1p L2	OUT	Diff: TRIP - Only L2
3144	Diff TRIP 1p L3	OUT	Diff: TRIP - Only L3
3145	Diff TRIP L123	OUT	Diff: TRIP L123
3146	Diff TRIP 1pole	OUT	Diff: TRIP 1pole
3147	Diff TRIP 3pole	OUT	Diff: TRIP 3pole
3148	Diff block	OUT	Diff: Differential protection is blocked
3149	Diff OFF	OUT	Diff: Diff. protection is switched off
3176	Diff Flt. 1p.L1	OUT	Diff: Fault detection L1 (only)
3177	Diff Flt. L1E	OUT	Diff: Fault detection L1E
3178	Diff Flt. 1p.L2	OUT	Diff: Fault detection L2 (only)
3179	Diff Flt. L2E	OUT	Diff: Fault detection L2E
3180	Diff Flt. L12	OUT	Diff: Fault detection L12
3181	Diff Flt. L12E	OUT	Diff: Fault detection L12E
3182	Diff Flt. 1p.L3	OUT	Diff: Fault detection L3 (only)
3183	Diff Flt. L3E	OUT	Diff: Fault detection L3E
3184	Diff Flt. L31	OUT	Diff: Fault detection L31
3185	Diff Flt. L31E	OUT	Diff: Fault detection L31E
3186	Diff Flt. L23	OUT	Diff: Fault detection L23
3187	Diff Flt. L23E	OUT	Diff: Fault detection L23E
3188	Diff Flt. L123	OUT	Diff: Fault detection L123
3189	Diff Flt. L123E	OUT	Diff: Fault detection L123E
3190	Test Diff.	IntSP	Diff: Set Teststate of Diff. protection
3191	Comm. Diff	IntSP	Diff: Set Commissioning state of Diff.
3192	TestDiff.remote	OUT	Diff: Remote relay in Teststate
3193	Comm.Diff act.	OUT	Diff: Commissioning state is active
3194	>Test Diff.	SP	Diff: >Test Diff.
3195	>Comm. Diff	SP	Diff: >Comm. Diff
3525	> Diff block	SP	>Differential protection blocking signal
3526	Diffblk.rec PI1	OUT	Differential blocking received at PI1
3527	Diffblk.rec PI2	OUT	Differential blocking received at PI2

No.	Information	Type of Information	Comments
3528	Diffblk.sen PI1	OUT	Differential blocking sending via PI1
3529	Diffblk.sen PI2	OUT	Differential blocking sending via PI2

2.4 Breaker Intertrip and Remote Tripping

7SD5 allows to transmit a tripping command created by the local differential protection to the other end or ends of the protected object (intertripping). Likewise, any desired command of another internal protection function or of an external protection, monitoring or control equipment can be transmitted for remote tripping.

The reaction when such a command is received can be set individually for each device. Thus, selection can be made for which end(s) the intertrip command should be effective.

Commands are transmitted separately for each phase, so that a simultaneous single-pole auto-reclosure is always possible, provided that devices and circuit breakers are designed for single-pole tripping.

2.4.1 Functional Description

Transmission Circuit

The transmission signal can originate from two different sources (Figure 2-25). If the parameter **I-TRIP SEND** is set to **YES**, each tripping command of the differential protection is routed immediately to the transmission function „I-Trip Send L1“ to „...L3“ (intertrip) and transmitted via the protection data interfaces and communication links.

Furthermore, it is possible to trigger the transmission function via binary inputs (remote tripping). This can be done either separately for each phase via the input functions „>Intertrip L1“, „>Intertrip L2“ and „>Intertrip L3“, or for all phases together (three-pole) via the binary input function „>Intertrip 3pol“. The transmission signal can be delayed with **T-ITRIP BI** and prolonged with **T-ITRIP PROL BI**.




Figure 2-25 Logic diagram of the intertrip — transmission circuit

In order to ensure that the transmission signal reaches all devices in objects with more than two ends, it is also looped through the protection data interface.

Receive Circuit

On the receiving end the signal can lead to a trip. Alternatively it can also cause an alarm only. In this way it is possible to determine for each end of the protected object whether the received signal is to trip at this particular end or not.

Figure 2-26 shows the logic diagram. If the received signal is supposed to cause a trip, it will be forwarded to the tripping logic. The tripping logic of the entire device (see also Section 2.23.1) ensures, if necessary, that the conditions for single-pole tripping are fulfilled (e.g. single-pole tripping permissible, auto-reclosure function ready).




Figure 2-26 Logic diagram of the intertrip — receiving circuit

Ancillary Functions

Since the signals for remote tripping can be set to cause only an alarm, any other desired signals can be transmitted in this way as well. After the binary input(s) have been activated, the signals which are set to cause an alarm at the receiving end are transmitted. These alarms can in turn execute any desired actions at the receiving end. It should be noted that for the transmission of remote alarms and remote commands a further 24 transmission channels and, in addition, 4 fast transmission channels are optionally available (see also Section 2.12).

2.4.2 Setting Notes

General

The intertrip function for tripping caused by the differential protection can be activated (**YES**) or deactivated (**NO**) with address 1301 **I - TRIP SEND**. Since the differential protection devices theoretically operate with the same measured values at all ends of the protected object, a tripping in the event of an internal fault normally is also carried out at all ends, regardless of the infeed conditions at the ends. In special cases, i.e. if fault currents are to be expected near to the pickup threshold, it may occur that one or more ends do not issue a tripping command due to inevitable device tolerances. For these cases **I - TRIP SEND = YES** ensures the tripping at all ends of the protected object.

Intertrip/Remote Tripping

If the intertrip function is activated, it will automatically start when the differential protection trips.

If the relevant binary inputs are allocated and activated by an external source, the intertrip signal is transmitted as well. In this case, the signal to be transmitted can be delayed with address 1303 **T - ITRIP BI**. This delay stabilizes the originating signal against dynamic interferences which may possibly occur on the control cabling. Address 1304 **T - ITRIP PROL BI** is used to extend a signal after it has been effectively injected from an external source.

The reaction of a device when receiving an intertrip/remote tripping signal is set in address 1302 **I - TRIP RECEIVE**. If it is supposed to cause tripping, set the value **Trip**. If the received signal, however, is supposed to cause an alarm only, **Alarm only** must be set even if this annunciation is to be further processed externally.

The setting times depend on the individual case of application. A delay is necessary if the external control signal originates from a disturbed source and a restraint seems appropriate. Of course, the control signal has to be longer than the delay for the signal to be effective. If the signal is processed externally at the receiving end, a prolongation time might become necessary for the transmitting end so that the reaction desired at the receiving end can be executed reliably.

2.4.3 Settings

Addr.	Parameter	Setting Options	Default Setting	Comments
1301	I-TRIP SEND	YES NO	NO	State of transmit. the intertrip command
1302	I-TRIP RECEIVE	Alarm only Trip	Trip	Reaction if intertrip command is receiv.
1303	T-ITRIP BI	0.00 .. 30.00 sec	0.02 sec	Delay for intertrip via binary input
1304	T-ITRIP PROL BI	0.00 .. 30.00 sec	0.00 sec	Prolongation for intertrip via bin.input

2.4.4 Information List

No.	Information	Type of Information	Comments
3501	>Intertrip L1	SP	I.Trip: >Intertrip L1 signal input
3502	>Intertrip L2	SP	I.Trip: >Intertrip L2 signal input

No.	Information	Type of Information	Comments
3503	>Intertrip L3	SP	I.Trip: >Intertrip L3 signal input
3504	>Intertrip 3pol	SP	I.Trip: >Intertrip 3 pole signal input
3505	ITrp.rec.PI1.L1	OUT	I.Trip: Received at Prot.Interface 1 L1
3506	ITrp.rec.PI1.L2	OUT	I.Trip: Received at Prot.Interface 1 L2
3507	ITrp.rec.PI1.L3	OUT	I.Trip: Received at Prot.Interface 1 L3
3508	ITrp.rec.PI2.L1	OUT	I.Trip: Received at Prot.Interface 2 L1
3509	ITrp.rec.PI2.L2	OUT	I.Trip: Received at Prot.Interface 2 L2
3510	ITrp.rec.PI2.L3	OUT	I.Trip: Received at Prot.Interface 2 L3
3511	ITrp.sen.PI1.L1	OUT	I.Trip: Sending at Prot.Interface 1 L1
3512	ITrp.sen.PI1.L2	OUT	I.Trip: Sending at Prot.Interface 1 L2
3513	ITrp.sen.PI1.L3	OUT	I.Trip: Sending at Prot.Interface 1 L3
3514	ITrp.sen.PI2.L1	OUT	I.Trip: Sending at Prot.Interface 2 L1
3515	ITrp.sen.PI2.L2	OUT	I.Trip: Sending at Prot.Interface 2 L2
3516	ITrp.sen.PI2.L3	OUT	I.Trip: Sending at Prot.Interface 2 L3
3517	ITrp. Gen. TRIP	OUT	I.Trip: General TRIP
3518	ITrp.TRIP 1p L1	OUT	I.Trip: TRIP - Only L1
3519	ITrp.TRIP 1p L2	OUT	I.Trip: TRIP - Only L2
3520	ITrp.TRIP 1p L3	OUT	I.Trip: TRIP - Only L3
3521	ITrp.TRIP L123	OUT	I.Trip: TRIP L123
3522	Diff TRIP 1pole	OUT	I.Trip: TRIP 1pole
3523	Diff TRIP 3pole	OUT	I.Trip: TRIP 3pole

2.5 Distance Protection

Distance protection is the second main function of the device. It can operate as a fully-fledged redundant second protection function (Main2) in parallel to differential protection, or be configured as the only main protection function of the device (Main only). The distance protection distinguishes itself by high measuring accuracy and the ability to adapt to the given system conditions. It is supplemented by a number of additional functions.

2.5.1 Distance Protection, General Settings

2.5.1.1 Earth Fault Detection

Functional Description

Recognition of an earth fault is an important element in identifying the type of fault, as the determination of the valid loops for measurement of the fault distance and the shape of the distance zone characteristics substantially depend on whether the fault at hand is an earth fault or not. The 7SD5 has a stabilized earth current measurement, a zero sequence current/negative sequence current comparison as well as a displacement voltage measurement.

Furthermore, special measures are taken to avoid a pickup for single earth faults in an isolated or resonant-earthed system.

Earth Current $3I_0$

For earth current measurement, the fundamental sum of the numerically filtered phase currents is supervised to detect if it exceeds the set value (parameter **3I0>Threshold**). Restraint is provided against spurious operation resulting from unsymmetrical operating currents and error currents in the secondary circuits of the current transformer due to different degrees of current transformer saturation during short-circuits without earth: the actual pick-up threshold automatically increases as the phase current increases (Figure 2-27). The dropout threshold is approximately 95 % of the pickup threshold.




Figure 2-27 Earth current stage: pickup characteristic

Negative Sequence Current $3I_2 >$

On long, heavily loaded lines, large currents could cause excessive restraint of the earth current measurement (ref. Figure 2-27). To ensure secure detection of earth faults in this case, a negative sequence comparison stage is additionally provided. In the event of a single-phase fault, the negative sequence current I_2 has approximately the same magnitude as the zero sequence current I_0 . When the ratio zero sequence current / negative sequence current exceeds a preset ratio, this stage picks up. It is also stabilized in the event of large negative sequence currents by a parabolic characteristic. Figure 2-28 illustrates this relationship. A release by means of the negative sequence current comparison requires a current of at least $0.2 I_N$ for $3I_0$ and $3I_2$.




Figure 2-28 Characteristic of the I_0/I_2 stage

Displacement Voltage $3U_0$

For the neutral displacement voltage recognition the displacement voltage ($3 \cdot U_0$) is numerically filtered and the fundamental frequency is monitored to recognize whether it exceeds the set threshold. The reset threshold is approximately 95 % of the pickup threshold. In earthed systems (**$3U_0 > \text{Threshold}$**) it can be used as an additional criterion for earth faults. For earthed systems, the U_0 -criterion may be disabled by applying the ∞ setting.

Logical Combination for Earthed Systems

The current and voltage criteria supplement each other, as the displacement voltage increases when the zero sequence to positive sequence impedance ratio is large, whereas the earth current increases when the zero sequence to positive sequence impedance ratio is smaller. The current and voltage criteria are logically combined with an OR-function for earthed systems. It is however also possible to establish an AND gate of the two criteria (see Figure 2-29). If detection of the displacement voltage has been disabled by setting **$3U_0 > \text{Threshold}$** to infinite, earth fault detection using the current criterion is still possible in case of CT saturation.

If the relay detects current transformer saturation in any of the phase currents, the voltage criterion is however an indispensable prerequisite for detection of an earth fault since unequal current transformer saturation may cause a faulted secondary zero-sequence current without a primary zero-sequence current flowing in the first place.

The earth fault recognition alone does not cause a general pickup of the distance protection, but merely controls the further fault detection modules. It is only alarmed in case of a general fault detection.




Figure 2-29 Logic of the earth fault detection

Earth Fault Recognition during Single-Pole Open Condition

In order to prevent undesired pickup of the earth fault detection, caused by load currents during single-pole open condition, a modified earth fault detection is used during single-pole open condition in earthed power systems (Figure 2-30). In this case, the magnitudes of the currents and voltages are monitored in addition to the angles between the currents.




Figure 2-30 Earth fault recognition during single-pole open condition

Logical Combination for Non-earthed Systems

In non-earthed systems (isolated system starpoint or resonant-earthed by means of a Peterson coil) the measured displacement voltage is not used for fault detection. Furthermore, in these systems a simple earth fault is assumed initially in case of a single-phase fault and the fault detection is suppressed in order to avoid an erroneous pickup as a result of the earth fault initiation transients. After a time delay **T3I0 1PHAS** which can be set, the fault detection is released again; this is necessary for the distance protection to still be able to detect a double earth fault with one base point on a dead-end feeder.

If, however, an earth fault is already present in the system, it is detected by the displacement voltage detection (**3U0 > COMP / ISOL .**). In this case, there is no delay time: an earth fault occurring now in a different phase can only be a double earth fault.

If, apart from the displacement measurement (**3U0 > COMP / ISOL.**), there is a fault detection in more than one phase, this is also rated as a double earth fault. In this way, double earth faults can be detected even if no or only little earth current flows via the measuring point.

2.5.1.2 Fault Detection (optional)

Prerequisite

Depending on the ordered version, the 7SD5 distance protection, if configured as the main or backup protection function, features a range of fault detection modes, from which the appropriate type for the particular system conditions can be selected. If, according to the ordering code, the device only has impedance fault detection (7SD5***-****-**E**** and 7SD5***-****-**H****), or if you have set **Dis. PICKUP = Z < (quadrilat.)** (address 117) as detection mode, please go to Section 2.5.1.3 „Calculation of the Impedances“. The sections below refer to the ordering codes 7SD5***-****-**D**** and 7SD5***-****-**G****.

Fault detection has to detect a faulty condition in the power system and to initiate all the necessary procedures for selective clearance of the fault:

- Start of the delay times for the directional and non-directional final stages,
- Determination of the faulted loop(s),
- Enabling of impedance calculation and direction determination,
- Enabling of tripping command,
- Initiation of supplementary functions
- Indication/output of the faulted conductor(s).

The type of fault detection selected with address 117 **Dis. PICKUP = Z < (quadrilat.)** works implicitly, i.e. the above-mentioned operations are executed automatically as soon as a fault is detected in one of the distance zones.

Overcurrent Pickup

Overcurrent pickup is a phase-selective pickup procedure. After numeric filtering, the currents are monitored in each phase for transgression of a set value. A signal is output for the phase(s) where the set threshold has been exceeded.

For processing the measured values (see Section 2.5.1 „Calculation of the Impedances“), the phase-selective pickup signals are converted into loop information. This depends on the earth fault detection and - in earthed power systems - on the parameter **1ph FAULTS** according to Table 2-4. For single-phase pickup without earth fault detection in non-earthed power systems the phase-phase loop is always selected.

The phases that have picked up are signalled. If an earth fault has been detected, it will also be alarmed.

The pickup will drop out if the signal falls below 95% of the pickup value.

Table 2-4 Loops and phase indications for single-phase overcurrent pickup

Pickup Module	Earth Fault Detection	Parameter 1ph FAULTS	Valid Loop	Alarmed Phase(s)
L1 L2 L3	No No No	phase-phase	L3-L1 L1-L2 L2-L3	L1, L3 L1, L2 L2, L3
L1 L2 L3	No No No	phase-earth ¹⁾	L1-E L2-E L3-E	L1 L2 L3
L1 L2 L3	Yes Yes Yes	any	L1-E L2-E L3-E	L1, E L2, E L3, E

¹⁾ only active for earthed power systems

Voltage-Dependent Current Fault Detection U/I

The U/I pickup is a per phase and per loop pickup mode. Here the phase currents must exceed a threshold, while the threshold value depends on the magnitude of the loop voltage.

Pickup on earth faults is effectively suppressed in networks with non-earthed neutral points by means of the measures described above in Section „Earth Fault Detection“.

The basic characteristics of the U/I pickup can be seen from the current–voltage characteristic shown in Figure 2-31. The first requirement for every phase pickup is that of the minimum current **I_{ph>}** is exceeded. For the evaluation of phase-phase loops, both relevant phase currents have to exceed this value. Above this current, the current pickup is voltage-dependent with the slope being determined by the settings **U(I>)** and **U(I>>)**. For short-circuits with large currents the overcurrent pickup **I_{ph>>}** is superimposed. The bold dots in Figure 2-31 mark the settings which determine the geometry of the current/voltage characteristic.

The phases that have picked up are signalled. The picked up loops are relevant for processing the measured values.

Loop pickup will drop out if the signal falls below 95 % of the respective current value or exceeds approx. 105 % of the respective voltage value.




Figure 2-31 U/I characteristic

Pickup Modes

The adaptation to different network conditions is determined by pickup modes.

The setting (**PROGAM U / I**) determines whether the phase-phase loops or the phase-earth loops are always valid, or whether this depends on the earth fault detection. This allows a very flexible adaptation to the network conditions. Optimum control mainly depends on whether the network neutral is not earthed (isolated or compensated), has a low-resistance or effective earthing. Setting notes are given in Section 2.5.1.4.

The evaluation of phase-earth loops is characterized by a high sensitivity in the event of earth faults and is therefore highly advantageous in networks with earthed star points. It automatically adapts to the prevailing infeed conditions; i.e. in the weak-infeed operation mode it becomes more current-sensitive, with high load currents the pickup threshold will be higher. This applies in particular if the network neutral is earthed low-resistance. If only the phase-earth loops are evaluated, it must be ensured that the overcurrent stage **Iph>>** responds in the event of phase-phase faults. If only one measuring system picks up, it can be decided whether this will result in a pickup of the phase-earth loops or the phase-phase loops in the earthed network (see Table 2-5).

Table 2-5 Loops and phase indications for single-phase overcurrent pickup U I; Phase-to-earth-voltages program

Pickup module	Measuring Current	Measuring Voltage	Earth fault detection	Parameter 1ph FAULTS	Valid Loop	Alarmed Phase(s)
L1 L2 L3	L1 L2 L3	L1-E L2-E L3-E	No No No	phase-phase	L3-L1 L1-L2 L2-L3	L1, L3 L1, L2 L2, L3
L1 L2 L3	L1 L2 L3	L1-E L2-E L3-E	No No No	phase-earth ¹⁾	L1-E L2-E L3-E	L1 L2 L3
L1 L2 L3	L1 L2 L3	L1-E L2-E L3-E	Yes Yes Yes	any	L1-E L2-E L3-E	L1, E L2, E L3, E

¹⁾ only active for earthed power systems

When evaluating phase-phase loops, the sensitivity towards phase-phase faults is particularly high. In extensive compensated networks this selection is advantageous because it excludes pickup as a result of single earth faults on principle. With two- and three-phase faults it automatically adapts to the prevailing infeed conditions, i.e. in the weak-infeed operation mode it becomes more current-sensitive, with strong infeed and high load currents the pickup threshold will be higher. If only phase-phase faults are evaluated, the measuring loop is independent of the earth-fault detection, therefore this procedure is not suitable for earthed networks (see Table 2-6).

Table 2-6 Loops and phase indications for single-phase overcurrent pickup U I; Phase-to-earth-voltages program

Pickup module	Measuring Current	Measuring Voltage	Earth Fault Detection	Parameter 1ph FAULTS	Valid Loop	Alarmed Phase(s)
L1 L2 L3	L1 L2 L3	L1-L2 L2-L3 L3-L1	any	any	L1-L2 L2-L3 L3-L1	L1, L2 L2, L3 L1, L3

If the option has been chosen whereby voltage loop selection is dependent on earth-fault detection, then high sensitivity applies to phase-earth faults and to phase-phase faults. On principle, this option is independent of the treatment of the network neutral, however, it requires that the earth-fault criteria according to Section Earth Fault Detection are met for all earth faults or double earth faults (see Table 2-7).

Table 2-7 Loops and phase indications for single-phase overcurrent pickup U I; Phase-to-earth-voltages program for earth fault, phase-to-phase voltages without earth fault

Pickup Module	Measuring Current	Measuring Voltage	Earth Fault Detection	Parameter 1ph FAULTS	Valid Loop	Alarmed Phase(s)
L1 L2 L3	L1 L2 L3	L1-L2 L2-L3 L3-L1	No No No	any	L1-L2 L2-L3 L3-L1	L1, L2 L2, L3 L1, L3
L1 L2 L3	L1 L2 L3	L1-E L2-E L3-E	Yes Yes Yes	any	L1-E L2-E L3-E	L1, E L2, E L3, E

Finally, it is also possible to only evaluate phase-earth voltage loops if an earth fault has been detected. For phase-phase faults only the overcurrent **I_{ph}>>** will then pick up. This is advantageous in networks with neutral points that have been earthed low-resistance, i.e. using earth-fault current limiting measures (so-called semi-solid earthing). In these cases only earth faults must be detected by the U/I pickup. In such networks it is usually even undesirable that phase-phase faults lead to a U/I pickup.

The measuring loop is independent of the setting **1ph FAULTS**. Table 2-8 shows the assignment of phase currents, loop voltages and measuring results.

Table 2-8 Loops and phase indications for single-phase overcurrent pickup U I; Phase-to-earth-voltages program for earth fault, I>> without earth fault

Pickup Module	Measuring Current	Measuring Voltage	Earth Fault Detection	Parameter 1ph FAULTS	Valid Loop	Alarmed Phase(s)
L1 L2 L3	L1 L2 L3	L1-E L2-E L3-E	Yes Yes Yes	any	L1-E L2-E L3-E	L1, E L2, E L3, E
L1 L2 L3	L1 L2 L3	L1-E L2-E L3-E	No No No	any	no pickup no alarm via $U_{Ph-E} < I >$	

The pickup signals of the loops are converted into phase signals so that the faulted phase(s) can be indicated. If an earth fault has been detected, it will also be alarmed.

Voltage and Angle-dependent Current Pickup U/I/φ

Phase-angle controlled U/I pickup can be applied when the U/I characteristic criteria can no longer distinguish reliably between load and short-circuit conditions. This is the case with small source impedances together with long lines or a sequence of lines and intermediate infeed. Then the local measured voltage will only drop to a small extent in the event of a short-circuit at the line end or in the back-up range of the distance protection so that the phase angle between current and voltage is required as an additional criterion for fault detection.

The U/I/φ pickup is a per phase and per loop pickup mode. It is crucial for the phase currents to exceed the pickup threshold, with the pickup value being dependent on the size of the loop voltages and the phase angle between current and voltage.

A precondition for measuring the phase-phase angles is that the associated phase currents as well as the current difference relevant for the loop have exceeded a settable minimum value $I_{ph>}$. The angle is determined by the phase-to-phase voltage and its corresponding current difference.

A precondition for measuring the phase-earth angle is that the associated phase current has exceeded a settable minimum value $I_{ph>}$ and that an earth fault has been detected or only phase-to-earth measurements have been stipulated by setting parameters. The angle is determined by the phase-to-earth voltage and its corresponding phase current without considering the earth current.

Pickup on earth faults is effectively suppressed in networks with non-earthed neutral points by means of the measures described in Section „Earth Fault Detection“.

The basic characteristics of the $U/I/\varphi$ pickup can be seen from the current-voltage characteristic shown in Figure 2-32. Initially it is shaped like the U/I pickup characteristic (Figure 2-31).

For angles in the range of large phase difference, i.e. in the short-circuit angle area above the threshold angle $\varphi>$, the characteristic between $U(I>)$ and $U(I\varphi>)$ also takes effect; it is cut off by the overcurrent stage $I\varphi>$. The bold dots in Figure 2-32 mark the settings which determine the geometry of the current/voltage characteristic. The angle-dependent area, i.e. the area within the short-circuit angle of the characteristic in Figure 2-32, can either be set to affect in forward direction (in direction of line) or in both directions.




Figure 2-32 $U/I/\varphi$ characteristic

Loop pickup will drop out if the signal falls below 95% of the respective current value or exceeds approx. 105% of the respective voltage value. A hysteresis of 5° applies to phase-angle measuring.

The adaptation to different network conditions is determined by pickup modes. As the $U/I/\varphi$ fault detection represents an extension of the U/I fault detection, the same program options apply. Tables 2-5 to 2-8 also apply for single-phase pickup.

2.5.1.3 Calculation of the Impedances

A separate measuring system is provided for each of the six possible impedance loops L1-E, L2-E, L3-E, L1-L2, L2-L3, L3-L1. The phase-earth loops are evaluated when an earth fault detection is recognized and the phase current exceeds a settable minimum value **Minimum I_{ph}**. The phase-phase loops are evaluated when the phase current in both of the affected phases exceeds the minimum value **Minimum I_{ph}**.

A jump detector synchronizes all the calculations with the fault inception. If a further fault occurs during the evaluation, the new measured values are immediately used for the calculation. The fault evaluation is therefore always done with the measured values of the current fault condition.

Phase-Phase Loops

To calculate the phase-phase loop, for instance during a two-phase short circuit L1-L2 (Figure 2-33) the loop equation is:

$$\underline{I}_{L1} \cdot \underline{Z}_L - \underline{I}_{L2} \cdot \underline{Z}_L = \underline{U}_{L1-E} - \underline{U}_{L2-E}$$

with

$\underline{U}, \underline{I}$

the (complex) measured quantities and

$\underline{Z} = R + jX$

the (complex) line impedance.

The line impedance is computed to be

$$Z_L = \frac{U_{L1-E} - U_{L2-E}}{I_{L1} - I_{L2}}$$




Figure 2-33 Short-circuit of a phase-phase loop

The calculation of the phase-phase loop does not take place as long as one of the concerned phases is switched off (during single-pole dead time), to avoid an incorrect measurement with the undefined measured values existing during this state. A state recognition (refer to Section 2.23.1) provides the corresponding block signal. A logic block diagram of the phase-phase measuring system is shown in Figure 2-34.




Figure 2-34 Logic for a phase-phase measuring unit

Phase-Earth Loops

For the calculation of the phase-earth loop, for example during a L3-E (Figure 2-35) it must be noted that the impedance of the earth return path does not correspond to the impedance of the phase. In the loop equation

$$I_{L3} \cdot Z_L - I_E \cdot Z_E = U_{L3-E}$$

Z_E is replaced by $(Z_E/Z_L) \cdot Z_L$ yielding:

$$I_{L3} \cdot Z_L - I_E \cdot Z_L \cdot \frac{Z_E}{Z_L} = U_{L3-E}$$

From this the line impedance can be extracted

$$Z_L = \frac{U_{L3-E}}{I_{L3} - Z_E/Z_L \cdot I_E}$$




Figure 2-35 Short-circuit of a phase-earth loop

The factor Z_E/Z_L solely depends on the line parameters and not on the fault distance.

The evaluation of the phase-earth loop does not take place as long as the affected phase is switched off (during single-pole dead time), to avoid an incorrect measurement with the undefined measured values existing in this state. A state recognition provides the corresponding block signal. A logic block diagram of the phase-earth measuring system is shown in Figure 2-36.




Figure 2-36 Logic for a phase-earth measuring unit

Unfaulted Loops

The above considerations apply to the relevant short-circuited loop. A pickup with the current-based fault detection modes ($I>$, U/I , $U/I/\varphi$) guarantees that only the faulty loop(s) are released for the distance calculation. All six loops are calculated for the impedance pickup; the impedances of the unfaulted loops are also influenced by the short-circuit currents and voltages in the short-circuited phases. During a L1-E fault for example, the short-circuit current in phase L1 also appears in the measuring loops L1-L2 and L3. The earth current is also measured in loops L2-E and L3-E. Combined with load currents which may flow, the unfaulted loops produce the so called „apparent impedances“ which have nothing to do with the actual fault distance.

These „apparent impedances“ in the unfaulted loops are usually larger than the short-circuit impedance of the faulted loop because the unfaulted loop only carries a part of the fault current and always has a larger voltage than the faulted loop. For the selectivity of the zones, they are usually of no consequence.

Apart from the **zone selectivity**, the **phase selectivity** is also important to achieve correct identification of the faulted phases, required to alarm the faulted phase and especially to enable single-pole automatic reclosure. Depending on the infeed conditions, close-in short-circuits may cause unfaulted loops to „see“ the fault further away than the faulted loop, but still within the tripping zone. This would cause three-pole tripping and therefore void the possibility of single-pole automatic reclosure. As a result power transfer via the line would be lost.

In the 7SD5 this is avoided by the implementation of a „loop verification“ function which operates in two steps:

- Initially, the calculated loop impedances and its components (phase and/or earth) are used to simulate a replica of the line impedance. If this simulation returns a plausible line image, the corresponding loop pickup is designated as a definitely valid loop.

- If the impedances of more than one loop are now located within the range of the zone, the smallest is still declared to be a valid loop. Furthermore, all loops that have an impedance which does not exceed the smallest loop impedance by more than 50% are declared as being valid. Loops with larger impedance are eliminated. Those loops

which were declared as being valid in the initial stage, cannot be eliminated by this stage, even if they have larger impedances.

In this manner unfaulted „apparent impedances“ are eliminated on the one hand, while on the other hand, unsymmetrical multi-phase faults and multiple short-circuits are recognized correctly.

The loops that were designated as being valid are converted to phase information so that the fault detection correctly alarms the faulted phases.

Double Faults in Effectively Earthed Systems

In systems with an effectively or low-resistant earthed starpoint, each connection of a phase with earth results in a short-circuit condition which must be isolated immediately by the closest protection systems. Fault detection occurs in the faulted loop associated with the faulted phase.

With double earth faults, fault detection is generally in two phase-earth loops. If both earth loops are in the same direction, a phase-phase loop may also pick up. It is possible to restrict the fault detection to particular loops in this case. It is often desirable to block the phase-earth loop of the leading phase, as this loop tends to overreach when there is infeed from both ends to a fault with a common earth fault resistance (Parameter 1521 **2Ph-E faults = Block leading Ø**). Alternatively, it is also possible to block the lagging phase-earth loop (Parameter **2Ph-E faults = Block lagging Ø**). All the affected loops can also be evaluated (Parameter **2Ph-E faults = All loops**), or only the phase-phase loop (Parameter **2Ph-E faults = Ø-Ø loops only**) or only the phase-earth loops (Parameter **2Ph-E faults = Ø-E loops only**).

A prerequisite for these restrictions is that the relevant loops indicate fault locations which are close together and within the reach of the first zone Z1. The loops are considered to be close together when they have the same direction and have both been observed in zone Z1. The loops are considered to be close together when they do not differ by more than a factor 1.5 (largest to smallest impedance). This prevents the elimination, during multiple faults with separate fault location, of the loop relating to the closer fault location by the set restriction. Furthermore a phase-to-phase measurement can only be performed if two earth faults as described above are located close to one another.

In Table 2-9 the measured values used for the distance measurement in earthed systems during double earth faults are shown.

Table 2-9 Evaluation of the measured loops for double loop faults in an earthed system in case both earth faults are close to each other

Loop pickup	Evaluated loop(s)	Setting of parameter 1521
L1-E, L2-E, L1-L2 L2-E, L3-E, L2-L3 L1-E, L3-E, L3-L1	L2-E, L1-L2 L3-E, L2-L3 L1-E, L3-L1	2Ph-E faults = Block leading Ø
L1-E, L2-E, L1-L2 L2-E, L3-E, L2-L3 L1-E, L3-E, L3-L1	L1-E, L1-L2 L2-E, L2-L3 L3-E, L3-L1	2Ph-E faults = Block lagging Ø
L1-E, L2-E, L1-L2 L2-E, L3-E, L2-L3 L1-E, L3-E, L3-L1	L1-E, L2-E, L1-L2 L2-E, L3-E, L2-L3 L1-E, L3-E, L3-L1	2Ph-E faults = All loops

Loop pickup	Evaluated loop(s)	Setting of parameter 1521
L1-E, L2-E, L1-L2 L2-E, L3-E, L2-L3 L1-E, L3-E, L3-L1	L1-L2 L2-L3 L3-L1	2Ph-E faults = Ø-Ø loops only
L1-E, L2-E, L1-L2 L2-E, L3-E, L2-L3 L1-E, L3-E, L3-L1	L1-E, L2-E L2-E, L3-E L1-E, L3-E	2Ph-E faults = Ø-E loops only

During three phase faults the fault detection of all three phase-phase loops usually occurs. In this case the three phase-phase loops are evaluated. If earth fault detection also occurs, the phase-earth loops are also evaluated.

Double Earth Faults in Non-earthed Systems

In isolated or resonant-earthed networks a single earth fault does not result in a short circuit current flow. There is only a displacement of the voltage triangle (Figure 2-37). For the system operation this state is no immediate danger. The distance protection must not pick up in this case even though the voltage of the phase with the earth fault is equal to zero in the whole galvanically connected system. Any load currents will result in an impedance value that is equal to zero. Therefore a single-phase pickup phase-earth without earth current pickup is avoided in the 7SD5.




Figure 2-37 Earth fault in non-earthed neutral system

With the occurrence of earth faults — especially in large resonant-earthed systems — large fault inception transient currents can appear that may evoke the earth current pickup. In case of an overcurrent pickup there may also be a phase current pickup. 7SD5 provides special measures against such undesirable pickups.

With the occurrence of a double earth fault in isolated or resonant-earthed systems it is sufficient to switch off one of the faults. The second fault may remain in the system as a simple earth fault. Which of the faults is switched off depends on the double earth fault preference which is set the same in the whole galvanically-connected system. With 7SD5 the following double earth fault preferences (Parameter 1520 **PHASE PREF. 2phe**) can be selected:

Acyclic L3 before L1 before L2	L3 (L1) ACYCLIC
Acyclic L1 before L3 before L2	L1 (L3) ACYCLIC
Acyclic L2 before L1 before L3	L2 (L1) ACYCLIC
Acyclic L1 before L2 before L3	L1 (L2) ACYCLIC
Acyclic L3 before L2 before L1	L3 (L2) ACYCLIC
Acyclic L2 before L3 before L1	L2 (L3) ACYCLIC
Cyclic L3 before L1 before L2 before L3	L3 (L1) CYCLIC

Cyclic L1 before L3 before L2 before L1	L1 (L3) CYCLIC
All loops are measured	All loops

In all eight preference options, one earth fault is switched off according to the preference scheme. The second fault can remain in the system as a simple earth fault. It can be detected with the Earth Fault Detection in Non-earthed Systems (optional).

The 7SD5 also enables the user to switch off both fault locations of a double earth fault. Set the double earth fault preference to **All loops**.

Table 2-10 lists all measured values used for the distance measuring in isolated or resonant-earthed systems.

Table 2-10 Evaluation of the Measuring Loops for Multi-phase Pickup in the Non-earthed Network

Loop pickup	Evaluated loop(s)	Setting of parameter 1520
L1-E, L2-E, (L1-L2) L2-E, L3-E, (L2-L3) L1-E, L3-E, (L3-L1)	L1-E L3-E L3-E	PHASE PREF.2phe = L3 (L1) ACYCLIC
L1-E, L2-E, (L1-L2) L2-E, L3-E, (L2-L3) L1-E, L3-E, (L3-L1)	L1-E L3-E L1-E	PHASE PREF.2phe = L1 (L3) ACYCLIC
L1-E, L2-E, (L1-L2) L2-E, L3-E, (L2-L3) L1-E, L3-E, (L3-L1)	L2-E L2-E L1-E	PHASE PREF.2phe = L2 (L1) ACYCLIC
L1-E, L2-E, (L1-L2) L2-E, L3-E, (L2-L3) L1-E, L3-E, (L3-L1)	L1-E L2-E L1-E	PHASE PREF.2phe = L1 (L2) ACYCLIC
L1-E, L2-E, (L1-L2) L2-E, L3-E, (L2-L3) L1-E, L3-E, (L3-L1)	L2-E L3-E L3-E	PHASE PREF.2phe = L3 (L2) ACYCLIC
L1-E, L2-E, (L1-L2) L2-E, L3-E, (L2-L3) L1-E, L3-E, (L3-L1)	L2-E L2-E L3-E	PHASE PREF.2phe = L2 (L3) ACYCLIC
L1-E, L2-E, (L1-L2) L2-E, L3-E, (L2-L3) L1-E, L3-E, (L3-L1)	L1-E L2-E L3-E	PHASE PREF.2phe = L3 (L1) CYCLIC
L1-E, L2-E, (L1-L2) L2-E, L3-E, (L2-L3) L1-E, L3-E, (L3-L1)	L2-E L3-E L1-E	PHASE PREF.2phe = L1 (L3) CYCLIC
L1-E, L2-E, (L1-L2) L2-E, L3-E, (L2-L3) L1-E, L3-E, (L3-L1)	L1-E, L2-E L2-E, L3-E L3-E; L1-E	PHASE PREF.2phe = All loops

Parallel Line Measured Value Correction (optional)

During earth faults on parallel lines, the impedance values calculated by means of the loop equations are influenced by the coupling of the earth impedance of the two conductor systems (Figure 2-38). This causes measuring errors in the result of the impedance computation unless special measures are taken. A parallel line compensation may therefore be activated. In this manner the earth current of the parallel line is taken into consideration by the line equation and thereby allows for compensation of the coupling influence. The earth current of the parallel line must be connected to the device for this purpose. The loop equation is then modified as shown below, refer also to Figure 2-35.

$$I_{L3} \cdot Z_L - I_E \cdot Z_E - I_{EP} \cdot Z_M = U_{L3-E}$$

$$I_{L3} \cdot Z_L - I_E \cdot Z_L \cdot \frac{Z_E}{Z_L} - I_{EP} \cdot Z_L \cdot \frac{Z_M}{Z_L} = U_{L3-E}$$

where I_{EP} is the earth current of the parallel line and the ratio Z_M/Z_L is a constant line parameter, resulting from the geometry of the double circuit line and the nature of the ground below the line. These line parameters are input to the device — along with all the other line data — during the parameterization of the device. The line impedance is calculated with the equation below similar to the calculation shown earlier.

$$Z_L = \frac{U_{L3-E}}{I_{L3} - Z_E/Z_L \cdot I_E - Z_M/Z_L \cdot I_{EP}}$$




Figure 2-38 Earth fault on a double circuit line

Without parallel line compensation, the earth current on the parallel line will in most cases cause the reach threshold of the distance protection to be shortened (under-reach of the distance measurement). In some cases — for example when the two feeders are terminated to different busbars, and the location of the earth fault is on one of the remote busbars (at B in Figure 2-38) — it is possible that an overreach may occur.

The parallel line compensation only applies to faults on the protected feeder. For faults on the parallel line, the compensation may not be carried out, as this would cause severe overreach. The relay located in position II in Figure 2-38 may therefore not be compensated.

Earth current balance is therefore additionally provided in the device, which carries out a cross comparison of the earth currents in the two lines. The compensation is only applied to the line end where the earth current of the parallel line is not substantially larger than the earth current in the line itself. In example in Figure 2-38, the current I_E is larger than I_{EP} : compensation is applied at I in that $Z_M \cdot I_{EP}$ is included in the evaluation, at II compensation is not applied.

Blocking of Zone Z1

If the main protection functions - differential protection and distance protection - operate in parallel, the distance protection of Zone Z1 may pick up before the differential protection (e.g. in the case of close-up faults). If this is desired, the distance protection works as a „booster“ stage for fast tripping. If the fast tripping acts on one end of the line only, accelerated tripping of zone Z1 is not desired (see also Section 2.5.1.4).

There are two ways of blocking Z1. If the device operates in differential protection mode, zone Z1 can be blocked by setting a parameter (address 1533 **Z1 blkd by**

diff). Another way of blocking the zone is to set a binary input (No 3610 „>BLOCK Z1-Trip“).

Switching onto a Fault

If the circuit breaker is manually closed onto a short circuit, the distance protection can issue an instantaneous trip command. By setting parameters it may be determined which zone(s) is/are released following a manual close (refer to Figure 2-39). The line energization information (input „SOTF“) is derived from the state recognition.




Figure 2-39 Switching onto a fault



Note

When switching onto a three-pole fault with the MHO characteristic, there will be no voltage in the memory or unfaulted loop voltage available. To ensure fault clearance when switching onto three-pole close-up faults, please make sure that in conjunction with the configured MHO characteristic the instantaneous tripping function is always enabled.

2.5.1.4 Setting Notes

At address 1501 **FCT Distance** the distance protection function can be switched **ON** or **OFF**.

Minimum Current

The minimum current for fault detection **Minimum Iph>** (address 1502) in case of impedance pickup is set somewhat (approx. 10 %) below the minimum short-circuit current that may occur. For the other pickup modes it is set at address 1911.

Earth Fault Detection

In systems with earthed starpoint, the setting **3I0> Threshold** (address 1503) is set somewhat below the minimum expected earth fault current. $3I_0$ is defined as the sum of the phase currents $|I_{L1} + I_{L2} + I_{L3}|$, which equals the starpoint current of the set of current transformers. In non-earthed systems the setting value is recommended to be below the earth current value for double earth faults.

The preset value **3IO> / Iphmax** = 0,10 (address 1507) usually is recommended for the slope of the 3IO characteristic. This setting can only be changed via DIGSI® at **Additional Settings**.

Addresses 1504 and 1509 are only relevant for **earthed** power systems. In non-earthed systems this setting is not relevant and therefore not accessible.

When setting **3U0> Threshold** (address 1504), care must be taken that operational asymmetries do not cause a pickup. $3U_0$ is defined as the sum of the phase-earth voltages $|\underline{U}_{L1-E} + \underline{U}_{L2-E} + \underline{U}_{L3-E}|$. If the U_0 criterion is not required, the address 1504 is set to ∞ .

In earthed power systems the earth fault detection can be complemented by a zero sequence voltage detection function. You can determine whether an earth fault is detected when a zero sequence current or a zero sequence voltage threshold is exceeded or when both criteria are met. **3IO> OR 3U0>** (default setting) applies at address 1509 **E/F recognition** if only one of the two criteria is valid. Select **3IO> AND 3U0>** to activate both criteria for earth-fault detection. This setting can only be changed via DIGSI® at **Additional Settings**. If you want to detect only the earth current, set **3IO> OR 3U0>** and also **3U0> Threshold** (address 1504) to ∞ .



Note

Under no circumstances set address 1504 **3U0> Threshold** to ∞ , if you have set address 1509 **E/F recognition = 3IO> AND 3U0>**, or earth-fault detection will no longer be possible.

If in isolated or resonant earthed systems the earth fault detection threatens to pick up due to fault inception transients following the occurrence of a single earth fault, the detection can be delayed with setting address 1218 **T3IO 1PHAS**. Set parameter **T3IO 1PHAS** to ∞ if the earth current threshold can also be exceeded during steady-state conditions. Then, even with high earth current, no single-phase pickup is possible anymore. Double earth faults are however correctly detected and measured according to the preference program (also see Section 2.5.1 at margin heading „Double Earth Faults in Non-earthed Systems“).

Please note that the parameter **T3IO 1PHAS** is also used by the differential protection function. The setting that you make here affects the differential protection function as well (see also Section 2.3.2 under margin heading „Delay Times“).

Application with Series-Compensated Lines

With series-compensated lines (lines with series capacitors), set address 1508 **SER-COMP.** to **YES**, to ensure that the direction determination works correctly in all cases. The influence of the series capacitors on the direction determination is described in Section 2.5.2 under margin heading „Direction Determination in Case of Series-compensated Lines“.

Start of Delay Times

As was mentioned in the description of the measuring technique, each distance zone generates an output signal which is associated with the zone and the affected phase. The zone logic combines these zone fault detections with possible further internal and external signals. The delay times for the distance zones can be started either all together on general fault detection by the distance protection function, or individually at the moment the fault enters the respective distance zone. Parameter **Start Timers** (address 1510) is set by default to **on Dis. Pickup**. This setting ensures that all delay times continue to run together even if the type of fault or the selected measuring loop changes, e.g. because an intermediate infeed is switched off. This is also the pre-

ferred setting in the case of other distance protection relays in the power system working with this start timing. Where grading of the delay times is especially important, for instance if the fault location shifts from zone Z3 to zone Z2, the setting **on Zone Pickup** should be chosen.

Angle of Inclination of the Tripping Characteristics

The shape of the tripping characteristic is among other factors influenced by the inclination angle **Distance Angle** (address 1540). Details about the tripping characteristics can be found in Section 2.5.2 and 2.5.3). Usually, the line angle is set here, i.e. the same value as in address 1105 **Line Angle** (Section 2.1.4.1). Irrespective of the line angle it is, however, possible to select a different inclination angle of the tripping characteristic.

Parallel Line Measured Value Correction (optional)

The mutual coupling between the two lines of a double-circuit configuration is only relevant to the 7SD5 when it is applied on a double-circuit line and when it is intended to implement parallel line compensation. A prerequisite is that the earth current of the parallel line is connected to the I_4 measuring input of the device and this is entered in the configuration settings. In this case, address 1515 **Paral.Line Comp** has to be set to **YES** (default setting).

The coupling factors were already set as part of the general protection data (Section 2.1.4.1), as was the reach of the parallel line compensation.

Double Earth Faults in Effectively Earthed Systems

The loop selection for double earth faults is set in address 1521 **2Ph-E faults** (Phase-Phase-Earth fault detection). This parameter can only be altered with DIGSI® under **Additional Settings**. In most cases, **Block leading 0** (blocking of the leading phase, default setting) is favourable because the leading phase-earth loop tends to overreach, especially in conjunction with large earth fault resistance. In certain cases (fault resistance phase-phase larger than phase-earth) the setting **Block lagging 0** (blocking of the lagging phase) may be more favourable. The evaluation of all affected loops with the setting **All loops** allows a maximum degree of redundancy. It is also possible to evaluate as loop **0-0 loops only**. This ensures the most accuracy for two phase-to-earth faults. Ultimately it is possible to declare the phase-to-earth loops as valid (setting **0-E loops only**).

Double Earth Faults in Non-earthed Systems

In isolated or resonant-earthed systems it must be guaranteed that the preference for double earth faults in whole galvanically-connected systems is consistent. The double earth fault preference is set in address 1520 **PHASE PREF.2phe**.

7SD5 enables the user to detect all base points of a multiple earth fault. **PHASE PREF.2phe = All loops** means that each earth fault point on a protected line is switched off independent from the preference. It can also be combined with a different preference. For a transformer feeder, for example, any base point can be switched off following occurrence of a double earth fault, whereas **L1 (L3) ACYCLIC** is consistently valid for the remainder of the system.

If the earth fault detection threatens to pick up due to fault inception transients following the occurrence of a single earth fault, the detection can be delayed via parameter **T3IO 1PHAS** (address 1218). Usually the presetting (0.04 s) is sufficient. For large resonant-earthed systems the time delay should be increased. Set parameter **T3IO 1PHAS** to ∞ if the earth current threshold can also be exceeded during steady-state conditions. Then, even with high earth current, no single-phase pickup is possible anymore. Double earth faults are, however, detected correctly and evaluated according to the preference mode.

If a double earth fault occurs right after a single earth fault, it is detected and evaluated according to the preference scheme. The already existing earth fault is detected by

the zero-sequence voltage (address 1505 **3U0> COMP/ISOL.**). Please note that triple zero-sequence voltage $3U_0$ is relevant here. With a full displacement its value will be $\sqrt{3}$ times the phase-to-phase voltage. Afterwards the delay **T3I0 1PHAS** is not active anymore: an earth fault occurring now in a different phase can only be a double earth fault.

Switching onto a Fault

To determine the reaction of the distance protection during closure of the circuit breaker onto a dead fault, the parameter in address 1532 **S0TF zone** is used. The setting **Inactive** specifies that there is no special reaction, i.e. all distance stages operate according to their set zone parameters. The setting **Zone Z1B** causes all faults inside the overreaching zone Z1B (in the direction specified for these zones) to be cleared without delay following closure of the circuit breaker. If **Z1B undirect.** is set, the zone Z1B is relevant, but it acts in both directions, regardless of the operating direction set in address 1651 or 1751 **Op. mode Z1B**. The setting **PICKUP** implies that the non-delayed tripping following line energization is activated for all recognized faults in any zone (i.e. with general fault detection of the distance protection).

Blocking of Zone Z1

When the differential protection is active, zone Z1 can be blocked by setting 1533 **Z1 blkd by diff** to **YES**; this means that there will be no measurement and no pickup in Z1 as long as the differential protection is effective (No. 3120 „Diff active“). Zone Z1 will be reactivated immediately when the differential protection is ineffective, e.g. due to a communication failure. With address 1533 **Z1 blkd by diff** set to **NO**, zone Z1 operates independently of the differential protection.

Zone Z1 can also be blocked by the binary input 3610 „>BLOCK Z1-Trip“. This binary input allows, for instance, to specify further blocking conditions relating to the interaction with the differential protection using CFC. The effect of the binary input does not depend on the status of the differential protection.

**Load Range (only
for Impedance
Pickup)**

When using the impedance pickup function, or with the variants 7SD5***_*****_E** and 7SD5***_*****_H*, there may be a risk of encroachment of the load impedance into the tripping characteristic of the distance protection on long heavily loaded lines. To exclude the risk of unwanted fault detection by the distance protection during heavy load flow, a load trapezoid characteristic may be set for tripping characteristics with large R-reaches, which excludes such unwanted fault detection by overload. This load trapezoid does not apply for the other pickup modes since the trip polygons are only released after pickup and the pickup function fulfills the task of distinguishing clearly between load operation and short-circuit. This load area is considered in the description of the tripping characteristics (see also Sections 2.5.2 and 2.5.3).

The R-value **R load (0-E)** (address 1541) refers to the phase-earth loops, **R load (0-0)** (address 1543) to the phase-phase loops. The values are set somewhat (approx. 10 %) below the minimum expected load impedance. The minimum load impedance results when the maximum load current and minimum operating voltage exist.

Calculation Example:

110 kV overhead line 150 mm² with the following data:

maximum transmittable power

$$P_{\max} = 100 \text{ MVA corresponds to}$$
$$I_{\max} = 525 \text{ A}$$

minimum operating voltage

$$U_{\min} = 0,9 U_N$$

Current Transformer 600 A / 5 A
 Voltage Transformer 110 kV / 0.1 kV

The resulting minimum load impedance is therefore:

$$R_{\text{Load prim}} = \frac{U_{\min}}{\sqrt{3} \cdot I_{L \max}} = \frac{0.9 \cdot 110 \text{ kV}}{\sqrt{3} \cdot 525 \text{ A}} = 108.87 \text{ } \Omega$$

This value can be entered as a primary value when parameterizing with a personal computer and DIGSI®. The conversion to secondary values is

$$R_{\text{Load sec}} = \frac{N_{\text{CT}}}{N_{\text{VT}}} \cdot R_{\text{Load prim}} = \frac{600 \text{ A}/5 \text{ A}}{110 \text{ kV}/0.1 \text{ kV}} \cdot 108.87 \text{ } \Omega = 11.88 \text{ } \Omega$$

when applying a security margin of 10 % the following is set:

primary: **R load (0-0) = 97.98** Ω or

secondary: **R load (0-0) = 10.69** Ω .

The spread angle of the load trapezoid **φ load (0-E)** (address 1542) and **φ load (0-0)** (address 1544) must be greater (approx. 5°) than the maximum arising load angle (corresponding to the minimum power factor cosφ).

Calculation Example:

Minimum power factor

$$\cos \varphi_{\min} = 0.63$$

$$\varphi_{\max} = 51^\circ$$

$$\text{Setting value } \varphi \text{ load (0-0)} = \varphi_{\max} + 5^\circ = 56^\circ.$$

Overcurrent, U/I and U/I/φ pickup

Depending on the ordered version, the 7SD5 distance protection, if configured as the main or backup protection function, features a range of fault detection modes, from which the appropriate type for the particular system conditions can be selected (7SD5***-*****-**D**** and 7SD5***-*****-**G******).

If the device does not feature an explicit pickup function or if during configuration of the protection functions (Section 2.1.1.3) you have selected as pickup type **Dis. PICKUP = Z< (quadrilat.)** (address 117), the mentioned settings are not relevant and cannot be accessed.

Available pickup modes are described in Section 2.5.1 in detail. If the device has several alternative pickup modes, one option has been selected when configuring in address 117. Below, parameters are given and discussed for all pickup modes. With the following settings, only those parameters will appear that apply for the selected pickup mode.

With the U/I(/φ) pickup mode you can determine the voltage measurement and, if applicable, the phase-angle measurement for phase-to-earth measuring units, and for phase-to-phase measuring loops separately. Address 1901 **PROGAM U/I** indicates which loop voltages apply to phase-to-earth and which to phase-to-phase:

In networks with **earthed** starpoint, a selection using $U_{\text{Ph-E}}$ with earth faults and $U_{\text{Ph-Ph}}$ with non-earthed faults is often preferred (address 1901 **PROGAM U/I** = **LE:Uphe / LL:Uphp**). This mode has a maximum sensitivity for all fault types; however, it requires the unambiguous detection of earth faults via the earth-fault detection function (also see Section 2.5.1). Otherwise, a mode using $U_{\text{Ph-E}}$ for all fault types may

be useful (address 1901 **PROGAM U/I = LE:Uphe/LL:Uphe**), accepting lesser sensitivity for earth-free faults, since the overcurrent stage $I_{ph}>>$ usually picks up there.

In networks with **low-resistance earthed** starpoint, the $U/I/\phi$ pickup should only come into effect on earth faults as phase-to-phase faults are detected by the overcurrent pickup. In this case it is reasonable to set address 1901 **PROGAM U/I = LE:Uphe/LL:I>>**.

In **isolated** or **resonant-earthed** power systems it is possible to control the $U/I/\phi$ pickup using phase-to-phase voltages only (address 1901 **PROGAM U/I = LE:Uphe/LL:Uphe**). Naturally, this excludes pickup by single earth faults, however, it also does not allow a correct double earth fault detection, therefore it is suitable only for small isolated cable networks.

Two further general settings refer to the final times, i.e. the tripping times in a worst case scenario for faults outside all distance zones. They should be set above the delay times for distance zones providing a final back-up option (see also configuration of the function settings for the distance zones in Section 2.5.2.2).

The directional final time **DELAY FORW. PU** (address 1902) only works with short-circuits in forward (line) direction if there is no impedance within a distance zone after pickup.

The non-directional final time **DEL. NON-DIR PU** (address 1903) works for all faults if there is no impedance within a distance zone after pickup.

Overcurrent Pickup

The maximum operational load current that can occur is crucial for the setting of **overcurrent pick-up**. Pickup due to overload must be ruled out! Therefore the pickup value $I_{ph}>>$ (address 1910) must be set above the maximum (over-)load current that is expected (approx. 1.2 times). In this case, it must be ensured that the minimum fault current is above this value. If this is not the case, U/I pickup is required.

Calculation Example:

Maximum operational current (incl. overload) is 680 A, for current transformers 600 A/5 A, minimum short circuit is 1200 A. The following settings are made:

$$I_{ph}>> = I_{L \max} \cdot 1.2 = 680 \text{ A} \cdot 1.2 = 816 \text{ A}$$

This value is sufficiently below the minimum short-circuit current of 1200 A. When configuring via PC and DIGSI® this value can be entered directly as primary value. The conversion to secondary values is

$$I_{ph}>> = 816 \text{ A} \cdot \frac{5 \text{ A}}{600 \text{ A}} = 6.8 \text{ A}$$

The condition for minimum short-circuit current also applies to earth faults (in the earthed network) or for double earth faults as long as overcurrent pickup is solely used.

$U/I(\phi)$ pickup

If U/I pickup is required because the minimum short-circuit current is below the maximum load current (incl. a safety factor of 1.2), the condition for maximum load current in respect to $I_{ph}>>$ still has to be observed. Then, the minimum current limit $I_{ph}>$ (address 1911) is set to below the minimum short-circuit current (approx. 10 %). This also applies to the phase currents during earth faults or double earth faults.

In address 1930 **1ph FAULTS** you can choose whether a phase-to-earth loop shall be selected in an earthed network during single-phase pickup without earth current (I_E release). The setting **1ph FAULTS = PHASE - EARTH** is useful if no or only little earth current can flow via the measuring point in the event of earth faults. With **1ph FAULTS**

= **PHASE - PHASEONLY** the leading phase-phase loop is measured in the event of a single-phase pick-up in the earthed network. This parameter can only be altered with DIGSI® under **Additional Settings**.

The meaning of the settings is illustrated in Figure 2-40. **I_{ph>}** (section a, address 1911) is the minimum current as described in the previous section, **I_{ph>>}** (section c) is the overcurrent pickup.




Figure 2-40 Parameters of the U/I/φ pickup

Angular dependence is not needed in the majority of cases. Then the voltage-dependent section b is valid which results in the characteristic a-b-c. When controlling with U_{ph-e} the voltages for phase-to-earth current are inserted in address 1912 **U_{ph-e} (I>>)** and 1913 **U_{ph-e} (I>)** for the voltage-dependent section b. When controlling with U_{ph-ph} the voltages for phase-to-phase are set in address 1914 **U_{ph-ph} (I>>)** and 1915 **U_{ph-ph} (I>)**. The relevant settings are determined according to the pickup mode (see above).

The characteristic has to be set such that it is just below the minimum expected voltage at the maximum expected load current. If in doubt, check the pickup conditions in accordance with the U/I characteristic.

Angular Dependence

If a distinction between short-circuit and load conditions is not always possible using the U/I characteristic, which is independent of the phase angle, the angular dependent section d-e can additionally be used. This is required for long lines and section of lines with intermediate infeed in combination with small source impedances. Then the local measured voltage will only drop to a small extent in the event of a short-circuit at the line end or in the back-up range of the distance protection so that the phase angle between current and voltage is required as an additional criterion for fault detection.

The parameters **I_{phi>}** (address 1916) and **U_{ph-e} (I_{phi>})** (address 1917) or **U_{ph-ph} (I_{phi>})** (address 1918) determine the characteristic in the range of large angles φ_K , i.e. in the short-circuit angular range. The threshold angles themselves, which define the short-circuit angle range φ_K , are set in address 1920 $\varphi>$ and 1921 $\varphi<$. The short-circuit angle range φ_K is between these two angles. Here, too, the required voltage settings according to the pickup mode (see above) are relevant.

The characteristic for the load angle range has to be set in a way that is just below the minimum expected operating voltage at the maximum expected load current. In the range of the short-circuit angles ϕ_K it must be ensured that load current may not cause pickup in this area. If reactive power has to be transferred via this line, it must be ensured that the maximum reactive current at minimum operating voltage is not within the pickup range, i.e. the short-circuit angle range ϕ_K . If in doubt, check the pickup conditions in accordance with the $U/I/\phi$ characteristic. An arithmetic short-circuit calculation is recommended for extensive networks.

The lower threshold angle $\phi>$ (address 1920) should be between the load angle and the short-circuit angle. Therefore it must be set smaller than the line angle $\phi_L = \arctan(X_L/R_L)$ (approx. 10° to 20°). Subsequently, you should check that the angle is not exceeded during load conditions. If this is the case, for instance because the reactive power has to be transferred via this line, it must be ensured that the parameters of the voltage-dependent segment d, that is **Iphi>** and **Uph-e (Iphi>)** or **Uph-ph (Iphi>)** rule out a pickup as the result of reactive power (see above).

The upper threshold angle $\phi<$ (address 1921) is not critical. 100° to 120° should be sufficient in all cases.

Angular dependence, i.e. increasing the sensitivity for a large short-circuit angle with section d and e in the characteristic, can be limited to the forward direction (line direction) using address 1919 **EFFECT ϕ** . In this case, **EFFECT ϕ** is set to **Forward**. Otherwise **EFFECT ϕ** = **forward&reverse**. This setting is only possible via DIGSI® at "Additional Settings".

2.5.1.5 Settings

Addresses which have an appended "A" can only be changed with DIGSI, under Additional Settings.

The table indicates region-specific presettings. Column C (configuration) indicates the corresponding secondary nominal current of the current transformer.

Addr.	Parameter	C	Setting Options	Default Setting	Comments
1218	T3I0 1PHAS		0.00 .. 0.50 sec; ∞	0.04 sec	Delay 1ph-faults (comp/isol. star-point)
1501	FCT Distance		ON OFF	ON	Distance protection
1502	Minimum Iph>	1A	0.05 .. 4.00 A	0.10 A	Phase Current threshold for dist. meas.
		5A	0.25 .. 20.00 A	0.50 A	
1503	3I0> Threshold	1A	0.05 .. 4.00 A	0.10 A	3I0 threshold for neutral current pickup
		5A	0.25 .. 20.00 A	0.50 A	
1504	3U0> Threshold		1 .. 100 V; ∞	5 V	3U0 threshold zero seq. voltage pickup
1505	3U0> COMP/ISOL.		10 .. 200 V	40 V	3U0> pickup (comp/ isol. star-point)
1507A	3I0>/ Iphmax		0.05 .. 0.30	0.10	3I0>-pickup-stabilisation (3I0> /Iphmax)
1508	SER-COMP.		NO YES	NO	Series compensated line

Addr.	Parameter	C	Setting Options	Default Setting	Comments
1509A	E/F recognition		3I0> OR 3U0> 3I0> AND 3U0>	3I0> OR 3U0>	criterion for earth fault recognition
1510	Start Timers		on Dis. Pickup on Zone Pickup	on Dis. Pickup	Condition for zone timer start
1515	Paral.Line Comp		NO YES	YES	Mutual coupling parall.line compensation.
1520	PHASE PREF.2phe		L3 (L1) ACYCLIC L1 (L3) ACYCLIC L2 (L1) ACYCLIC L1 (L2) ACYCLIC L3 (L2) ACYCLIC L2 (L3) ACYCLIC L3 (L1) CYCLIC L1 (L3) CYCLIC All loops	L3 (L1) ACYCLIC	Phase preference for 2ph-e faults
1521A	2Ph-E faults		Block leading Ø Block lagging Ø All loops Ø-Ø loops only Ø-E loops only	Block leading Ø	Loop selection with 2Ph-E faults
1532	SOTF zone		PICKUP Zone Z1B Inactive Z1B undirect.	Inactive	Instantaneous trip after SwitchOnToFault
1533	Z1 blkd by diff		YES NO	YES	Zone Z1 blocked by diff. active
1540	Distance Angle		30 .. 90 °	85 °	Angle of inclination, distance charact.
1541	R load (Ø-E)	1A	0.100 .. 600.000 Ω; ∞	∞ Ω	R load, minimum Load Impedance (ph-e)
		5A	0.020 .. 120.000 Ω; ∞	∞ Ω	
1542	φ load (Ø-E)		20 .. 60 °	45 °	PHI load, maximum Load Angle (ph-e)
1543	R load (Ø-Ø)	1A	0.100 .. 600.000 Ω; ∞	∞ Ω	R load, minimum Load Impedance (ph-ph)
		5A	0.020 .. 120.000 Ω; ∞	∞ Ω	
1544	φ load (Ø-Ø)		20 .. 60 °	45 °	PHI load, maximum Load Angle (ph-ph)
1605	T1-1phase		0.00 .. 30.00 sec; ∞	0.00 sec	T1-1phase, delay for single phase faults
1606	T1-multi-phase		0.00 .. 30.00 sec; ∞	0.00 sec	T1multi-ph, delay for multi phase faults
1615	T2-1phase		0.00 .. 30.00 sec; ∞	0.30 sec	T2-1phase, delay for single phase faults
1616	T2-multi-phase		0.00 .. 30.00 sec; ∞	0.30 sec	T2multi-ph, delay for multi phase faults
1617A	Trip 1pole Z2		NO YES	NO	Single pole trip for faults in Z2
1625	T3 DELAY		0.00 .. 30.00 sec; ∞	0.60 sec	T3 delay
1635	T4 DELAY		0.00 .. 30.00 sec; ∞	0.90 sec	T4 delay

Addr.	Parameter	C	Setting Options	Default Setting	Comments
1645	T5 DELAY		0.00 .. 30.00 sec; ∞	0.90 sec	T5 delay
1655	T1B-1phase		0.00 .. 30.00 sec; ∞	0.00 sec	T1B-1phase, delay for single ph. faults
1656	T1B-multi-phase		0.00 .. 30.00 sec; ∞	0.00 sec	T1B-multi-ph, delay for multi ph. faults
1657	1st AR -> Z1B		NO YES	YES	Z1B enabled before 1st AR (int. or ext.)
1901	PROGAM U/I		LE:Uphe/LL:Uphp LE:Uphp/LL:Uphp LE:Uphe/LL:Uphe LE:Uphe/LL:I>>	LE:Uphe/LL:Uphp	Pickup program U/I
1902	DELAY FORW. PU		0.00 .. 30.00 sec; ∞	1.20 sec	Trip delay for Forward-PICKUP
1903	DEL. NON-DIR PU		0.00 .. 30.00 sec; ∞	1.20 sec	Trip delay for non-directional PICKUP
1910	Iph>>	1A	0.25 .. 10.00 A	1.80 A	Iph>> Pickup (overcurrent)
		5A	1.25 .. 50.00 A	9.00 A	
1911	Iph>	1A	0.10 .. 4.00 A	0.20 A	Iph> Pickup (minimum current)
		5A	0.50 .. 20.00 A	1.00 A	
1912	Uph-e (I>>)		20 .. 70 V	48 V	Undervoltage (ph-e) at Iph>>
1913	Uph-e (I>)		20 .. 70 V	48 V	Undervoltage (ph-e) at Iph>
1914	Uph-ph (I>>)		40 .. 130 V	80 V	Undervoltage (ph-ph) at Iph>>
1915	Uph-ph (I>)		40 .. 130 V	80 V	Undervoltage (ph-ph) at Iph>
1916	Iphi>	1A	0.10 .. 8.00 A	0.50 A	Iphi> Pickup (minimum current at phi>)
		5A	0.50 .. 40.00 A	2.50 A	
1917	Uph-e (Iphi>)		20 .. 70 V	48 V	Undervoltage (ph-e) at Iphi>
1918	Uph-ph (Iphi>)		40 .. 130 V	80 V	Undervoltage (ph-ph) at Iphi>
1919A	EFFECT φ		forward&reverse Forward	forward&reverse	Effective direction of phi-pickup
1920	$\varphi>$		30 .. 60 °	50 °	PHI> pickup (lower set-point)
1921	$\varphi<$		90 .. 120 °	110 °	PHI< pickup (upper set-point)
1930A	1ph FAULTS		PHASE-EARTH PHASE-PHASEONLY	PHASE-EARTH	1ph-pickup loop selection (PU w/o earth)

2.5.1.6 Information List

No.	Information	Type of Information	Comments
3603	>BLOCK Z1 Dist.	SP	>BLOCK Z1 Distance
3610	>BLOCK Z1-Trip	SP	>BLOCK Z1-Trip
3611	>ENABLE Z1B	SP	>ENABLE Z1B (with setted Time Delay)
3613	>ENABLE Z1Binst	SP	>ENABLE Z1B instantaneous (w/o T-Delay)
3617	>BLOCK Z4-Trip	SP	>BLOCK Z4-Trip
3618	>BLOCK Z5-Trip	SP	>BLOCK Z5-Trip
3619	>BLOCK Z4 Ph-E	SP	>BLOCK Z4 for ph-e loops
3620	>BLOCK Z5 Ph-E	SP	>BLOCK Z5 for ph-e loops
3651	Dist. OFF	OUT	Distance is switched off
3652	Dist. BLOCK	OUT	Distance is BLOCKED
3653	Dist. ACTIVE	OUT	Distance is ACTIVE
3654	Dis.ErrorK0(Z1)	OUT	Setting error K0(Z1) or Angle K0(Z1)
3655	DisErrorK0(>Z1)	OUT	Setting error K0(>Z1) or Angle K0(>Z1)
3671	Dis. PICKUP	OUT	Distance PICKED UP
3672	Dis.Pickup L1	OUT	Distance PICKUP L1
3673	Dis.Pickup L2	OUT	Distance PICKUP L2
3674	Dis.Pickup L3	OUT	Distance PICKUP L3
3675	Dis.Pickup E	OUT	Distance PICKUP Earth
3681	Dis.Pickup 1pL1	OUT	Distance Pickup Phase L1 (only)
3682	Dis.Pickup L1E	OUT	Distance Pickup L1E
3683	Dis.Pickup 1pL2	OUT	Distance Pickup Phase L2 (only)
3684	Dis.Pickup L2E	OUT	Distance Pickup L2E
3685	Dis.Pickup L12	OUT	Distance Pickup L12
3686	Dis.Pickup L12E	OUT	Distance Pickup L12E
3687	Dis.Pickup 1pL3	OUT	Distance Pickup Phase L3 (only)
3688	Dis.Pickup L3E	OUT	Distance Pickup L3E
3689	Dis.Pickup L31	OUT	Distance Pickup L31
3690	Dis.Pickup L31E	OUT	Distance Pickup L31E
3691	Dis.Pickup L23	OUT	Distance Pickup L23
3692	Dis.Pickup L23E	OUT	Distance Pickup L23E
3693	Dis.Pickup L123	OUT	Distance Pickup L123
3694	Dis.Pickup123E	OUT	Distance Pickup123E
3695	Dis Pickup ϕ L1	OUT	Dist.: Phi phase L1 Pickup
3696	Dis Pickup ϕ L2	OUT	Dist.: Phi phase L2 Pickup
3697	Dis Pickup ϕ L3	OUT	Dist.: Phi phase L3 Pickup
3701	Dis.Loop L1-E f	OUT	Distance Loop L1E selected forward
3702	Dis.Loop L2-E f	OUT	Distance Loop L2E selected forward
3703	Dis.Loop L3-E f	OUT	Distance Loop L3E selected forward
3704	Dis.Loop L1-2 f	OUT	Distance Loop L12 selected forward
3705	Dis.Loop L2-3 f	OUT	Distance Loop L23 selected forward
3706	Dis.Loop L3-1 f	OUT	Distance Loop L31 selected forward
3707	Dis.Loop L1-E r	OUT	Distance Loop L1E selected reverse
3708	Dis.Loop L2-E r	OUT	Distance Loop L2E selected reverse
3709	Dis.Loop L3-E r	OUT	Distance Loop L3E selected reverse

No.	Information	Type of Information	Comments
3710	Dis. Loop L1-2 r	OUT	Distance Loop L12 selected reverse
3711	Dis. Loop L2-3 r	OUT	Distance Loop L23 selected reverse
3712	Dis. Loop L3-1 r	OUT	Distance Loop L31 selected reverse
3713	Dis. Loop L1E<->	OUT	Distance Loop L1E selected non-direct.
3714	Dis. Loop L2E<->	OUT	Distance Loop L2E selected non-direct.
3715	Dis. Loop L3E<->	OUT	Distance Loop L3E selected non-direct.
3716	Dis. Loop L12<->	OUT	Distance Loop L12 selected non-direct.
3717	Dis. Loop L23<->	OUT	Distance Loop L23 selected non-direct.
3718	Dis. Loop L31<->	OUT	Distance Loop L31 selected non-direct.
3719	Dis. forward	OUT	Distance Pickup FORWARD
3720	Dis. reverse	OUT	Distance Pickup REVERSE
3741	Dis. Z1 L1E	OUT	Distance Pickup Z1, Loop L1E
3742	Dis. Z1 L2E	OUT	Distance Pickup Z1, Loop L2E
3743	Dis. Z1 L3E	OUT	Distance Pickup Z1, Loop L3E
3744	Dis. Z1 L12	OUT	Distance Pickup Z1, Loop L12
3745	Dis. Z1 L23	OUT	Distance Pickup Z1, Loop L23
3746	Dis. Z1 L31	OUT	Distance Pickup Z1, Loop L31
3747	Dis. Z1B L1E	OUT	Distance Pickup Z1B, Loop L1E
3748	Dis. Z1B L2E	OUT	Distance Pickup Z1B, Loop L2E
3749	Dis. Z1B L3E	OUT	Distance Pickup Z1B, Loop L3E
3750	Dis. Z1B L12	OUT	Distance Pickup Z1B, Loop L12
3751	Dis. Z1B L23	OUT	Distance Pickup Z1B, Loop L23
3752	Dis. Z1B L31	OUT	Distance Pickup Z1B, Loop L31
3755	Dis. Pickup Z2	OUT	Distance Pickup Z2
3758	Dis. Pickup Z3	OUT	Distance Pickup Z3
3759	Dis. Pickup Z4	OUT	Distance Pickup Z4
3760	Dis. Pickup Z5	OUT	Distance Pickup Z5
3771	Dis. Time Out T1	OUT	DistanceTime Out T1
3774	Dis. Time Out T2	OUT	DistanceTime Out T2
3777	Dis. Time Out T3	OUT	DistanceTime Out T3
3778	Dis. Time Out T4	OUT	DistanceTime Out T4
3779	Dis. Time Out T5	OUT	DistanceTime Out T5
3780	Dis. TimeOut T1B	OUT	DistanceTime Out T1B
3781	Dis. TimeOut Tfw	OUT	DistanceTime Out Forward PICKUP
3782	Dis. TimeOut Tnd	OUT	DistanceTime Out Non-directional PICKUP
3801	Dis. Gen. Trip	OUT	Distance protection: General trip
3802	Dis. Trip 1pL1	OUT	Distance TRIP command - Only Phase L1
3803	Dis. Trip 1pL2	OUT	Distance TRIP command - Only Phase L2
3804	Dis. Trip 1pL3	OUT	Distance TRIP command - Only Phase L3
3805	Dis. Trip 3p	OUT	Distance TRIP command Phases L123
3811	Dis. TripZ1/1p	OUT	Distance TRIP single-phase Z1
3813	Dis. TripZ1B1p	OUT	Distance TRIP single-phase Z1B
3816	Dis. TripZ2/1p	OUT	Distance TRIP single-phase Z2
3817	Dis. TripZ2/3p	OUT	Distance TRIP 3phase in Z2
3818	Dis. TripZ3/T3	OUT	Distance TRIP 3phase in Z3
3819	Dis. Trip FD->	OUT	Dist.: Trip by fault detection, forward

No.	Information	Type of Information	Comments
3820	Dis.Trip <->	OUT	Dist.: Trip by fault detec, rev/non-dir.
3821	Dis.TRIP 3p. Z4	OUT	Distance TRIP 3phase in Z4
3822	Dis.TRIP 3p. Z5	OUT	Distance TRIP 3phase in Z5
3823	DisTRIP3p. Z1sf	OUT	DisTRIP 3phase in Z1 with single-ph Flt.
3824	DisTRIP3p. Z1mf	OUT	DisTRIP 3phase in Z1 with multi-ph Flt.
3825	DisTRIP3p.Z1Bsf	OUT	DisTRIP 3phase in Z1B with single-ph Flt
3826	DisTRIP3p Z1Bmf	OUT	DisTRIP 3phase in Z1B with multi-ph Flt.
3850	DisTRIP Z1B Tel	OUT	DisTRIP Z1B with Teleprotection scheme

2.5.2 Distance Protection with Quadrilateral Characteristic (optional)

A tripping characteristic in the shape of a polygon is defined for each of the distance zones.

2.5.2.1 Method of Operation

Operating Polygons

In total there are five independent and one additional controlled zone for each fault impedance loop. Figure 2-41 shows the shape of the polygons as example. The first zone is shaded and forward directional. The third zone is reverse directional.

In general, the polygon is defined by means of a parallelogram which intersects the axes with the values R and X as well as the tilt φ_{Dist} . A load trapezoid with the setting R_{Load} and φ_{Load} may be used to cut the area of the load impedance out of the polygon. The axial coordinates can be set individually for each zone; φ_{Dist} , R_{Load} and φ_{Load} are common for all zones. The parallelogram is symmetrical with respect to the origin of the R - X -coordinate system; the directional characteristic however limits the tripping range to the desired quadrants (refer to „Determination of Direction“ below).

The R -reach may be set separately for the phase-phase faults and the phase-earth faults to achieve a larger fault resistance coverage for earth faults if this is desired.

For the first zone Z1 an additional settable tilt α exists, which may be used to prevent overreach resulting from angle variance and/or two ended infeed to short-circuits with fault resistance. For Z1B and the higher zones this tilt does not exist.




Figure 2-41 Polygonal characteristic (setting values are marked by dots)

Determination of Direction

For each loop an impedance vector is also used to determine the direction of the short-circuit. Usually similar to the distance calculation, $\underline{Z}_L$ is used. However, depending on the „quality“ of the measured values, different computation techniques are used. Immediately after fault inception, the short-circuit voltage is disturbed by transients. The voltage memorized prior to fault inception is therefore used in this situation. If the steady-state short-circuit voltage (during a close-in fault) is even too small for direction determination, an unfaulted voltage is used. This voltage is in theory quadrilateral to the actual short-circuit voltage for both phase-earth loops as well as for phase-phase loops (refer to Figure 2-42). This is taken into account when computing the direction vector by means of a 90° rotation. In Table 2-11 the allocation of the measured values to the six fault loops for the determination of the fault direction is shown.




Figure 2-42 Direction determination with quadrature voltages

Table 2-11 Voltage and current values for the determination of fault direction

Loop	Measuring Current (Direction)	Actual short-circuit voltage	Quadrature voltage
L1-E	$\underline{I}_{L1}$	$\underline{U}_{L1-E}$	$\underline{U}_{L2} - \underline{U}_{L3}$
L2-E	$\underline{I}_{L2}$	$\underline{U}_{L2-E}$	$\underline{U}_{L3} - \underline{U}_{L1}$
L3-E	$\underline{I}_{L3}$	$\underline{U}_{L3-E}$	$\underline{U}_{L1} - \underline{U}_{L2}$
L1-E ¹⁾	$\underline{I}_{L1} - k_E \cdot \underline{I}_E^{(1)}$	$\underline{U}_{L1-E}$	$\underline{U}_{L2} - \underline{U}_{L3}$
L2-E ¹⁾	$\underline{I}_{L2} - k_E \cdot \underline{I}_E^{(1)}$	$\underline{U}_{L2-E}$	$\underline{U}_{L3} - \underline{U}_{L1}$
L3-E ¹⁾	$\underline{I}_{L3} - k_E \cdot \underline{I}_E^{(1)}$	$\underline{U}_{L3-E}$	$\underline{U}_{L1} - \underline{U}_{L2}$
L1-L2	$\underline{I}_{L1} - \underline{I}_{L2}$	$\underline{U}_{L1} - \underline{U}_{L2}$	$\underline{U}_{L2-L3} - \underline{U}_{L3-L1}$
L2-L3	$\underline{I}_{L2} - \underline{I}_{L3}$	$\underline{U}_{L2} - \underline{U}_{L3}$	$\underline{U}_{L3-L1} - \underline{U}_{L1-L2}$
L3-L1	$\underline{I}_{L3} - \underline{I}_{L1}$	$\underline{U}_{L3} - \underline{U}_{L1}$	$\underline{U}_{L1-L2} - \underline{U}_{L2-L3}$

¹⁾ $k_E = Z_E / Z_L$; if only one phase-earth loop picks up, the earth current $\underline{I}_E$ is taken into account.

If there is neither a current measured voltage nor a memorized voltage available which is sufficient for measuring the direction, the relay selects the **Forward** direction. In practice this can only occur when the circuit breaker closes onto a de-energized line, and there is a fault on this line (e.g. closing onto an earthed line).

Figure 2-43 shows the theoretical steady-state characteristic. In practice, the position of the directional characteristic when using memorized voltages is dependent on both the source impedance as well as the load transferred across the line prior to fault inception. Accordingly the directional characteristic includes a safety margin with respect to the limits of the first quadrant in the R-X diagram (Figure 2-43).




Figure 2-43 Directional characteristic in the R-X-diagram

Since each zone can be set to **Forward**, **Reverse** or **Non-Directional**, different (centrically mirrored) directional characteristics are available for **Forward** and **Reverse**. A non-directional zone has no directional characteristic. The entire tripping region applies here.

Characteristics of the Directional Measurement

The theoretical steady-state directional characteristic shown in Figure 2-43 applies to faulted loop voltages. In the case of quadrature voltages or memorized voltage, the position of the directional characteristic is dependent on both the source impedance as well as the load transferred across the line prior to fault inception.

Figure 2-44 shows the directional characteristic using quadrature or memorized voltage as well as taking the source impedance into account (no load transfer). As these voltages are equal to the corresponding generator voltage $\underline{E}$ and they do not change after fault inception, the directional characteristic is shifted in the impedance diagram by the source impedance $\underline{Z}_{S1} = \underline{E}_1 / \underline{I}_1$. For the fault location F_1 (Figure 2-44a) the short-circuit location is in the forward direction and the source impedance is in the reverse direction. For all fault locations, right up to the device location (current transformers), a definite **Forward** decision is made (Figure 2-44b). If the current direction is reversed, the position of the directional characteristic changes abruptly (Figure 2-44c). A reversed current $\underline{I}_2$ now flows via the measuring location (current transformer) which is determined by the source impedance $\underline{Z}_{S2} + \underline{Z}_L$. When load is transferred across the line, the directional characteristic may additionally be rotated by the load angle.




Figure 2-44 Directional characteristic with quadrature or memorized voltages

Determination of Direction in Case of Series-compensated Lines

The directional characteristics and their displacement by the source impedance apply also for lines with series capacitors. If a short-circuit occurs behind the local series capacitors, the short-circuit voltage however reverses its direction until the protective spark gap has picked up (see Figure 2-45).




Figure 2-45 Voltage characteristic while a fault occurs after a series capacitor.

- a) without pickup of the protective spark gap
- b) with pickup of the protective spark gap

The distance protection function would thus detect a wrong fault direction. The use of memorized voltages however ensures that the direction is correctly detected (see Figure 2-46a).

Since the voltage prior to the fault is used for determining the direction, the zeniths of the directional characteristics in dependence of the source impedance and infeed conditions before the fault are thus far displaced that the capacitor reactance — which is

always smaller than the series reactance — does not cause the apparent direction reversal (Figure 2-46b).

If the short-circuit is located before the capacitor, from the relay location (current transformer) in reverse direction, the zeniths of the directional characteristics are shifted to the other direction (Figure 2-46c). A correct determination of the direction is thus also ensured in this case.




Figure 2-46 Determination of direction in case of series-compensated lines

Pickup and Assignment to the Polygons

Using the fault detection modes I, U/I or $U/I/\varphi$, the impedances that were calculated from the valid loops, are assigned, after the pickup, to the zone characteristics set for the distance protection. To avoid unstable signals at the boundaries of a polygon, the characteristics have a hysteresis of approximately 5 %, i.e. as soon as it has been determined that the fault impedance lies within a polygon, the boundaries are increased by 5 % in all directions. The loop information is also converted to phase segregated information.

Using the impedance pickup the calculated loop impedances are also assigned to the zone characteristics set for the distance protection, but without a query of an explicit fault detection scheme. The pickup range of the distance protection is determined from the thresholds of the largest-set polygon taking into consideration the respective direction. Here the loop information is also converted into faulted phase indication.

„Pickup“ signals are generated for each zone and converted into phase information, e.g. „Dis. L1L1“ (internal message) for zone Z1 and phase L1. This means that each phase and each zone is provided with separate pickup information. The information is then processed in the zone logic and by additional functions (e.g. teleprotection logic, Section 2.7). The loop information is also converted to phase segregated information. Further conditions for „pickup“ of a zone are that the direction corresponds to the set direction for the zone, and that the zone is not blocked by the power swing blocking (refer to Section 2.6). Furthermore the distance protection may not be blocked or switched off completely. Figure 2-47 shows these conditions.




Figure 2-47 Release logic for a zone (example for Z1)

In total, the following zones are available:

Independent zones:

- 1st zone (fast tripping zone) Z1 with $X(Z1)$; $R(Z1) \emptyset-\emptyset$, $RE(Z1) \emptyset-E$; delayable with **T1-1phase** or **T1-multi-phase**,
- 2nd zone (backup zone) Z2 with $X(Z2)$; $R(Z2) \emptyset-\emptyset$, $RE(Z2) \emptyset-E$; may be delayed by **T2-1phase** or **T2-multi-phase**,
- 3rd zone (backup zone) Z3 with $X(Z3)$; $R(Z3) \emptyset-\emptyset$, $RE(Z3) \emptyset-E$; may be delayed by **T3 DELAY**,
- 4th zone (backup zone) Z4 with $X(Z4)$; $R(Z4) \emptyset-\emptyset$, $RE(Z4) \emptyset-E$; may be delayed by **T4 DELAY**,
- 5th zone (backup zone) Z5 with $X(Z5)+$ (forward) and $X(Z5)-$ (reverse); $R(Z5) \emptyset-\emptyset$, $RE(Z5) \emptyset-E$, delayable with **T5 DELAY**.

Dependent (controlled) zone:

- Overreaching zone Z1B with $X(Z1B)$; $R(Z1B) \emptyset-\emptyset$, $RE(Z1B) \emptyset-E$; may be delayed by **T1B-1phase** or **T1B-multi-phase**.

2.5.2.2 Setting Notes

Grading Coordination Chart

It is recommended to initially create a grading coordination chart for the entire galvanically interconnected system. This diagram should reflect the line lengths with their primary reactances X in Ω/km . For the reach of the distance zones, the reactances X are the deciding quantity.

The first zone Z1 is usually set to cover 85 % of the protected line without any trip time delay (i.e. $T1 = 0.00 \text{ s}$). The protection clears faults in this range without additional time delay, i.e. the tripping time is the relay basic operating time.

The tripping time of the higher zones is sequentially increased by one time grading interval. The grading margin must take into account the circuit breaker operating time including the spread of this time, the resetting time of the protection equipment as well as the spread of the protection delay timers. Typical values are 0.2 s to 0.4 s. The reach is selected to cover up to approximately 80% of the zone with the same set time delay on the shortest neighbouring feeder.

When using a personal computer and DIGSI® to apply the settings, these can be optionally entered as primary or secondary values.

In the case of parameterization with secondary quantities, the values derived from the grading coordination chart must be converted to the secondary side of the current and voltage transformers. In general:

$$Z_{\text{secondary}} = \frac{\text{Current Transformer Ratio}}{\text{Voltage Transformer Ratio}} \cdot Z_{\text{primary}}$$

Accordingly, the reach for any distance zone can be specified as follows:

$$X_{\text{sec}} = \frac{N_{\text{CT}}}{N_{\text{VT}}} \cdot X_{\text{prim}}$$

where

N_{CT} = Current transformer ratio

N_{VT} = Transformation ratio of voltage transformer

Calculation Example:

110 kV overhead line 150 mm² with the following data:

s (length) = 35 km

R_1/s = 0.19 Ω/km

X_1/s = 0.42 Ω/km

R_0/s = 0.53 Ω/km

X_0/s = 1.19 Ω/km

Current Transformer 600 A/5 A

Voltage transformer 110 kV / 0.1 kV

The following line data is calculated:

$R_L = 0.19 \text{ Ω/km} \cdot 35 \text{ km} = 6.65 \text{ Ω}$

$X_L = 0.42 \text{ Ω/km} \cdot 35 \text{ km} = 14.70 \text{ Ω}$

For the first zone, a setting of 85 % of the line length should be applied, which results in primary:

$$X1_{\text{prim}} = 0.85 \cdot X_L = 0.85 \cdot 14.70 \text{ Ω} = 12.49 \text{ Ω}$$

or secondary:

$$X1_{\text{sec}} = \frac{N_{\text{CT}}}{N_{\text{VT}}} \cdot X1_{\text{prim}} = \frac{600 \text{ A} / 5 \text{ A}}{110 \text{ kV} / 0.1 \text{ kV}} \cdot 12.49 \text{ Ω} = 1.36 \text{ Ω}$$

Resistance Tolerance

The resistance setting R allows a reserve for fault resistance which appears as an additional resistance at the fault location and is added to the impedance of the line conductors. It comprises, for example, the resistance in arcs, the earth distribution resistance of earth points and others. The setting must consider these fault resistances, but should at the same time not be larger than necessary. On long heavily loaded lines, the setting may extend into the load impedance range. Fault detection due to overload conditions is then prevented with the load trapezoid. Refer to margin heading „Load range (only for impedance pickup)“ in Subsection 2.5.1. The resistance tolerance may be separately set for the phase-phase faults on the one hand and the phase-earth faults on the other hand. It is therefore possible to allow for a larger fault resistance for earth faults for example.

Most important for this setting on overhead lines, is the resistance of the fault arc. In cables on the other hand, an appreciable arc can not exist. On very short cables, care must however be taken that an arc fault on the local cable termination is inside the set resistance of the first zone.

The resistance of the line itself does not have to be considered since it is accounted for through the shape of the polygon provided that the line angle is at least as large as the inclination angle **Distance Angle** (address 1540) of the polygon.

Example:

A maximum arc voltage of 8 kV is assumed for phase-phase faults (line data as above). If the minimum primary short-circuit current is assumed to be 1000 A this corresponds to 8 Ω primary. For the resistance setting of the first zone this implies

primary:

$$R1_{\text{prim}} = \frac{1}{2} \cdot R_{\text{Arc}} = \frac{1}{2} \cdot 8 \, \Omega = 4 \, \Omega$$

or secondary:

$$R1_{\text{sec}} = \frac{N_{\text{CT}}}{N_{\text{VT}}} \cdot R1_{\text{prim}} = \frac{600 \, \text{A} / 5 \, \text{A}}{110 \, \text{kV} / 0.1 \, \text{kV}} \cdot 4 \, \Omega = 0.44 \, \Omega$$

Only half the arc resistance was applied in the equation, as it is added to the loop impedance and therefore only half the arc resistance appears in the **per phase** impedance.

A separate resistance tolerance can be set for earth faults. An arc resistance of 6 Ω and a tower footing resistance of 12 Ω is assumed. This results in the following

primary:

$$R1E_{\text{prim}} = R_{\text{arc}} + R_{\text{tower}} = 6 \, \Omega + 12 \, \Omega = 18 \, \Omega$$

or secondary:

$$R1E_{\text{sec}} = \frac{N_{\text{CT}}}{N_{\text{VT}}} \cdot R1_{\text{prim}} = \frac{600 \, \text{A} / 5 \, \text{A}}{110 \, \text{kV} / 0.1 \, \text{kV}} \cdot 18 \, \Omega = 1.96 \, \Omega$$

In this case the least favourable condition was assumed, whereby the earth current does not return via the measuring point. If all the earth current, or a portion of the earth current flows via the measuring point, the measured resistance decreases. When there is an infeed from the remote end, the measured resistance may be increased.

Independent Zones Z1 up to Z5

By means of the parameter **MODE** = **Forward** or **Reverse** or **Non-Directional** each zone can be set (address 1601 **Op. mode Z1**, 1611 **Op. mode Z2**, 1621 **Op. mode Z3**, 1631 **Op. mode Z4** and 1641 **Op. mode Z5**). This allows any combination of graded zones - forward, reverse or non-directional -, for example on transformers, generators or bus couplers. In the fifth zone different reach in the X direction can be set for forward or reverse. Zones that are not required are set **Inactive**.

The values derived from the grading coordination chart are set for each of the required zones. The setting parameters are grouped for each zone. For the first zone these are the parameters **R(Z1) 0-0** (address 1602) for the R intersection of the polygon applicable to phase-phase faults, **X(Z1)** (address 1603) for the X intersection (reach), **RE(Z1) 0-E** (address 1604) for the R intersection applicable to phase-earth faults and delay time settings.

For the first zone, Z1, an additional tilt α can be set by means of the parameter in address 1607 **Zone Reduction**. This setting is required if short-circuits with a large

fault resistance (e.g. overhead lines without earth wire) are expected on lines with an infeed at both ends and load transfer in the direction of the line (export).

Different delay times can be set for single- and multiple-phase faults in the first zone: **T1-1phase** (address 1605) and **T1-multi-phase** (address 1606). The first zone is typically set to operate without additional time delay.

For the remaining zones the following correspondingly applies:

X(Z2) (address 1613), **R(Z2) 0-0** (address 1612), **RE(Z2) 0-E** (address 1614);
X(Z3) (address 1623), **R(Z3) 0-0** (address 1622), **RE(Z3) 0-E** (address 1624);
X(Z4) (address 1633), **R(Z4) 0-0** (address 1632), **RE(Z4) 0-E** (address 1634);
X(Z5)+ (address 1643) for forward direction, **X(Z5)-** (address 1646) for reverse direction, **R(Z5) 0-0** (address 1642), **RE(Z5) 0-E** (address 1644).

For the second zone it is also possible to set separate delay times for single- and multiple-phase faults. In general the delay times are set the same. If stability problems are expected during multiple-phase faults a shorter delay time can be considered for **T2-multi-phase** (address 1616) while a higher setting for single phase faults may be tolerated **T2-1phase** (address 1615).

The zone timers for the remaining zones are set with the parameters **T3 DELAY** (address 1625), **T4 DELAY** (address 1635) and **T5 DELAY** (address 1645).

If the device is provided with the capability to trip single-pole, single-pole tripping is then possible in the zones Z1 and Z2. While single-pole tripping usually applies to single-phase faults in Z1 (if the remaining conditions for single-pole tripping are satisfied), this may also be selected for the second zone with address 1617 **Trip 1pole Z2**. Single pole tripping in zone 2 is only possible if this address is set to **YES**. The default setting is **NO**.

Note

For instantaneous tripping (undelayed) in the forward direction, the first zone **Z1** should always be used, as only the Z1 and Z1B are guaranteed to trip with the shortest operating time of the device. The further zones should be used sequentially for grading in the forward direction.

If instantaneous tripping (undelayed) is required in the reverse direction, the zone **Z3** should be used for this purpose, as only this zone ensures instantaneous pickup with the shortest device operating time for faults in the reverse direction. This setting is also recommended in teleprotection **BLOCKING** schemes.

Blocking of Zone Z1 If the main protection functions - differential protection and distance protection - operate in parallel, the distance protection of Zone Z1 may pick up before the differential protection (e.g. in the case of close-up faults). If this is desired, the distance protection works as a „booster“ stage for fast tripping. If the fast tripping acts on one end of the line only, accelerated tripping of zone Z1 is not desired (see also Section 2.5.1.4).

There are two ways of blocking Z1. If the device operates in differential protection mode, zone Z1 can be blocked by setting a parameter (address 1533 **Z1 blkd by diff**). Another way of blocking the zone is to set a binary input (No. 3610 „>BLOCK Z1-Trip“).

Controlled Zone Z1B

The overreaching zone Z1B is a controlled zone. The normal zones Z1 to Z5 are not influenced by Z1B. There is therefore no zone switching, but rather the overreaching zone is activated or deactivated by the corresponding criteria. In address 1651 **Op. mode Z1B = Forward**, it can also be switched **Reverse** or **Non-Directional**. If this stage is not required, it is set to **Inactive** in address 1651. The setting options are similar to those of zone Z1: address 1652 **R(Z1B) 0-0**, address 1653 **X(Z1B)**, address 1654 **RE(Z1B) 0-E**. The delay times for single-phase and multiple-phase faults can again be set separately: **T1B-1phase** (address 1655) and **T1B-multi-phase** (address 1656). If parameter **Op. mode Z1B** is set to **Forward** or **Reverse**, a non-directional trip is also possible in case of closure onto a fault if parameter 1532 **SOTF zone** is set to **Z1B undirect**. (see also Section 2.5.1.4).

Zone Z1B is usually used in combination with automatic reclosure and/or teleprotection systems. It can be activated internally by the teleprotection functions (see also Section 2.7) or the integrated automatic reclosure (if available, see also Section 2.15), or externally by a binary input. It is generally set to at least 120 % of the line length. On three-terminal line applications („teed feeders“), it must be set to securely reach beyond the longest line section, even when there is additional infeed via the tee point. The delay times are set in accordance with the type of application, usually to zero or a very small delay. When used in conjunction with teleprotection comparison schemes, the dependence on the fault detection must be considered (refer to margin heading „Distance Protection Prerequisites“ in Section 2.7.14).

If the distance protection is used in conjunction with an automatic recloser, it can be determined in address 1657 **1st AR -> Z1B** which distance zones are released prior to a rapid automatic reclosure. Usually the overreaching zone Z1B is used for the first cycle **1st AR -> Z1B = YES**. This may be suppressed by changing the setting of **1st AR -> Z1B** to **NO**. In this case the overreaching zone Z1B is not released before and during the 1st automatic reclose cycle. The zone Z1 is always released, unless it is blocked by a binary input or in differential protection mode. The setting only has an effect when the service condition of the automatic reclose function is input to the device via binary input „>Enable ARzones“ (No. 383).

The zones **Z4** and **Z5** can be blocked using a binary input message 3619 „>BLOCK Z4 Ph-E“ or 3620 „>BLOCK Z5 Ph-E“ for phase-earth loops. To block these zones permanently for phase-earth loops, said binary inputs must be set to the logic value of 1 via CFC.

2.5.2.3 Settings

Addresses which have an appended "A" can only be changed with DIGSI, under Additional Settings.

The table indicates region-specific presettings. Column C (configuration) indicates the corresponding secondary nominal current of the current transformer.

Addr.	Parameter	C	Setting Options	Default Setting	Comments
1601	Op. mode Z1		Forward Reverse Non-Directional Inactive	Forward	Operating mode Z1
1602	R(Z1) 0-0	1A	0.050 .. 600.000 Ω	1.250 Ω	R(Z1), Resistance for ph-ph-faults
		5A	0.010 .. 120.000 Ω	0.250 Ω	
1603	X(Z1)	1A	0.050 .. 600.000 Ω	2.500 Ω	X(Z1), Reactance
		5A	0.010 .. 120.000 Ω	0.500 Ω	

Addr.	Parameter	C	Setting Options	Default Setting	Comments
1604	RE(Z1) Ø-E	1A	0.050 .. 600.000 Ω	2.500 Ω	RE(Z1), Resistance for phase faults
		5A	0.010 .. 120.000 Ω	0.500 Ω	
1605	T1-1phase		0.00 .. 30.00 sec; ∞	0.00 sec	T1-1phase, delay for single phase faults
1606	T1-multi-phase		0.00 .. 30.00 sec; ∞	0.00 sec	T1multi-ph, delay for multi phase faults
1607	Zone Reduction		0 .. 45 °	0 °	Zone Reduction Angle (load compensation)
1611	Op. mode Z2		Forward Reverse Non-Directional Inactive	Forward	Operating mode Z2
1612	R(Z2) Ø-Ø	1A	0.050 .. 600.000 Ω	2.500 Ω	R(Z2), Resistance for phase faults
		5A	0.010 .. 120.000 Ω	0.500 Ω	
1613	X(Z2)	1A	0.050 .. 600.000 Ω	5.000 Ω	X(Z2), Reactance
		5A	0.010 .. 120.000 Ω	1.000 Ω	
1614	RE(Z2) Ø-E	1A	0.050 .. 600.000 Ω	5.000 Ω	RE(Z2), Resistance for phase faults
		5A	0.010 .. 120.000 Ω	1.000 Ω	
1615	T2-1phase		0.00 .. 30.00 sec; ∞	0.30 sec	T2-1phase, delay for single phase faults
1616	T2-multi-phase		0.00 .. 30.00 sec; ∞	0.30 sec	T2multi-ph, delay for multi phase faults
1617A	Trip 1pole Z2		NO YES	NO	Single pole trip for faults in Z2
1621	Op. mode Z3		Forward Reverse Non-Directional Inactive	Reverse	Operating mode Z3
1622	R(Z3) Ø-Ø	1A	0.050 .. 600.000 Ω	5.000 Ω	R(Z3), Resistance for phase faults
		5A	0.010 .. 120.000 Ω	1.000 Ω	
1623	X(Z3)	1A	0.050 .. 600.000 Ω	10.000 Ω	X(Z3), Reactance
		5A	0.010 .. 120.000 Ω	2.000 Ω	
1624	RE(Z3) Ø-E	1A	0.050 .. 600.000 Ω	10.000 Ω	RE(Z3), Resistance for phase faults
		5A	0.010 .. 120.000 Ω	2.000 Ω	
1625	T3 DELAY		0.00 .. 30.00 sec; ∞	0.60 sec	T3 delay
1631	Op. mode Z4		Forward Reverse Non-Directional Inactive	Non-Directional	Operating mode Z4
1632	R(Z4) Ø-Ø	1A	0.050 .. 600.000 Ω	12.000 Ω	R(Z4), Resistance for phase faults
		5A	0.010 .. 120.000 Ω	2.400 Ω	
1633	X(Z4)	1A	0.050 .. 600.000 Ω	12.000 Ω	X(Z4), Reactance
		5A	0.010 .. 120.000 Ω	2.400 Ω	

Addr.	Parameter	C	Setting Options	Default Setting	Comments
1634	RE(Z4) Ø-E	1A	0.050 .. 250.000 Ω	12.000 Ω	RE(Z4), Resistance for ph-e faults
		5A	0.010 .. 50.000 Ω	2.400 Ω	
1635	T4 DELAY		0.00 .. 30.00 sec; ∞	0.90 sec	T4 delay
1641	Op. mode Z5		Forward Reverse Non-Directional Inactive	Inactive	Operating mode Z5
1642	R(Z5) Ø-Ø	1A	0.050 .. 600.000 Ω	12.000 Ω	R(Z5), Resistance for ph-ph-faults
		5A	0.010 .. 120.000 Ω	2.400 Ω	
1643	X(Z5)+	1A	0.050 .. 600.000 Ω	12.000 Ω	X(Z5)+, Reactance for Forward direction
		5A	0.010 .. 120.000 Ω	2.400 Ω	
1644	RE(Z5) Ø-E	1A	0.050 .. 600.000 Ω	12.000 Ω	RE(Z5), Resistance for ph-e faults
		5A	0.010 .. 120.000 Ω	2.400 Ω	
1645	T5 DELAY		0.00 .. 30.00 sec; ∞	0.90 sec	T5 delay
1646	X(Z5)-	1A	0.050 .. 600.000 Ω	4.000 Ω	X(Z5)-, Reactance for Reverse direction
		5A	0.010 .. 120.000 Ω	0.800 Ω	
1651	Op. mode Z1B		Forward Reverse Non-Directional Inactive	Forward	Operating mode Z1B (overreach zone)
1652	R(Z1B) Ø-Ø	1A	0.050 .. 600.000 Ω	1.500 Ω	R(Z1B), Resistance for ph-ph-faults
		5A	0.010 .. 120.000 Ω	0.300 Ω	
1653	X(Z1B)	1A	0.050 .. 600.000 Ω	3.000 Ω	X(Z1B), Reactance
		5A	0.010 .. 120.000 Ω	0.600 Ω	
1654	RE(Z1B) Ø-E	1A	0.050 .. 600.000 Ω	3.000 Ω	RE(Z1B), Resistance for ph-e faults
		5A	0.010 .. 120.000 Ω	0.600 Ω	
1655	T1B-1phase		0.00 .. 30.00 sec; ∞	0.00 sec	T1B-1phase, delay for single ph. faults
1656	T1B-multi-phase		0.00 .. 30.00 sec; ∞	0.00 sec	T1B-multi-ph, delay for multi ph. faults
1657	1st AR -> Z1B		NO YES	YES	Z1B enabled before 1st AR (int. or ext.)

2.5.3 Distance Protection with MHO Characteristic (optional)

Depending on the version ordered, the universal line protection 7SD5 can be equipped with an MHO characteristic in combination with the distance protection function. If both the polygonal and the MHO characteristic are available, they may be selected separately for phase-phase loops and phase-earth loops. The polygonal tripping characteristic is described in Section 2.5.2.

2.5.3.1 Functional Description

Basic Characteristic

One MHO characteristic is defined for each distance zone, which represents the tripping characteristic of the corresponding zone. In total there are five independent and one additional controlled zone for each fault impedance loop. The basic shape of a MHO characteristic for one zone is shown in Figure 2-48 as an example.

The MHO characteristic is defined by the line of its diameter which intersects the origin of the coordinate system and the magnitude of the diameter which corresponds to the impedance Z_r which determines the reach, and by the angle of inclination. The angle of inclination is set in address 1540 **Distance Angle** and corresponds normally to the line angle φ_{Line} . A load trapezoid with the setting R_{Load} and φ_{Load} may be used to cut the area of the load impedance out of the characteristic. The reach Z_r may be separately set for each zone; the inclination angle φ_{Dist} as well as the load impedance parameters R_{Load} and φ_{Load} are common to all zones. As the characteristic intersects the origin of the coordinate system, a separate directional characteristic is not required.




Figure 2-48 Basic shape of an MHO characteristic

Polarized MHO Characteristic

As is the case with all characteristics that pass through the origin of the coordinate system, the MHO characteristic boundary around the origin itself is also not defined as the measured voltage is zero or too small to be evaluated in this case. For this reason, the MHO characteristic is polarized. The polarization determines the lower zenith of the circle, i.e. the lower intersection of the diameter line with the circle. The upper zenith which is determined by the reach setting Z_r remains unchanged. Immediately after fault inception, the short-circuit voltage is disturbed by transients; the voltage memorized prior to fault inception is therefore used for polarization. This causes a displacement of the lower zenith by an impedance corresponding to the memorized voltage (refer to Figure 2-49). When the memorized short-circuit voltage is too small, an unfaulted voltage is used. In theory this voltage is perpendicular to the voltage of the faulted loop for both phase-earth loops as well as phase-phase loops. This is taken into account by the calculation by means of a 90° rotation. The unfaulted loop voltages also cause a displacement of the lower zenith of the MHO characteristic.




Figure 2-49 Polarized MHO characteristic

Properties of the MHO Characteristic

As the quadrature or memorized voltage (without load transfer) equals the corresponding generator voltage $\underline{E}$ and does not change after fault inception (refer also to Figure 2-50), the lower zenith is shifted in the impedance diagram by the polarizing quantity $k \cdot \underline{Z}_{V1} = k \cdot \underline{E}_1 / \underline{I}_1$. The upper zenith is still defined by the setting value $\underline{Z}_r$. For the fault location F_1 (Figure 2-50a) the short-circuit location is in the forward direction and the source impedance is in the reverse direction. All fault locations, right up to the device mounting location (current transformers) are clearly inside the MHO characteristic (Figure 2-50b). If the current is reversed, the zenith of the circle diameter changes abruptly (Figure 2-50c). A reversed current $\underline{I}_2$ now flows via the measuring location (current transformer) which is determined by the source impedance $\underline{Z}_{S2} + \underline{Z}_L$. The zenith $\underline{Z}_r$ remains unchanged; it now is the lower boundary of the circle diameter. In conjunction with load transport via the line, the zenith vector may additionally be rotated by the load angle.




Figure 2-50 Polarized MHO characteristic with quadrature or memorized voltages

Selecting Polarization

Incorrect directional decisions may be reached with short lines resulting in tripping or blocking in spite of a reverse fault. This occurs because their zone reach is set very small. Therefore their loop voltages are also very small, resulting in the phase angle comparison between difference voltage and loop voltage being insufficiently accurate. If phase angle comparison is performed using a polarization voltage consisting of a loop voltage component recorded before the fault and a component of the current loop voltage, these problems may be avoided. The following equation shows the polarization voltage $\underline{U}_P$ for a Ph-E loop:

$$\underline{U}_P = (1 - k_{Pre}) \cdot \underline{U}_{L-E} + k_{Pre} \cdot \underline{U}_{Ph-E \text{ Memorized}}$$

The evaluation (factor k_{Pre}) of the prefault voltage may be set separately for Ph-E and Ph-Ph loops. In general the factor is set to 15 %. The memory polarization is only performed if the RMS value of the corresponding memorized voltage for Ph-E loops is greater than a 40 % of the nominal voltage U_N (address 204) and greater than a 70 % of U_N for Ph-Ph loops.

If there is no prefault voltage due to a sequential fault or energization onto a fault, the memorized voltage can only be used for a limited time. For single-pole faults and two-pole faults without earth path component a voltage which is not involved in the fault may be used for polarization. This voltage is rotated by 90° in comparison with the fault-accurate voltage (cross polarization). The polarization voltage $\underline{U}_P$ is a mixed voltage which consists of the valid voltage and the corresponding unfaulted voltages. The following equation shows the polarization voltage $\underline{U}_P$ for a Ph-E loop:

$$\underline{U}_P = (1 - k_{Cross}) \cdot \underline{U}_{L-E} + k_{Cross} \cdot \underline{U}_{L-E \text{ Unfaulted}}$$

The cross polarization is used if there is no memorized voltage available. The evaluation (factor k_{Cross}) of the voltage may be set separately for Ph-E and Ph-Ph loops. In general the factor is set to 15 %.

**Note**

When switching onto a three-pole fault with the MHO characteristic, there will be no voltage in the memory or unfaulted loop voltage available. To ensure fault clearance when switching onto three-pole close-up faults, please make sure that in conjunction with the configured MHO characteristic the instantaneous tripping function is always enabled.

**Determination of
Direction in Case of
Series-compensat-
ed Lines**

The displacement of the characteristics by the source impedance applies also for lines with series capacitors. If a short-circuit occurs behind the local series capacitors, the short-circuit voltage however reverses its direction until the protective spark gap has picked up (see Figure 2-51).




Figure 2-51 Voltage characteristic for a short-circuit after a series capacitor

- a) without pickup of the protective spark gap
- b) with pickup of the protective spark gap

The distance protection function would thus detect a wrong fault direction. However, even in this case pickup of the correct directional MHO characteristic is ensured by mixing in stored voltages (see Figure 2-52 a).

Since the voltage prior to the fault is mixed with the current voltage, the zeniths of the MHO characteristic dependent on the source impedance and infeed conditions before the fault are thus far displaced that the capacitor reactance — which is always smaller than the series reactance — does not cause the apparent direction reversal (Figure 2-52 b).

If the short-circuit is located before the capacitor, from the relay location (current transformer) in reverse direction, the zeniths of the MHO characteristic are shifted to the other direction (Figure 2-52c). A correct determination of the direction is thus also ensured in this case.




Figure 2-52 Polarized MHO characteristic for series-compensated lines

Assignment to Tripping Zones and Zone Pickup

The assignment of measured values to the tripping zones of the MHO characteristic is done for each zone by determining the angles between two differential phasors ΔZ_1 and ΔZ_2 (Figure 2-53). These phasors result from the difference between the two zeniths of the circle diameter and the fault impedance. The zenith Z_r corresponds to the set value for the zone under consideration (Z_r and ϕ_{MHO} as shown in Figure 2-48), the zenith kZ_v corresponds to the polarizing magnitude. Therefore the difference phasors are

$$\Delta Z_1 = Z_F - Z_r$$

$$\Delta Z_2 = Z_F - k \cdot Z_s$$

In the limiting case, Z_F is located on the perimeter of the circle. In this case the angle between the two difference phasors is 90° (Thales-theorem). Inside the characteristic the angle is greater than 90° and outside the circle it is less than 90° .




Figure 2-53 Phasor diagram of the MHO characteristic measured values

For each distance zone an MHO characteristic can be defined by means of the parameter Z_r . For each zone it may also be determined whether it operates **forwards** or **reverse**. In reverse direction the MHO characteristic is mirrored in the origin of the coordinate system. As soon as the fault impedance of any loop is confidently measured inside the MHO characteristic of a distance zone, the affected loop is designated as „picked up“. The loop information is also converted to phase segregated information. Further conditions for the pickup of a zone is that the zone may not be blocked by the power swing blocking. Furthermore the distance protection may not be blocked or switched off completely. Figure 2-54 shows these conditions.

The zones and phases of such a valid pickup, e.g. „Dis. Z1 L1“ for zone Z1 and phase L1 are processed by the zone logic and the supplementary functions (e.g. teleprotection logic).




Figure 2-54 Release logic of a zone (example for Z1)

*) **forward** and **reverse** affect only the measured values, not the logic

In total, the following zones are available:

Independent zones:

- 1st zone (fast tripping zone) Z1 with **ZR(Z1)**; may be delayed by **T1 - 1phase** and **T1-multi-phase**,
- 2nd zone (backup zone) Z2 with **ZR(Z2)**; may be delayed by **T2 - 1phase** and **T2-multi-phase**,
- 3rd zone (backup zone) Z3 with **ZR(Z3)**; may be delayed by **T3 DELAY**,
- 4th zone (backup zone) Z4 with **ZR(Z4)**; may be delayed by **T4 DELAY**,
- 5th zone (backup zone) Z5 with **ZR(Z5)**; may be delayed by **T5 DELAY**.

Dependent (controlled) zone:

- Overreaching zone Z1B with **ZR(Z1B)**; may be delayed by **T1B - 1phase** and / or **T1B-multi-phase**.

2.5.3.2 Setting Notes

General

The function parameters for the MHO characteristic only apply if during the configuration of the scope of functions the MHO characteristic was selected for phase-phase measurement (address 115) and/or phase-earth measurement (address 116).

Grading Coordination Chart

It is recommended to initially create a grading coordination chart for the entire galvanically interconnected system. This diagram should reflect the line lengths with their primary impedances Z in Ω/km . For the reach of the distance zones, the impedances Z are the deciding quantities.

The first zone Z1 is usually set to cover 85 % of the protected line without any trip time delay (i.e. $T1 = 0.00 \text{ s}$). The protection clears faults in this range without additional time delay, i.e. the tripping time is the relay basic operating time.

The tripping time of the higher zones is sequentially increased by one time grading interval. The grading margin must take into account the circuit breaker operating time including the spread of this time, the resetting time of the protection equipment as well as the spread of the protection delay timers. Typical values are 0.2 s to 0.4 s. The reach is selected to cover up to approximately 80 % of the zone with the same set time delay on the shortest neighbouring feeder.

When using a personal computer and DIGSI® to apply the settings, these can be optionally entered as primary or secondary values.

In the case of parameterization with secondary quantities, the values derived from the grading coordination chart must be converted to the secondary side of the current and voltage transformers. In general:

$$Z_{\text{secondary}} = \frac{\text{Current Transformer Ratio}}{\text{Voltage Transformer Ratio}} \cdot Z_{\text{primary}}$$

Accordingly, the reach for any distance zone can be specified as follows:

$$Z_{\text{sec}} = \frac{N_{\text{CT}}}{N_{\text{VT}}} \cdot Z_{\text{prim}}$$

with

N_{CT} = Current transformer ratio

N_{VT} = Transformation ratio of voltage transformer

On long, heavily loaded lines, the MHO characteristic may extend into the load impedance range. This is of no consequence as the pickup by overload is prevented by the load trapezoid. Refer to margin heading „Load Area“ in Section 2.5.1.

Calculation Example:

110 kV overhead line 150 mm² with the following data:

s (length) = 35 km

R_1/s = 0.19 Ω/km

X_1/s = 0.42 Ω/km

R_0/s = 0.53 Ω/km

X_0/s = 1.19 Ω/km

Current Transformer 600 A / 5 A

Voltage Transformer 110 kV / 0.1 kV

The following line data is calculated:

$R_L = 0.19 \text{ Ω/km} \cdot 35 \text{ km} = 6.65 \text{ Ω}$

$X_L = 0.42 \text{ Ω/km} \cdot 35 \text{ km} = 14.70 \text{ Ω}$

For the first zone, a setting of 85 % of the line length should be applied, which results in primary:

$X1_{\text{prim}} = 0.85 \cdot X_L = 0.85 \cdot 14.70 \text{ Ω} = 12.49 \text{ Ω}$

or secondary:

$$X1_{\text{sec}} = \frac{N_{\text{CT}}}{N_{\text{VT}}} \cdot X1_{\text{prim}} = \frac{600 \text{ A} / 5 \text{ A}}{110 \text{ kV} / 0.1 \text{ kV}} \cdot 12.49 \text{ Ω} = 1.36 \text{ Ω}$$

Independent Zones Z1 up to Z5

Each zone can be set using the parameter MODE **Forward** or **Reverse** (address 1701 **Op. mode Z1**, 1711 **Op. mode Z2**, 1721 **Op. mode Z3**, 1731 **Op. mode Z4** and 1741 **Op. mode Z5**). This allows any combination of forward or reverse graded zones. Zones that are not required, are set **Inactive**.

The values derived from the grading coordination chart are set for each of the required zones. The setting parameters are grouped for each zone. For the first zone these are

the parameters **ZR(Z1)** (address 1702) specifying the impedance of the upper zenith of the MHO characteristic from the origin (reach), as well as the relevant delay time settings.

For the first zone the delay times for single-phase and multiple-phase faults can be set separately: **T1-1phase** (address 1605) and **T1-multi-phase** (address 1606). The first zone is typically set to operate without additional time delay.

For the remaining zones the following correspondingly applies:

ZR(Z2) (address 1712);

ZR(Z3) (address 1722);

ZR(Z4) (address 1732);

ZR(Z5) (address 1742);

For the second zone it is also possible to set separate delay times for single- and multi-phase faults. In general the delay times are set the same. If stability problems are expected during multiple-phase faults a shorter delay time can be considered for **T2-multi-phase** (address 1616) while a higher setting for single phase faults may be tolerated **T2-1phase** (address 1615).

The zone timers for the remaining zones are set with the parameters **T3 DELAY** (address 1625), **T4 DELAY** (address 1635) and **T5 DELAY** (address 1645).

If the device is provided with the capability to trip single-pole, single-pole tripping is then possible in the zones Z1 and Z2. While single-pole tripping usually applies to single-phase faults in Z1 (if the remaining conditions for single-pole tripping are satisfied), this may also be selected for the second zone with address 1617 **Trip 1pole Z2**. Single pole tripping in zone 2 is only possible if this address is set to **Yes**. The pre-setting is **No**.



Note

For instantaneous tripping (undelayed) in the forward direction, the first zone **Z1** should always be used, as only the Z1 and Z1B are guaranteed to trip with the shortest operating time of the device. The further zones should be used sequentially for grading in the forward direction.

If instantaneous tripping (undelayed) is required in the reverse direction, the zone **Z3** should be used for this purpose, as only this zone ensures instantaneous pickup with the shortest device operating time for faults in the reverse direction. This setting is also recommended in teleprotection **BLOCKING** schemes.

With binary input indications 3619 „>BLOCK Z4 Ph-E“ and 3620 „>BLOCK Z5 Ph-E“ zones Z4 and Z5 for phase-earth loops may be blocked. To block these zones permanently for phase-earth loops, said binary inputs must be set to the logic value of 1 via CFC.

Blocking of Zone Z1

If the main protection functions - differential protection and distance protection - operate in parallel, the distance protection of Zone Z1 may pick up before the differential protection (e.g. in the case of close-up faults). If this is desired, the distance protection works as a „booster“ stage for fast tripping. If the fast tripping acts on one end of the line only, accelerated tripping of zone Z1 is not desired (see also Section 2.5.1.4).

There are two ways of blocking Z1. If the device operates in differential protection mode, zone Z1 can be blocked by setting a parameter (address 1533 **Z1 blkd by diff**). Another way of blocking the zone is to set a binary input (No 3610 „>BLOCK Z1 - Trip“).

Controlled zone Z1B

The overreaching zone Z1B is a controlled zone. The normal zones Z1 to Z5 are not influenced by Z1B. There is therefore no zone switching, but rather the overreaching zone is activated or deactivated by the corresponding criteria. It can also be set in address 1751 **Op. mode Z1B** to **Forward** or **Reverse**. If this stage is not required, it is set to **Inactive** in address 1751. The setting options are similar to those of zone Z1: address 1752 **ZR(Z1B)**. The delay times for single-phase and multiple-phase faults can again be set separately: **T1B-1phase** (address 1655) and **T1B-multi-phase** (address 1656).

Zone Z1B is usually used in combination with automatic reclosure and/or teleprotection systems. It can be activated internally by the teleprotection functions (see also Section 2.7) or the integrated automatic reclosure (if available, see also Section 2.15), or externally by a binary input. It is generally set to at least 120 % of the line length. On three-terminal line applications („teed feeders“), it must be set to securely reach beyond the longest line section, even when there is additional infeed via the tee-off point. The delay times are set in accordance with the type of application, usually to zero or a very small delay. When used in conjunction with teleprotection comparison schemes, the dependence on the fault detection must be considered (refer to margin heading „Distance Protection Prerequisites“ in Section 2.7.14).

If the distance protection is used in conjunction with an automatic recloser, it may be determined in address 1657 **1st AR -> Z1B** which distance zones are released prior to a rapid automatic reclosure. Usually the overreaching zone Z1B is used for the first cycle (**1st AR -> Z1B = YES**). This may be suppressed by changing the setting of **1st AR -> Z1B** to **NO**. In this case the overreaching zone Z1B is not released before and during the 1st automatic reclose cycle. Zone Z1 is always released. The setting only has an effect when the service condition of the automatic reclose function is input to the device via binary input „>Enable ARzones“ (No. 383).

Polarization

The degree of polarization with a fault-accurate memory voltage can be set in address 1771 **Mem. Polariz. PhE** for Ph-E loops, and in address 1773 **Mem. Polariz. P-P** for Ph-Ph loops. With an unfaulted valid voltage (cross-polarization), the evaluation factor can be set separately for Ph-E and Ph-Ph in address 1772 **CrossPolarizPhE** and 1774 **CrossPolarizP-P**. This setting can only be changed via DIGSI® at **Additional Settings**.

These parameters have an impact on the expansion of the characteristics dependent on the source impedance. If the parameter is set to zero, the basic characteristic is displayed without expansion.

2.5.3.3 Settings

Addresses which have an appended "A" can only be changed with DIGSI, under **Additional Settings**.

The table indicates region-specific presettings. Column C (configuration) indicates the corresponding secondary nominal current of the current transformer.

Addr.	Parameter	C	Setting Options	Default Setting	Comments
1605	T1-1phase		0.00 .. 30.00 sec; ∞	0.00 sec	T1-1phase, delay for single phase faults
1606	T1-multi-phase		0.00 .. 30.00 sec; ∞	0.00 sec	T1multi-ph, delay for multi phase faults
1615	T2-1phase		0.00 .. 30.00 sec; ∞	0.30 sec	T2-1phase, delay for single phase faults
1616	T2-multi-phase		0.00 .. 30.00 sec; ∞	0.30 sec	T2multi-ph, delay for multi phase faults
1617A	Trip 1pole Z2		NO YES	NO	Single pole trip for faults in Z2
1625	T3 DELAY		0.00 .. 30.00 sec; ∞	0.60 sec	T3 delay
1635	T4 DELAY		0.00 .. 30.00 sec; ∞	0.90 sec	T4 delay
1645	T5 DELAY		0.00 .. 30.00 sec; ∞	0.90 sec	T5 delay
1655	T1B-1phase		0.00 .. 30.00 sec; ∞	0.00 sec	T1B-1phase, delay for single ph. faults
1656	T1B-multi-phase		0.00 .. 30.00 sec; ∞	0.00 sec	T1B-multi-ph, delay for multi ph. faults
1657	1st AR -> Z1B		NO YES	YES	Z1B enabled before 1st AR (int. or ext.)
1701	Op. mode Z1		Forward Reverse Inactive	Forward	Operating mode Z1
1702	ZR(Z1)	1A	0.050 .. 200.000 Ω	2.500 Ω	ZR(Z1), Impedance Reach
		5A	0.010 .. 40.000 Ω	0.500 Ω	
1711	Op. mode Z2		Forward Reverse Inactive	Forward	Operating mode Z2
1712	ZR(Z2)	1A	0.050 .. 200.000 Ω	5.000 Ω	ZR(Z2), Impedance Reach
		5A	0.010 .. 40.000 Ω	1.000 Ω	
1721	Op. mode Z3		Forward Reverse Inactive	Reverse	Operating mode Z3
1722	ZR(Z3)	1A	0.050 .. 200.000 Ω	5.000 Ω	ZR(Z3), Impedance Reach
		5A	0.010 .. 40.000 Ω	1.000 Ω	
1731	Op. mode Z4		Forward Reverse Inactive	Forward	Operating mode Z4
1732	ZR(Z4)	1A	0.050 .. 200.000 Ω	10.000 Ω	ZR(Z4), Impedance Reach
		5A	0.010 .. 40.000 Ω	2.000 Ω	
1741	Op. mode Z5		Forward Reverse Inactive	Inactive	Operating mode Z5
1742	ZR(Z5)	1A	0.050 .. 200.000 Ω	10.000 Ω	ZR(Z5), Impedance Reach
		5A	0.010 .. 40.000 Ω	2.000 Ω	

Addr.	Parameter	C	Setting Options	Default Setting	Comments
1751	Op. mode Z1B		Forward Reverse Inactive	Forward	Operating mode Z1B (extended zone)
1752	ZR(Z1B)	1A	0.050 .. 200.000 Ω	3.000 Ω	ZR(Z1B), Impedance Reach
		5A	0.010 .. 40.000 Ω	0.600 Ω	
1771A	Mem.Polariz.PhE		0.0 .. 100.0 %	15.0 %	Voltage Memory polarization (phase-e)
1772A	CrossPolarizPhE		0.0 .. 100.0 %	15.0 %	Cross polarization (phase-e)
1773A	Mem.Polariz.P-P		0.0 .. 100.0 %	15.0 %	Voltage Memory polarization (ph-ph)
1774A	CrossPolarizP-P		0.0 .. 100.0 %	15.0 %	Cross polarization (phase-phase)

2.5.4 Tripping Logic of the Distance Protection

2.5.4.1 Method of Operation

General Pickup

Using the fault detection modes I, U/I or U/I/ ϕ , the signal „Dis. PICKUP“ (general pickup of the distance protection function) is generated after the pickup as soon as one of the conditions for pickup is fulfilled. As soon as any of the distance zones has determined with certainty that the fault is inside the tripping range, the signal „Dis. PICKUP“ is generated when using the impedance pickup.

This signal „Dis. PICKUP“ is alarmed and made available for the initialisation of internal and external supplementary functions. (e.g. teleprotection signal transmission, automatic reclosure).

Zone Logic of the Independent Zones Z1 up to Z5

As was mentioned in the description of the measuring technique, each distance zone generates an output signal which is associated with the zone and the affected phase. The zone logic combines these zone fault detections with possible further internal and external signals. The delay times for the distance zones can be started either all together on general fault detection by the distance protection function, or individually at that moment the fault enters the respective distance zone. Parameter **Start Timers** (address 1510) is set by default to **on Dis. Pickup**. This setting ensures that all delay times continue to run together even if the type of fault or the selected measuring loop changes, e.g. because an intermediate infeed is switched off. This is also the preferred setting in the case of other distance protection relays in the power system working with this start timing. Where grading of the delay times is especially important, for instance if the fault location shifts from zone Z3 to zone Z2, the setting **on Zone Pickup** should be chosen. The simplified zone logic is shown in Figure 2-55 for zone 1, Figure 2-56 for zone 2 and Figure 2-57 for zone 3. Zones Z4 and Z5 function according to Figure 2-58.

In the case of zones Z1, Z2 and Z1B single-pole tripping is possible for single-phase faults, if the device version includes the single-pole tripping option. Therefore the event output in these cases is provided for each pole. Different trip delay times can be set for single-phase and multiple-phase faults in these zones. For multiple-phase faults and faults in the other zones, the tripping is always three pole.

**Note**

Binary input „>1p Trip Perm“ (No. 381) must be activated to achieve single-pole tripping. The internal automatic reclosing function may also grant the single-pole permission. The binary input is usually controlled by an external automatic reclosure device.

The trip delay times of the zones (except for Z1 which is usually always set without delay) can be bypassed. The grading times are started either via zone pickup or general pickup of the distance protection function. The undelayed release results from the line energization logic, which may be externally initiated via the circuit breaker close signal derived from the circuit breaker control switch or from an internal line energization detection. Zones Z4 and Z5 may be blocked by external criteria (No. 3617 „BLOCK Z4-Trip“, No. 3618 „BLOCK Z5-Trip“).




Figure 2-55 Tripping logic for the 1st zone




Figure 2-56 Tripping logic for the 2nd zone




Figure 2-57 Tripping logic for the 3rd zone




Figure 2-58 Tripping logic for the 4th and 5th zone, shown is zone Z4

**Zone Logic of the
Controlled Zone
Z1B**

The controlled zone Z1B is usually applied as an overreaching zone. The logic is shown in Figure 2-59. It may be activated via various internal and external functions. The binary inputs for external activation of Z1B of the distance protection are „>ENABLE Z1B“ and „>Enable ARzones“. The former can, for example, be from an external teleprotection device, and only affects Z1B of the distance protection. The latter can also be controlled, e.g. by an external automatic reclosure device. In addition, it is possible to use the zone Z1B as a rapid autoclosure stage that only operates for single-pole faults, for example, if only single-pole automatic reclose cycles are executed.

It is possible for the 7SD5 to trip single-pole during two-phase faults without earth-connection in the overreaching zone when single-pole automatic reclosure is used.

As the device has an integrated teleprotection function, release signals from this function may activate the zone Z1B, provided that the internal teleprotection signal transmission function has been configured to one of the available techniques with parameter 121 **Teleprot. Dist.**, i.e., the function has not been set to **Disabled**.




Figure 2-59 Tripping logic for the controlled zone Z1B

Tripping Logic

The output signals generated by the individual zones are logically connected to the output signals „Dis.Gen. Trip“, „Dis.Trip 1pL1“, „Dis.Trip 1pL2“, „Dis.Trip 1pL3“, „Dis.Trip 3p“ in the actual tripping logic. The single-pole information implies that tripping will take place single-pole only. Furthermore, the zone that initiated the tripping is identified; if single-pole tripping is possible, this is also alarmed, as shown in the zone logic diagrams (Figures 2-55 up to 2-59). The actual generation of the commands for the tripping (output) relay is executed within the tripping logic of the entire device.

2.5.4.2 Setting Notes

The trip delay times of the distance stages and intervention options which are also processed in the tripping logic of the distance protection were already considered with the zone settings.

Further setting options which affect the tripping are described as part of the tripping logic of the device.

2.6 Power Swing Detection (optional)

The 7SD5 has an integrated power swing supplement which allows both the blocking of trips by the distance protection during power swings (power swing blocking) and the calculated tripping during unstable power swings (out-of-step tripping). To avoid uncontrolled tripping, the distance protection devices are supplemented with power swing blocking functions. At particular locations in the system, out-of-step tripping devices are also applied to split the system into islanded networks at selected locations, when system stability (synchronism) is lost due to severe (unstable) power swings.

2.6.1 Method of Operation

Following dynamic events such as load jumps, short-circuits, reclose dead times or switching actions it is possible that the generators must realign themselves, in an oscillatory manner, with the new load balance of the system. The distance protection registers large transient currents during the power swing and, especially at the electrical centre, small voltages (Figure 2-60). Small voltages with simultaneous large currents apparently imply small impedances, which again could lead to tripping by the distance protection. In expansive networks with large transferred power, even the stability of the energy transfer could be endangered by such power swings.




Figure 2-60 Power swing

Note

The power swing supplement works together with the impedance pickup and is only available in this combination.

System power swings are three-phase symmetrical processes. Therefore in general a certain degree of measured value symmetry may be assumed. System power swings may however also occur during unsymmetrical processes, e.g. during two-phase short-circuits or during single-pole dead times. The power swing detection in the 7SD5 is therefore based on three measuring systems. For each phase, a dedicated measuring system is available. Even if a power swing has been detected, any subsequent short-circuits will result in the fast cancellation of the power swing block in the affected phases, thereby allowing the tripping of the distance protection.

To detect a power swing, the rate of change of the impedance vectors is measured. The message is triggered when the impedance vector enters the power swing measuring range PPOL (refer to Figure 2-61) and the other criteria of power swing detec-



tion are met. The fault detection range APOL is made up of the largest set values for R and X (polygon characteristic) or of the largest set value for ZR (MHO characteristic) of all the activated zones. The power swing zone has a minimum distance Z_{Diff} of $5\ \Omega$ (at $I_N = 1\text{ A}$) or $1\ \Omega$ (at $I_N = 5\text{ A}$) in all directions from the fault detection zone. In the event of a short-circuit (1), the impedance vector abruptly changes from the load condition into this fault detection range. However, in the event of a power swing, the apparent impedance vector initially enters the power swing range PPOL and only later enters the fault detection range APOL (2). It is also possible that a power swing vector will enter the area of the power swing range and leave it again without coming into contact with the fault detection range (3). If the vector enters the power swing polygon and passes through it leaving on the opposite side, then the sections of the network seen from the relay location have lost synchronism (4): the power transfer is unstable.




Figure 2-61 Pickup characteristic of the power swing detection for a polygon.

The same applies to the MHO characteristic (refer to Figure 2-62). The power swing circle also has a distance Z_{Diff} of $5\ \Omega$ (at $I_N = 1\text{ A}$) or $1\ \Omega$ (at $I_N = 5\text{ A}$) from the largest zone circle. If one or more reverse zones are set, this impedance distance from all zones is maintained.

The rate of change of the 3 impedance vectors is monitored in $1/4$ cycle intervals.




Figure 2-62 Pickup characteristic of the power swing detection for the MHO characteristic




Figure 2-63 Impedance vector during power swing

Trajectory Continuity and Monotony

The rate of change of the impedance vector is very important for the differentiation between faults and power swing conditions. This is shown in Figure 2-63. During the power swing the measured impedance from one sample to the next has a defined change in R and X , referred to as $dR(k)$ and $dX(k)$. Important is also the fact that from one sample to the next the difference is small: i.e. $|dR(k) - dR(k+1)| < \text{threshold}$.

During a fault entry there is a rapid change that will not cause the power swing function to pick up.

Trajectory Stability

When the impedance vector enters the impedance characteristic during a power swing this is on a point of the elliptical curve that corresponds to steady state instability. For release of the power swing detection a further criterion is therefore used. In Figure 2-64 the range for steady state instability is shown. This range is detected in 7SD5. This is done by calculating the centre of the ellipse and checking if the actual measured X value is less than this value.




Figure 2-64 Steady state instability range

Trajectory Symmetry

In addition to these measures, a comparison of the three phases is done to ensure that they are symmetrical. During a power swing condition in the single pole open condition, only two of the three phases will have an impedance trajectory. In this case only these 2 remaining phase trajectories are checked to ensure that they are symmetrical.

Power Swing Detection

To ensure stable and secure operation of the power swing detection without risking unwanted power swing blocking during power system faults, a logical combination of a number of measuring criteria are used.




Figure 2-65 Logic diagram of power swing detection

In Figure 2-65 a simplified logic diagram for the power swing function is given. This measurement is done on a per phase basis although Figure 2-65 only shows the logic for one phase. Before a power swing detected signal is generated, the measured impedance must be inside the power swing polygon (PPOL).

In the following there are 4 measuring criteria:

Trajectory continuity	The calculated R and X values must create a constant line. There must be no jump from one measured value to the next. Refer to Figure 2-63.
Trajectory monotony	The impedance trajectory must initially not change R-direction. Refer to Figure 2-63.
Trajectory symmetry	The trajectory of each phase is evaluated. If no fault is present these 3 trajectories must be symmetrical. During single pole open conditions the remaining 2 trajectories must be symmetrical.
Trajectory stability	When the impedance trajectory enters the PPOL during a swing condition, the system must be in the area of steady state instability. In Figure 2-64 this corresponds to the lower half of the circle.

All these conditions must be true for the generation of a power swing block condition. Once the power swing block condition is set it will remain picked up until the impedance vector leaves the power swing polygon (PPOL). This is unless a fault occurs during this phase. The detection of a jump in the trajectory or non-symmetry of the trajectories will reset the power swing blocking condition. The power swing detection can be blocked via a binary input.

Power Swing Blocking

The power swing blocking affects the distance protection. If the criteria for power swing detection have been fulfilled in at least one phase, the following reactions are possible in relation to the power swing blocking function (set in address 2002 **P/S Op. mode**):

- Block all zones (**All zones block**): all zones of the distance protection are blocked during a power swing.
- Blocking of the first zone only (**Z1/Z1B block**): the first zone (Z1) and the overreaching zone (Z1B) are blocked during a power swing. Faults in other zones are tripped with the associated grading time.
- Blocking of the higher zone only (**Z2 to Z5 block**): the higher zones (Z2 to Z5) are blocked during a power swing. Only the first and the overreaching zone (Z1 and Z1B) remain active.
- Blocking of the first two zones only (**Z1, Z1B, Z2 block**): the first and second zone (Z1 and Z2) and the overreaching zone (Z1B) are blocked during a power swing. The higher zones Z3 to Z5 remain active.

Only the phases in the configured zones are blocked in which power swings were detected. The associated measures taken apply to all phases when power swing has been detected. They are active for as long as the measured impedance vector is inside the power swing range PPOL, or if due to an abrupt change of the associated impedance vector the power swing criteria are no longer satisfied. But the influence of the power swing block on the distance protection relay will be prolonged for a defined time (address 2007 **Trip DELAY P/S**). Thus transient states (e.g. switching operations) are compensated, which occur during a power swing and cause a jump in the measured quantities.

It is possible with No. 4160 „>Pow. Swing BLK“ to block the power swing detection via a binary input.

Power Swing Tripping

If tripping in the event of an unstable power swing (out-of-step condition) is desired, the parameter **PowerSwing trip = YES** is set. If the criteria for power swing detection are satisfied, the distance protection is initially blocked according to the configured program for power swing blocking, to avoid tripping by the distance protection.

When the impedance vectors identified by the power swing detection exit the power swing characteristic PPOL, the sign of the R components in the vectors are checked to see if they are the same on exiting and entering the pickup polygon. If this is the case, the power swing process is inclined to stabilize. Otherwise, the vector passed through the power swing characteristic (loss of synchronism, case (4) in Figure 2-61). Stable power transmission is then no longer possible. The device outputs an alarm to that effect (No. 4163 „P.Swing unstab.“), provided that the parameter in address 2006 **PowerSwing trip** is set to **NO**. The alarm No. 4163 „P.Swing unstab.“ is a pulse with a duration of approx. 50 ms, which can also be processed further via output relay, e.g. for a cycle counter or a pulse counter.

Once instability is detected, the device issues a three-pole trip command, thereby isolating the two system segments from each other. Power swing tripping is alarmed.

As the operating range of the power swing supplement depends on the distance protection settings, the power swing tripping can only be active when the distance protection has been activated.

2.6.2 Setting Notes

The power swing supplement is only active if it has been set to **Power Swing = Enabled** (address 120) during the configuration. For **Power Swing** no other parameters have to be set.

The four possible programs may be set in address 2002 **P/S Op. mode**, as described in Section 2.6: **All zones block**, **Z1/Z1B block**, **Z2 to Z5 block** or **Z1,Z1B,Z2 block**.

Additionally the tripping function for unstable oscillations (out-of-step condition, loss of system synchronism) can be set with parameter **PowerSwing trip** (address 2006), which should be set to **YES** if required (presetting is **NO**). In the event of power swing tripping it is recommended to set **P/S Op. mode = All zones block** for the power swing blocking, to avoid premature tripping by the distance protection.

The tripping delay after power swing blocking can be set in address 2007 **Trip DELAY P/S**.

2.6.3 Settings

Addr.	Parameter	Setting Options	Default Setting	Comments
2002	P/S Op. mode	All zones block Z1/Z1B block Z2 to Z5 block Z1,Z1B,Z2 block	All zones block	Power Swing Operating mode
2006	PowerSwing trip	NO YES	NO	Power swing trip
2007	Trip DELAY P/S	0.08 .. 5.00 sec; 0	0.08 sec	Trip delay after Power Swing Blocking

2.6.4 Information List

No.	Information	Type of Information	Comments
4160	>Pow. Swing BLK	SP	>BLOCK Power Swing detection
4163	P.Swing unstab.	OUT	Power Swing unstable
4164	Power Swing	OUT	Power Swing detected
4166	Pow. Swing TRIP	OUT	Power Swing TRIP command
4167	Pow. Swing L1	OUT	Power Swing detected in L1
4168	Pow. Swing L2	OUT	Power Swing detected in L2
4169	Pow. Swing L3	OUT	Power Swing detected in L3

2.7 Teleprotection for Distance Protection (optional)

2.7.1 General

Purpose of Teleprotection

Faults which occur on the protected line, beyond the first distance zone, can only be cleared selectively by the distance protection after a delay time. On line sections that are shorter than the smallest sensible distance setting, faults can also not be selectively cleared instantaneously.

To achieve non-delayed and selective tripping on 100 % of the line length for all faults by the distance protection, the distance protection can exchange and process information with the opposite line end by means of signal transmission systems. For this purpose, the device has signal send outputs and receive inputs.

As an alternative, digital communication lines can be used for signal transmission.

Teleprotection Schemes

A distinction is made between underreach and overreach schemes.

In underreach schemes, the protection is set with a normal grading characteristic. If a trip command occurs in the first zone, the other line end receives this information via a transmission channel. There the received signal initiates a trip, either by activation of overreach zone Z1B or via a direct trip command.

7SD5 allows:

- PUTT (Pickup),
- Permissive Underreach Transfer Trip with Zone Acceleration Z1B (PUTT),
- Direct (Underreach) Transfer Trip

In overreach schemes, the protection works from the start with a fast overreaching zone. This zone, however, can only cause a trip if the opposite end also detects a fault in the overreaching zone. A release (unblock) signal or a block signal can be transmitted. The following teleprotection schemes are differentiated:

Permissive (release) schemes:

- Permissive Overreach Transfer Trip (POTT) (with overreaching zone Z1B).
- Directional comparison,
- Unblocking with overreaching zone Z1B.

Blocking scheme:

- Blocking of overreaching zone Z1B.

Schemes via pilot wire:

- Pilot Wire Comparison
- Reverse Interlocking

As the distance zones Z1 ... Z5 (without Z1B) function independently, an instantaneous trip in Z1 without a release or blocking signal is always possible. If fast tripping in Z1 is not required (e.g. on very short lines), then Z1 must be delayed with T1.

Transmission Channels

For the signal transmission, one channel in each direction is required. For example, fibre optic connections or voice frequency modulated high frequency channels via pilot cables, power line carrier or microwave radio links can be used for this purpose.

As an alternative, digital communication lines connected to one of the protection data interfaces can be used for signal transmission. For example: fibre optic cables, com-

munication networks or dedicated cables (control cable or twisted phone wire). The send and receive signals must in this case be assigned to fast command channels of the protection data interface (DIGSI matrix).

The pilot wire comparison, that is exclusively applied to short lines, enables the user to operate a pilot wire pair (pilot wires or control wires) with direct current to guarantee the exchange of information between the line ends. Also the reverse interlocking operates with DC control signals.

7SD5 allows also the transmission of phase-selective signals. This presents the advantage that dependable single-pole automatic reclosure can be carried out even when two single-phase faults occur on different lines in the system.

The signal transmission schemes are also suited to three terminal lines (teed feeders). In this case, a signal is transmitted from each of the three ends to each of the others in both directions.

During disturbances in the transmission path, the teleprotection supplement may be blocked without affecting the normal time graded distance protection. The measuring reach control (enable zone Z1B) can be transmitted from the internal automatic reclose function or via the binary input „>Enable ARzones“ from an external reclosure device. With conventional signal transmission schemes, the disturbance is signalled by a binary input, with digital communication it is detected automatically by the protection device.

2.7.2 Method of Operation

Activation and Deactivation

The teleprotection function can be switched on and off by means of the parameter 2101 **FCT Telep. Dis.**, via the system interface (if available) or via binary input (if this is allocated). The switched state is saved internally (refer to Figure 2-66) and secured against loss of auxiliary supply. It is only possible to switch on from the source where previously it had been switched off from. To be active, it is necessary that the function is switched on from all three switching sources.




Figure 2-66 Activation and deactivation of teleprotection

If at one line end there is weak or zero infeed, so that the distance protection does not pick up, the circuit breaker can still be tripped. This „Weak-infeed tripping“ is referred to in Section 2.10.1.




Figure 2-68 Logic diagram of the permissive underreach transfer trip (PUTT) with pickup (one line end)

2.7.4 Permissive Underreach Transfer Trip with Zone Acceleration Z1B (PUTT)

Principle

Figure 2-69 shows the operation scheme for the permissive underreach transfer trip with zone acceleration. In the case of a fault inside zone Z1, the transfer trip signal is sent to the opposite line end. The signal received there causes tripping if the fault is detected in the pre-set direction inside the zone Z1B. The transmit signal can be prolonged by T_s (settable in address 2103 **Send Prolong.**), to compensate for possible differences in the pickup time at the two line ends. The distance protection is set such that the first zone reaches up to approximately 85% of the line length, the overreaching zone, however, is set to reach beyond the opposite substation (approximately 120% of the line length). On three terminal lines Z1 is also set to approximately 85 % of the shorter line section, but at least beyond the tee off point. Z1B must securely reach beyond the longer line section, even when additional infeed is possible via the tee point.

In address 121 **Teleprot. Dist.** the option **PUTT (Z1B)** can be configured. Address 2101 **FCT Telep. Dis.** allows to switch the teleprotection scheme (**ON**).




Figure 2-69 Operation scheme of the permissive underreach transfer trip via Z1B

Sequence




Figure 2-70 Logic diagram of the permissive underreach transfer trip (PUTT) using Z1B (one line end)

The permissive transfer trip should only send for faults in the „Forward“ direction. Accordingly, the first zone Z1 of the distance protection must definitely be set to **Forward** in address 1601 **Op. mode Z1**, refer also to Section 2.5.1 under the margin heading „Independent Zones Z1 up to Z5“.

On two terminal lines, the signal transmission may be phase segregated. Send and receive circuits in this case are built up for each phase. On three terminal lines, the transmit signal is sent to both opposite line ends. The receive signals are then combined with an OR logic function.

With the parameter **Type of Line** (address 2102) the device is informed as to whether it has one or two opposite line ends.

During disturbance of the signal transmission path, the overreaching zone Z1B may be activated by an automatic reclosure (internal or external) via the binary input „>Enable ARzones“.

If at one line end there is weak or zero infeed, so that the distance protection does not pick up, the circuit breaker can still be tripped. This „Weak-infeed tripping“ is referred to in Section 2.10.1.

2.7.5 Direct Underreach Transfer Trip

The following scheme is suited for conventional transmission media.

Principle

As is the case with PUTT (pickup) or PUTT with zone acceleration, a fault in the first zone Z1 is transmitted to the opposite line end by means of a transfer trip signal. The signal received there causes a trip without further queries after a short security margin T_v (settable in address 2202 **Trip Time DELAY**) (Figure 2-71). The transmit signal can be prolonged by T_s (settable in address 2103 **Send Prolong.**), to compensate for possible differences in the pickup time at the two line ends. The distance protection is set such that the first zone reaches up to approximately 85% of the line length. On three terminal lines Z1 is also set to approximately 85 % of the shorter line section, but at least beyond the tee-off point. The overreaching zone Z1B is not required here. It may, however, be activated by internal automatic reclosure or external criteria via the binary input „>Enable ARzones“.

The advantage compared to the permissive underreach transfer trip with zone acceleration lies in the fact that both line ends are tripped without the necessity for any further measures, even if one line end has no infeed. There is however no further supervision of the trip signal at the receiving end.

The direct underreach transfer trip application is not provided by its own selectable teleprotection scheme setting, but implemented by setting the teleprotection supplement to operate in the permissive underreach transfer trip scheme (address 121 **Teleprot. Dist. = PUTT (Z1B) or PUTT (Pickup)**), and using the binary inputs for direct external trip at the receiving end. Correspondingly, the transmit circuit in Section „The principle of PUTT“ (Figure 2-68) applies. For the receive circuit the logic of the „external trip“ as described in Section 2.11 applies.

On two terminal lines, the signal transmission may be phase segregated. On three terminal lines, the transmit signal is sent to both opposite line ends. The receive signals are then combined with a logical OR function.




Figure 2-71 Function diagram of the direct underreach transfer trip scheme

2.7.6 Permissive Overreach Transfer Trip (POTT)

The following procedure is suited for both conventional and digital transmission media.

Principle

The permissive overreach transfer mode uses a permissive release principle. The overreaching zone Z1B set beyond the opposite station is decisive. This mode can also be used on extremely short lines where a setting of 85% of line length for zone Z1 is not possible and accordingly selective non-delayed tripping could not be achieved. In this case, however, zone Z1 must be delayed by T1, to avoid non-selective tripping by zone Z1 (Figure 2-72).

If the distance protection recognizes a fault inside the overreaching zone Z1B, it initially sends a release signal to the opposite line end. If a release signal is received from the opposite end, a trip signal is forwarded to the trip logic. A prerequisite for fast tripping is therefore that the fault is recognized inside Z1B in the forward direction at both line ends. The distance protection is set such that the overreaching zone Z1B reaches beyond the opposite station (approximately 120% of line length). On three terminal lines, Z1B must be set to reliably reach beyond the longer line section, even if there is an additional infeed via the tee point. The first zone is set in accordance with the usual grading scheme, i.e. approximately 85% of the line length; on three terminal lines at least beyond the tee point.

The transmit signal can be prolonged by T_s (settable under address 2103 **Send Prolong.**). The prolongation of the send signal only comes into effect if the protection has already issued a trip command. This ensures release of the opposite line end even when the short-circuit has been switched off rapidly by the independent zone Z1.

For all zones except Z1B, tripping results without release from the opposite line end, allowing the protection to function with the usual grading characteristic independent of the signal transmission.




Figure 2-72 Operation scheme of the permissive overreach transfer trip method

Sequence

The permissive overreach transfer trip only functions for faults in the „Forward“ direction. Accordingly, the first overreach zone ZB1 of the distance protection must definitely be set to **Forward** in addresses 1651 **Op. mode Z1B**, refer also to Section 2.5.2 under the margin heading „Controlled Zone ZB1“.

On two terminal lines, the signal transmission may be phase segregated. Send and receive circuits in this case are built up for each phase. On three terminal lines, the transmit signal is sent to both opposite line ends. The receive signals are then combined with a logical AND gate, as all three line ends must transmit a send signal during an internal fault.

With the parameter **Type of Line** (address 2102) the device is informed as to whether it has one or two opposite line ends (Figure 2-73).

During disturbance of the signal transmission path, the overreaching zone Z1B may be activated by an automatic reclosure (internal or external) via the binary input „>Enable ARzones“.

The occurrence of erroneous signals resulting from transients during clearance of external faults or from direction reversal resulting during the clearance of faults on parallel lines, is neutralized by the „Transient Blocking“.

On feeders with single-sided infeed, the line end with no infeed cannot generate a release signal, as no fault detection occurs there. To achieve tripping by the permissive overreach transfer scheme even in this case, the device contains a special function. This „Weak Infeed Function“ (echo function) is referred to in Section „Measures for Weak and Zero Infeed“. It is activated when a signal is received from the opposite line end — in the case of three terminal lines from at least one of the opposite line ends — without the device having detected a fault.

The circuit breaker can also be tripped at the line end with no or only weak infeed. This „Weak-infeed tripping“ is referred to in Section 2.10.1.




Figure 2-73 Logic diagram of the permissive overreach transfer trip (POTT) scheme (one line end)

2.7.7 Directional Comparison Pickup

The following scheme is suited for conventional transmission media.

Principle

The directional comparison scheme is a permissive release scheme. Figure 2-74 shows the operation scheme.




Figure 2-74 Function diagram of the directional comparison method

If the distance protection detects a fault in line direction, it initially sends a release signal to the opposite line end. If a release signal is also received from the opposite line end, a trip signal is transmitted to the trip relay. This is only the case if the opposite line end also detects a fault in line direction. A prerequisite for fast tripping is therefore that the fault is recognized in **both** line ends in forward direction. The distance stages operate independent from the directional comparison pickup.

The transmit signal can be prolonged by T_s (settable under address 2103 **Send Prolong.**). The prolongation of the send signal only comes into effect if the protection has already issued a trip command. This ensures release of the opposite line end even when the short-circuit has been switched off rapidly by the independent zone Z1.

Sequence

Figure 2-75 shows the logic diagram of the directional comparison scheme for one line end.

On two terminal lines, the signal transmission may be phase segregated. Send and receive circuits in this case are built up for each phase. On three terminal lines, the transmit signal is sent to both opposite line ends. The receive signals are then combined with a logical AND gate, as all three line ends must transmit a send signal during an internal fault. With the setting parameter **Type of Line** (address 2102) the device is informed as to whether it has one or two opposite line ends.

The occurrence of erroneous signals resulting from transients during clearance of external faults or from direction reversal resulting during the clearance of faults on parallel lines, is neutralized by the „Transient Blocking“.

On feeders with single-sided infeed, the line end with no infeed cannot generate a release signal, as no fault detection occurs there. To achieve tripping by the permis-

sive overreach transfer scheme even in this case, the device contains a special function. The „weak-infeed function“ (echo function) is activated when a signal is received from the opposite line end — in the case of three terminal lines from at least one of the opposite line ends — without the device having detected a fault.

The circuit breaker can also be tripped at the line end with no or only weak infeed. This „Weak-infeed tripping“ is referred to in Section 2.10.1.




Figure 2-75 Logic diagram of the directional comparison scheme (one line end)

2.7.8 Directional Unblocking Scheme

The following scheme is suited for conventional transmission media.

Principle

The unblocking method is a permissive release scheme. It differs from the permissive overreach transfer scheme in that tripping is possible also when no release signal is received from the opposite line end. It is therefore mainly used for long lines when the signal must be transmitted across the protected line by means of power line carrier (PLC) and the attenuation of the transmitted signal at the fault location may be so severe that reception at the other line cannot necessarily be guaranteed. Here, a special unblocking logic takes effect.

The scheme functionality is shown in Figure 2-76.

Two signal frequencies which are keyed by the transmit output of the 7SD5 are required for the transmission. If the transmission device has a channel monitoring, then the monitoring frequency f_0 is keyed over to the working frequency f_U (unblocking frequency). When the protection recognizes a fault inside the overreaching zone Z1B, it initiates the transmission of the unblock frequency f_U . During the quiescent state or during a fault outside Z1B, or in the reverse direction, the monitoring frequency f_0 is transmitted.

If the release frequency is received from the opposite end, a trip signal is forwarded to the trip logic. Accordingly, it is a prerequisite for fast tripping, that the fault is recognized inside Z1B in the forward direction at both line ends. The distance protection is set such that the overreaching zone Z1B reaches beyond the opposite station (approximately 120% of line length). On three terminal lines, Z1B must be set to reliably reach beyond the longer line section, even if there is an additional infeed via the tee point. The first zone is set in accordance with the usual grading scheme, i.e. approximately 85% of the line length; on three terminal lines at least beyond the tee point.

The transmit signal can be prolonged by T_S (settable under address 2103 **Send Prolong.**). The prolongation of the send signal only comes into effect if the protection has already issued a trip command. This ensures release of the opposite line end even when the short circuit has been switched off rapidly by the independent zone Z1.




Figure 2-76 Function diagram of the directional unblocking method

For all zones except Z1B, tripping results without release from the opposite line end, allowing the protection to function with the usual grading characteristic independent of the signal transmission.

Sequence

Figure 2-77 shows the logic diagram of the unblocking scheme for one line end.

The unblock scheme only functions for faults in the „forward“ direction. Accordingly, the overreaching zone Z1B of the distance protection must definitely be set to **Forward** in Address 1651 **Op. mode Z1B**, see also Subsection 2.5.1 at margin heading „Controlled Zone Z1B“.

On two terminal lines, the signal transmission may be phase segregated. Send and receive circuits in this case are built up for each phase. On three terminal lines the send signal is transmitted to both opposite ends. The receive signals are then combined with a logical AND gate, as all three line ends must transmit a send signal during an internal fault. With the setting parameter **Type of Line** (address 2102) the device is informed as to whether it has one or two opposite line ends.

An unblock logic is inserted before the receive logic, which in essence corresponds to that of the permissive overreach transfer scheme, see Figure 2-78. If an interference free unblock signal is received, a receive signal, e.g. „>Dis.T.UB ub 1“, appears and the blocking signal, e.g. „>Dis.T.UB bl 1“ disappears. The internal signal „Unblock 1“ is passed on to the receive logic, where it initiates the release of the overreaching zone Z1B of the distance protection (when all remaining conditions have been fulfilled).

If the transmitted signal does not reach the other line end because the short-circuit on the protected feeder causes too much attenuation or reflection of the transmitted signal, neither the unblocking signal e.g., „>Dis.T.UB ub 1“, nor the blocking signal „>Dis.T.UB bl 1“ will appear on the receiving side. In this case, the release „Unblock 1“ is issued after a security delay time of 20 ms and passed onto the receive logic. This release is however removed after a further 100 ms via the timer stage 100/100ms. When the transmission is functional again, one of the two receive signals must appear again, either „>Dis.T.UB ub 1“ or „>Dis.T.UB bl 1“; after a further

100 ms (drop-off delay of the timer stage 100/100 ms) the quiescent state is reached again, i.e. the direct release path to the signal „Unblock L1“ and thereby the usual release is possible.

If none of the signals is received for a period of more than 10 s the alarm „Dis. T. UB Fail1“ is generated.

During disturbance of the signal transmission path, the overreaching zone Z1B may be activated by an automatic reclosure (internal or external) via the binary input „>Enable ARzones“.

The occurrence of erroneous signals resulting from transients during clearance of external faults or from direction reversal resulting during the clearance of faults on parallel lines, is neutralized by the „Transient Blocking“.

On feeders with single-sided infeed, the line end with no infeed cannot generate a release signal, as no fault detection occurs there. To achieve tripping by the permissive overreach transfer scheme even in this case, the device contains a special function. This „Weak Infeed Function“ (echo function) is referred to in Section „Measures for Weak and Zero Infeed“. It is activated when a signal is received from the opposite line end — in the case of three terminal lines from at least one of the opposite line ends — without the device having detected a fault.

The circuit breaker can also be tripped at the line end with no or only weak infeed. This „Weak-infeed tripping“ is referred to in Section 2.10.1.




Figure 2-77 Logic diagram of the unblocking scheme (one line end)




Figure 2-78 Unblock logic

2.7.9 Directional Blocking Scheme

The following scheme is suited for conventional transmission media.

Principle

In the case of the blocking scheme, the transmission channel is used to send a block signal from one line end to the other. The signal may be sent directly after fault inception (jump detector above dotted line in Figure 2-79), and stopped immediately, as soon as the distance protection detects a fault in the forward direction, alternatively the signal is only sent when the distance protection detects the fault in the reverse direction. It is stopped immediately as soon as the distance protection detects a fault in forward direction. Tripping is possible with this scheme even if no signal is received from the opposite line end. It is therefore mainly used for long lines when the signal must be transmitted across the protected line by means of power line carrier (PLC) and the attenuation of the transmitted signal at the fault location may be so severe that reception at the other line end cannot necessarily be guaranteed.

The scheme functionality is shown in Figure 2-79.

Faults inside the overreaching zone Z1B, which is set to approximately 120% of the line length, will initiate tripping if a blocking signal is not received from the other line end. On three terminal lines, Z1B must be set to reliably reach beyond the longer line section, even if there is an additional infeed via the tee point. Due to possible differences in the pickup times of the devices at both line ends and due to the signal transmission time delay, the tripping must be somewhat delayed by T_V in this case.

To avoid signal race conditions, a transmit signal can be prolonged by the settable time T_S once it has been initiated.




Figure 2-79 Function diagram of the blocking scheme

Sequence

Figure 2-80 shows the logic diagram of the blocking scheme for one line end.

The overreach zone Z1B is blocked which is why it must be set to **Forward** (address 1651 **Op. mode Z1B**, see also Section 2.5.1 at margin heading „Controlled Zone Z1B“).

On two terminal lines, the signal transmission may be phase segregated. Send and receive circuits in this case are built up for each phase. On three terminal lines, the transmit signals are sent to both opposite line ends. The receive signals are then combined with a logical OR gate as no blocking signal must be received from any line end during an internal fault. With the setting parameter **Type of Line** (address 2102) the device is informed as to whether it has one or two opposite line ends.




Figure 2-80 Logic diagram of the blocking scheme (one line end)

As soon as the distance protection has detected a fault in the reverse direction, a blocking signal is transmitted (e.g. „Dis.T.SEND“, No. 4056). The transmitted signal may be prolonged by setting address 2103 accordingly. The blocking signal is stopped if a fault is detected in the forward direction (e.g. „Dis.T.BL STOP“, No. 4070). Very rapid blocking is possible by transmitting also the output signal of the jump detector for measured values. To do so, the output „DisJumpBlocking“ (No. 4060) must also be allocated to the transmitter output relay. As this jump signal appears at every measured value jump, it should only be used if the transmission channel can be relied upon to respond promptly to the disappearance of the transmitted signal.

If there is a disturbance in the signal transmission path the overreaching zone can be blocked via a binary input. The distance protection operates with the usual time grading characteristic (non delayed trip in Z1). The overreach zone Z1B may, however, be activated by internal automatic reclosure or external criteria via the binary input „>Enable ARzones“.

The occurrence of erroneous signals resulting from transients during clearance of external faults or from direction reversal resulting during the clearance of faults on parallel lines, is neutralized by the „Transient Blocking“. It prolongs the blocking signal by the transient blocking time **TrBlk BlockTime** (address 2110), if it has been present for the minimum duration equal to the waiting time **TrBlk Wait Time** (address 2109).

It lies in the nature of the blocking scheme that single end fed short-circuits can also be tripped rapidly without any special measures, as the non feeding end cannot generate a blocking signal.

2.7.10 Pilot Wire Comparison

In the pilot wire comparison the overreaching zone Z1B functions as instantaneous zone at both ends of the protected line. Zone Z1B is set to reach beyond the next station. The pilot wire comparison avoids non-selective tripping.

The information exchange between both line ends is carried out via a closed quiescent current loop (Figure 2-81) that is fed by a substation battery. One NC contact must be allocated for each signal output, the receiving input must be configured to „low“-active. As an alternative two auxiliary relay combinations (e.g. 7PA5210-3D) are possible for inverting the contact.

In the quiescent state the pilot wires carry direct current that, at the same time, monitors the healthy state of the connection.

If the distance protection picks up, the following signal appears: „Dis.T.SEND“. The NC contact is opened and the pilot wire loop is initially interrupted. A trip by Z1B is blocked via the receiving input „>DisTel Rec.Ch1“. If the protection system then detects a fault within the overreaching zone Z1B, the send signal resets. The NC contact returns to its quiescent state (closed). If the loop in the remote station is also closed after the same sequence, the loop is energized again: the tripping is again released at both ends.

In case the short-circuit occurred outside the protected line the pilot wire loop is also interrupted by the pickup of both devices (both NC contacts „Dis.T.SEND“ are opened). Since the send signal will not reset at least at one of the line ends (fault is not in line direction in zone Z1B), the loop at that end will remain open. Both receiving inputs are deenergized and block the tripping (because of L-active). The other distance stages including Z1, however, operate independently so that the back-up protection function is not affected.

For lines shorter than the shortest settable line please take into consideration that the first distance zone is either set to disabled or that T1 is delayed for at least one grading time interval.

If the line has single-end infeed an instantaneous trip for the whole line is possible. Since no pickup occurs on the non-feeding line end, the loop is not interrupted at that point, but only on the feeding line end. After the fault is detected within Z1B, the loop will be closed again and the trip command is executed.

To guarantee that the time period between pickup and tripping of the protection function is sufficient to open and close the pilot wire loop, T1B must be delayed for a short period. If the pilot wire comparison is used with two different types of devices at both line ends (e.g. 7SD5 at one line end and a standard protection relay at the other end) care must be taken that the difference in pickup and trip delay of the two devices, which may be considerable, does not lead to an unwanted release. This must also be taken into consideration for the delay of T1B.

The quiescent state loop ensures a steady check of the pilot wire connections against interruptions. Since the loop is interrupted during each fault, the signal for pilot wire failure is delayed by 10 s. The pilot wire comparison supplement is then blocked. It does not need to be blocked from external as the pilot wire failure is recognized internally. The other stages of the distance protection continue operating according to the normal grading coordination chart.

Due to the low current consumption of the binary inputs it may be necessary to additionally burden the pilot wire loop with an external shunt connected resistor so that the binary inputs are not hold by the charge of the pilot wire after an interruption of the loop. As an alternative it is possible to connect auxiliary relay combinations (e.g. 7PA5210-3D).




Figure 2-81 Pilot wire comparison - principle

Please take note that both binary inputs are connected in series with each other and the resistance of the pilot wires. Therefore the loop voltage must not be too low or the pickup voltage of the binary inputs must not be too high.

Operation with three terminals is also possible if the device allows it. The following figure shows the logic for two terminals.




Figure 2-82 Receive circuit of pilot wire comparison logic

The isolation voltage of the pilot wires and the binary inputs and outputs must also be taken into account. In the event of an earth fault the induced longitudinal voltage must neither exceed 60% of the isolation voltage of the pilot wires nor 60% of the isolation of the device. The pilot wire comparison is therefore only suited for short lines.

2.7.11 Reverse Interlocking

If the distance protection function of the 7SD5 is used as backup protection in single-end fed transformer feeders, the reverse interlocking function ensures a fast protection of the busbar without endangering the selectivity for faults on the outgoing feeders.

Figure 2-83 shows the logic for reverse interlocking.




Figure 2-83 Logic diagram of the reverse interlocking

According to Figure 2-84 the distance zones Z1 and Z2 serve as back-up stages for faults on the outgoing lines, for example a fault in **F2**. For distance grading the shortest outgoing line is to be used.

The overreach zone Z1B, whose delay time T1B must be set longer than the pickup time T_a of the protection devices of the outgoing lines, is blocked after the pickup of an inferior protection. The pickup signal is sent (according to Figure 2-84) via the receive input (4006 „>DisTel Rec.Ch1“) of the distance protection. If no signal is received this zone guarantees fast tripping of the busbar for

- faults on the busbar, such as for example in **F1**,
- failure of the line protection during a fault, such as for example in **F2**.

The reverse interlocking of the distance protection is performed by specific release or blocking of the overreach zone Z1B. It can be realized by the blocking mode (parallel connection of the NO contacts as illustrated in Figure 2-84) or the release mode (series connection of the NC contacts).

To avoid transient false signals after clearance of external faults, the blocking condition of the reverse interlocking is extended by a transient blocking time (TB in Figure 2-84).




Figure 2-85 Transient blocking for permissive schemes

2.7.13 Measures for Weak and Zero Infeed

In cases where there is weak or no infeed present at one line end, the distance protection will not pick up. Neither a trip nor a send signal can therefore be generated there. With the comparison schemes, using a permissive signal, fast tripping could not even be achieved at the line end with strong infeed without special measures, as the end with weak infeed does not transmit a permissive release signal.

To achieve fast tripping at both line ends in such cases, the distance protection provides special supplements for feeders with weak infeed.

To enable the line end with the weak infeed condition to trip independently, 7SD5 has a special tripping function for weak infeed conditions. As this is a separate protection function with a dedicated trip command, it is described in a separate section (refer to Section 2.10.1).

Echo Function

Figure 2-86 shows the method of operation of the echo function. At address 2501 **FCT Weak Infeed** (weak infeed FunCTion) can be activated (**ECHO only**) or deactivated (**OFF**). By means of this „switch“ the weak infeed tripping function can also be activated (**ECHO and TRIP**, refer also to Section 2.10.1). This setting is common to the tele-protection function for the distance protection and for the earth fault protection.

If there is no fault detection, the echo function causes the received signal to be sent back to the other line end as an „echo“, where it is used to initiate permissive tripping.

The detection of the weak infeed condition and accordingly the requirement for an echo are combined in a central AND gate. The distance protection must neither be switched off nor blocked, as it would otherwise always produce an echo due to the missing fault detection. If, however, the time delayed overcurrent protection is used as an emergency function, an echo is nevertheless possible if the distance protection is out of service, because the fault detection of the emergency overcurrent protection replaces the distance protection fault detection. During this mode of operation, the emergency overcurrent protection must naturally not also be blocked or switched off.

Even when the emergency overcurrent protection does not pick up an echo is created for permissive release scheme during emergency function. The time overcurrent protection at the weaker end must operate with more sensitivity than the distance protection at the end with high infeed. Otherwise the selectivity concerning 100% of the line length is not given.

The essential condition for an echo is the absence of distance protection or overcurrent protection fault detection with the simultaneous reception of a signal from the tele-protection scheme logic, as shown in the corresponding logic diagrams (Figure 2-73 or 2-77).

In case of single- or two-pole pickup of the distance protection, it is nevertheless possible to send an echo if measurement of the phases that have not picked up recognizes a weak-infeed condition.

To avoid an incorrect echo following switching off of the line and reset of the fault detection, the RS flip-flop in Figure 2-86 latches the fault detection condition until the signal receive condition resets, thereby barring the release of an echo. The echo can in any event be blocked via the binary input „>Dis.T.BlkEcho“.

If the conditions for an echo signal are met, a short delay **Trip/Echo DELAY** is initially activated. This delay is necessary to avoid transmission of the echo if the protection at the weak line end has a longer fault detection time during reverse faults or if it picks up a little later due to unfavourable short-circuit current distribution. If, however, the circuit breaker at the non-feeding line end is open, this delay of the echo signal is not required. The echo delay time may then be bypassed. The circuit breaker position is provided by the central information control functions (refer to Section 2.23.1).

The echo impulse is then transmitted (alarm output „ECHO SIGNAL“), the duration of which can be set with the parameter **Trip EXTENSION**. The „ECHO SIGNAL“ must be allocated separately to the output relay(s) for transmission, as it is not contained in the transmit signals „Dis.T.SEND“ or „Dis.T.SEND L*“.



Note

The „ECHO SIGNAL“ (No. 4246) must be allocated separately to the output relays for the transmitter actuation, as it is not contained in the transmit signals of the transmission functions.

After output of the echo pulse or during the transmission signal of the distance protection, a new echo can not be sent for at least 50 ms (default setting). This prevents echo repetition after the line has been switched off.

In the case of the blocking scheme and the underreach transfer trip scheme, the echo function is not required and therefore ineffective.




Figure 2-86 Logic diagram of the echo function for distance protection with teleprotection

2.7.14 Setting Notes

General

The teleprotection supplement of distance protection is only in service if it is set during the configuration to one of the possible modes of operation in address 121. Depending on this configuration, only those parameters which are applicable to the selected mode appear here. If the teleprotection supplement is not required the address 121 is set to **Teleprot. Dist. = Disabled**.

The following modes are possible with conventional transmission links (as described in Section 2.7):

Direct Underreach Transfer Trip Remote trip without any pickup,

PUTT (Pickup)

PUTT (Pickup)

PUTT (Z1B)

Permissive Underreach Transfer Trip with Zone Acceleration Z1B (PUTT)

POTT

Permissive Overreach Transfer Trip (POTT),

Dir.Comp.Pickup

Directional comparison pickup,

UNBLOCKING

Directional unblocking scheme,

BLOCKING

Directional blocking scheme,

Pilot wire comp

Pilot wire comparison,

Rev. Interlock

Reverse interlock

At address 2101 **FCT Telep. Dis.** the use of a teleprotection scheme can be turned **ON** or **OFF**.

If the teleprotection has to be applied to a three terminal line the setting in address 2102 must be **Type of Line = Three terminals**, if not, the setting remains **Two Terminals**.

The following modes are possible with digital transmission using the protection data interface:

PUTT (Z1B)	Permissive Underreach Transfer Trip with Zone Acceleration Z1B (PUTT) via protection interface,
POTT	Permissive Overreach Transfer Trip (POTT),
Dir.Comp.Pickup	Directional comparison pickup,

The send and receive signals must in these cases be assigned to fast command channels of the protection data interface (DIGSI matrix).

Distance Protection Prerequisites

For all applications of teleprotection schemes (except PUTT), it must be ensured that the fault detection of the distance protection in the reverse direction has a greater reach than the overreaching zone of the opposite line end (refer to the shaded areas in Figure 2-87 on the right hand side)! This is normally predefined for the U/I/φ pickup since the local voltage of a reverse fault is smaller than the voltage of the remote supplying end. For impedance pickup at least one of the distance stages must be set to **Reverse** or **Non-Directional**. During a fault in the shaded area (in the left section of the picture), this fault would be in zone Z1B of the protection at B as zone Z1B is set incorrectly. The distance protection at A would not pick up and therefore the protection in B would interpret this as a fault with single end infeed from B (echo from A or no block signal at A). This would result in a false trip!

The blocking scheme needs furthermore a fast reverse stage to generate the blocking signal. Apply zone 3 with non-delayed setting to this end.




Figure 2-87 Distance protection setting with permissive overreach schemes

Time Settings

The send signal prolongation **Send Prolong.** (address 2103) must ensure that the send signal reliably reaches the opposite line end, even if there is very fast tripping at the sending line end and/or the signal transmission time is relatively long. In the case of the permissive overreaching schemes **POTT**, **Dir.Comp.Pickup** and **UNBLOCKING** this signal prolongation time is only effective if the device has already issued a trip command. This ensures the release of the other line ends even if the short-circuit has been cleared very rapidly by the instantaneous zone Z1. In the case of the blocking scheme **BLOCKING** the transmit signal is always prolonged by this time. In this case it corresponds to a transient blocking following a reverse fault. This setting is only possible via DIGSI® at **Additional Settings**.

In order to detect steady-state line faults such as open circuits, a monitoring time **Delay for alarm** is started when a fault is detected (address 2107). Upon expira-

tion of this time the fault is considered a permanent failure. This parameter can only be altered with DIGSI® under **Additional Settings**.

With the release delay **Release Delay** (address 2108) the release of the zone Z1B can be delayed. This is only required for the blocking scheme **BLOCKING** to allow sufficient transmission time for the blocking signal during external faults. This delay **only** has an effect on the receive circuit of the teleprotection scheme. Conversely, the permissive signal is not delayed by the set time delay T1B of the overreaching zone Z1B. For **Pilot wire comp** and **Rev. Interlock** T1B must be delayed so that there is enough time between the pickup of the distance protection function and the trip signal of zone Z1B.

Transient Blocking

The parameters **TrBlk Wait Time** and **TrBlk BlockTime** serve the transient blocking with the permissive overreaching schemes POTT and UNBLOCKING. With permissive underreach transfer trip they are of no consequence.

The time **TrBlk Wait Time** (address 2109) is a waiting time prior to transient blocking. Not before the distance protection recognizes a reverse fault inside this time after fault detection, will the transient blocking become activated in the permissive overreach transfer schemes. In the case of the blocking scheme, the waiting time prevents transient blocking in the event that the blocking signal reception from the opposite line end is very fast. With the setting ∞ there is no transient blocking. This setting is only possible via DIGSI® at **Additional Settings**.

The transient blocking time **TrBlk BlockTime** (address 2110) must be definitely longer than the duration of severe transients resulting from the inception or clearance of external short circuits. The send signal is delayed by this time with the permissive overreach schemes **POTT** and **UNBLOCKING** if the protection had initially detected a reverse fault. In the case of the blocking scheme **BLOCKING** the received (blocking) signal is prolonged by this time. This setting is only possible via DIGSI® at **Additional Settings**.

The preset value should be sufficient in most cases.

Echo Function

In the case of line ends with weak infeed, the echo function is sensible in conjunction with permissive overreach transfer schemes POTT and UNBLOCKING with release signal, so that the feeding line end is also released. The setting lists concerning the weak infeed are listed in Section 2.10.2.2. The echo function in address 2501 **FCT Weak Infeed** can be activated (**ECHO only** or deactivated (**OFF**). By means of this „switch“ the weak infeed tripping function can also be activated (**ECHO and TRIP**, refer also to Section 2.10.1).

Please do not fail to observe the notes on the setting of the distance protection stages at margin heading „Distance Protection Prerequisites“.

The echo delay time **Trip/Echo DELAY** (address 2502) must be set long enough to avoid incorrect echo signals resulting from the difference in pickup time of the distance protection functions at all line ends during external faults (through-fault current).

Typical setting is approx. 40 ms (presetting). This parameter can only be altered with DIGSI® under **Additional Settings**.

• The echo impulse duration **Trip EXTENSION** (address 2503) may be matched to the configuration data of the signal transmission equipment. It must be long enough to ensure that the receive signal is recognized even with different pickup times by the protection devices at the line ends and different response times of the transmission equipment. In most cases approx. 50 ms (presetting) is sufficient. This parameter can only be altered with DIGSI® under **Additional Settings**.

An endless echo signal between the line ends can be avoided (e.g. interference coupling in the signal path) by blocking a new echo for a certain time **Echo BLOCK Time** (address 2504) after each output of an echo signal. The typical setting is approx. 50 ms. After the distance protection signal was sent, the echo is equally blocked for the time **Echo BLOCK Time**. This setting is only possible via DIGSI® at **Additional Settings**.

If the distance protection and earth fault protection use a common transmission channel, spurious tripping may occur when the distance protection and the earth fault protection create an echo independently of each other. For this scenario, parameter **Echo: 1channel1** (address 2509) must be set to **YES**. The default setting is **NO**.



Note

The „ECHO SIGNAL“ (No. 4246) must be allocated separately to the output relays for the transmitter actuation, as it is not contained in the transmit signals of the transmission functions.

The echo function settings are common to all weak infeed measures and summarized in tabular form in Section 2.10.1.

2.7.15 Settings

Addresses which have an appended "A" can only be changed with DIGSI, under Additional Settings.

Addr.	Parameter	Setting Options	Default Setting	Comments
2101	FCT Telep. Dis.	ON OFF	ON	Teleprotection for Distance prot. is
2102	Type of Line	Two Terminals Three terminals	Two Terminals	Type of Line
2103A	Send Prolong.	0.00 .. 30.00 sec	0.05 sec	Time for send signal prolongation
2107A	Delay for alarm	0.00 .. 30.00 sec	10.00 sec	Time Delay for Alarm
2108	Release Delay	0.000 .. 30.000 sec	0.000 sec	Time Delay for release after pickup
2109A	TrBlk Wait Time	0.00 .. 30.00 sec; ∞	0.04 sec	Transient Block.: Duration external flt.
2110A	TrBlk BlockTime	0.00 .. 30.00 sec	0.05 sec	Transient Block.: Blk.T. after ext. flt.

2.7.16 Information List

No.	Information	Type of Information	Comments
4001	>Dis.Telep. ON	SP	>Distance Teleprotection ON
4002	>Dis.Telep.OFF	SP	>Distance Teleprotection OFF
4003	>Dis.Telep. Blk	SP	>Distance Teleprotection BLOCK
4005	>Dis.RecFail	SP	>Dist. teleprotection: Carrier faulty

No.	Information	Type of Information	Comments
4006	>DisTel Rec.Ch1	SP	>Dis.Tele. Carrier RECEPTION Channel 1
4007	>Dis.T.RecCh1L1	SP	>Dis.Tele.Carrier RECEPTION Channel 1,L1
4008	>Dis.T.RecCh1L2	SP	>Dis.Tele.Carrier RECEPTION Channel 1,L2
4009	>Dis.T.RecCh1L3	SP	>Dis.Tele.Carrier RECEPTION Channel 1,L3
4010	>Dis.T.Rec.Ch2	SP	>Dis.Tele. Carrier RECEPTION Channel 2
4030	>Dis.T.UB ub 1	SP	>Dis.Tele. Unblocking: UNBLOCK Channel 1
4031	>Dis.T.UB bl 1	SP	>Dis.Tele. Unblocking: BLOCK Channel 1
4032	>Dis.T.UB ub1L1	SP	>Dis.Tele. Unblocking: UNBLOCK Ch. 1, L1
4033	>Dis.T.UB ub1L2	SP	>Dis.Tele. Unblocking: UNBLOCK Ch. 1, L2
4034	>Dis.T.UB ub1L3	SP	>Dis.Tele. Unblocking: UNBLOCK Ch. 1, L3
4035	>Dis.T.UB ub 2	SP	>Dis.Tele. Unblocking: UNBLOCK Channel 2
4036	>Dis.T.UB bl 2	SP	>Dis.Tele. Unblocking: BLOCK Channel 2
4040	>Dis.T.BlkEcho	SP	>Dis.Tele. BLOCK Echo Signal
4050	Dis.T.on/off BI	IntSP	Dis. Teleprotection ON/OFF via BI
4052	Dis.Telep. OFF	OUT	Dis. Teleprotection is switched OFF
4054	Dis.T.Carr.rec.	OUT	Dis. Telep. Carrier signal received
4055	Dis.T.Carr.Fail	OUT	Dis. Telep. Carrier CHANNEL FAILURE
4056	Dis.T.SEND	OUT	Dis. Telep. Carrier SEND signal
4057	Dis.T.SEND L1	OUT	Dis. Telep. Carrier SEND signal, L1
4058	Dis.T.SEND L2	OUT	Dis. Telep. Carrier SEND signal, L2
4059	Dis.T.SEND L3	OUT	Dis. Telep. Carrier SEND signal, L3
4060	DisJumpBlocking	OUT	Dis.Tele.Blocking: Send signal with jump
4068	Dis.T.Trans.Blk	OUT	Dis. Telep. Transient Blocking
4070	Dis.T.BL STOP	OUT	Dis. Tele.Blocking: carrier STOP signal
4080	Dis.T.UB Fail1	OUT	Dis. Tele.Unblocking: FAILURE Channel 1
4081	Dis.T.UB Fail2	OUT	Dis. Tele.Unblocking: FAILURE Channel 2
4082	Dis.T.BL STOPL1	OUT	DisTel Blocking: carrier STOP signal, L1
4083	Dis.T.BL STOPL2	OUT	DisTel Blocking: carrier STOP signal, L2
4084	Dis.T.BL STOPL3	OUT	DisTel Blocking: carrier STOP signal, L3

2.8 Earth Fault Protection in Earthed Systems (optional)

The 7SD5 line protection features protection functions for high-resistance earth faults in earthed power systems. These options are available — depending on the ordered model:

- Three overcurrent stages with definite time tripping characteristic (definite time),
- One overcurrent stage with inverse time characteristic (IDMT) or
- One zero sequence voltage stage with inverse time characteristic
- One zero sequence power stage with inverse time characteristic

The elements may be configured independently from each other and combined according to the user's requirements. If the fourth current-, voltage or power-dependent stage is not required, it may be employed as a fourth definite time stage.

Each stage may be set to be non-directional or directional — forward or reverse. A signal transmission may be combined with these four stages. For each stage it may be determined if it should coordinate with the teleprotection function. If the protection is applied in the proximity of transformers, an inrush restraint can be activated. Furthermore, blocking by external criteria is possible via binary inputs (e.g. for reverse interlocking or external automatic reclosure). During energization of the protected feeder onto a dead fault it is also possible to release any stage, or also several, for non-delayed tripping. Stages that are not required, are set inactive.

In the line protection 7SD5, the distance protection function (order option) can be supplemented by the earth fault protection function. In the case of short-circuits with high fault resistances, the fault detection of the distance protection often does not pick up because the measured impedance is outside the fault detection characteristic of the distance protection. High fault resistances can be found, for instance, in overhead lines without earth wire or in sandy soil.

2.8.1 Method of Operation

Measured Quantities

The zero-sequence current is used as measured variable. According to its definition equation it is obtained from the sum of the three phase currents, i.e.

$3 \cdot I_0 = I_{L1} + I_{L2} + I_{L3}$. Depending on the version ordered, and the configured application for the fourth current input I_4 of the device, the zero-sequence current can be measured or calculated.

If the input I_4 is connected in the starpoint of the set of current transformers or to a separate earth current transformer, on the protected feeder, the earth current is directly available as a measured value.

If the device is fitted with the highly sensitive current input for I_4 , this current I_4 is used with the factor **I4 / Iph CT** (address 221, refer to Section 2.1.2.1). As the linear range of this measuring input is severely restricted in the high range, this current is only evaluated up to an amplitude of approx. 1.6A. In the event of larger currents, the device automatically switches over to the evaluation of the zero sequence current derived from the phase currents. Naturally, all three phase currents obtained from a set of three star-connected current transformers must be available and connected to the device. The processing of the earth current is then also possible if very small as well as large earth fault currents may occur.

If the fourth current input I_4 is otherwise utilized, e.g. for a transformer starpoint current or for the earth current of a parallel line, the device calculates the zero-sequence

current from the phase currents. Naturally in this case also all three phase currents derived from a set of three star connected current transformers must be available and connected to the device.


The zero sequence voltage is determined by its defining equation $3 \underline{U}_0 = \underline{U}_{L1-E} + \underline{U}_{L2-E} + \underline{U}_{L3-E}$. Depending on the application for the fourth voltage input U_4 of the device, the zero sequence voltage can be measured or calculated. If the fourth voltage input is connected to the open delta winding U_{Δ} of a voltage transformer set and if it is configured accordingly (address 210 **U4 transformer = Udelta transf.**, see Section 2.1.2.1), this voltage is used with the factor **Uph / Udelta** (address 211, see Section 2.1.2.1). If not, the device calculates the zero-sequence voltage from the phase voltages. Naturally, all three phase-to-earth voltages obtained from a set of three star-connected voltage transformers must be available and connected to the device.

Definite Time Very High-set Current Stage $3I_0>>>$

The triple zero-sequence current $3 I_0$ is passed through a numerical filter and then compared with the set value **3I0>>>**. If this value is exceeded an alarm is issued. After the corresponding delay time **T 3I0>>>** has expired, a trip command is issued which is also alarmed. The reset threshold is approximately 95 % of the pickup threshold.

Figure 2-88 shows the logic diagram of the $3I_0>>>$ stage. The function modules „direction determination“, „permissive teleprotection“, „switch onto fault“, and „inrush stabilization“ are common to all stages and described below. They may, however, affect each stage individually. This is accomplished with the following setting parameters:

- **Op. mode 3I0>>>**, determines the operating direction of the stage: **Forward**, **Reverse**, **Non-Directional** or **Inactive**,
- **3I0>>> Telep/BI** determines whether a non-delayed trip with the teleprotection scheme or via binary input 1310 „>EF InstTRIP“ is possible (**YES**) or not (**NO**),
- **3I0>>>SOTF-Trip**, determines whether during energization of the feeder onto a fault tripping with this stage shall be non-delayed (**YES**) or not (**NO**) and
- **3I0>>>InrushBlk** which is used to switch the inrush stabilization (rush blocking) on (**YES**) or off (**NO**).

Figure 2-88 Logic diagram of the $3I_{0>>>}$ stage

Definite Time High-set Current Stage $3I_{0>>}$

The logic of the high-set current stage $3I_{0>>}$ is the same as that of the $3I_{0>>>}$ stage. In all references $3I_{0>>>}$ must merely be replaced with $3I_{0>>}$. In all other respects Figure 2-88 applies.

Definite Time Over-current Stage $3I_{0>}$

The logic of the high set current stage $3I_{0>}$, too, is the same as that of the $3I_{0>>>}$ stage. In all references $3I_{0>>>}$ must merely be replaced with $3I_{0>}$. In all other respects Figure 2-88 applies. This stage operates with a specially optimized digital filter that completely suppresses all harmonic components beginning with the 2nd harmonic. Therefore it is particularly suited for a highly-sensitive earth fault detection.

A fourth, definite time stage can be implemented by setting the „inverse-time“ stage (refer to the next paragraph) to a definite-time stage.

Inverse Time Over-current Stage $3I_{0P}$

The logic of the stages with inverse time delay functions in the same way as the remaining stages. This stage operates with a specially optimized digital filter that completely suppresses all harmonic components beginning with the 2nd harmonic. Therefore it is particularly suited for a highly-sensitive earth fault detection. However, the time delay is calculated here based on the type of the set characteristic, the intensity

of the earth current and a time multiplier **3I0p Time Dial** (IEC characteristic, Figure 2-89) or a time multiplier **TimeDial TD3I0p** (ANSI characteristic). A pre-selection of the available characteristics was already carried out during the configuration of the protection functions. Furthermore, an additional fixed delay **Add.T-DELAY** may be selected. The characteristics are shown in the Technical Data.

Fig. 2-89 shows the logic diagram. The setting addresses of the IEC characteristics are shown by way of an example. In the setting information the different setting addresses are described in detail.

It is also possible to implement this stage equally with a definite time delay. In this case **3I0p PICKUP** is the pickup threshold and **Add.T-DELAY** the definite time delay. The inverse time characteristic is then effectively bypassed.




Figure 2-89 Logic diagram of the 3I_{0p} stage (inverse time overcurrent protection), for example IEC characteristics

The inverse logarithmic characteristic differs from the other inverse characteristics mainly by the fact that the shape of the curve can be influenced by a number of parameters. The slope and a time shift **3Iop MaxT-DELAY** which directly affect the curve, can be changed. The characteristics are shown in the Technical Data.

Further information regarding the effect of the various parameters can be found in the setting information of the function parameters in Section 2.8.2.

The remaining setting options are the same as for the other curves.




Figure 2-90 Logic diagram of the $3I_{OP}$ stage for the inverse logarithmic characteristic

Zero Sequence Voltage Time Protection (U_0 -inverse)

The zero sequence voltage time protection operates according to a voltage-dependent trip time characteristic. It can be used instead of the time overcurrent stage with inverse time delay.

The voltage/time characteristic can be displaced in voltage direction for a determined constant voltage **U0inv. minimum**, valid for $t \rightarrow \infty$ and in time direction by a determined constant time **T forw. (U0inv)**. The characteristics are shown in the Technical Data.

Figure 2-91 shows the logic diagram. The tripping time depends on the level of the zero sequence voltage U_0 . For meshed earthed systems the zero sequence voltage increases towards the earth fault location. The inverse characteristic results in the shortest command time for the relay closest to the fault. The other relays then reset.




Figure 2-91 Directional zero-sequence voltage time protection with non-directional backup stage

A further time stage **T rev. (U0inv)** provokes non-directional tripping with a voltage-independent delay. This stage can be set above the directional stage. When tripping with this stage it is, however, a prerequisite that the time of the voltage-controlled stage has already expired (without directional check). In case the zero sequence voltage is too low or the voltage transformer circuit breaker is tripped, this stage is also disabled.

Zero Sequence Power Protection

The zero sequence power protection operates according to a power-dependent trip time characteristic. It can be used instead of an inverse time overcurrent stage.

The power is calculated from the zero-sequence voltage and the zero-sequence current. The component S_r is decisive in direction of a configurable compensation angle φ_{comp} , which is also referred to as compensated zero-sequence power, i.e.

$$S_r = 3I_0 \cdot 3U_0 \cdot \cos(\varphi - \varphi_{Comp})$$

where $\varphi = \angle(U_0; I_0)$. φ_{Comp} thus determines the direction of the maximum sensitivity ($\cos(\varphi - \varphi_{Comp}) = 1$ if $\varphi = \varphi_{Comp}$). Due to its sign information the power calculation automatically includes the direction. The power for the reverse direction can be determined by reversing the sign.

The power-time characteristic can be displaced in power direction via a reference value S_{ref} (= basic value for the inverse characteristic for $\varphi = \varphi_{comp}$) and in time direction by a factor k .

Figure 2-92 shows the logic diagram. The tripping time depends on the level of the compensated zero sequence power S_r as defined above. For meshed earthed systems the zero sequence voltage and the zero sequence current increase towards the earth fault location. The inverse characteristic results in the shortest command time for the relay closest to the fault. The other relays then reset.




Figure 2-92 Zero-sequence power protection

Phase Current Stabilization

Non-symmetrical load conditions in multiple-earthed systems or different current transformer errors can result in a zero sequence current. This zero sequence current could cause faulty pickup of the earth current stages if low pickup thresholds are set. To avoid this, the earth current stages are stabilized by the phase current: as the phase currents increase, the pickup thresholds are increased (Figure 2-93). The stabilization factor (= slope) may be changed by means of the parameter **Iph-STAB.Slope** (address 3104). It applies to all stages.




Figure 2-93 Phase current stabilization

Inrush Stabilization

If the device is connected to a transformer feeder, large inrush currents can be expected when the transformer is energized; if the transformer starpoint is earthed, also in the zero sequence path. The inrush current may be a multiple of the rated current and flow for several tens of milliseconds up to several minutes.

Although the fundamental current is evaluated by filtering of the measured current, an incorrect pickup during energization of the transformer may result if very short delay times are set. In the rush current there is a substantial portion of fundamental current depending on the type and size of the transformer that is being energized.

The inrush stabilization blocks tripping of all those stages for which it has been activated, for as long as the rush current is recognized.

The inrush current contains a relatively large second harmonic component (twice the nominal frequency) which is nearly absent during a fault current. Numerical filters that carry out a Fourier analysis of the current are used for the frequency analysis. As soon as the harmonic content is greater than the set value (**2nd InrushRest**), the affected stage is blocked.

Inrush blocking is not effective below a certain current threshold. This threshold is 22 mA on the secondary side for devices with sensitive earth current transformer and $0.41 I_N$ for devices with normal earth current transformer.

Direction Determination with Zero-Sequence System

The direction determination is carried out with the measured current $I_E (= -3 \cdot I_0)$, which is compared to a reference voltage U_P .

The voltage required for direction determination U_P may be derived of the starpoint current I_Y of an earthed transformer (source transformer), provided that the transformer is available.

Moreover, both the zero sequence voltage $3 \cdot U_0$ and the starpoint current I_Y of a transformer can be used for measurement. The reference magnitude U_P then is the sum of the zero sequence voltage $3 \cdot U_0$ and a value which is proportional to reference current I_Y . This value is about 20 V for rated current (Figure 2-94).

The directional polarization using the transformer starpoint current is independent of voltage transformers and therefore also functions reliably during a fault in the voltage transformer secondary circuit. It is, however, a requirement that not all, but at least a substantial amount of the earth fault current flows via the transformer, the starpoint current of which is measured.

For the determination of direction, a minimum current $3I_0$ and a minimum displacement voltage which can be set as **3U0>** is required. If the displacement voltage is too

small, the direction can only be determined if it is polarized with the transformer star-point current and this exceeds a minimum value corresponding to the setting $\mathbf{IY>}$. The direction determination with $3\mathbf{U_0}$ is inhibited if a „trip of the voltage transformer mcb“ is reported via binary input.




Figure 2-94 Directional characteristic of the earth fault protection

Direction Determination with Negative Phase-Sequence System

It is advantageous to use negative sequence system values for the direction measurement if the resulting zero sequence voltages during earth faults are too small for an accurate measurement or when the zero sequence values are subject to interference by, for example, mutual coupling from a parallel line. It can also be used if the zero sequence voltage is not available at the device.

Otherwise this function operates the same as the direction measurement with zero sequence current and zero sequence voltage. Instead of $3\mathbf{I_0}$ and $3\mathbf{U_0}$ the negative sequence signals $3\mathbf{I_2}$ and $3\mathbf{U_2}$ are simply used for the measurement. These signals must also have a minimum magnitude of $\mathbf{3I2>}$ or $\mathbf{3U2>}$.

It is also possible to determine the direction with a zero sequence system or a negative sequence system. In this case the device determines whether the zero sequence quantity ($\mathbf{U_P}$ according to Figure 2-94) is larger, or the negative sequence voltage. The direction is determined by the larger of the two values.

Determination of Direction with Compensated Zero Sequence System Power

The zero-sequence power may also be used for direction determination. In this case the sign of the compensated zero-sequence power is decisive. This is the zero-sequence power component as mentioned in the above paragraph „Zero-Sequence Power“ S_r in direction of a configurable compensation angle φ_{comp} , i.e.

$$S_r = 3\mathbf{I_0} \cdot 3\mathbf{U_0} \cdot \cos(\varphi - \varphi_{comp}).$$

The direction determination yields

- forward if S_r is positive and $S_r > \mathbf{S FORWARD}$,
- reverse if S_r negative and $|S_r| > \mathbf{S REVERSE}$,

For the determination of direction, a minimum current $3\mathbf{I_0}$ and a minimum displacement voltage which can be set as $\mathbf{3U0>}$ is required. The prerequisite is still that the compensated zero-sequence power has a configurable minimum magnitude. The di-

rection determination is also inhibited when a „trip of the voltage transformer mcb“ is reported via binary input. Figure 2-95 gives an example for the directional characteristic.




Figure 2-95 Directional characteristic with zero sequence power, example S_r = setting value
S FORWARD

Selection of the Earth Faulted Phase

Since the earth fault protection employs the quantities of the zero sequence system and the negative sequence system, the faulted phase cannot be determined directly. To enable single-pole automatic reclosure in case of high-resistance earth faults, the earth fault protection function features a phase selector. By means of the distribution of the currents and voltages it detects whether a fault is single-phase or multiple-phase. If the fault is single-phase, it locates the faulted phase.

Once a multi-phase fault has been detected, a three-pole trip command is generated. Three-pole tripping is also initiated if single-pole tripping is not permitted (due to the setting or three-pole coupling of other internal extra functions or external devices via binary input, e.g. reclosing device).

The phase selector evaluates the phase-to-earth voltages, the phase currents and the symmetrical components of the currents. If a single-phase fault can be detected with certainty due to a considerable voltage collapse or a high overcurrent, the trip is initiated in the concerned phase. Three-pole tripping is initiated accordingly if the currents and/or voltages indicate a multi-phase fault.

If the methods described cannot detect the fault type beyond doubt, the negative sequence system and the zero sequence system are ultimately filtered out of the phase currents. The phase angle between negative sequence current and zero sequence current is used to determine the fault type, i.e. whether the fault is single-phase or multi-phase. To this end, the phase currents are also evaluated to rectify the load current if necessary. This method relies on the fact that in the event of a single phase fault the fault-free phases can conduct either no fault currents at all or only such fault currents that are approximately in phase.

The phase selector has an action time of approximately 40ms. If the phase selector has not made a decision during this time, three-pole tripping is initiated. Three-pole

tripping is initiated anyway as soon as a multi-pole fault has been detected, as described above.

Figure 2-96 shows the logic diagram. The phase determined by the phase selector can be processed selectively for each phase, for example the internal information „E/F Pickup L1“ etc. is used for phase-selective signal transmission.

External signaling of the phase-selective pickup is accomplished via the information „E/F L1 selec.“ etc. They appear only if the phase was clearly detected. Single-pole tripping requires of course the general prerequisites to be fulfilled (device must be suited for single-pole tripping, single-pole tripping allowed).




Figure 2-96 Logic diagram of single-pole tripping with phase selector

Blocking

The earth fault protection can be blocked by the distance protection. If in this case a fault is detected by the distance protection, the earth fault protection will not trip. This gives the selective fault clearance by the distance protection preference over tripping by the earth fault protection. The blocking can be restricted by configuration to single-phase or multi-phase faults and to faults in distance zone Z1 or Z1/Z1B. The blocking only affects the time sequence and tripping by the earth fault protection function and after the cause of the blocking has been cleared, it is maintained for approximately 40ms to prevent signal race conditions. It is issued as fault indication „EF TRIP BLOCK“ (No. 1335).

The earth fault protection can also be blocked during the single-pole dead time of an automatic reclose cycle. This prevents an incorrect measurement resulting from the zero sequence current and voltage signals arising in this state. The blocking affects the entire protection function and is maintained for approximately 40ms after reclosure to prevent signal race conditions. It is issued as fault indication „E/F BLOCK“ (No. 1332).

If the device is combined with an external automatic reclose device or if single-pole tripping can result from a separate (parallel tripping) protection device, the earth fault protection must be blocked via binary input during the single-pole open condition.

Switching Onto an Earth Fault

The line energization detection can be used to achieve quick tripping when energizing the circuit breaker in case of an earth fault. The earth fault protection can then trip three-pole without delay. Parameters can be set to determine for which stage(s) the non-delayed tripping following energization apply (see also logic diagrams from Figure 2-88 to Figure 2-92).

The non-delayed tripping in case of line energization detection is blocked as long as the inrush-stabilization recognizes a rush current. This prevents instantaneous tripping by a stage which, under normal conditions, is sufficiently delayed during energization of a transformer.

2.8.2 Setting Notes

General

During the configuration of the device scope of functions (refer to Section 2.1.1, address 131 **Earth Fault 0/C**) it was determined which group of characteristics is to be available. Only those parameters that apply to the available characteristics, according to the selected configuration and the version of the device, are accessible in the procedures described below.

Parameter 3101 **FCT EarthFlt0/C** can be used to switch the earth fault protection **ON** or **OFF**. This refers to all stages of the earth fault protection.

If not required, each of the four stages can be deactivated by setting its **MODE...** to **Inactive** (see below).

Blocking

The earth fault protection can be blocked by the distance protection to give preference to the selective fault clearance by the distance protection over tripping by the earth fault protection. In setting address 3102 **BLOCK for Dist.** it is determined whether blocking is carried out during each fault detection of the distance protection (**every PICKUP**) or only during single-phase fault detection by the distance protection (**1phase PICKUP**) or only during multiple-phase fault detection by the distance protection (**multiph. PICKUP**). If blocking is desired, set **NO**.

It is also possible to block the earth fault protection trip only for pickup of the distance protection on the protected line section. To block the earth fault protection for faults occurring within zone Z1, set address 3174 **BLK for DisZone to in zone Z1**. To block the earth fault protection for faults occurring within zone Z1 or Z1B, set address 3174 **BLK for DisZone to in zone Z1/Z1B**. If, however, blocking of the earth fault protection by the distance protection is to take effect regardless of the fault location, set address 3174 **BLK for DisZone to in each zone**.

Address 3102 thus refers to the fault type and address 3174 to the fault location. The two blocking options create an AND condition. To block the earth fault protection only for single-phase faults occurring within zone Z1, set address 3102 **BLOCK for Dist. = 1phase PICKUP** and 3174 **BLK for DisZone = in zone Z1**. To block

the earth fault protection for any fault type (any distance protection pickup) occurring within zone Z1, the setting 3102 **BLOCK for Dist. = every PICKUP** and 3174 **BLK for DisZone = in zone Z1** applies.

The earth fault protection must be blocked during single-pole automatic reclose dead time to avoid pick-up with the false zero sequence values and, if applicable, the negative sequence values arising during this state (address 3103 **BLOCK 1pDeadTim**). A setting of **YES** (default setting for devices with single-pole tripping) is required if single-pole automatic reclosure is to be carried out. Otherwise set **NO**. Setting parameter 3103 **BLOCK 1pDeadTim** to **YES** completely blocks the earth fault protection if the Open-Pole Detector has recognized a single-pole dead time. If no single-pole tripping is carried out in the protected network, it is absolutely necessary to set this parameter to **NO**.

Regardless of how parameter address 3103 **BLOCK 1pDeadTim** is set, the earth fault protection will always be blocked during the single-pole dead time, if it has issued a trip command itself. This is necessary because otherwise the picked up earth fault protection cannot drop out if the fault current was caused by load current.

Trip

Address 3109 **Trip 1pole E/F** specifies that the earth fault protection trips single pole, provided that the faulted phase can be determined with certainty. This address is only valid for devices that have the option to trip single-pole. If you are using single-pole automatic reclosure, the setting **YES** (default setting) remains valid. Otherwise set **NO**.

Definite Time Stages

First of all, the mode for each stage is set: address 3110 **Op. mode 3I0>>>**, address 3120 **Op. mode 3I0>>** and address 3130 **Op. mode 3I0>**. Each stage can be set to operate **Forward** (usually towards line), **Reverse** (usually towards busbar) or **Non-Directional** (in both directions). If a single stage is not required, set its mode to **Inactive**.

The definite time stages **3I0>>>** (address 3111), **3I0>>** (address 3121) and **3I0>** (address 3131) can be used for a three-stage definite time overcurrent protection. They can also be combined with the inverse time stage **3I0p PICKUP** (address 3141, see below). The pick up thresholds should in general be selected such that the most sensitive stage picks up with the smallest expected earth fault current.

The **3I0>>** and **3I0>>>** stages are best suited for fast tripping stages (instantaneous), as these stages use an abridged filter with shorter response time. On the other hand, the stages **3I0>** and **3I0p** are best suited for very sensitive earth fault detection due to their effective method of suppressing harmonics.

If no inverse time stage, but rather a fourth definite time stage is required, the „inverse time“ stage can be implemented as a definite time stage. This must already be taken regard of during the configuration of the protection functions (refer to Section 2.1.1.3, address 131 **Earth Fault O/C = Definite Time**). For this stage, the address 3141 **3I0p PICKUP** then determines the current pickup threshold and address 3147 **Add. T-DELAY** the definite time delay.

The values for the time delay settings **T 3I0>>>** (address 3112), **T 3I0>>** (address 3122) and **T 3I0>** (address 3132) are derived from the earth fault grading coordination diagram of the system.

During the selection of the current and time settings, regard must be taken as to whether a stage should be direction dependent and whether it uses teleprotection. Refer also to the margin headings „Determination of Direction“ and „Teleprotection with Earth Fault Protection“.

The set time delays are pure additional delays, which do not include the operating time (measuring time).

Inverse Time Stage with IEC Characteristic

Also for the inverse time overcurrent stage the operating mode is initially set: address 3140 **Op. mode 3I_{OP}**. The stage can be set to operate **Forward** (usually towards line), **Reverse** (usually towards busbar) or **Non-Directional** (in both directions). If the stage is not required, set its mode to **Inactive**.

For the inverse time overcurrent stage 3I_{OP} it is possible to select from a variety of characteristics depending on the version of the relay and the configuration (Section 2.1.1.3, address 131) that was selected. If an inverse overcurrent stage is not required, set address 131 **Earth Fault 0/C = Definite Time**. The 3I_{OP} stage can then be used as a fourth definite time stage (refer to „Definite Time Stages“ above) or deactivated. With the IEC characteristics (address 131 **Earth Fault 0/C = TOC IEC**) the following options are available in address 3151 **IEC Curve**:

Normal Inverse (inverse, type A according to IEC 60255–3),

Very Inverse (very inverse, type B according to IEC 60255–3),

Extremely Inv. (extremely inverse, type C according to IEC 60255–3), and

LongTimeInverse (longtime, type B according to IEC 60255–3).

The characteristics and equations they are based on are listed in the Technical Data.

The setting of the pickup threshold **3I_{OP} PICKUP** (address 3141) is similar to the setting of definite time stages (see above). In this case it must be noted that a safety margin between the pickup threshold and the set value has already been incorporated. Pickup only occurs at a current which is approximately 10 % above the set value.

The time multiplier setting **3I_{OP} Time Dial** (address 3143) is derived from the grading coordination chart which was set up for earth faults in the system.

In addition to the inverse current dependant time delay, a constant (fixed length) time delay can also be set if this is required. The setting **Add. T-DELAY** (address 3147) is added to the time of the set curve.

During the selection of the current and time settings, regard must be taken as to whether a stage should be direction dependent and whether it uses teleprotection. Refer also to the margin headings „Determination of Direction“ and „Teleprotection with Earth Fault Protection“.

Inverse Time Stage with ANSI Characteristic

Also for the inverse time overcurrent stage the operating mode is initially set: address 3140 **Op. mode 3I_{OP}**. The stage can be set to operate **Forward** (usually towards line), **Reverse** (usually towards busbar) or **Non-Directional** (in both directions). If the stage is not required, set its mode to **Inactive**.

For the inverse time overcurrent stage 3I_{OP} it is possible to select from a variety of curves depending on the version of the relay and the configuration (Section 2.1.1, address 131) that was selected. If an inverse overcurrent stage is not required, set address 131 **Earth Fault 0/C = Definite Time**. The 3I_{OP} stage can then be used as a fourth definite time stage (refer to „Definite Time Stages“ above). With the ANSI characteristics (address 131 **Earth Fault 0/C = TOC ANSI**) are available at address 3152 **ANSI Curve**:

Inverse,

Short Inverse,

Long Inverse,

Moderately Inv.,

Very Inverse,

Extremely Inv.,

Definite Inv..

The characteristics and equations they are based on are listed in the Technical Data.

The setting of the pickup threshold **3I_{Op} PICKUP** (address 3141) is similar to the setting of definite time stages (see above). In this case it must be noted that a safety margin between the pickup threshold and the set value has already been incorporated. Pickup only occurs at a current which is approximately 10 % above the set value.

The time multiplier setting **3I_{Op} Time Dial** (address 3144) is derived from the grading coordination chart which was set up for earth faults in the system.

In addition to the inverse time delay, a constant (fixed length) time delay can also be set if this is required. The setting **Add. T-DELAY** (address 3147) is added to the time of the set curve.

During the selection of the current and time settings, regard must be taken as to whether a stage should be direction dependent and whether it uses teleprotection. Refer also to the margin headings „Determination of Direction“ and „Teleprotection with Earth Fault Protection“.

Inverse Time Stage with Logarithmic Inverse Characteristic

If you have configured the inverse time overcurrent stage with the logarithmic inverse characteristic (address 131 **Earth Fault O/C = TOC Logarithm.**), the operating mode is initially set: address 3140 **Op. mode 3I_{Op}**. The stage can be set to operate **Forward** (usually towards line), **Reverse** (usually towards busbar) or **Non-Directional** (in both directions). If the stage is not required, set its mode to **Inactive**.

For the logarithmic inverse characteristic (address 131 **Earth Fault O/C = TOC Logarithm.**) the setting of address is 3153 **ANSI Curve = Log. inverse**.

The characteristics and equations they are based on are listed in the Technical Data.

Figure 2-97 illustrates the influence of the most important setting parameters on the curve. **3I_{Op} PICKUP** (address 3141) is the reference value for all current values, while **3I_{Op} Startpoint** (address 3154) determines the beginning of the curve, i.e. the lowest operating range on the current axis (referred to **3I_{Op} PICKUP**). The timer setting **3I_{Op} MaxT-DELAY** (address 3146) determines the starting point of the curve (for $3I_0 = 3I_{Op} \text{ PICKUP}$). The time factor **3I_{Op} Time Dial** (address 3145) changes the slope of the curve. For large currents, **3I_{Op} MinT-DELAY** (address 3142) determines the lower limit on the time axis. For currents larger than $30 \cdot 3I_{Op} \text{ PICKUP}$ the operating time no longer decreases.

Finally in address 3147 **Add. T-DELAY** a fixed time delay can be set as was done for other curves.

During the selection of the current and time settings, regard must be taken as to whether a stage should be direction dependent and whether it uses teleprotection. Refer also to the margin headings „Determination of Direction“ and „Teleprotection with Earth Fault Protection“.




Figure 2-97 Curve parameters in the logarithmic-inverse characteristic

Zero Sequence Voltage Stage with Inverse Characteristic

If you have configured the zero sequence voltage controlled stage (address 131 **Earth Fault 0/C = U0 inverse**), the operating mode is initially set: address 3140 **Op. mode 3I0p**. The stage can be set to operate **Forward** (usually towards line), **Reverse** (usually towards busbar) or **Non-Directional** (in both directions). If the stage is not required, set its mode to **Inactive**.

Address 3141 **3I0p PICKUP** indicates the minimum current value above which this stage is required to operate. The value must be exceeded by the minimum earth fault current value.

The voltage-controlled characteristic is based on the following formula:

$$t = \frac{2 s}{0.25 U_0 \sqrt{V} - U_{0 \min} \sqrt{V}}$$

U_0 is the actual zero sequence voltage. $U_{0 \min}$ is the setting value **U0inv. minimum** (address 3183). Please take into consideration that the formula is based on the zero sequence voltage U_0 , not on $3U_0$. The function is illustrated in the Technical Data.

Figure 2-98 shows the most important parameters. **U0inv. minimum** displaces the voltage-controlled characteristic in direction of $3U_0$. The set value is the asymptote for this characteristic ($t \rightarrow \infty$). In Figure 2-98, **a'** shows an asymptote that belongs to the characteristic **a**.

The minimum voltage **3U0>(U0 inv)** (address 3182) is the lower voltage threshold. It corresponds to the line **c** in Figure 2-98. In characteristic **b** (asymptote not drawn) the curve is cut by the minimum voltage **3U0>(U0 inv)** (line **c**).

In address 3184, an additional time **T forw. (U0inv)** that is added to the voltage-controlled characteristic can be set for directional-controlled tripping.

With the non-directional time **T rev. (U0inv)** (address 3185) a non-directional back-up stage can be generated.




Figure 2-98 Characteristic settings of the zero-sequence voltage time dependent stage — without additional times

Zero-Sequence Power Stage

If you have configured the fourth stage as zero-sequence power stage (address 131 **Earth Fault 0/C = Sr inverse**), set the mode first: address 3140 **Op. mode 3I0p**. This stage can be set to operate **Forward** (usually towards line) or **Reverse** (usually towards busbar) or **Non-Directional** (in both directions). If the stage is not required, set its mode to **Inactive**. The zero-sequence power protection is to operate always in line direction.

Address 3141 **3I0p PICKUP** indicates the minimum current value above which this stage is required to operate. The value must be exceeded by the minimum earth fault current value.

The zero-sequence power S_r is calculated according to the formula:

$$S_r = 3I_0 \cdot 3U_0 \cdot \cos(\varphi - \varphi_{\text{Comp}})$$

The angle φ_{Comp} is set as maximum-sensitivity angle at address 3168 **PHI comp**. It refers to the zero-sequence voltage in relation to the zero-sequence current. The default setting 255° thus corresponds to a zero sequence impedance angle of 75° ($255^\circ - 180^\circ$). Refer also to margin heading „Zero Sequence Power Protection“.

The trip time depends on the zero sequence power according to the following formula:

$$t = k \cdot \frac{S_{\text{ref}}}{S_r}$$

Where S_r is the compensated power according to above formula. S_{ref} is the setting value **S ref** (address 3156) that indicates the pickup value of the stage at $\varphi = \varphi_{\text{Comp}}$. Factor **k** (address 3155) can be set to displace the zero sequence time characteristic in time direction, the reference value **S ref** can be set for displacement in power direction.

The time setting **Add. T-DELAY** (address 3147) allows an additional power-independent delay time to be set.

Determination of Direction

The direction of each required stage was already determined when setting the different stages.

According to the requirements of the application, the directionality of each stage is individually selected. If, for instance, a directional earth fault protection with a non-directional back-up stage is required, this can be implemented by setting the $3I_0>>$ stage directional with a short or no delay time and the $3I_0>$ stage with the same pickup threshold, but a longer delay time as directional backup stage. The $3I_0>>>$ stage could be applied as an additional high set instantaneous stage.

If a stage is to operate with teleprotection according to Section 2.9, it may operate without delay in conjunction with a permissive scheme. In the blocking scheme, a short delay equal to the signal transmission time, plus a small reserve margin of approx. 20 ms is sufficient.

Direction determination of the overcurrent stages usually uses the earth current as measured quantity $I_E = -3I_0$, whose angle is compared with a reference quantity. The desired reference quantity is set in **POLARIZATION** (address 3160):

The default setting **U0 + IY or U2** is universal. The device then selects automatically whether the reference quantity is composed of the zero sequence voltage plus the transformer starpoint current, or whether the negative-sequence voltage is used, depending on which quantity prevails. You can even apply this setting when no transformer starpoint current I_Y is connected to the device since an unconnected current does not have any effect.

The setting **U0 + IY** can also be applied with or without transformer starpoint current connected.

If the direction determination must be carried out using only I_Y as reference signal, apply the setting **with IY only**. This makes sense if a reliable transformer starpoint current I_Y is always available at the device input I_4 . The direction determination is then not influenced by disturbances in the secondary circuit of the voltage transformers. This presupposes that the device is equipped with a current input I_4 of normal sensitivity and that the current from the transformer starpoint infeed is connected to I_4 .

If direction determination is to be carried out using exclusively the negative sequence system signals $3I_2$ and $3U_2$, the setting **with U2 and I2** is applied. In this case, only the negative-sequence signals calculated by the device are used for direction determination. The device does not require any zero-sequence signals for direction determination.

If you are using the zero-sequence power protection (address 131 **Earth Fault 0/C = Sr inverse**), it is reasonable to conduct the direction determination also via the zero-sequence power. In this case, apply the option **zero seq. power** for **POLARIZATION**.

Finally, the threshold values of the reference quantities must be set. **3U0>** (address 3164) determines the minimum operating voltage for direction determination with U_0 . If U_0 is not used for the direction determination, this setting is of no consequence. The set threshold should not be exceeded by asymmetries in the operational measured voltage. The setting value relates to the triple zero-sequence voltage, that is

$$3 \cdot U_0 = |U_{L1} + U_{L2} + U_{L3}|$$

If the voltage dependent characteristic (**U0 inverse**) is used as directional stage, it is reasonable for the minimum polarizing voltage to use a value that is equal to or below the minimum voltage of the voltage-controlled characteristic (address 3182).

Only if you have set in the **P.System Data 1** (see Section 2.1.2.1) the connection of the fourth current transformer **I4 transformer** (address 220) = **IY starpoint**, address 3165 **IY>** will appear. It is the lower threshold for the current measured in the

starpoint of a source transformer. A relatively sensitive setting can be applied for this value, as the measurement of the starpoint current is quite accurate by nature.

If the direction determination must be carried out with the negative sequence system signals, the setting values **3U2>** (address 3166) and **3I2>** (address 3167) are decisive for the lower limit of the direction determination. The setting values must in this case also be selected such that operational asymmetry in the system does not lead to a pickup.

If you are using the zero-sequence power protection and the fault direction is determined on the basis of the zero-sequence power, address 3169 **S forward** indicates the value of the compensated zero-sequence power above which the direction is recognized as forward. This value should be smaller than the reference power **S ref** (address 3156, see above paragraph at „Zero-Sequence Power Stage“). This ensures the availability of direction determination even with smaller zero-sequence power conditions.

The position of the directional characteristic can be changed in dependence of the selected method of direction determination (address 3160 **POLARIZATION**, see above). All methods based on angle measurement between measured signal and reference signal (i.e. all methods except **POLARIZATION = zero seq. power**), allow the angle range of the direction determination to be changed with the setting angles **Dir. ALPHA** and **Dir. BETA** (addresses 3162 and 3163). This parameter can only be altered with DIGSI® under **Additional Settings**. As these set values are not critical, the presets may be left unchanged. If you want to change these values, refer to margin heading „Direction Determination with Zero-Sequence System“ for the angle determination.

The direction determination **POLARIZATION** with **zero seq. power** determines the directional characteristic by means of the compensation angle **PHI comp** (address 3168) which indicates the symmetry axis of the directional characteristic. This value is also not critical for direction determination. For information on the angle definition, refer to margin heading „Direction Determination with Zero-Sequence Power“. This angle determines at the same time the maximum sensitivity of the zero-sequence power stage thus also affecting indirectly the trip time as described above (margin heading „Zero-Sequence Power Stage“).

Teleprotection with Earth Fault Protection

The earth fault protection in the 7SD5 may be expanded to a directional comparison protection using the integrated teleprotection logic. Additional information regarding the available teleprotection schemes and their mode of operation may be obtained from Section 2.9. If this is to be used, certain preconditions must already be observed when setting the earth current stage.

Initially, it must be determined which stage must operate in conjunction with the teleprotection. This stage must be set directional in the line direction. If, for example, the **3I₀>** stage should operate as directional comparison, set address 3130 **Op. mode 3I0> = Forward** (see above „Definite Time Stages“).

Furthermore, the device must be informed that the applicable stage has to function together with the teleprotection to allow undelayed release of the tripping during internal faults. For the **3I₀>** stage this means that address 3133 **3I0> Telep/BI** is set to **YES**. The time delay set for this stage **T 3I0>** (address 3132) then functions as a back-up stage, e.g. during failure of the signal transmission. For the remaining stages the corresponding setting parameter is set to **NO**, therefore, in this example: address 3123 **3I0>> Telep/BI** for stage **3I₀>>**, address 3113 **3I0>>> Telep/BI** for stage **3I₀>>>**, address 3148 **3I0p Telep/BI** for stage **3I_{0p}** (if used).

If the echo function is used in conjunction with the teleprotection scheme, or if the weak-infeed tripping function should be used, the additional teleprotection stage

3IoMin Teleprot (address 3105) must be set to avoid non-selective tripping during through-fault earth current measurement. For further information refer to Section 2.9, margin heading „Earth Fault Protection Prerequisites“.

Switching onto an Earth Fault

It is possible to determine with a setting which stage trips without delay following closure onto a dead fault. The parameters **3IO>>>SOTF-Trip** (address 3114), **3IO>> SOTF-Trip** (address 3124), **3IO> SOTF-Trip** (address 3134) and, if necessary, **3IOp SOTF-Trip** (address 3149) are available for the stages which can be set to **YES** or **NO** for each stage. Selection of the most sensitive stage is usually not reasonable as a solid short-circuit may be assumed following switching onto a fault, whereas the most sensitive stage often also has to detect high resistance faults. It is important to avoid that the selected stage picks up in a transient way during line energization.

On the other hand, it does not matter if a selected stage may pick up due to inrush conditions on transformers. The switch-onto-fault tripping of a stage is blocked by the inrush restraint even if it is set as instantaneous switch-onto-fault stage for manual closure.

To avoid a spurious pickup due to transient overcurrents, the delay **SOTF Time DELAY** (address 3173) can be set. Usually, the default setting **0** can be retained. In the case of long cables, where large peak inrush currents can occur, a short delay may be useful. The time delay depends on the severity and duration of the transient overcurrents as well as on which stages were selected for the fast switch onto fault clearance.

With the parameter **SOTF Op. Mode** (address 3172) it is finally possible to determine whether the fault direction must be checked (**PICKUP+DIRECT.**) or not (**PICKUP**), before a switch-onto-fault tripping is generated. It is the direction setting for each stage that applies for this direction check.

Phase Current Restraint

To avoid a spurious pickup of the stages in the case of asymmetrical load conditions or varying current transformer measuring errors in earth systems, the earth current stages are restrained by the phase currents: as the phase currents increase, the pickup thresholds are increased. By means of the setting in address 3104 **Iph-STAB. Slope** the preset value of 10 % for all stages can be jointly changed for all stages. This setting is only possible via DIGSI® at **Additional Settings**.

Inrush Restraint

The inrush restraint is only required if the device is applied to transformer feeders or on lines that end on a transformer; in this case also only for such stages that have a pickup threshold below the inrush current and have a very short or zero delay. The parameters **3IO>>>InrushBlk** (address 3115), **3IO>> InrushBlk** (address 3125), **3IO> InrushBlk** (address 3135) and **3IOp InrushBlk** (address 3150) can be set to **YES** (inrush restraint active) or **NO** (inrush restraint inactive) for each stage. If the inrush restraint has been disabled for all stages, the following parameters are of no consequence.

For the recognition of the inrush current, the portion of second harmonic current content referred to the fundamental current component can be set in address 3170 **2nd InrushRest**. Above this threshold the inrush blocking is effective. The preset value (15 %) should be sufficient in most cases. Lower values imply higher sensitivity of the inrush blocking (smaller portion of second harmonic current results in blocking).

In applications on transformer feeders or lines that are terminated on transformers it may be assumed that, if very large currents occur, a short-circuit has occurred in front of the transformer. In the event of such large currents, the inrush restraint is inhibited.

This threshold value which is set in the address 3171 **Imax InrushRest**, should be larger than the maximum expected inrush current (RMS value).

2.8.3 Settings

Addresses which have an appended "A" can only be changed with DIGSI, under Additional Settings.

The table indicates region-specific presettings. Column C (configuration) indicates the corresponding secondary nominal current of the current transformer.

Addr.	Parameter	C	Setting Options	Default Setting	Comments
3101	FCT EarthFltO/C		ON OFF	ON	Earth Fault overcurrent function is
3102	BLOCK for Dist.		every PICKUP 1phase PICKUP multiph. PICKUP NO	every PICKUP	Block E/F for Distance protection
3103	BLOCK 1pDeadTim		YES NO	YES	Block E/F for 1pole Dead time
3104A	lph-STAB. Slope		0 .. 30 %	10 %	Stabilisation Slope with lphase
3105	3IoMin Teleprot	1A	0.01 .. 1.00 A	0.50 A	3Io-Min threshold for Teleprot. schemes
		5A	0.05 .. 5.00 A	2.50 A	
3105	3IoMin Teleprot	1A	0.003 .. 1.000 A	0.500 A	3Io-Min threshold for Teleprot. schemes
		5A	0.015 .. 5.000 A	2.500 A	
3109	Trip 1pole E/F		YES NO	YES	Single pole trip with earth flt.prot.
3110	Op. mode 3I0>>>		Forward Reverse Non-Directional Inactive	Inactive	Operating mode
3111	3I0>>>	1A	0.05 .. 25.00 A	4.00 A	3I0>>> Pickup
		5A	0.25 .. 125.00 A	20.00 A	
3112	T 3I0>>>		0.00 .. 30.00 sec; ∞	0.30 sec	T 3I0>>> Time delay
3113	3I0>>> Telep/BI		NO YES	NO	Instantaneous trip via Teleprot./BI
3114	3I0>>>SOTF-Trip		NO YES	NO	Instantaneous trip after SwitchOnToFault
3115	3I0>>>InrushBlk		NO YES	NO	Inrush Blocking
3120	Op. mode 3I0>>		Forward Reverse Non-Directional Inactive	Inactive	Operating mode
3121	3I0>>	1A	0.05 .. 25.00 A	2.00 A	3I0>> Pickup
		5A	0.25 .. 125.00 A	10.00 A	

Addr.	Parameter	C	Setting Options	Default Setting	Comments
3122	T 3I0>>		0.00 .. 30.00 sec; ∞	0.60 sec	T 3I0>> Time Delay
3123	3I0>> Telep/BI		NO YES	NO	Instantaneous trip via Tele-prot./BI
3124	3I0>> SOTF-Trip		NO YES	NO	Instantaneous trip after SwitchOnToFault
3125	3I0>> InrushBlk		NO YES	NO	Inrush Blocking
3130	Op. mode 3I0>		Forward Reverse Non-Directional Inactive	Inactive	Operating mode
3131	3I0>	1A	0.05 .. 25.00 A	1.00 A	3I0> Pickup
		5A	0.25 .. 125.00 A	5.00 A	
3131	3I0>	1A	0.003 .. 25.000 A	1.000 A	3I0> Pickup
		5A	0.015 .. 125.000 A	5.000 A	
3132	T 3I0>		0.00 .. 30.00 sec; ∞	0.90 sec	T 3I0> Time Delay
3133	3I0> Telep/BI		NO YES	NO	Instantaneous trip via Tele-prot./BI
3134	3I0> SOTF-Trip		NO YES	NO	Instantaneous trip after SwitchOnToFault
3135	3I0> InrushBlk		NO YES	NO	Inrush Blocking
3140	Op. mode 3I0p		Forward Reverse Non-Directional Inactive	Inactive	Operating mode
3141	3I0p PICKUP	1A	0.05 .. 25.00 A	1.00 A	3I0p Pickup
		5A	0.25 .. 125.00 A	5.00 A	
3141	3I0p PICKUP	1A	0.003 .. 25.000 A	1.000 A	3I0p Pickup
		5A	0.015 .. 125.000 A	5.000 A	
3142	3I0p MinT-DELAY		0.00 .. 30.00 sec	1.20 sec	3I0p Minimum Time Delay
3143	3I0p Time Dial		0.05 .. 3.00 sec; ∞	0.50 sec	3I0p Time Dial
3144	3I0p Time Dial		0.50 .. 15.00 ; ∞	5.00	3I0p Time Dial
3145	3I0p Time Dial		0.05 .. 15.00 sec; ∞	1.35 sec	3I0p Time Dial
3146	3I0p MaxT-DELAY		0.00 .. 30.00 sec	5.80 sec	3I0p Maximum Time Delay
3147	Add.T-DELAY		0.00 .. 30.00 sec; ∞	1.20 sec	Additional Time Delay
3148	3I0p Telep/BI		NO YES	NO	Instantaneous trip via Tele-prot./BI
3149	3I0p SOTF-Trip		NO YES	NO	Instantaneous trip after SwitchOnToFault
3150	3I0p InrushBlk		NO YES	NO	Inrush Blocking

Addr.	Parameter	C	Setting Options	Default Setting	Comments
3151	IEC Curve		Normal Inverse Very Inverse Extremely Inv. LongTimeInverse	Normal Inverse	IEC Curve
3152	ANSI Curve		Inverse Short Inverse Long Inverse Moderately Inv. Very Inverse Extremely Inv. Definite Inv.	Inverse	ANSI Curve
3153	LOG Curve		Log. inverse	Log. inverse	LOGARITHMIC Curve
3154	3I0p Startpoint		1.0 .. 4.0	1.1	Start point of inverse characteristic
3155	k		0.00 .. 3.00 sec	0.50 sec	k-factor for Sr-characteristic
3156	S ref	1A	1 .. 100 VA	10 VA	S ref for Sr-characteristic
		5A	5 .. 500 VA	50 VA	
3160	POLARIZATION		U0 + IY or U2 U0 + IY with IY only with U2 and I2 zero seq. power	U0 + IY or U2	Polarization
3162A	Dir. ALPHA		0 .. 360 °	338 °	ALPHA, lower angle for forward direction
3163A	Dir. BETA		0 .. 360 °	122 °	BETA, upper angle for forward direction
3164	3U0>		0.5 .. 10.0 V	0.5 V	Min. zero seq.voltage 3U0 for polarizing
3165	IY>	1A	0.05 .. 1.00 A	0.05 A	Min. earth current IY for polarizing
		5A	0.25 .. 5.00 A	0.25 A	
3166	3U2>		0.5 .. 10.0 V	0.5 V	Min. neg. seq. polarizing voltage 3U2
3167	3I2>	1A	0.05 .. 1.00 A	0.05 A	Min. neg. seq. polarizing current 3I2
		5A	0.25 .. 5.00 A	0.25 A	
3168	PHI comp		0 .. 360 °	255 °	Compensation angle PHI comp. for Sr
3169	S forward	1A	0.1 .. 10.0 VA	0.3 VA	Forward direction power threshold
		5A	0.5 .. 50.0 VA	1.5 VA	
3170	2nd InrushRest		10 .. 45 %	15 %	2nd harmonic ratio for inrush restraint
3171	Imax InrushRest	1A	0.50 .. 25.00 A	7.50 A	Max.Current, overriding inrush restraint
		5A	2.50 .. 125.00 A	37.50 A	
3172	SOTF Op. Mode		PICKUP PICKUP+DIRECT.	PICKUP+DIRECT.	Instantaneous mode after SwitchOnToFault
3173	SOTF Time DELAY		0.00 .. 30.00 sec	0.00 sec	Trip time delay after SOTF

Addr.	Parameter	C	Setting Options	Default Setting	Comments
3174	BLK for DisZone		in zone Z1 in zone Z1/Z1B in each zone	in each zone	Block E/F for Distance Protection Pickup
3182	3U0>(U0 inv)		1.0 .. 10.0 V	5.0 V	3U0> setpoint
3183	U0inv. minimum		0.1 .. 5.0 V	0.2 V	Minimum voltage U0min for T->oo
3184	T forw. (U0inv)		0.00 .. 32.00 sec	0.90 sec	T-forward Time delay (U0inv)
3185	T rev. (U0inv)		0.00 .. 32.00 sec	1.20 sec	T-reverse Time delay (U0inv)

2.8.4 Information List

No.	Information	Type of Information	Comments
1305	>EF BLK 3I0>>>	SP	>Earth Fault O/C Block 3I0>>>
1307	>EF BLOCK 3I0>>	SP	>Earth Fault O/C Block 3I0>>
1308	>EF BLOCK 3I0>	SP	>Earth Fault O/C Block 3I0>
1309	>EF BLOCK 3I0p	SP	>Earth Fault O/C Block 3I0p
1310	>EF InstTRIP	SP	>Earth Fault O/C Instantaneous trip
1331	E/F Prot. OFF	OUT	Earth fault protection is switched OFF
1332	E/F BLOCK	OUT	Earth fault protection is BLOCKED
1333	E/F ACTIVE	OUT	Earth fault protection is ACTIVE
1335	EF TRIP BLOCK	OUT	Earth fault protection Trip is blocked
1336	E/F L1 selec.	OUT	E/F phase selector L1 selected
1337	E/F L2 selec.	OUT	E/F phase selector L2 selected
1338	E/F L3 selec.	OUT	E/F phase selector L3 selected
1345	EF Pickup	OUT	Earth fault protection PICKED UP
1354	EF 3I0>>>Pickup	OUT	E/F 3I0>>> PICKED UP
1355	EF 3I0>> Pickup	OUT	E/F 3I0>> PICKED UP
1356	EF 3I0> Pickup	OUT	E/F 3I0> PICKED UP
1357	EF 3I0p Pickup	OUT	E/F 3I0p PICKED UP
1358	EF forward	OUT	E/F picked up FORWARD
1359	EF reverse	OUT	E/F picked up REVERSE
1361	EF Trip	OUT	E/F General TRIP command
1362	E/F Trip L1	OUT	Earth fault protection: Trip 1pole L1
1363	E/F Trip L2	OUT	Earth fault protection: Trip 1pole L2
1364	E/F Trip L3	OUT	Earth fault protection: Trip 1pole L3
1365	E/F Trip 3p	OUT	Earth fault protection: Trip 3pole
1366	EF 3I0>>> TRIP	OUT	E/F 3I0>>> TRIP
1367	EF 3I0>> TRIP	OUT	E/F 3I0>> TRIP
1368	EF 3I0> TRIP	OUT	E/F 3I0> TRIP
1369	EF 3I0p TRIP	OUT	E/F 3I0p TRIP
1370	EF InrushPU	OUT	E/F Inrush picked up

2.9 Teleprotection for Earth Fault Protection (optional)

2.9.1 General

With the aid of the integrated comparison logic, the directional earth fault protection according to Section 2.8 can be expanded to a directional comparison protection scheme.

Transmission Modes

One of the stages which must be directional **Forward** is used for the directional comparison. This stage can only trip fast if a fault is also recognized in the forward direction at the other line end. A release (unblock) signal or a block signal can be transmitted.

The following permissive schemes exist:

- Directional comparison,
- Directional unblock scheme

and blocking scheme:

- Blocking of the directional stage.

Further stages may be implemented as directional and/or nondirectional backup stages.

Transmission Channels

For the signal transmission, one channel in each direction is required. Fibre optic connections or voice frequency modulated high frequency channels via pilot cables, power line carrier or microwave radio links can be used for this purpose. If the same transmission channel is used as for the transmission by the distance protection, the transmission mode must also be the same!

The signal processing can also be used via digital communication lines via a protection data interface. For example: fibre optic cables, communication networks or dedicated cables (control cable or twisted phone wire). The send and receive signals must in this case be assigned to fast command channels of the protection data interface (DIGSI matrix). The direction comparison scheme is suited for these kinds of transmission:

7SD5 allows also the transmission of phase-selective signals. This presents the advantage that single-pole automatic reclosure can be carried out even when two single-phase faults occur on different lines in the system. If no single-phase fault is detected, signals are transmitted for all three phases. With earth fault protection, phase-segregated transmission only makes sense if the earth faulted phase is identified by means of the phase selector (address 3109 **Trip 1pole E/F** is set to **YES**, refer also to Section 2.8 under „Tripping“).

The signal transmission schemes are also suited to three terminal lines (teed feeders). In this case, signal transmission channels are required from each of the three ends to each of the others in both directions.

During disturbances on the transmission path, the teleprotection supplement may be blocked. With conventional signal transmission schemes, the disturbance is signalled by a binary input, with digital communication it is detected automatically by the protection device.

Activation and De-activation

The comparison function can be switched on and off by means of the parameter 3201 **FCT Telep. E/F**, via the system interface (if available) and via binary input (if allocated). The switched state is saved internally (refer to Figure 2-99) and secured against loss of auxiliary supply. It is only possible to switch on from the source where previously it had been switched off from. To be active, it is necessary that the function is not switched off from one of the three switching sources.




Figure 2-99 Activation and deactivation of the signal transmission logic

2.9.2 Directional Comparison Pickup

The following procedure is suited for both conventional and digital transmission media.

Principle

The directional comparison scheme is a permissive scheme. The scheme functionality is shown in Figure 2-100.

When the earth fault protection recognizes a fault in the forward direction, it initially sends a permissive signal to the opposite line end. If a permissive signal is also received from the opposite end, a trip signal is routed to the trip logic. Accordingly it is a prerequisite for fast tripping that the fault is recognized in the forward direction at both line ends.

The send signal can be prolonged by T_s (settable). The prolongation of the send signal only comes into effect if the protection has already issued a trip command. This ensures that the permissive signal releases the opposite line end even if the earth fault is very rapidly cleared by a different independent protection.




Figure 2-100 Operation scheme of the directional comparison pickup

Sequence

Figure 2-101 shows the logic diagram of the directional comparison scheme for one line end.

The permissive overreach transfer trip only functions for faults in the „Forward“ direction. Accordingly the overcurrent stage intended for operation in the direction comparison mode must definitely be set to **Forward (3I0... 3I0...)**, see also Section 2.82.8 at margin heading „Teleprotection with Earth Fault Protection“.

On two terminal lines, the signal transmission may be phase segregated. Send and receive circuits in this case are built up for each phase. On three terminal lines, the transmit signal is sent to both opposite line ends. The receive signals are then combined with a logical AND gate, as all three line ends must transmit a send signal during an internal fault. With the setting parameter **Line Config.** (address 3202) the device is informed as to whether it has one or two opposite line ends.

The occurrence of erroneous signals resulting from transients during clearance of external faults or from direction reversal resulting during the clearance of faults on parallel lines, is neutralized by the „Transient Blocking“ (see margin heading „Transient Blocking“).

On lines where there is only a single sided infeed or where the starpoint is only earthed behind one line end, the line end without zero sequence current cannot generate a permissive signal, as fault detection does not take place there. To also ensure tripping by the directional comparison in this case the device has special features. This „Weak Infeed Function“ (echo function) is referred to under the margin heading „Echo Function“. It is activated when a signal is received from the opposite line end — in the case of three terminal lines from at least one of the opposite line ends — without the device having detected a fault.

The circuit breaker can also be tripped at the line end with no or only weak infeed. This „Weak-infeed tripping“ is referred to in Section 2.10.1.




Figure 2-101 Logic diagram of the directional comparison scheme (one line end)

2.9.3 Directional Unblocking Scheme

The following scheme is suited for conventional transmission media.

Principle

The unblocking method is a permissive scheme. It differs from the directional comparison scheme in that tripping is possible also when no release signal is received from the opposite line end. It is therefore mainly used for long lines when the signal must be transmitted across the protected feeder by means of power line carrier (PLC) and the attenuation of the transmitted signal at the fault location may be so severe that reception at the other line end cannot necessarily be guaranteed.

The scheme functionality is shown in Figure 2-102.

Two signal frequencies which are keyed by the transmit output of the 7SD5 are required for the transmission. If the transmission device has a channel monitoring, then the monitoring frequency f_0 is keyed over to the working frequency f_U (unblocking frequency). When the protection recognizes an earth fault in the forward direction, it initiates the transmission of the unblock frequency f_U . During the quiescent state or during an earth fault in the reverse direction, the monitoring frequency f_0 is transmitted.

If the unblock frequency is received from the opposite end, a signal is routed to the trip logic. A pre-condition for fast fault clearance is therefore that the earth fault is recognized in the forward direction at both line ends.

The send signal can be prolonged by T_S (settable). The prolongation of the send signal only comes into effect if the protection has already issued a trip command. This ensures that the permissive signal releases the opposite line end even if the earth fault is very rapidly cleared by a different independent protection.




Figure 2-102 Operation scheme of the directional unblocking method

Sequence

Figure 2-103 shows the logic diagram of the unblocking scheme for one line end.

The directional unblocking scheme only functions for faults in the „forward“ direction. Accordingly the overcurrent stage intended for operation in the directional unblocking scheme must definitely be set to **Forward (RICH. 310. . .)**; refer also to Section 2.8 at the margin heading „Teleprotection with Earth Fault Protection“.

On two terminal lines, the signal transmission may be phase segregated. Send and receive circuits in this case are built up for each phase. On three terminal lines, the transmit signal is sent to both opposite line ends. The receive signals are then combined with a logical AND gate, as all three line ends must transmit a send signal during an internal fault. With the setting parameter **Line Config.** (address 3202) the device is informed as to whether it has one or two opposite line ends.

An unblock logic is inserted before the receive logic, which in essence corresponds to that of the directional comparison scheme, see Figure 2-104. If an interference free unblock signal is received, a receive signal, e.g. „>EF UB ub 1“, appears and the blocking signal, e.g. „>EF UB bl 1“ disappears. The internal signal „Unblock 1“ is passed on to the receive logic, where it initiates the release of the tripping (when all remaining conditions have been fulfilled).

If the transmitted signal does not reach the other line end because the short-circuit on the protected feeder causes too much attenuation or reflection of the transmitted signal, the unblock logic takes effect: neither the unblocking signal „>EF UB ub 1“ nor the monitoring signal „>EF UB bl 1“ are received. In this case, the release „Unblock 1“ is issued after a security delay time of 20 ms and passed onto the receive logic. This release is however removed after a further 100 ms via the timer stage 100/100 ms. When the transmission is functional again, one of the two receive signals must appear again, either „>EF UB ub 1“ or „>EF UB bl 1“; after a further 100 ms (dropout delay of the timer stage 100/100 ms) the quiescent state is reached again, i.e. the direct release path to the signal „Unblock 1“ and thereby the usual release is possible. On three terminal lines, the unblock logic can be controlled via both receive channels.

If none of the signals is received for a period of more than 10 s the alarm „EF TeleUB Fail1“ is generated.

The occurrence of erroneous signals resulting from transients during clearance of external faults or from direction reversal resulting during the clearance of faults on parallel lines, is neutralized by the „Transient Blocking“.

On lines where there is only a single-sided infeed or where the starpoint is only earthed behind one line end, the line end without zero sequence current cannot generate a permissive signal, as fault detection does not take place there. To also ensure tripping by the directional comparison in this case the device has special features. This „Weak Infeed Function“ is referred to in Section „Measures for Weak and Zero Infeed“. It is activated when a signal is received from the opposite line end — on three terminal lines, from at least one of the opposite ends — without the device recognizing an earth fault.

The circuit breaker can also be tripped at the line end with no or only weak infeed. This „Weak-infeed tripping“ is referred to in Section 2.10.1.




Figure 2-103 Logic diagram of the unblocking scheme (one line end)




Figure 2-104 Unblock logic

2.9.4 Directional Blocking Scheme

The following scheme is suited for conventional transmission media.

Principle

In the case of the blocking scheme, the transmission channel is used to send a block signal from one line end to the other. The signal may be sent directly after fault inception (jump detector above dotted line), and stopped immediately, as soon as the distance protection detects a fault in the forward direction, alternatively the signal is only sent when the distance protection detects the fault in the reverse direction. It is stopped immediately as soon as the earth fault protection detects an earth fault in forward direction. Tripping is possible with this scheme even if no signal is received from the opposite line end. It is therefore mainly used for long lines when the signal

must be transmitted across the protected feeder by means of power line carrier (PLC) and the attenuation of the transmitted signal at the fault location may be so severe that reception at the other line cannot necessarily be guaranteed.

The scheme functionality is shown in Figure 2-105.

Earth faults in the forward direction cause tripping if a blocking signal is not received from the opposite line end. Due to possible differences in the pick up time delays of the devices at both line ends and due to the signal transmission time delay, the tripping must be somewhat delayed by T_V in this case.

To avoid signal race conditions, a transmit signal can be prolonged by the settable time T_S once it has been initiated.




Figure 2-105 Operation scheme of the directional blocking method

Sequence

Figure 2-106 shows the logic diagram of the blocking scheme for one line end.

The stage to be blocked must be set to **Forward (310... DIRECTION)**; refer also to Section 2.8 under margin heading „Teleprotection with Earth Fault Protection“.

On two terminal lines, the signal transmission may be phase segregated. Send and receive circuits in this case are built up for each phase. On three terminal lines, the transmit signal is sent to both opposite line ends. The receive signal is then combined with a logical OR gate as no blocking signal must be received from any line end during an internal fault. With the setting parameter **Line Config.** (address 3202) the device is informed as to whether it has one or two opposite line ends.




Figure 2-106 Logic diagram of the blocking scheme (one line end)

As soon as the distance protection has detected a fault in the reverse direction, a blocking signal is transmitted (e.g. „EF Tele SEND“, FNo 1384). The transmitted signal may be prolonged by setting address 3203 accordingly. The blocking signal is stopped if a fault is detected in the forward direction (e.g. „EF Tele BL STOP“, FNo 1389). Very rapid blocking is possible by transmitting also the output signal of the jump detector for measured values. To do so, the output „EF Tele BL Jump“ (No 1390) must also be allocated to the transmitter output relay. As this jump signal appears at every measured value jump, it should only be used if the transmission channel can be relied upon to respond promptly to the disappearance of the transmitted signal.

The occurrence of erroneous signals resulting from transients during clearance of external faults or from direction reversal resulting during the clearance of faults on parallel lines, is neutralized by the „Transient Blocking“. It prolongs the blocking signal by the transient blocking time **TrBlk BlockTime** (address 3210), if it has been present for the minimum duration equal to the waiting time **TrBlk Wait Time** (address 3209).

It lies in the nature of the blocking scheme that single end fed short-circuits can also be tripped rapidly without any special measures, as the non-feeding end cannot generate a blocking signal.

2.9.5 Transient Blocking

Transient blocking provides additional security against erroneous signals due to transients caused by clearance of an external fault or by fault direction reversal during clearance of a fault on a parallel line.

The principle of transient blocking scheme is that following the incidence of an external fault, the formation of a release signal is prevented for a certain (settable) time. In the case of permissive schemes, this is achieved by blocking of the transmit and receive circuit.

Figure 2-107 shows the principle of the transient blocking for a directional comparison and directional unblocking scheme.

If, following fault detection, a non-directional fault or a fault in the reverse direction is determined within the waiting time **TrBlk Wait Time** (address 3209), the transmit circuit and the trip release are prevented. This blocking is maintained for the duration of the transient blocking time **TrBlk BlockTime** (address 3210) also after the reset of the blocking criterion.

In the case of the blocking scheme, the transient blocking prolongs the received blocking signal as shown in the logic diagram Figure 2-106.




Figure 2-107 Transient blocking for a directional comparison and directional unblocking schemes

2.9.6 Measures for Weak or Zero Infeed

On lines where there is only a single-sided infeed or where the starpoint is only earthed behind one line end, the line end without zero sequence current cannot generate a permissive signal, as fault detection does not take place there. With the comparison schemes, using a permissive signal, fast tripping could not even be achieved at the line end with strong infeed without special measures, as the end with weak infeed does not transmit a permissive release signal.

To achieve rapid tripping at both line ends under these conditions, the device has a special supplement for lines with weak zero sequence infeed.

To enable even the line end with the weak infeed to trip, 7SD5 provides a weak infeed tripping supplement. Since this is a separate protection function with a dedicated trip command, it is described separately in Section 2.10.1.

Echo Function

Figure 2-108 shows the method of operation of the echo function. The function can be activated (**ECHO only**) or deactivated (**OFF**) in address 2501 **FCT Weak Infeed** (**Weak Infeed FunCTion**). By means of this „switch“ the weak infeed tripping function can also be activated (**ECHO and TRIP**, refer also to Section 2.10.1). This setting is common to the teleprotection function for the distance protection and for the earth fault protection.

The received signal at the line end that has no earth current is returned to the other line end as an „echo“ by the echo function. The received echo signal at the other line end enables the release of the trip command.

The detection of the weak infeed condition and accordingly the requirement for an echo are combined in a central AND gate. The earth fault protection must neither be switched off nor blocked, as it would otherwise always produce an echo due to the missing fault detection.

The essential condition for an echo is the absence of an earth current (current stage **3IoMin Teleprot**) with simultaneous receive signal from the teleprotection scheme logic, as shown in the corresponding logic diagrams (Figure 2-101 or 2-103).

To prevent the generation of an echo signal after the line has been tripped and the earth current stage **3IoMin Teleprot** reset, it is no longer possible to generate an echo if a fault detection by the earth current stage had already been present (RS flip-flop in Figure 2-108). The echo can in any event be blocked via the binary input „>EF BlkEcho“.

If the conditions for an echo signal are met, a short delay **Trip/Echo DELAY** is initially activated. This delay is necessary to avoid transmission of the echo if the protection at the weak line end has a longer fault detection time during reverse faults or if it picks up a little later due to unfavourable short-circuit current distribution. If, however, the circuit breaker at the non-feeding line end is open, this delay of the echo signal is not required. The echo delay time may then be bypassed. The circuit breaker position is provided by the central information control functions (refer to Section 2.23.1).

The echo impulse is then transmitted (alarm output „ECHO SIGNAL“), the duration of which can be set with the parameter **Trip EXTENSION**. The „ECHO SIGNAL“ must be allocated separately to the output relay for transmission, as it is not contained in the transmission signal „EF Tele SEND“.

After output of the echo pulse or transmission of the distance protection, a new echo cannot be sent for at least 50 ms. This prevents echo repetition after the line has been switched off.

The echo function is not required for the blocking scheme, and is therefore ineffective.




Figure 2-108 Logic diagram of the echo function for the earth fault protection with teleprotection

2.9.7 Setting Notes

General

The teleprotection supplement for earth fault protection is only operational if it was set to one of the available modes during the configuration of the device (address 132). Depending on this configuration, only those parameters which are applicable to the selected mode appear here. If the teleprotection supplement is not required the address 132 is set to **Teleprot. E/F = Disabled**.

The following modes are possible with conventional transmission links (as described in Section 2.9):

Dir.Comp.Pickup	= Directional Comparison Pickup,
UNBLOCKING	= Directional Unblocking Scheme,
BLOCKING	= Directional Blocking Scheme.

At address 3201 **FCT Telep. E/F** the use of a teleprotection scheme can be switched **ON** or **OFF**.

If the teleprotection has to be applied to a three terminal line, the setting in address 3202 must be **Line Config. = Three terminals**, if not, the setting remains **Two Terminals**.

The following mode is possible with digital transmission using the protection data interface:

Dir.Comp.Pickup = Directional comparison pickup,

The send and receive signals must in this case be assigned to fast command channels of the protection data interface (DIGSI matrix).

Earth Fault Protection Prerequisites

In the application of the comparison schemes, absolute care must be taken that both line ends recognize an external earth fault (earth fault through-current) in order to avoid a faulty echo signal in the case of the permissive schemes, or in order to ensure the blocking signal in the case of the blocking scheme. If, during an earth fault according to Figure 2-109, the protection at B does not recognize the fault, this would be interpreted as a fault with single-sided infeed from A (echo from B or no blocking signal from B), which would lead to unwanted tripping by the protection at A. Therefore, the earth fault protection features an earth fault stage **3IoMin Teleprot** (address 3105). This stage must be set more sensitive than the earth current stage used for the teleprotection. The larger the capacitive earth current (I_{EC} in Figure 2-109) is, the smaller this stage must be set. On overhead lines a setting equal to 70 % to 80 % of the earth current stage is usually adequate. On cables or very long lines where the capacitive currents in the event of an earth fault are of the same order of magnitude as the earth fault currents, the echo function should not be used or restricted to the case where the circuit breaker is open; the blocking scheme should not be used under these conditions at all.




Figure 2-109 Possible current distribution during external earth fault

On three terminal lines (teed feeders) it should further be noted that the earth fault current is not equally distributed on the line ends during an external fault. The most unfavourable case is shown in Figure 2-110. In this case, the earth current flowing in from A is distributed equally on the line ends B and C. The setting value **3IoMin Teleprot** (address 3105), which is decisive for the echo or the blocking signal, must therefore be set smaller than one half of the setting value for the earth current stage used for teleprotection. In addition, the above comments regarding the capacitive earth current which is left out in Figure 2-110 apply. If the earth current distribution is different from the distribution assumed here, the conditions are more favourable as one of the two earth currents I_{EB} or I_{EC} must then be larger than in the situation described previously.




Figure 2-110 Possible unfavourable current distribution on a three terminal line during an external earth fault

Time Settings

The send signal prolongation **Send Prolong** (address 3203) must ensure that the send signal reliably reaches the opposite line end, even if there is very fast tripping at the sending line end and/or the signal transmission time is relatively long. In the case of the permissive schemes **Dir. Comp. Pickup** and **UNBLOCKING**, this signal prolongation time is only effective if the device has already issued a trip command. This ensures the release of the other line end even if the short-circuit is cleared very rapidly by a different protection function or other stage. In the case of the blocking scheme **BLOCKING**, the transmit signal is always prolonged by this time. In this case, it corresponds to a transient blocking following a reverse fault. This parameter can only be altered with DIGSI® under **Additional Settings**.

In order to detect steady-state line faults such as open circuits, a monitoring time **Delay for alarm** is started when a fault is detected (address 3207). Upon expiration of this time the fault is considered a permanent failure. This setting is only possible via DIGSI® at **Additional Settings**.

The release of the directional tripping can be delayed by means of the permissive signal delay **Release Delay** (address 3208). In general, this is **only** required for the blocking scheme **BLOCKING** to allow sufficient transmission time for the blocking signal during external faults. This delay only has an effect on the receive circuit of the teleprotection. Conversely, tripping by the comparison protection is **not** delayed by the set time delay of the directional stage.

Transient Blocking

The setting parameters **TrBlk Wait Time** and **TrBlk BlockTime** are for the transient blocking with the comparison schemes. This setting is only possible via DIGSI® at **Additional Settings**.

The time **TrBlk Wait Time** (address 3209) is a waiting time prior to transient blocking. In the case of the permissive schemes, only once the directional stage of the earth fault protection has recognized a fault in the reverse direction, within this period of time after fault detection, will the transient blocking be activated. In the case of the blocking scheme, the waiting time prevents transient blocking in the event that the blocking signal reception from the opposite line end is very fast. With the setting ∞ there is no transient blocking.

The transient blocking time **TrBlk BlockTime** (address 3210) must definitely be set longer than the duration of severe transients resulting from the inception or clearance of external faults. The send signal is delayed by this time with the permissive over-reach schemes **Dir. Comp. Pickup** and **UNBLOCKING** if the protection had initially detected a reverse fault. In the case of the blocking scheme **BLOCKING** the received (blocking) signal is prolonged by this time.

The preset value should be sufficient in most cases.

Echo Function

In the case of line ends with weak infeed, or not sufficient earth current, the echo function is sensible for the permissive scheme so that the infeeding line end can be released. The echo function at address 2501 **FCT Weak Infeed** can be activated (**ECHO only**) or deactivated (**OFF**). By means of this „switch“ the weak infeed tripping function can also be activated (**ECHO and TRIP**, refer also to Section 2.10.1).

Please do not fail to read the comments regarding the setting of the current stage **3IoMin Teleprot** (address 3105) in the above margin heading „Earth Fault Protection Prerequisites“.

The echo delay time **Trip/Echo DELAY** (address 2502) must be set long enough to avoid incorrect echo signals resulting from the difference in pickup time of the earth fault protection functions at all line ends during external faults (through-fault current). Typical setting is approx. 40 ms (presetting). This parameter can only be altered with DIGSI® under **Additional Settings**.

The echo impulse duration **Trip EXTENSION** (address 2503) may be matched to the configuration data of the signal transmission equipment. It must be long enough to ensure that the receive signal is recognized even with different pickup times by the protection devices at the two line ends and different response times of the transmission equipment. In most cases approx. 50 ms (presetting) is sufficient. This parameter can only be altered with DIGSI® under **Additional Settings**.

An endless echo signal between the line ends can be avoided (e.g. interference coupling in the signal path) by blocking after each output of an echo signal a new echo for a certain time **Echo BLOCK Time** (address 2504). The typical setting is approx. 50 ms. After the earth fault protection signal was sent, the echo is equally blocked for the time **Echo BLOCK Time**. This setting is only possible via DIGSI® at **Additional Settings**.

If the distance protection and earth fault protection use a common transmission channel, spurious tripping may occur when the distance protection and the earth fault protection create an echo independently of each other. For this scenario, parameter **Echo: 1channel** (address 2509) must be set to **YES**. The default setting is **NO**.



Note

The „ECHO SIGNAL“ (No. 4246) must be allocated separately to the output relays for the transmitter actuation, as it is not contained in the transmit signals of the transmission functions.

The echo function settings are common to all weak infeed measures and summarized in tabular form in Section 2.10.1.

2.9.8 Settings

Addresses which have an appended "A" can only be changed with DIGSI, under Additional Settings.

Addr.	Parameter	Setting Options	Default Setting	Comments
3201	FCT Telep. E/F	ON OFF	ON	Teleprotection for Earth Fault O/C
3202	Line Config.	Two Terminals Three terminals	Two Terminals	Line Configuration
3203A	Send Prolong.	0.00 .. 30.00 sec	0.05 sec	Time for send signal prolongation
3207A	Delay for alarm	0.00 .. 30.00 sec	10.00 sec	Unblocking: Time Delay for Alarm
3208	Release Delay	0.000 .. 30.000 sec	0.000 sec	Time Delay for release after pickup
3209A	TrBlk Wait Time	0.00 .. 30.00 sec; ∞	0.04 sec	Transient Block.: Duration external fit.
3210A	TrBlk BlockTime	0.00 .. 30.00 sec	0.05 sec	Transient Block.: Blk.T. after ext. fit.

2.9.9 Information List

No.	Information	Type of Information	Comments
1311	>EF Teleprot.ON	SP	>E/F Teleprotection ON
1312	>EF TeleprotOFF	SP	>E/F Teleprotection OFF
1313	>EF TeleprotBLK	SP	>E/F Teleprotection BLOCK
1318	>EF Rec.Ch1	SP	>E/F Carrier RECEPTION, Channel 1
1319	>EF Rec.Ch2	SP	>E/F Carrier RECEPTION, Channel 2
1320	>EF UB ub 1	SP	>E/F Unblocking: UNBLOCK, Channel 1
1321	>EF UB bl 1	SP	>E/F Unblocking: BLOCK, Channel 1
1322	>EF UB ub 2	SP	>E/F Unblocking: UNBLOCK, Channel 2
1323	>EF UB bl 2	SP	>E/F Unblocking: BLOCK, Channel 2
1324	>EF BlkEcho	SP	>E/F BLOCK Echo Signal
1325	>EF Rec.Ch1 L1	SP	>E/F Carrier RECEPTION, Channel 1, Ph.L1
1326	>EF Rec.Ch1 L2	SP	>E/F Carrier RECEPTION, Channel 1, Ph.L2
1327	>EF Rec.Ch1 L3	SP	>E/F Carrier RECEPTION, Channel 1, Ph.L3
1328	>EF UB ub 1-L1	SP	>E/F Unblocking: UNBLOCK Chan. 1, Ph.L1
1329	>EF UB ub 1-L2	SP	>E/F Unblocking: UNBLOCK Chan. 1, Ph.L2
1330	>EF UB ub 1-L3	SP	>E/F Unblocking: UNBLOCK Chan. 1, Ph.L3
1371	EF Tele SEND L1	OUT	E/F Telep. Carrier SEND signal, Phase L1
1372	EF Tele SEND L2	OUT	E/F Telep. Carrier SEND signal, Phase L2
1373	EF Tele SEND L3	OUT	E/F Telep. Carrier SEND signal, Phase L3
1374	EF Tele STOP L1	OUT	E/F Telep. Block: carrier STOP signal L1
1375	EF Tele STOP L2	OUT	E/F Telep. Block: carrier STOP signal L2
1376	EF Tele STOP L3	OUT	E/F Telep. Block: carrier STOP signal L3
1380	EF TeleON/offBI	IntSP	E/F Teleprot. ON/OFF via BI
1381	EF Telep. OFF	OUT	E/F Teleprotection is switched OFF

No.	Information	Type of Information	Comments
1384	EF Tele SEND	OUT	E/F Telep. Carrier SEND signal
1386	EF TeleTransBlk	OUT	E/F Telep. Transient Blocking
1387	EF TeleUB Fail1	OUT	E/F Telep. Unblocking: FAILURE Channel 1
1388	EF TeleUB Fail2	OUT	E/F Telep. Unblocking: FAILURE Channel 2
1389	EF Tele BL STOP	OUT	E/F Telep. Blocking: carrier STOP signal
1390	EF Tele BL Jump	OUT	E/F Tele.Blocking: Send signal with jump

2.10 Weak-infeed Tripping (optional)

In cases, where there is no or only weak infeed present at one line end, the distance protection does not pick up there during a short-circuit on the line. The settings and information table at „Weak Infeed“ applies for the following functions.

If there is no or only a very small zero sequence current at one line end during an earth fault, the earth fault protection can also not function.

2.10.1 Classical Tripping

2.10.1.1 Method of Operation

Transmission Schemes

By coordinating the weak infeed function with the teleprotection in conjunction with distance protection and/or earth fault protection, fast tripping can also be achieved at both line ends in the above cases.

At the strong infeed line end, the distance protection can always trip instantaneously for faults inside zone Z1. With permissive teleprotection schemes, fast tripping for faults on 100% of the line length is achieved by activation of the echo function (refer to Section 2.7). This provides the permissive release of the trip signal at the strong infeed line end.

The permissive teleprotection scheme in conjunction with the earth fault protection can also achieve release of the trip signal at the strong infeed line end by means of the echo function (refer to Section 2.9).

In many cases tripping of the circuit breaker at the weak infeeding line end is also desired. For this purpose the device 7SD5 has a dedicated protection function with dedicated trip command.

Pickup with Undervoltage

In Figure 2-111 the logic diagram of the weak-infeed tripping is shown. The function can be activated (**ECHO and TRIP**) or deactivated (**OFF**) in address 2501 **FCT Weak Infeed** (Weak Infeed FunCTion). If this „switch“ is set to **ECHO only**, the tripping is also disabled; however the echo function to release the infeeding line end is activated (refer also to Section 2.7 and 2.9). The tripping function can be blocked at any time via the binary input „>BLOCK Weak Inf“.

The logic for the detection of a weak-infeed condition is built up per phase in conjunction with the distance protection and additionally once for the earth fault protection. Since the undervoltage check is performed for each phase, single-pole tripping is also possible, provided the device version has the single-pole tripping option.

In the event of a short-circuit, it may be assumed that only a small voltage appears at the line end with the weak-infeed condition, as the small fault current only produces a small voltage drop in the short-circuit loop. In the event of zero-infeed, the loop voltage is approximately zero. The weak-infeed tripping is therefore dependent on the measured undervoltage **UNDervOLTAGE** which is also used for the selection of the faulty phase.

If a signal is received from the opposite line end without fault detection by the local protection, this indicates that there is a fault on the protected feeder. In the case of three terminal lines when using a permissive overreach scheme a receive signal from both ends may be present. In case of permissive underreach schemes, one receive signal from at least one end is sufficient.

After a security margin time of 40 ms following the start of the receive signal, the weak-infeed tripping is released if the remaining conditions are satisfied: undervoltage, circuit breaker closed and no pickup of the distance protection or of the earth fault protection.

To avoid a faulty pickup of the weak infeed function following tripping of the line and reset of the fault detection, the function cannot pick up anymore once a fault detection in the affected phase was present (RS flip-flop in Figure 2-111).

In the case of the earth fault protection, the release signal is routed via the phase segregated logic modules. Single-phase tripping is therefore also possible if both distance protection and earth fault protection or exclusively earth fault protection issues a release condition.




Figure 2-111 Logic diagram of the weak infeed tripping

2.10.1.2 Setting Notes

General

It is a prerequisite for the operation of the weak infeed function that it was enabled during the configuration of the device at address 125 **Weak Infeed** = **Enabled**.

With the parameter **FCT Weak Infeed** (address 2501) it is determined whether the device shall trip during a weak infeed condition or not. With the setting **ECHO and TRIP** both the echo function and the weak infeed tripping function are activated. With the setting **ECHO only** the echo function for provision of the release signal at the in-feeding line end is activated. There is, however, no tripping at the line end with missing or weak infeed condition. As the weak-infeed measures are dependent on the signal reception from the opposite line end, they only make sense if the protection is coordinated with teleprotection (refer to Section 2.7 and/or 2.9).

The receive signal is a functional component of the trip condition. Accordingly, the weak infeed tripping function must **not be used with the blocking schemes**. It is only permissible with the permissive schemes and the comparison schemes with release signals! In all other cases it should be switched **OFF** at address 2501. In such cases it is better to disable this function from the onset by setting address 125 to **Disabled** during the device configuration. The associated parameters are then not accessible.

The undervoltage setting value **UNDervOLTAGE** (address 2505) must in any event be set below the minimum expected operational phase-earth voltage. The lower limit for this setting is given by the maximum expected voltage drop at the relay location on the weak-infeed side during a short-circuit on the protected feeder for which the distance protection may no longer pick up.

Echo Enable

In applications with a transmission channel used by both the distance and the earth fault protection spurious trippings may occur, if distance protection and earth fault protection create an echo independently from each other. In this case parameter **Echo: 1channel1** (address 2509) has to be set to **YES**. The default setting is **NO**.

The remaining settings apply to the echo function and are described in the corresponding sections (2.7 and 2.9 respectively).

A summary of the settings and the information table can be found right after the setting notes for the French specification.

2.10.2 Tripping According to Specification RTE

2.10.2.1 Functional Description

An alternative for detecting weak infeed is only available in the models 7SD5***-**D**.

Pickup with Relative Voltage Jump

In addition to the classical function of weak infeed, the so called **Logic no. 2** (address 125) presents an alternative to the method used so far.

This function operates independently of the teleprotection scheme by using its own receive signal and it is able to trip with delay and without delay.

Non-delayed Tripping




Figure 2-112 Logic diagram for non-delayed tripping

Trip with Delay




Figure 2-113 Logic diagram for delayed tripping

2.10.2.2 Setting Notes

Echo Enable

In applications with a transmission channel used by both the distance and the earth fault protection spurious trippings may occur, if distance protection and earth fault protection create an echo independently from each other. In this case parameter **Echo: 1 channel** (address 2509) has to be set to **YES**. The default setting is **NO**.

Phase Selection

Phase selection is accomplished via undervoltage detection. For this purpose no absolute voltage threshold in volts is parameterized, but a factor (address 2510 **Uphe< Factor**) which is multiplied with the measured phase-phase voltage, and yields the voltage threshold. This method accounts for operational deviations from the nominal voltage in the undervoltage threshold and adjusts them to the prevailing conditions.

Since a sound positive phase-to-phase voltage is not available in the event of a fault, the undervoltage threshold is delayed. Thus changes in the positive phase-to-phase voltage affect the threshold only slowly. The time constant can be set at address 2511 **Time const. τ** . The undervoltage is determined for all 3 phases.

If the measured phase-to-phase voltage falls below the threshold (address 1131 **PoleOpenVoltage**), undervoltage is no longer detected in this phase.




Figure 2-114 Undervoltage detection for U_{L1-E}

Non-delayed Tripping

A non-delayed TRIP command is issued if a receive signal „>WI reception“ is present and an undervoltage condition is detected simultaneously. If another protection function capable to detect faults has picked up in the relay, the corresponding phases in the weak-infeed function are blocked. The receive signal is prolonged at address 2512 **Rec. Ext.**, so that a trip command is still possible in the event of a quick dropout of the transmitting line end.

To avoid a faulty pick up of the weak infeed function following tripping of the line and reset of the fault detection, the function cannot pick up any more once an inverse-time overcurrent fault detection in the affected phase was present.

If a receive signal applies and no undervoltage is detected, but the zero sequence current threshold **3I0> Threshold** is exceeded (address 2514), a fault on the line can be assumed. If this state (receive signal, no undervoltage and zero sequence current) applies for longer than 500 ms, 3-pole tripping is initiated. The time delay for the signal „3I0> exceeded“ is set at address 2513 **T 3I0> Ext.**. If the zero sequence current exceeds the threshold **3I0> Threshold** for longer than the set time **T 3I0> alarm** (address 2520), the annunciation „3I0 detected“ is issued.

The non-delayed stage operates only if binary input „>WI rec. OK“ reports the proper functioning of the transmission channel.

Moreover, the phase-selective block signals **BLOCK Weak Inf** affect the non-delayed logic. Faulty pickups are thus prevented, especially after the dedicated line end was shut down.

In address 2530 **WI non delayed** the stage for instantaneous tripping is switched **OFF** or **ON** continuously.

Trip with Delay

The operation of the delayed tripping is determined by three parameters:

- Address 2517 **1pol. Trip** enables a single-pole trip command in case of single-pole faults if set to **ON**.
- If set to **ON**, address 2518 **1pol. with 3IO** allows a single-pole trip command only if the threshold **3IO> Threshold** for the zero current has been exceeded. If the threshold **3IO> Threshold** is not exceeded, single-pole faults do not lead to tripping. Position **OFF** allows a single-pole trip command even when **3IO> Threshold** is not exceeded. The time delay for the signal „3IO> exceeded“ is set at address 2513 **T 3IO> Ext..**
- If set to **ON**, address 2519 **3pol. Trip** allows also a three-pole trip command in the event of a multi-pole pickup. In position **OFF** the multi-pole pickup is only reported but a three-pole trip command is not issued (only report). But a single-pole or three-pole trip command can nevertheless be issued.

A delayed tripping stage is implemented to allow tripping the dedicated line end in case the transmission channel is faulted. When undervoltage conditions have been detected, this stage picks up in one or more phases and after a configured time (address 2515 **TM** and address 2516 **TT**) has elapsed it trips without delay.

Address 2531 **WI delayed** allows to set delayed tripping as operating mode. With **ON** this stage is permanently active. With the setting **by receive fail**, this stage will only be active if „>WI rec. OK“ is **not** reported OFF.

To avoid spurious pickup, phase selection via undervoltage is blocked entirely in the event of voltage failure (pickup of the fuse failure monitor or of the VT mcb). Moreover, the corresponding phases are equally blocked if another protection function, capable to detect faults, picks up.

2.10.3 Weak Infeed Tripping (optional)

2.10.3.1 Settings

Addresses which have an appended "A" can only be changed with DIGSI, under Additional Settings.

The table indicates region-specific presettings. Column C (configuration) indicates the corresponding secondary nominal current of the current transformer.

Addr.	Parameter	C	Setting Options	Default Setting	Comments
2501	FCT Weak Infeed		OFF ECHO only ECHO and TRIP	ECHO only	Weak Infeed function is
2502A	Trip/Echo DELAY		0.00 .. 30.00 sec	0.04 sec	Trip / Echo Delay after carrier receipt
2503A	Trip EXTENSION		0.00 .. 30.00 sec	0.05 sec	Trip Extension / Echo Impulse time

Addr.	Parameter	C	Setting Options	Default Setting	Comments
2504A	Echo BLOCK Time		0.00 .. 30.00 sec	0.05 sec	Echo Block Time
2505	UNDERVOLTAGE		2 .. 70 V	25 V	Undervoltage (ph-e)
2509	Echo:1channel		NO YES	NO	Echo logic: Dis and EF on common channel
2510	Uphe< Factor		0.10 .. 1.00	0.70	Factor for undervoltage Uphe<
2511	Time const. τ		1 .. 60 sec	5 sec	Time constant Tau
2512A	Rec. Ext.		0.00 .. 30.00 sec	0.65 sec	Reception extension
2513A	T 3I0> Ext.		0.00 .. 30.00 sec	0.60 sec	3I0> exceeded extension
2514	3I0> Threshold	1A	0.05 .. 1.00 A	0.50 A	3I0 threshold for neutral current pickup
		5A	0.25 .. 5.00 A	2.50 A	
2515	TM		0.00 .. 30.00 sec	0.40 sec	WI delay single pole
2516	TT		0.00 .. 30.00 sec	1.00 sec	WI delay multi pole
2517	1pol. Trip		ON OFF	ON	Single pole WI trip allowed
2518	1pol. with 3I0		ON OFF	ON	Single pole WI trip with 3I0
2519	3pol. Trip		ON OFF	ON	Three pole WI trip allowed
2520	T 3I0> alarm		0.00 .. 30.00 sec	10.00 sec	3I0> exceeded delay for alarm
2530	WI non delayed		ON OFF	ON	WI non delayed
2531	WI delayed		ON by receive fail	by receive fail	WI delayed

2.10.3.2 Information List

No.	Information	Type of Information	Comments
4203	>BLOCK Weak Inf	SP	>BLOCK Weak Infeed
4204	>BLOCK del. WI	SP	>BLOCK delayed Weak Infeed stage
4205	>WI rec. OK	SP	>Reception (channel) for Weak Infeed OK
4206	>WI reception	SP	>Receive signal for Weak Infeed
4221	WeakInf. OFF	OUT	Weak Infeed is switched OFF
4222	Weak Inf. BLOCK	OUT	Weak Infeed is BLOCKED
4223	Weak Inf ACTIVE	OUT	Weak Infeed is ACTIVE
4225	3I0 detected	OUT	Weak Infeed Zero seq. current detected
4226	WI U L1<	OUT	Weak Infeed Undervoltg. L1
4227	WI U L2<	OUT	Weak Infeed Undervoltg. L2
4228	WI U L3<	OUT	Weak Infeed Undervoltg. L3
4229	WI TRIP 3I0	OUT	WI TRIP with zero sequence current
4231	WeakInf. PICKUP	OUT	Weak Infeed PICKED UP
4232	W/I Pickup L1	OUT	Weak Infeed PICKUP L1

No.	Information	Type of Information	Comments
4233	W/I Pickup L2	OUT	Weak Infeed PICKUP L2
4234	W/I Pickup L3	OUT	Weak Infeed PICKUP L3
4241	WeakInfeed TRIP	OUT	Weak Infeed General TRIP command
4242	Weak TRIP 1p.L1	OUT	Weak Infeed TRIP command - Only L1
4243	Weak TRIP 1p.L2	OUT	Weak Infeed TRIP command - Only L2
4244	Weak TRIP 1p.L3	OUT	Weak Infeed TRIP command - Only L3
4245	Weak TRIP L123	OUT	Weak Infeed TRIP command L123
4246	ECHO SIGNAL	OUT	ECHO Send SIGNAL

2.11 Direct Local Trip

Any signal from an external protection or monitoring device can be coupled into the signal processing of the 7SD5 by means of a binary input. This signal may be delayed, alarmed and routed to one or several output relays.

2.11.1 Functional Description

External Trip of the Local Circuit Breaker

Figure 2-115 shows the logic diagram. If the device and circuit breaker are capable of single-phase operation, it is also possible to trip single phase. The tripping logic of the device in this case ensures that the conditions for single-phase tripping are satisfied (e.g. single-phase tripping enabled, automatic reclosure ready).

The external tripping can be switched on and off with a setting parameter and may be blocked via binary input.




Figure 2-115 Logic diagram of the local external tripping

Remote Trip of the Circuit Breaker at the Opposite Line End

On conventional transmission paths, one transmission channel per desired transmission direction is required for remote tripping at the remote end. For example, fibre optic connections or voice frequency modulated high frequency channels via pilot cables, power line carrier or microwave radio links can be used for this purpose in the following ways.

If the trip command of the distance protection is to be transmitted, it is best to use the integrated teleprotection function for the transmission of the signal as this already incorporates the optional extension of the transmitted signal, as described in Section 2.7. Any of the commands can of course be used to trigger the transmitter to initiate the send signal.

On the receiver side, the local external trip function is used. The receive signal is routed to a binary input which is assigned to the logical binary input function „>DTT Trip L123“. If single-pole tripping is desired, you can also use binary inputs „>DTT Trip L1“, „>DTT Trip L2“ and „>DTT Trip L3“. Figure 2-115 therefore also applies in this case.

2.11.2 Setting Notes

General

A precondition for the direct local trip is that the configuration of the functions (Section 2.1.1) has been configured in address 122 **DTT Direct Trip = Enabled**. At address 2201 **FCT Direct Trip** it can also be switched **ON** or **OFF**.

For direct local trip, a trip time delay can be set in address 2202 **Trip Time DELAY**. This delay can be used as a grading margin.

Once a trip command has been issued, it is maintained for at least as long as the set minimum trip command duration **TMin TRIP CMD** which was set for the device in general in address 240 (Section 2.1.2). Reliable operation of the circuit breaker is therefore ensured, even if the initiating signal pulse is very short.

2.11.3 Settings

Addr.	Parameter	Setting Options	Default Setting	Comments
2201	FCT Direct Trip	ON OFF	OFF	Direct Transfer Trip (DTT)
2202	Trip Time DELAY	0.00 .. 30.00 sec; ∞	0.01 sec	Trip Time Delay

2.11.4 Information List

No.	Information	Type of Information	Comments
4403	>BLOCK DTT	SP	>BLOCK Direct Transfer Trip function
4412	>DTT Trip L1	SP	>Direct Transfer Trip INPUT Phase L1
4413	>DTT Trip L2	SP	>Direct Transfer Trip INPUT Phase L2
4414	>DTT Trip L3	SP	>Direct Transfer Trip INPUT Phase L3
4417	>DTT Trip L123	SP	>Direct Transfer Trip INPUT 3ph L123
4421	DTT OFF	OUT	Direct Transfer Trip is switched OFF
4422	DTT BLOCK	OUT	Direct Transfer Trip is BLOCKED
4432	DTT TRIP 1p. L1	OUT	DTT TRIP command - Only L1
4433	DTT TRIP 1p. L2	OUT	DTT TRIP command - Only L2
4434	DTT TRIP 1p. L3	OUT	DTT TRIP command - Only L3
4435	DTT TRIP L123	OUT	DTT TRIP command L123

2.12 Direct Remote Trip and Transmission of Binary Information

2.12.1 Functional Description

7SD5 allows the transmission of up to 28 items of binary information of any type from one device to the others via the communications links provided for protection tasks. Four of them are transmitted like protection signals with high priority, i.e. very fast, and are therefore especially suitable for the transmission of external protection and trip signals which are generated outside of 7SD5. The other 24 are transmitted in the back-ground and are therefore suitable for any information that does not depend on high-speed transmission, such as information on the events taking place in a substation which may also be useful in other substations as well, (see also the specifications in chapter „Technical Data“).

The information is injected into the device via binary inputs and can be output at the other ends again via binary outputs. The integrated user-defined CFC logic allows to perform on both the transmitting and the receiving side logical operations on the signals and on other information from the protection and monitoring functions of the devices. Also an internal indication can be assigned via CFC to a transmission input and transmitted to the remote end(s).

The binary outputs and the binary inputs to be used must be allocated appropriately during the configuration of the inputs and outputs. The 4 high-priority signals are injected into the device via the binary inputs „>Remote Trip1“ to „>Remote Trip4“, are transmitted to the devices at the other ends and can be processed at each receiving side with the output functions „RemoteTrip1 rec“ to „RemoteTrip4 rec“.

The other 24 items of information reach the device via the binary inputs „>Rem. Signal 1“ to „>Rem. Signal24“ and are available under „Rem. Sig 1 recv“ etc. at the receiving side.

When allocating the binary inputs and outputs with DIGSI® you can provide the information to be transmitted with your own designation. If, for example, a line has a unit connected power transformer at one end and you wish to transmit trip by the Buchholz protection as „>Remote Trip1“ to the other end, you may use the input and designate it „Buchholz Trip“. At the other end, you designate the incoming information, „RemoteTrip1 rec“ e.g. „Buchholz remote“, and assign it to an output trip relay. In case of Buchholz protection trip, the annunciations will then be given according to your designations.

Even devices that have logged out functionally (see Section 2.4.1 under margin heading „Changeover of the Operating Mode“) can send and receive remote information and commands.

The annunciations of the devices, e.g. „Rel1 Login“ of the topology exploration can be used to determine whether the signals of the sending devices are still available. They are issued if device x is involved in the communication topology and this state is stable.

Once a transmission fault has been detected, the time **Td ResetRemote** at address 4512 is started for resetting the remote signals.

No further settings are required for the transmission of binary information. Each device sends the injected information to all other devices at the ends of the protected object. Where selection is necessary, it will have to be carried out by appropriate allocation and, if necessary, by a link at the receiving side.

2.12.2 Information List

No.	Information	Type of Information	Comments
3541	>Remote Trip1	SP	>Remote Trip 1 signal input
3542	>Remote Trip2	SP	>Remote Trip 2 signal input
3543	>Remote Trip3	SP	>Remote Trip 3 signal input
3544	>Remote Trip4	SP	>Remote Trip 4 signal input
3545	RemoteTrip1 rec	OUT	Remote Trip 1 received
3546	RemoteTrip2 rec	OUT	Remote Trip 2 received
3547	RemoteTrip3 rec	OUT	Remote Trip 3 received
3548	RemoteTrip4 rec	OUT	Remote Trip 4 received
3549	>Rem. Signal 1	SP	>Remote Signal 1 input
3550	>Rem.Signal 2	SP	>Remote Signal 2 input
3551	>Rem.Signal 3	SP	>Remote Signal 3 input
3552	>Rem.Signal 4	SP	>Remote Signal 4 input
3553	>Rem.Signal 5	SP	>Remote Signal 5 input
3554	>Rem.Signal 6	SP	>Remote Signal 6 input
3555	>Rem.Signal 7	SP	>Remote Signal 7 input
3556	>Rem.Signal 8	SP	>Remote Signal 8 input
3557	>Rem.Signal 9	SP	>Remote Signal 9 input
3558	>Rem.Signal10	SP	>Remote Signal 10 input
3559	>Rem.Signal11	SP	>Remote Signal 11 input
3560	>Rem.Signal12	SP	>Remote Signal 12 input
3561	>Rem.Signal13	SP	>Remote Signal 13 input
3562	>Rem.Signal14	SP	>Remote Signal 14 input
3563	>Rem.Signal15	SP	>Remote Signal 15 input
3564	>Rem.Signal16	SP	>Remote Signal 16 input
3565	>Rem.Signal17	SP	>Remote Signal 17 input
3566	>Rem.Signal18	SP	>Remote Signal 18 input
3567	>Rem.Signal19	SP	>Remote Signal 19 input
3568	>Rem.Signal20	SP	>Remote Signal 20 input
3569	>Rem.Signal21	SP	>Remote Signal 21 input
3570	>Rem.Signal22	SP	>Remote Signal 22 input
3571	>Rem.Signal23	SP	>Remote Signal 23 input
3572	>Rem.Signal24	SP	>Remote Signal 24 input
3573	Rem.Sig 1recv	OUT	Remote signal 1 received
3574	Rem.Sig 2recv	OUT	Remote signal 2 received
3575	Rem.Sig 3recv	OUT	Remote signal 3 received
3576	Rem.Sig 4recv	OUT	Remote signal 4 received
3577	Rem.Sig 5recv	OUT	Remote signal 5 received
3578	Rem.Sig 6recv	OUT	Remote signal 6 received
3579	Rem.Sig 7recv	OUT	Remote signal 7 received
3580	Rem.Sig 8recv	OUT	Remote signal 8 received
3581	Rem.Sig 9recv	OUT	Remote signal 9 received
3582	Rem.Sig10recv	OUT	Remote signal 10 received
3583	Rem.Sig11recv	OUT	Remote signal 11 received
3584	Rem.Sig12recv	OUT	Remote signal 12 received

No.	Information	Type of Information	Comments
3585	Rem.Sig13recv	OUT	Remote signal 13 received
3586	Rem.Sig14recv	OUT	Remote signal 14 received
3587	Rem.Sig15recv	OUT	Remote signal 15 received
3588	Rem.Sig16recv	OUT	Remote signal 16 received
3589	Rem.Sig17recv	OUT	Remote signal 17 received
3590	Rem.Sig18recv	OUT	Remote signal 18 received
3591	Rem.Sig19recv	OUT	Remote signal 19 received
3592	Rem.Sig20recv	OUT	Remote signal 20 received
3593	Rem.Sig21recv	OUT	Remote signal 21 received
3594	Rem.Sig22recv	OUT	Remote signal 22 received
3595	Rem.Sig23recv	OUT	Remote signal 23 received
3596	Rem.Sig24recv	OUT	Remote signal 24 received

2.13 Instantaneous High-Current Switch-onto-Fault Protection (SOTF)

2.13.1 Functional Description

General

The instantaneous high-current switch-onto-fault protection function is provided to disconnect immediately, and without delay, feeders that are switched onto a high-current fault. It serves, e.g. as a rapid protection for connecting a feeder with closed grounding disconnector. In order to function properly, the devices at all ends of the protected object must know the circuit breaker positions (breaker auxiliary contacts).

A second stage works fast and without delay, regardless of the circuit breaker position.

I>>> Stage

The pickup of the I>>> stage measures each phase current and compares it to the setting value $I_{>>>}$. The currents are numerically filtered so that only the fundamental frequency is evaluated. DC current components in the fault current and in the CT secondary circuit following the switching off of large currents practically have no influence on this high-current pickup operation. If the setting value is exceeded by more than twice its value, the stage will automatically use the peak value of the unfiltered measured quantity so that extremely short command times are possible.

This stage is only enabled when the local circuit breaker is closed while all remaining line ends of the protected object are open. The devices exchange the status of their respective circuit breakers continuously via the communication link. If the protected object is already live (from a different end) the stage is not effective. An indispensable precondition for the functioning of the I-STUB stage is that the auxiliary contacts of the circuit breakers are connected at all ends of the protected object and allocated to the relevant binary inputs. If this is not the case, this stage is not effective. The central function control communicates the information of the circuit breaker position to the high-current instantaneous tripping (see also Section 2.23.1).

Figure 2-116 shows the logic diagram. The I-STUB stage at the bottom of the diagram operates separately for each phase. During the manual closing of the circuit breaker all three phases are enabled via the internal signal „SOTF enab. L123“ which is issued by the central functional control of the protection, provided that the manual closing can be recognized there (see Section 2.23.1).

Tripping can also be enabled separately for each phase by the signals „SOTF enab. Lx“. This applies also, for example, to automatic reclosure after single-pole tripping. Then, single-pole tripping with this stage is possible, but only if the device is designed for single-pole tripping.

I>>>> Stage

The I>>>> stage trips regardless of the position of the circuit breakers. Here, the currents are also numerically filtered and the peak value of the currents is measured from the double setting value onwards. Figure 2-116 shows the logic diagram in the upper part.

Therefore, this stage is used when current grading is possible. This is possible with a small source impedance and at the same time a high impedance of the protected object (an example can be found in the advice on setting notes, Section 2.13.2).

The I>>>> stage is enabled automatically by the current-step monitoring dI/dt of the device for a duration of 50 ms. This stage operates separately for each phase.




Figure 2-116 Logic diagram of the high current switch on to fault protection

2.13.2 Setting Notes

General

A precondition for the use of the switch-onto-fault overcurrent protection function is that the configuration of the device functions (Section 2.1.1) has been configured in address 124 **HS/SOTF-O/C = Enabled**. At address 2401 **FCT HS/SOTF-O/C** it can also be switched **ON** or **OFF**.

I>>> Stage

The magnitude of fault current which leads to the pickup of the I>>> stage is set as **I>>>** in address 2404. This stage is active only during the connecting of the local end while the circuit breakers at all other ends of the protected object are open. Choose a value which is high enough for the protection not to pick up on the RMS value of the inrush current produced during the connection of the protected object. On the other hand, fault currents flowing through the protected object need not be considered.

When using a PC and DIGSI® to apply the settings, these can be optionally entered as primary or secondary values. If secondary quantities are used, all currents must be converted to the secondary side of the current transformers.

I>>>> Stage

The I>>>> stage (address 2405) works regardless of the circuit breaker position. Since it trips extremely fast it must be set high enough not to pickup on a fault current flowing through the protected object. This means that it can be used only if the protected object allows current grading, as is the case with transformers, series reactors or

long lines with small source impedance. In other cases it is set to ∞ (default setting). This parameter can only be altered with DIGSI® under **Additional Settings**.

When using a PC and DIGSI® to apply the settings, these can be optionally entered as primary or secondary values. If secondary quantities are used, all currents must be converted to the secondary side of the current transformers.

Exemplary calculation:

110 kV overhead line 150 mm² with the data:

s (length)	= 60 km
R_1/s	= 0.19 Ω/km
X_1/s	= 0.42 Ω/km

Short-circuit power at the feeding end:

$S_{sc}'' = 3.5 \text{ GVA}$ (subtransient, since the $I_{>>>>}$ stage can respond to the first peak value)

Current transformers 600 A/5 A

From that the line impedance Z_L and the source impedance Z_S are calculated:

$$Z_1/s = \sqrt{0.19^2 + 0.42^2} \text{ } \Omega/\text{km} = 0.46 \text{ } \Omega/\text{km}$$

$$Z_L = 0.46 \text{ } \Omega/\text{km} \cdot 60 \text{ km} = 27.66 \text{ } \Omega$$

$$Z_V = \frac{110^2 \text{ kV}^2}{3500 \text{ MVA}} = 3.46 \text{ } \Omega$$

The three-phase short-circuit current at line end is $I_{sc \text{ end}}''$ (with source voltage 1.1 U_N):

$$I_{k \text{ End}}'' = \frac{1.1 \cdot U_N}{\sqrt{3} \cdot (Z_V + Z_L)} = \frac{1.1 \cdot 110 \text{ kV}}{\sqrt{3} \cdot (3.46 \text{ } \Omega + 27.66 \text{ } \Omega)} = 2245 \text{ A}$$

With a safety factor of 10 %, the following primary setting value results:

Setting value $I_{>>>>} = 1.1 \cdot 2245 \text{ A} = 2470 \text{ A}$

Or the secondary setting value:

$$\text{Setting Value } I_{>>>>} = 1.1 \cdot \frac{2245 \text{ A}}{600 \text{ A}} \cdot 5 \text{ A} = 20.6 \text{ A}$$

i.e. in case of fault currents exceeding 2470 A (primary) or 20.6 A (secondary) you can be sure that a short-circuit has occurred on the protected line. This line can be disconnected immediately.

Note: The calculation was carried out with absolute values, which is sufficiently precise for overhead lines. A complex calculation is only needed if the angles of the source impedance and the line impedance vary considerably.

2.13.3 Settings

Addresses which have an appended "A" can only be changed with DIGSI, under Additional Settings.

The table indicates region-specific presettings. Column C (configuration) indicates the corresponding secondary nominal current of the current transformer.

Addr.	Parameter	C	Setting Options	Default Setting	Comments
2401	FCT HS/SOTF-O/C		ON OFF	ON	Inst. High Speed/SOTF-O/C is
2404	I>>>	1A	0.10 .. 15.00 A; ∞	1.50 A	I>>> Pickup
		5A	0.50 .. 75.00 A; ∞	7.50 A	
2405A	I>>>>	1A	1.00 .. 25.00 A; ∞	∞ A	I>>>> Pickup
		5A	5.00 .. 125.00 A; ∞	∞ A	

2.13.4 Information List

No.	Information	Type of Information	Comments
4253	>BLOCK SOTF-O/C	SP	>BLOCK Instantaneous SOTF Overcurrent
4271	SOTF-O/C OFF	OUT	SOTF-O/C is switched OFF
4272	SOTF-O/C BLOCK	OUT	SOTF-O/C is BLOCKED
4273	SOTF-O/C ACTIVE	OUT	SOTF-O/C is ACTIVE
4281	SOTF-O/C PICKUP	OUT	SOTF-O/C PICKED UP
4282	SOF O/CpickupL1	OUT	SOTF-O/C Pickup L1
4283	SOF O/CpickupL2	OUT	SOTF-O/C Pickup L2
4284	SOF O/CpickupL3	OUT	SOTF-O/C Pickup L3
4285	I>>>>O/C p.upL1	OUT	High Speed-O/C Pickup I>>>> L1
4286	I>>>>O/C p.upL2	OUT	High Speed-O/C Pickup I>>>> L2
4287	I>>>>O/C p.upL3	OUT	High Speed-O/C Pickup I>>>> L3
4289	HS/SOF TRIP1pL1	OUT	High Speed/SOTF-O/C TRIP - Only L1
4290	HS/SOF TRIP1pL2	OUT	High Speed/SOTF-O/C TRIP - Only L2
4291	HS/SOF TRIP1pL3	OUT	High Speed/SOTF-O/C TRIP - Only L3
4292	HS/SOF TRIP 1p	OUT	High Speed/SOTF-O/C TRIP 1pole
4293	HS/SOF Gen.TRIP	OUT	High Speed/SOTF-O/C General TRIP
4294	HS/SOF TRIP 3p	OUT	High Speed/SOTF-O/C TRIP 3pole
4295	HS/SOF TRIPL123	OUT	High Speed/SOTF-O/C TRIP command L123

2.14 Backup Time Overcurrent Protection

The 7SD5 device has an integrated time overcurrent protection function. This function may optionally be used either as back-up time delayed overcurrent protection or as emergency overcurrent protection. Please note that this protection function is available in addition to main protection functions, such as differential and distance protection, to provide even more security.

2.14.1 General

While the general line protection 7SD5, when configured with differential protection, can only operate properly if each device receives correctly the data of the other devices, and distance protection can only operate properly if the correct measuring voltage is applied to the device, the emergency time overcurrent protection needs only the local currents. The emergency time overcurrent protection is automatically activated when the data communication of the differential protection is disturbed and the measuring voltage fails (emergency operation). Both the differential protection and distance protection are then blocked.

This means that emergency operation replaces the differential protection and/or the distance protection as short-circuit protection if protection data communication fails and the distance protection working in parallel detects a failure of the measuring voltages from one of the following conditions:

- The „Voltage transformer mcb tripped“ signal is received via binary input, indicating that the measured voltage signal is lost, or
- One of the internal monitoring functions (e.g. current sum, wire break or „Fuse-Failure-Monitor“) is activated, see Section 2.22.1.3.

For the overcurrent protection there are in total four stages for the phase currents and four stages for the earth currents as follows:

- Two overcurrent stages with a definite time characteristic (O/C with DT),
- One overcurrent stage with inverse time characteristic (IDMT),
- A further overcurrent stage which has an additional enable input.

These four stages are independent from each other and are freely combinable. Blocking from external criteria via binary inputs is possible, as well as switch-onto-fault tripping. It is also possible to release one or more of the stages in switching-onto-fault conditions. If not all stages are required, each individual stage can be deactivated by setting the pickup threshold to ∞ .

2.14.2 Functional Description

Measured Values

The phase currents are fed to the device via the input transformers of the measuring input. The earth current $3I_0$ is either measured directly or calculated.

If I_4 is connected to the starpoint of the current transformer set, the earth current will be available directly as measured quantity.

If I_4 is connected to a separate earth current transformer, this measurement will be used, while considering the factor **I4 / Iph CT** (address 221, see Section 2.1.2 under margin heading „Current Connections“) of Power System Data 1. If the residual current is not connected to the fourth current input I_4 (address 220 **I4 transformer**

= **Not connected**, see Section 2.1.2), the device will calculate the residual current from the phase currents. Of course, all three phase currents deriving from three star-connected current transformers must be available and connected in this case.

Definite Time High-set Current Stage I>>

Each phase current is compared with the setting value **Iph>>** after numerical filtering; the earth current is compared with **3IO>> PICKUP**. Currents above the associated pickup value are detected and signalled. After expiry of the associated time delays **T Iph>>** or **T 3IO>>** a trip command is issued. The dropout value is approximately 5% below pickup value, but at least 1.5% of the nominal current, below the pickup value.

Figure 2-117 shows the logic diagram of the I>> stages. The stages can be blocked via a binary input „>BLOCK O/C I>>“. In addition, the earth current stage can be blocked separately via the binary input „>BLOCK O/C Ie>>“, e.g. during a single-pole dead time before reclosure in order to avoid a spurious tripping with the zero phase-sequence system which is present then.

Binary inputs „>O/C InstTRIP“ and the function block „switch-onto-fault“ are common to all stages and described below. They may, however, separately affect the phase and/or earth current stages. This can be achieved with two parameters:

- **I>> Telep/BI** (address 2614), determines whether a non-delayed trip of this stage via binary input „>O/C InstTRIP“ is possible (**YES**) or impossible (**NO**). This parameter is also used for instantaneous tripping before automatic reclosure.
- **I>> SOTF** (address 2615), determines whether this stage shall issue non-delayed tripping (**YES**) or not (**NO**) in case of switching-onto-fault conditions.




Figure 2-117 Logic diagram of the I>> stage

In addition, the earth current stage can be blocked separately via the binary input „>BLOCK O/C Ie>>“, e.g. during a single-pole dead time before reclosure in order to avoid a spurious tripping with the zero phase-sequence system which is present then.

Definite Time Overcurrent Stage I>

The logic of the overcurrent stage I is the same as that of the I>> stages. In all references **Iph>>** must merely be replaced with **Iph>** or **3I0>> PICKUP** with **3I0>**. In all other respects Figure 2-117 applies.

Inverse Time Overcurrent Stage I_p

The logic of the inverse overcurrent stage also operates chiefly in the same way as the remaining stages. However, the time delay is calculated here based on the type of the set characteristic, the intensity of the current and a time multiplier (following figure). A pre-selection of the available characteristics was already carried out during the configuration of the protection functions. Furthermore, an additional constant time delay **T Ip Add** or **T 3I0p Add** may be selected, which is added to the inverse time. The possible characteristics are shown in the Technical Data.

The following figure shows the logic diagram. The setting parameter addresses of the IEC characteristics are shown by way of an example. In the setting information (Section 2.14.3) the different setting addresses are elaborated upon.




Figure 2-118 Logic diagram of the I_p -stage (inverse time overcurrent protection), for example IEC characteristic

Additional Stage I>>>

The additional definite time or instantaneous overcurrent stage I-STUB has an extra enable input (Figure 2-119). It is therefore also suitable e.g. as an emergency stage. The enable input „>I - STUB ENABLE“ can be assigned to the output signal „Emer . mode“ (either via binary outputs and inputs or via the user-definable logic CFC functions). The stage is then automatically active when the differential protection is not effective due to a data disturbance, and the distance protection due to a failure of the measuring voltage.

The I>>> stage can, however, also be used as a standard additional and independent overcurrent stage, since it works independent of the other stages. In this case, the enable input „>I - STUB ENABLE“ must be activated permanently (via a binary input or CFC).




Figure 2-119 Logic diagram of the I>>> stage

Instantaneous Tripping before Automatic Reclosure

Automatic reclosure is applied in order to instantaneously remove the fault before automatic reclosure. A release signal from an external automatic reclosure device can be injected via binary input „>O/C InstTRIP“. The internal automatic reclosure - if available - is also effected by this command. Any stage of the overcurrent protection can thus perform an instantaneous trip before reclosure via the parameter **Telep/BI**.

....

Switching onto a Fault

To perform an instantaneous trip when the circuit breaker is manually closed onto a dead fault, the manual closing command of the control discrepancy switch can be fed to the device via a binary input. The overcurrent protection can then trip three-pole without delay or with a reduced delay. It can be determined via parameter setting for which stage(s) the rapid tripping following manually closure on to a dead fault applies (refer also to the logic Figures 2-117, 2-118 and 2-119).

Pickup and Tripping Logic

The pickup signals of the individual phases (or the earth) and of the stages are linked in such a way that both the phase information and the stage which has picked up are indicated (Table 2-12).

In case of trip signals, the stage which resulted in the trip command is also indicated. For single-pole tripping, the pole is identified (see also Section 2.23.1 „Pickup Logic of the Entire Device“).

Table 2-12 Pickup signals of the single phases

Internal Indication	Display	Output Indication	No.
I>> PU L1 I> PU L1 Ip PU L1 I>>> PU L1	2-117 2-118 2-119	„O/C Pickup L1“	7162
I>> PU L2 I> PU L2 Ip PU L2 I>>> PU L2	2-117 2-118 2-119	„O/C Pickup L2“	7163
I>> PU L3 I> PU L3 Ip PU L3 I>>> PU L3	2-117 2-118 2-119	„O/C Pickup L3“	7164
I>> PU E I> PU E Ip PU E I>>> PU E	2-117 2-118 2-119	„O/C Pickup E“	7165
I>> PU L1 I>> PU L2 I>> PU L3 I>> PU E	2-117 2-117 2-117 2-117	„O/C PICKUP I>>“	7191
I> PU L1 I> PU L2 I> PU L3 I> PU E		„O/C PICKUP I>“	7192
Ip PU L1 Ip PU L2 Ip PU L3 Ip PU E	2-118 2-118 2-118 2-118	„O/C PICKUP Ip“	7193
I>>> PU L1 I>>> PU L2 I>>> PU L3 I>>> PU E	2-119 2-119 2-119 2-119	„I-STUB PICKUP“	7201
(All pickups)		„O/C PICKUP“	7161

2.14.3 Setting Notes

General

During configuration of the scope of functions for the device (address 126) the available characteristics were determined. Depending on the configuration and the order variant, only those parameters that apply to the selected characteristics are accessible in the procedures described below.

If the differential protection and the distance protection operate in parallel in the protective relay, emergency operation will not be activated unless both protection functions have become ineffective. If only one of the two protection functions fails, the other protection function can provide complete protection of the object, so that emergency operation is not yet required in such a case.

Emergency operation is activated if only one of the protection functions (address 115, 116 and 117 = **Disabled** or address 112 **DIFF. PROTECTION = Disabled**) has been configured.

Address 2601 is set according to the desired mode of operation of the overcurrent protection: **Operating Mode = ON** means that the time overcurrent protection operates independently of the other protection functions, i.e. as a backup time overcurrent protection. If it is intended to work only as an emergency function in case of a transmission and/or voltage failure, set **Only Emer. prot.** Finally, it can also be set to **OFF**.

If not all stages are required, each individual stage can be deactivated by setting the pickup threshold to ∞ . But if you set only an associated time delay to ∞ this does not suppress the pickup signals but prevents the timers from running.

The I>>> stage is effective even if the operating mode of the time overcurrent protection has been set to **Only Emer. prot** and „>I - STUB ENABLE“ is released.

One or several stages can be set as instantaneous tripping stages when switching onto a fault. This is chosen during the setting of the individual stages (see below). To avoid a spurious pickup due to transient overcurrents, the delay **SOTF Time DELAY** (address 2680) can be set. Typically, the presetting of **0** is correct. A short delay can be useful in case of long cables for which high inrush currents can be expected, or for transformers. The time delay depends on the severity and duration of the transient overcurrents as well as on which stages were selected for the fast switch onto fault clearance.

High-set stages I_{ph}>>, 3I₀>>

The I>> stages **I_{ph}>>** (address 2610) and **3I₀>> PICKUP** (address 2612) together with the I> stages or the I_p stages result in a two-stage characteristic. Of course, all three stages can be combined as well. If one stage is not required, the pickup value has to be set to ∞ . The I>> stages always operates with a defined delay time.

If the I>> stages are used for instantaneous tripping before the automatic reclosure, the current setting corresponds to the I> or I_p stages (see below). In this case only the different delay times are of interest. The times **T I_{ph}>>** (address 2611) and **T 3I₀>>** (address 2613) can then be set to **0** or a very low value, as the fast clearance of the fault takes priority over the selectivity before the automatic reclosure is initiated. These stages have to be blocked before final trip in order to achieve the selectivity.

For very long lines with a small source impedance or on applications with large reactances (e.g. transformers, series reactors), the I>> stages can also be used for current grading. In this case they must be set in such a way that they do not pick up in case of a fault at the end of the line. The times can then be set to **0** or to a small value.

When using a personal computer and DIGSI® to apply the settings, these can be optionally entered as primary or secondary values. If secondary quantities are used, all currents must be converted to the secondary side of the current transformers.

Calculation Example:

110 kV overhead line 150 mm²:

$$s \text{ (length)} = 60 \text{ km}$$

$$R_1/s = 0.19 \text{ } \Omega/\text{km}$$

$$X_1/s = 0.42 \text{ } \Omega/\text{km}$$

Short-circuit power at the beginning of the line:

$$S_k' = 2.5 \text{ GVA}$$

Current Transformer 600 A / 5 A

From that the line impedance Z_L and the source impedance Z_S are calculated:

$$Z_1/s = \sqrt{0.19^2 + 0.42^2} \text{ } \Omega/\text{km} = 0.46 \text{ } \Omega/\text{km}$$

$$Z_L = 0.46 \text{ } \Omega/\text{km} \cdot 60 \text{ km} = 27.66 \text{ } \Omega$$

$$Z_S = \frac{(110 \text{ kV})^2}{2500 \text{ MVA}} = 4.84 \text{ } \Omega$$

The three-phase fault current at the line end is $I_{F \text{ End}}$:

$$I_{F \text{ End}} = \frac{1.1 \cdot U_N}{\sqrt{3} \cdot (Z_S + Z_L)} = \frac{1.1 \cdot 110 \text{ kV}}{\sqrt{3} \cdot (4.84 \text{ } \Omega + 27.66 \text{ } \Omega)} = 2150 \text{ A}$$

With a safety factor of 10 %, the following primary setting value is calculated:

$$\text{Set value } I_{>>} = 1.1 \cdot 2150 \text{ A} = 2365 \text{ A}$$

or the secondary setting value:

$$\text{Setting value } I_{>>} = 1.1 \cdot \frac{2150 \text{ A}}{600 \text{ A}} \cdot 5 \text{ A} = 19.7 \text{ A}$$

i.e. in case of fault currents exceeding 2365 A (primary) or 19.7 A (secondary) you can be sure that a short-circuit has occurred on the protected line. This fault can immediately be cleared by the time overcurrent protection.

Note: the calculation was carried out with absolute values, which is sufficiently precise for overhead lines. If the angles of the source impedance and the line impedance vary considerably, a complex calculation must be carried out.

A similar calculation must be carried out for earth faults, with the maximum earth current occurring at the line end during a short-circuit being decisive.

The set time delays are pure additional delays, which do not include the operating time (measuring time).

The parameter **I>> Telep/BI** (address 2614) defines whether the time delays **T Iph>>** (address 2611) and **T 3IO>>** (address 2613) can be bypassed by the binary input „>0/C InstTRIP“ (No 7110) or by the operational automatic reclosure function. The binary input (if allocated) is applied to all stages of the time overcurrent protection. With **I>> Telep/BI = YES** you define that the I>> stages trip without delay after pickup if the binary input was activated. For **I>> Telep/BI = NO** the set delays are always active.

Instantaneous tripping by the operational auto-reclosure function should only be chosen if the overcurrent protection is set to emergency function. Since the fast main

protection function - differential protection and/or distance protection - guarantees a fast and selective tripping with or without auto-reclosure, the overcurrent protection as a back-up protection may not perform a non-selective trip, even before auto-reclosure.

If the **I>>** stage, when switching the line on to a fault, is to trip without delay or with a short delay, **SOTF Time DELAY** (address 2680, see above under margin heading „General“), the parameter **I>> SOTF** (address 2615) is set to **YES**. Any other stage can be selected as well for this instantaneous tripping.

Overcurrent Stages **I_{ph}>, 3I₀> in Definite-time Overcurrent Protection**

For the setting of the current pickup value, **I_{ph}>** (address 2620), the maximum operating current is most decisive. Pickup due to overload should never occur, since the device in this operating mode operates as fault protection with correspondingly short tripping times and not as overload protection. For this reason, a pickup value of about 10 % above the expected peak load is recommended for line protection, and a setting of about 20 % above the expected peak load is recommended for transformers and motors.

When using a personal computer and DIGSI® to apply the settings, these can be optionally entered as primary or secondary values. If secondary quantities are used, all currents must be converted to the secondary side of the current transformers.

Calculation Example:

110 kV overhead line 150 mm²

maximum transmittable power

$$P_{\max} = 120 \text{ MVA}$$

corresponding to

$$I_{\max} = 630 \text{ A}$$

Current Transformer 600 A / 5 A

Safety factor 1.1

With settings in primary quantities the following setting value is calculated:

$$\text{Set value } I > = 1.1 \cdot 630 \text{ A} = 693 \text{ A}$$

With settings in secondary quantities the following setting value is calculated:

$$\text{Setting value } I > = 1.1 \cdot \frac{630 \text{ A}}{600 \text{ A}} \cdot 5 \text{ A} = 5.8 \text{ A}$$

The earth current stage **3I₀>** (address 2622) should be set to detect the smallest earth fault current to be expected.

The time delay **T I_{ph}>** (address 2621) results from the time grading schedule designed for the network. For the use as emergency overcurrent protection shorter delay times make sense (one grading time step above instantaneous tripping), since this function is to work only in case of a failure of the main protection functions, i.e. differential and/or distance protection.

The time **T 3I₀>** (address 2623) can normally be set shorter, according to a separate time grading schedule for earth currents.

The set times are mere additional delays for the independent stages, which do not include the inherent operating time of the protection. If only the phase currents are to be monitored, set the pickup value of the earth fault stage to ∞.

The parameter **I> Telep/BI** (address 2624) defines whether the time delays **T I_{ph}>** (address 2621) and **T 3I₀>** (address 2623) can be bypassed by the binary input „>0/C InstTRIP“. The binary input (if allocated) is applied to all stages of the

time-overcurrent protection. With **I> Telep/BI = YES** you define that the I> stages trip without delay after pickup if the binary input was activated. For **I> Telep/BI = NO** the set delays are always active.

Instantaneous tripping by the operational auto-reclosure function should only be chosen if the overcurrent protection is set to emergency function. Since the fast main protection function - differential protection and/or distance protection - guarantees a fast and selective tripping with or without auto-reclosure, the overcurrent protection as a back-up protection may not perform a non-selective trip, even before auto-reclosure.

If the I> stage, when switching the line on to a fault, is to trip without delay or with a short delay, **SOTF Time DELAY** (address 2680, see above under margin heading „General“), the parameter **I> SOTF** (address 2625) is set to **YES**. We recommend, however, not to choose the sensitive setting for the switch on to a fault function as energizing of the line on to a fault should cause a large fault current. It is important to avoid that the selected stage picks up due to transients during line energization.

Overcurrent Stages I_p, 3I_{0p} in Inverse- Time O/C Protec- tion with IEC Char- acteristics

In the case of time inverse overcurrent stages, various characteristics can be selected, depending on the ordering version of the device and the configuration (address 126), with IEC characteristics (address 126 **Back-Up O/C = TOC IEC**) the following options are available in address 2660 **IEC Curve**:

Normal Inverse (inverse, type A according to IEC 60255-3),

Very Inverse (very inverse, type B according to IEC 60255-3),

Extremely Inv. (extremely inverse, type C according to IEC 60255-3), and

LongTimeInverse (longtime, type B according to IEC 60255-3).

The characteristics and equations they are based on are listed in the „Technical Data“.

For the setting of the current thresholds **I_p>** (address 2640) and **3I_{0p} PICKUP** (address 2650) the same considerations as for the overcurrent stages of the definite time protection (see above) apply. In this case it must be noted that a safety margin between the pickup threshold and the set value has already been incorporated. Pickup only occurs at a current which is approximately 10 % above the set value.

The above example shows that the maximum expected operating current may directly be applied as setting here.

Primary: Set value **I_p** = 630 A,

Secondary: Set value **I_p** = 5,25 A, d.h. (630 A/600 A) X 5 A.

The time multiplier **T I_p Time Dial** (address 2642) derives from the time grading schedule set for the network. For the use as emergency overcurrent protection shorter delay times make sense (one grading time step above instantaneous tripping), since this function is to work only in case of a failure of the main protection functions, i.e. differential and/or distance protection.

The time multiplier setting **T 3I_{0p} TimeDial** (address 2652) can usually be set smaller according to a separate earth fault grading plan. If only the phase currents are to be monitored, set the pickup value of the earth fault stage to ∞.

In addition to the current-dependent delays, a time fixed delay can be set, if necessary. The settings **T I_p Add** (address 2646 for phase currents) and **T 3I_{0p} Add** (address 2656 for earth currents) are in addition to the time delays resulting from the set curves.

The parameter **I(3I_{0p}) Tele/BI** (address 2670) defines whether the time delays **T I_p Time Dial** (address 2642), including the additional delay **T I_p Add** (address 2646), and **T 3I_{0p} TimeDial** (address 2652), including the additional delay **T 3I_{0p} Add** (address 2656), can be bypassed by the binary input „>O/C InstTRIP“

(No. 7110). The binary input (if allocated) is applied to all stages of the time-overcurrent protection. With **I(3IO)p Tele/BI = YES** you define that the IP stages trip without delay after pickup if the binary input was activated. For **I(3IO)p Tele/BI = NO** the set delays are always active.

Instantaneous tripping by the operational auto-reclosure function should only be chosen if the overcurrent protection is set to emergency function. Since the fast main protection function - differential protection and/or distance protection - guarantees a fast and selective tripping with or without auto-reclosure, the overcurrent protection as a back-up protection may not perform a non-selective trip, even before auto-reclosure.

If the IP stage, when switching the line on to a fault, is to trip without delay or with a short delay, **SOTF Time DELAY** (address 2680, see above under margin heading „General“), the parameter **I(3IO)p SOTF** (address 2671) is set to **YES**. We recommend, however, not to choose the sensitive setting for the switch on to a fault function as energizing of the line on to a fault should cause a large fault current. It is important to avoid that the selected stage picks up due to transients during line energization.

Overcurrent Stages I_p, 3I_{OP} in Inverse- Time O/C Protec- tion with ANSI Characteristics

In the case of the inverse overcurrent stages, various characteristics can be selected, depending on the ordering version of the device and the configuration (address 126). With the ANSI characteristics (address 126 **Back-Up O/C = TOC ANSI**), the following options are available at address 2661 **ANSI Curve**:

Inverse,
Short Inverse,
Long Inverse,
Moderately Inv.,
Very Inverse,
Extremely Inv. and
Definite Inv.

The characteristics and equations they are based on are listed in the „Technical Data“.

For the setting of the current thresholds **Ip>** (address 2640) and **3IOp PICKUP** (address 2650) the same considerations as for the overcurrent stages of the definite time protection (see above) apply. In this case, it must be noted that a safety margin between the pickup threshold and the set value has already been incorporated. Pickup only occurs at a current which is approximately 10% above the set value.

The above example shows that the maximum expected operating current may directly be applied as setting here.

Primary: Set value IP = 630 A,

Secondary: Setting value IP = 5,25 A, d.h. (630 A/600 A) X 5 A.

The time multiplier **Time Dial TD Ip** (address 2643) derives from the time grading schedule set for the network. For the use as emergency overcurrent protection shorter delay times make sense (one grading time step above instantaneous tripping), since this function is to work only in case of a failure of the main protection functions, i.e. differential and/or distance protection.

The time multiplier setting **TimeDial TD3IOp** (address 2653) can usually be set smaller according to a separate earth fault grading plan. If only the phase currents are to be monitored, set the pickup value of the earth fault stage to ∞.

In addition to the current-dependent delays, a delay of constant length can be set, if necessary. The setting **T Ip Add** (address 2646 for phase currents) and **T 3IOp**

Add (address 2656 for earth currents) are in addition to the time delays resulting from the set curves.

The parameter **I(3IO)p Tele/BI** (address 2670) defines whether the time delays **Time Dial TD Ip** (address 2643), including the additional delay **T Ip Add** (address 2646), and **TimeDial TD3IOp** (address 2653), including the additional delay **T 3IOp Add** (address 2656), can be bypassed by the binary input „>O/C InstTRIP“ (No. 7110). The binary input (if allocated) is applied to all stages of the time-overcurrent protection. With **I(3IO)p Tele/BI = YES** you define that the IP stages trip without delay after pickup if the binary input was activated. For **I(3IO)p Tele/BI = NO** the set delays are always active.

Instantaneous tripping by the operational auto-reclosure function should only be chosen if the overcurrent protection is set to emergency function. Since the fast main protection function - differential protection and/or distance protection - guarantees a fast and selective tripping with or without auto-reclosure, the overcurrent protection as a back-up protection may not perform a non-selective trip, even before auto-reclosure.

If the IP stage, when switching the line on to a fault, is to trip without delay or with a short delay, **SOTF Time DELAY** (address 2680, see above under margin heading „General“), the parameter **I(3IO)p SOTF** (address 2671) is set to **YES**. We recommend, however, not to choose the sensitive setting for the switch on to a fault function as energizing of the line on to a fault should cause a large fault current. It is important to avoid that the selected stage picks up due to transients during line energization.

Additional Stage

I_{ph}>>>

The I-STUB stage can be used as an additional definite time overcurrent stage, since it works independently of the other stages. In this case, the enable input „>I - STUB ENABLE“ (No 7131) must be activated permanently (via a binary input or CFC).

Since the I-STUB stage has an additional enable input, it is also suitable e.g. as an emergency stage if the remaining stages are used as backup stages. The release input „>I - STUB ENABLE“ (No. 7131) can be assigned the output signal „Emer . mode“ (No. 2054) (either via binary outputs and inputs or via the user-definable logic CFC functions).

The considerations for the use of the I-STUB stage as an emergency function are the same as for the I> stages. The setting value **Iph> STUB** (address 2630) must here too be higher than the maximum operational current to be expected, in order to avoid pickup without fault. The delay **T Iph STUB** (address 2631), however, can be shorter than defined in the time grading schedule, since this stage works only in emergency operation, i.e. in case of a communication failure of the differential protection or a local measurement voltage failure of the distance protection. Normally, one grading time above the base time of the differential protection is sufficient.

The residual current stage **3IO> STUB** (address 2632) should correspondingly pick up on the smallest residual current to be expected during an earth fault and the delay **T 3IO STUB** (address 2633) should exceed the base time of the differential protection by one grading time. If only the phase currents are to be monitored, set the pickup value of the residual current stage to ∞ .

The I-STUB stage can also be accelerated by the enable signal „>O/C InstTRIP“ (No 7110), e.g. before an auto-reclosure. This is defined with parameter **I - STUB Telep/BI** (address 2634). Set it to **YES** if the I-STUB stage is to trip without delay as long as the binary input „>O/C InstTRIP“ is activated or the internal auto-reclosure function is ready to operate. Instantaneous tripping by the operational auto-reclosure should only be chosen if the I-STUB stage is set as an emergency function. If the main protection function - differential and/or distance protection - are out of operation, this emergency stage guarantees instantaneous tripping before auto-reclosure.

Instantaneous tripping when the line is switched onto a fault is also possible with the I-STUB stage. Set parameter **I - STUB SOTF** (address 2635) to **YES**, if instantaneous tripping is desired.

2.14.4 Settings

The table indicates region-specific presettings. Column C (configuration) indicates the corresponding secondary nominal current of the current transformer.

Addr.	Parameter	C	Setting Options	Default Setting	Comments
2601	Operating Mode		ON Only Emer. prot OFF	ON	Operating mode
2610	Iph>>	1A	0.10 .. 25.00 A; ∞	2.00 A	Iph>> Pickup
		5A	0.50 .. 125.00 A; ∞	10.00 A	
2611	T Iph>>		0.00 .. 30.00 sec; ∞	0.30 sec	T Iph>> Time delay
2612	3I0>> PICKUP	1A	0.05 .. 25.00 A; ∞	0.50 A	3I0>> Pickup
		5A	0.25 .. 125.00 A; ∞	2.50 A	
2613	T 3I0>>		0.00 .. 30.00 sec; ∞	2.00 sec	T 3I0>> Time delay
2614	I>> Telep/BI		NO YES	YES	Instantaneous trip via Tele-prot./BI
2615	I>> SOTF		NO YES	NO	Instantaneous trip after SwitchOnToFault
2620	Iph>	1A	0.10 .. 25.00 A; ∞	1.50 A	Iph> Pickup
		5A	0.50 .. 125.00 A; ∞	7.50 A	
2621	T Iph>		0.00 .. 30.00 sec; ∞	0.50 sec	T Iph> Time delay
2622	3I0>	1A	0.05 .. 25.00 A; ∞	0.20 A	3I0> Pickup
		5A	0.25 .. 125.00 A; ∞	1.00 A	
2623	T 3I0>		0.00 .. 30.00 sec; ∞	2.00 sec	T 3I0> Time delay
2624	I> Telep/BI		NO YES	NO	Instantaneous trip via Tele-prot./BI
2625	I> SOTF		NO YES	NO	Instantaneous trip after SwitchOnToFault
2630	Iph> STUB	1A	0.10 .. 25.00 A; ∞	1.50 A	Iph> STUB Pickup
		5A	0.50 .. 125.00 A; ∞	7.50 A	
2631	T Iph STUB		0.00 .. 30.00 sec; ∞	0.30 sec	T Iph STUB Time delay
2632	3I0> STUB	1A	0.05 .. 25.00 A; ∞	0.20 A	3I0> STUB Pickup
		5A	0.25 .. 125.00 A; ∞	1.00 A	
2633	T 3I0 STUB		0.00 .. 30.00 sec; ∞	2.00 sec	T 3I0 STUB Time delay
2634	I-STUB Telep/BI		NO YES	NO	Instantaneous trip via Tele-prot./BI
2635	I-STUB SOTF		NO YES	NO	Instantaneous trip after SwitchOnToFault

Addr.	Parameter	C	Setting Options	Default Setting	Comments
2640	Ip>	1A	0.10 .. 4.00 A; ∞	∞ A	Ip> Pickup
		5A	0.50 .. 20.00 A; ∞	∞ A	
2642	T Ip Time Dial		0.05 .. 3.00 sec; ∞	0.50 sec	T Ip Time Dial
2643	Time Dial TD Ip		0.50 .. 15.00 ; ∞	5.00	Time Dial TD Ip
2646	T Ip Add		0.00 .. 30.00 sec	0.00 sec	T Ip Additional Time Delay
2650	3I0p PICKUP	1A	0.05 .. 4.00 A; ∞	∞ A	3I0p Pickup
		5A	0.25 .. 20.00 A; ∞	∞ A	
2652	T 3I0p TimeDial		0.05 .. 3.00 sec; ∞	0.50 sec	T 3I0p Time Dial
2653	TimeDial TD3I0p		0.50 .. 15.00 ; ∞	5.00	Time Dial TD 3I0p
2656	T 3I0p Add		0.00 .. 30.00 sec	0.00 sec	T 3I0p Additional Time Delay
2660	IEC Curve		Normal Inverse Very Inverse Extremely Inv. LongTimeInverse	Normal Inverse	IEC Curve
2661	ANSI Curve		Inverse Short Inverse Long Inverse Moderately Inv. Very Inverse Extremely Inv. Definite Inv.	Inverse	ANSI Curve
2670	I(3I0)p Tele/BI		NO YES	NO	Instantaneous trip via Teleprot./BI
2671	I(3I0)p SOTF		NO YES	NO	Instantaneous trip after SwitchOnToFault
2680	SOTF Time DELAY		0.00 .. 30.00 sec	0.00 sec	Trip time delay after SOTF

2.14.5 Information List

No.	Information	Type of Information	Comments
7104	>BLOCK O/C I>>	SP	>BLOCK Backup OverCurrent I>>
7105	>BLOCK O/C I>	SP	>BLOCK Backup OverCurrent I>
7106	>BLOCK O/C Ip	SP	>BLOCK Backup OverCurrent Ip
7107	>BLOCK O/C Ie>>	SP	>BLOCK Backup OverCurrent Ie>>
7108	>BLOCK O/C Ie>	SP	>BLOCK Backup OverCurrent Ie>
7109	>BLOCK O/C Iep	SP	>BLOCK Backup OverCurrent Iep
7110	>O/C InstTRIP	SP	>Backup OverCurrent InstantaneousTrip
7130	>BLOCK I-STUB	SP	>BLOCK I-STUB
7131	>I-STUB ENABLE	SP	>Enable I-STUB-Bus function
7132	>BLOCK O/C Ie>>>	SP	>BLOCK Backup OverCurrent Ie>>>
7151	O/C OFF	OUT	Backup O/C is switched OFF
7152	O/C BLOCK	OUT	Backup O/C is BLOCKED
7153	O/C ACTIVE	OUT	Backup O/C is ACTIVE

No.	Information	Type of Information	Comments
7161	O/C PICKUP	OUT	Backup O/C PICKED UP
7162	O/C Pickup L1	OUT	Backup O/C PICKUP L1
7163	O/C Pickup L2	OUT	Backup O/C PICKUP L2
7164	O/C Pickup L3	OUT	Backup O/C PICKUP L3
7165	O/C Pickup E	OUT	Backup O/C PICKUP EARTH
7171	O/C PU only E	OUT	Backup O/C Pickup - Only EARTH
7172	O/C PU 1p. L1	OUT	Backup O/C Pickup - Only L1
7173	O/C Pickup L1E	OUT	Backup O/C Pickup L1E
7174	O/C PU 1p. L2	OUT	Backup O/C Pickup - Only L2
7175	O/C Pickup L2E	OUT	Backup O/C Pickup L2E
7176	O/C Pickup L12	OUT	Backup O/C Pickup L12
7177	O/C Pickup L12E	OUT	Backup O/C Pickup L12E
7178	O/C PU 1p. L3	OUT	Backup O/C Pickup - Only L3
7179	O/C Pickup L3E	OUT	Backup O/C Pickup L3E
7180	O/C Pickup L31	OUT	Backup O/C Pickup L31
7181	O/C Pickup L31E	OUT	Backup O/C Pickup L31E
7182	O/C Pickup L23	OUT	Backup O/C Pickup L23
7183	O/C Pickup L23E	OUT	Backup O/C Pickup L23E
7184	O/C Pickup L123	OUT	Backup O/C Pickup L123
7185	O/C Pickup L123E	OUT	Backup O/C Pickup L123E
7191	O/C PICKUP I>>	OUT	Backup O/C Pickup I>>
7192	O/C PICKUP I>	OUT	Backup O/C Pickup I>
7193	O/C PICKUP Ip	OUT	Backup O/C Pickup Ip
7201	I-STUB PICKUP	OUT	O/C I-STUB Pickup
7211	O/C TRIP	OUT	Backup O/C General TRIP command
7212	O/C TRIP 1p.L1	OUT	Backup O/C TRIP - Only L1
7213	O/C TRIP 1p.L2	OUT	Backup O/C TRIP - Only L2
7214	O/C TRIP 1p.L3	OUT	Backup O/C TRIP - Only L3
7215	O/C TRIP L123	OUT	Backup O/C TRIP Phases L123
7221	O/C TRIP I>>	OUT	Backup O/C TRIP I>>
7222	O/C TRIP I>	OUT	Backup O/C TRIP I>
7223	O/C TRIP Ip	OUT	Backup O/C TRIP Ip
7235	I-STUB TRIP	OUT	O/C I-STUB TRIP

2.15 Automatic Reclosure Function (optional)

Experience shows that about 85% of the arc faults on overhead lines are extinguished automatically after being tripped by the protection. This means that the line can be re-closed. Reclosure is performed by an automatic reclosure function (AR).

Automatic reclosure is only permitted on overhead lines because the option of automatic extinguishing of a fault arc only exists there. It should not be used in any other case. If the protected object consists of a mixture of overhead lines and other equipment (e.g. overhead line directly connected to a transformer or overhead line/cable), it must be ensured that reclosure can only be performed in the event of a fault on the overhead line.

If the circuit breaker poles can be operated individually, a single-phase auto-reclosure is usually initiated for single-phase faults and a three-pole auto-reclosure for multiple-phase faults in the network with earthed system starpoint. If the fault still exists after automatic reclosure (arc has not disappeared, there is a metallic fault), then the protective elements will re-trip the circuit breaker. In some systems several reclosing attempts are performed.

In a model with single-pole tripping, the 7SD5 allows phase-selective, single-pole tripping. A single and three-pole, single and multiple shot automatic reclosure function is integrated, depending on the ordered version.

The 7SD5 can also operate in conjunction with an external automatic reclosure device. In this case, the signal exchange between 7SD5 and the external reclosure device must be effected via binary inputs and outputs.

It is also possible to initiate the integrated auto reclose function by an external protection device (e.g. a backup protection). The use of two 7SD5 with automatic reclosure function or the use of one 7SD5 with an automatic reclosure function and a second protection with its own automatic reclosure function is also possible.

2.15.1 Functional Description

Reclosure is performed by an automatic reclosure function (AR). An example of the normal time sequence of a double reclosure is shown in the following Figure.




Figure 2-120 Timing diagram of a double-shot reclosure with action time (2nd reclosure successful)

The integrated automatic reclosure circuit allows up to 8 reclosure attempts. The first four interrupt cycles may operate with different parameters (action and dead times, single/three-pole). The parameters of the fourth cycle also apply for the fifth cycle and onwards.

Activation and De-activation

The automatic reclosure function can be switched on and off by means of the parameter 3401 **AUTO RECLOSE**, or via the system interface (if available) and via binary input (if this is allocated). The switched state is saved internally (refer to Figure 2-121) and secured against loss of auxiliary supply. It is only possible to switch on from the source where previously it had been switched off from. To be active, it is necessary that the function of all three switching sources is switched on.

Alteration of the switching state via setting or the system interface is not possible during a running fault.




Figure 2-121 Activation and deactivation of the auto-reclosure function

Selectivity before Reclosure

In order for the automatic reclosure to be successful, all faults on the entire overhead line must be cleared at all line ends simultaneously — as fast as possible.

This is the usual case in differential protection schemes because the strict selective zone definition of the protected object by the current transformer sets always allows non-delayed tripping.

In the distance protection, for example, the overreach zone Z1B may be released before the first reclosure. This implies that faults up to the zone reach limit of Z1B are tripped without delay for the first cycle (Figure 2-122). A limited unselectivity in favour of fast simultaneous tripping is accepted here because a reclosure will be performed in any case. The normal stages of the distance protection (Z1, Z2, etc.) and the normal grading of the other short-circuit functions are independent of the automatic reclosure function.




Figure 2-122 Reach control before first reclosure, using distance protection

If the distance protection is operated with one of the signal transmission methods described in Section 2.7, the signal transmission logic controls the overreaching zone, i.e. it determines whether a non-delayed trip (or delayed with T1B) is permitted in the event of faults in the overreaching zone (i.e. up to the reach limit of zone Z1B) at both line ends simultaneously. Whether the automatic reclosure device is ready for reclosure or not is irrelevant, because the teleprotection function ensures the selectivity over 100% of the line length and fast, simultaneous tripping. The same applies for the earth fault-direction comparison protection (Section 2.9).

If, however, the signal transmission is switched off or the transmission path is disturbed, the internal automatic reclosure circuit can determine whether the overreaching zone (Z1B in the distance protection) is released for fast tripping. If no reclosure is expected (e.g. circuit breaker not ready) the normal grading of the distance protection (i.e. fast tripping only for faults in zone Z1) must apply to retain selectivity.

However, fast tripping of the protection may also be desired before reclosure after tripping by other short-circuit protection functions. For this purpose, every short-circuit protection which can start the automatic reclosure function has the possibility of initiating non-delayed tripping in at least one stage when the automatic reclosure function is ready for the first reclosure cycle. Please note, however, that fast, non-selective tripping should be avoided as long as the differential protection works properly: there should be no non-delayed tripping of the distance protection as the second main protection function, even if there is an automatic reclosure.

Fast tripping before reclosure is also possible with multiple reclosures. Appropriate links between the output signals (e.g. 2nd reclosure ready: „AR 2.CycZoneRe1“) and the inputs for enabling/releasing non-delayed tripping of the protection functions can be established via the binary inputs and outputs or the integrated user-definable logic functions (CFC).

Mixed Lines Overhead Line/Cable

In the distance protection, it is possible to use the distance zone signals to distinguish between cable and overhead line faults to a certain extent. The automatic reclosure circuit can then be blocked by appropriate signals generated by means of the user-programmable logic functions (CFC) if there is a fault in the cable section.

Initiation

Starting the automatic reclosure function means storing the first trip signal during a network fault that was generated by a protection function which operates with the automatic reclose function. In case of multiple reclosure, initiation therefore only takes place once, with the first trip command. The detection of the actual circuit breaker position is necessary for the correct functionality of the auto reclose function.

Starting is important when the first trip command has not appeared before expiry of an action time (see below under „Action times“).

Automatic reclosure is not started if the circuit breaker has not been ready for at least one TRIP–CLOSE–TRIP–cycle at the instant of the first trip command. This can be achieved by setting parameters. For further information, please refer to „Interrogation of Circuit Breaker Ready State“.

Each short-circuit protection function can be parameterized as to whether it should operate with the automatic reclose function or not, i.e. whether it should start the reclose function or not. The same goes for external trip commands applied via binary input and/or the trip commands generated by the teleprotection via permissive or intertrip signals.

Those protection and monitoring functions in the device which do not respond to short-circuits or similar conditions (e.g. an overload protection) do not initiate the automatic reclosure function because a reclosure will be of no use here. The breaker failure protection must not start the auto-reclosure either.

Action Times

It is often desirable to remove the ready-for-reclosure-state if the short-circuit condition was sustained for a certain time, e.g. because it is assumed that the arc has burned in to such an extent that there is no longer any chance of automatic arc extinction during the reclose dead time. Also for the sake of selectivity (see above), faults that are usually cleared after a time delay should not lead to reclosure. It is therefore recommended to use action times in conjunction with the distance protection.

The automatic reclosure function of the 7SD5 can be operated with or without action times (configuration parameter **AR control mode**, address 134, see Section 2.1.1.3). No starting signal is necessary from the protection functions or external protection devices that operate without action time. Starting takes place as soon as the first trip command appears.

When operating with action time, an action time is available for each reclose cycle. The action times are always started by the general starting signal (with logic OR combination of all internal and external protection functions which can start the automatic reclose function). If no trip command is present before the action time expires, the corresponding reclosure cycle is not carried out.

For each reclosure cycle, you may set whether or not it allows the initiation. Following the first general pickup, only the action times of those cycles that are set such that they may start off the recloser are considered since the other cycles are not allowed to be the first cycle under any circumstances. By means of the action times and the permission to start the recloser (permission to be the first cycle that is executed) it is possible to determine which reclose cycles are executed depending on the time used by the protection function to trip.

Example 1: 3 cycles are set. Starting of the auto-reclosure is allowed for at least the first cycle. The action times are set as follows:

- 1st Reclosure: T Action = 0.2 s;
- 2nd Reclosure: T Action = 0.8 s;
- 3rd Reclosure: T Action = 1.2 s;

Since reclosure is ready before the fault occurs, the first trip of a time overcurrent protection following a fault is fast, i.e. before the end of any action time. The automatic reclosure function is therefore started (the first cycle is initiated). After unsuccessful reclosure the 2nd cycle would then become active; but the time overcurrent protection would not trip in this example until after 1s according to its grading time. Since the action time for the second cycle was exceeded here, it is blocked. The 3rd cycle with its parameters is therefore carried out now. If the trip command only appeared more than 1.2s after the 1st reclosure, there would have been no further reclosure.

Example 2: 3 cycles are set. Starting is only allowed for the first. The action times are set as in example 1. The first protection trip takes place 0.5 s after starting. Since the action time for the 1st cycle has already expired at this time, this cannot start the automatic reclose function. As the 2nd and 3rd cycles are not permitted to start the reclose function they will also not be initiated. Therefore no reclosure takes place as no starting took place.

Example 3: 3 cycles are set. At least the first two cycles are set such that they can start the recloser. The action times are set as in example 1. The first protection trip takes place 0.5 s after starting. Since the action time for the 1st cycle has already expired at this time, it cannot start the automatic reclosure function, but the 2nd cycle, for which initiating is allowed, is activated immediately. This 2nd cycle therefore starts the automatic reclosure circuit, the 1st cycle is practically skipped.

Control Mode of the Automatic Reclosure

The dead times — these are the times from elimination of the fault (dropout of the trip command or signalling via auxiliary contacts) to the initiation of the automatic close command — may vary, depending on the automatic reclosure control mode selected when determining the functional scope and the resulting signals of the starting protective functions.

In control mode **TRIP...** (With TRIP command...) single-pole or single/three-pole reclose cycles are possible if the device and the circuit breaker are suitable. In this case different dead times after single-pole tripping on the one hand and after three-

pole tripping on the other hand are possible (for every reclose cycle). The protective function that issues the trip command determines the type of trip: single-pole or three-pole. Depending on the latter the dead time is selected.

In control mode **PICKUP** . . . (With PICKUP...) different dead times can be set for every reclosure cycle after single-phase, two-phase and three-phase faults. Selection of the dead time in this case depends on the type of fault determined by the initiating protection function at the instant that the trip commands reset. This operating mode allows the dead times to be dependent on the type of fault in the case of three-pole reclose cycles.

Reclose Block

Different conditions lead to blocking of the automatic reclosure. No reclosure is possible, for example, if it is blocked via a binary input. If the automatic reclosure has not yet been started, it cannot be started at all. If a reclosure cycle is already in progress, dynamic blocking takes place (see below).

Each individual cycle may also be blocked via binary input. In this case the cycle concerned is declared as invalid and will be skipped in the sequence of permissible cycles. If blocking takes place while the cycle concerned is already running, this leads to aborting of the reclosure, i.e. no reclosure takes place even if other valid cycles have been parameterized.

Internal blocking signals, with a limited duration, arise during the course of the reclose cycles:

The reclaim time **T-RECLAIM** begins with every automatic reclosure command. If the reclosure is successful, all the functions of the automatic reclosure return to the quiescent state at the end of the reclaim time; a fault after expiry of the reclaim time is treated as a new fault in the network. Re-tripping by a protection function during the reclaim time initiates the next reclose cycle in the case of multiple reclosure; if no further reclosure is permitted, the last reclosure cycle is declared as unsuccessful if re-tripping within the reclaim time takes place. The automatic reclosure is blocked dynamically.

The dynamic lock-out locks the reclosure for the duration of the dynamic lock-out time (0.5 s). This occurs, for example, after a final tripping or other events which block the auto reclose function after it has been started. Restarting is locked out for this time. When this time expires, the automatic reclosure function returns to its quiescent state and is ready for a new fault in the power system.

If the circuit breaker is closed manually (by the control discrepancy switch connected to a binary input, the local control functions or via one of the serial interfaces), the automatic reclosure is blocked for a manual-close-blocking time **T-BLOCK MC**. If a trip command is issued during this time, it can be assumed that a metallic short-circuit is the cause (e.g. closed earth switch). Every trip command within this time is therefore a final trip. With the user definable logic functions (CFC) further control functions can be processed in the same way as a manual-close command.

Interrogation of the Circuit Breaker Ready State

A precondition for automatic reclosure following clearance of a short-circuit is that the circuit breaker is ready for at least one OPEN-CLOSE-OPEN-cycle when the automatic reclosure circuit is started (i.e. at the time of the first trip command). The readiness of the circuit breaker is signalled to the device through the binary input „>CB1 Ready“ (No. 371). If no such signal is available, the circuit breaker interrogation can be suppressed (presetting) as automatic reclosure would otherwise not be possible at all.

In the event of a single cycle reclosure this interrogation is usually sufficient. Since, for example, the air pressure or the spring tension for the circuit breaker mechanism drops after the trip, no further interrogation should take place.

Especially when multiple reclosing attempts are programmed, it is recommended to monitor the circuit breaker condition not only prior to the first, but also before each following reclosing attempt. Reclosure will be blocked until the binary input indicates that the circuit breaker is ready to complete another CLOSE-TRIP cycle.

The time needed by the circuit breaker to regain the ready state can be monitored by the 7SD5. This monitoring time **CB TIME OUT** starts as soon as the CB indicates the not ready state. The dead time may be extended if the ready state is not indicated when it expires. However, if the circuit breaker does not indicate its ready status for a longer period than the monitoring time, reclosure is locked out dynamically (see also above under margin heading „Blocking of Auto-reclosure“).

Processing the Circuit Breaker Auxiliary Contacts

If the circuit breaker auxiliary contacts are connected to the device, the reaction of the circuit breaker is also checked for plausibility.

In the case of single-pole tripping this applies to each individual breaker pole. This assumes that the auxiliary contacts are connected to the appropriate binary inputs for each pole („>CB1 Pole L1“, No. 366; „>CB1 Pole L2“, No. 367; „>CB1 Pole L3“, No. 368).

If, instead of the individual pole auxiliary contacts, the series connections of the normally open and normally closed contacts are used, the CB is assumed to have all three poles open when the series connection of the normally closed contacts is closed (binary input „>CB1 3p Open“, No.411). All three poles are assumed closed when the series connection of the normally open contacts is closed (binary input „>CB1 3p Closed“, No. 410). If none of these input messages is active, it is assumed that the breaker is open at one pole (even if this condition also exists theoretically when two poles are open).

The device continuously checks the switching state of the circuit breaker: as long as the auxiliary contacts indicate that the CB is not closed (three-pole), the automatic reclosure function cannot be started. This guarantees that a close command can only be issued if the CB previously tripped (out of the closed state).

The valid dead time begins when the trip command disappears or signals taken from the CB auxiliary contacts indicate that the CB (pole) has opened.

If the CB opens **three-pole** after a **single-pole** trip command, this is considered as a three-pole tripping. If three-pole reclosure cycles are allowed, the dead time for three-pole tripping becomes active in the **control mode with trip command** (see margin heading „Control Mode of the Automatic Reclosure“); in control by pickup, the pickup configuration of the starting protective function(s) is still decisive. If three-pole cycles are not allowed, the reclosure is locked out dynamically. The trip command is final.

The latter also applies if the CB trips two poles following a single-pole trip command. The device can only detect this if the auxiliary contacts of each pole are connected individually. The device immediately initiates three pole coupling thus resulting in a three-pole trip command.

If the CB auxiliary contacts indicate that at least one further pole has opened during the dead time following a single-pole trip, a three-pole reclose cycle is initiated with the dead time for three-pole reclosure if this is allowed. If the auxiliary contacts are connected for each pole individually, the device can detect a two-pole open CB. In this case the device immediately sends a three-pole trip command provided the forced three-pole trip is activated (see Section 2.15.2 at margin heading „Forced three-pole Trip“).

Sequence of a Three-Pole Reclose Cycle

If the automatic reclosure function is ready, the fault protection trips three-pole for all faults inside the stage selected for reclosure. The auto reclose function is then started. When the trip command resets or the circuit breaker opens (auxiliary contact criterion) an (adjustable) dead time starts. At the end of this dead time, the circuit breaker receives a close command. At the same time the (adjustable) reclaim time is started. If during configuration of the protection function address 134 **AR control mode = with Pickup ...** was set, different dead times can be parameterized depending on the type of protection pickup.

If the fault is cleared (successful reclosure), the reclaim time expires and all functions return to their quiescent state. The fault is cleared.

If the fault is not cleared (unsuccessful reclosure), the short-circuit protection issues a final trip with the protection stage that is selected to operate without reclosure. Any fault during the reclaim time leads to a final trip.

After unsuccessful reclosure (final tripping) the automatic reclosure is blocked dynamically (see also margin heading „Reclose Block“, above).

The sequence above applies for single reclosure cycles. In 7SD5 multiple reclosure (up to 8 cycles) is also possible (see below).

Sequence of a Single-Pole Reclose Cycle

Single-pole reclose cycles are only possible with the appropriate device version and if this was selected during the configuration of the protection functions (address 110 **Trip mode**, see also Section 2.1.1.3). Of course, the circuit breaker must also be suitable for single-pole tripping.

If the automatic reclosure function is ready, the short-circuit protection trips single pole for all single-phase faults inside the stage selected for reclosure. Under the general settings (address 1156 **Trip2phFlt**, see also Section 2.1.4.1) it can also be selected that single-pole tripping takes place for two-phase faults without earth. Single-pole tripping is of course only possible with short-circuit protection functions that can determine the faulty phase.

If only single-pole reclosure is selected, then the fault protection issues a final three-pole trip with the stage that is valid/selected without reclosure. Any three-pole trip is final. The automatic reclose function is blocked dynamically (see also margin heading „Reclosure Block“, above).

The automatic reclosure function is started following a single-pole trip. The (adjustable) dead time for the single-pole reclose cycles starts with reset of the trip command or opening of the circuit breaker pole (auxiliary contact criterion). After expiry of the dead time, the circuit breaker receives a close command. At the same time, the (adjustable) reclaim time is started. If the reclosure is blocked during the dead time following a single-pole trip, immediate three-pole tripping can take place as an option (forced three-pole coupling).

If the fault is cleared (successful reclosure), the reclaim time expires and all functions return to their quiescent state. The fault is cleared.

If the fault is not cleared (unsuccessful reclosure), the short-circuit protection issues a final trip with the protection stage that is valid/selected without reclosure. All faults during the reclaim time also lead to the issue of a final three-pole trip.

After unsuccessful reclosure (final tripping) the automatic reclosure is blocked dynamically (see also margin heading „Reclose Block“, above).

The sequence above applies for single reclosure cycles. In 7SD5 multiple reclosure (up to 8 cycles) is also possible (see below).

Sequence of a Single-Pole and Three-Pole Reclose Cycle

This operating mode is only possible with the appropriate device version and if this was selected during configuration of the protection functions (address 110, see also Section 2.1.1.3). Of course, the circuit breaker must also be suitable for single-pole tripping.

If the automatic reclosure function is ready, the short-circuit protection trips single-pole for single-phase faults and three-pole for multi-phase faults. Under the general settings (address 1156 **Trip2phFlt**, see also Section 2.1.4.1) it can also be selected that single-pole tripping takes place for two-phase faults without earth. Single-pole tripping is of course only possible with short-circuit protection functions that can determine the faulty phase. The valid protection stage selected for reclosure ready state applies for all fault types.

The automatic reclosure function is started in the event of a trip. Depending on the type of fault, the (adjustable) dead time for the single-pole reclose cycle or the (separately adjustable) dead time for the three-pole reclose cycle starts following the reset of the trip command or opening of the circuit breaker (pole). After expiry of the dead time, the circuit breaker receives a close command. At the same time, the (adjustable) reclaim time is started. If the reclosure is blocked during the dead time following a single-pole trip, immediate three-pole tripping can take place as an option (forced three-pole coupling).

If the fault is cleared (successful reclosure), the reclaim time expires and all functions return to their quiescent state. The fault is cleared.

If the fault is not cleared (unsuccessful reclosure), the short-circuit protection initiates a final three-pole trip with the protection stage that is valid/selected when reclosure is not ready. All faults during the reclaim time also lead to the issue of a final three-pole trip.

After unsuccessful reclosure (final tripping), the automatic reclosure is blocked dynamically (see also margin heading „Reclose Block“, above).

The sequence above applies for single reclosure cycles. In 7SD5 multiple reclosure (up to 8 cycles) is also possible (see below).

Multi-shot Reclosing

If a short-circuit still exists after a reclosure attempt, further reclosure attempts can be made. Up to 8 reclosure attempts are possible with the automatic reclosure function integrated in the 7SD5.

The first four reclosure cycles are independent of each other. Each one has separate action and dead times, can operate single-or three-pole and can be blocked separately via binary inputs. The parameters and intervention possibilities of the fourth cycle also apply to the fifth cycle and onwards.

The sequence is the same in principle as in the different reclosure programs described above. However, if the first reclosure attempt was unsuccessful, the reclosure function is not blocked, but instead the next reclose cycle is started. The appropriate dead time starts with the reset of the trip command or opening of the circuit breaker (pole) (auxiliary contact criterion). The circuit breaker receives a new close command after expiry of the dead time. At the same time the reclaim time is started.

Until the set maximum number of permissible auto-reclose cycles has been reached, the reclaim time is reset with every new trip command after reclosure and started again with the next close command.

If one of the reclosing attempts is successful, i.e. the fault disappeared after reclosure, the blocking time expires and the automatic reclosing system is reset. The fault is cleared.

If none of the cycles is successful, the short-circuit protection initiates a final three-pole trip after the last permissible reclosure, following a protection stage active without auto-reclosure. The automatic reclosure is blocked dynamically (see also margin heading „Reclose Block“, above).

Handling Evolving Faults

When single-pole and single-and three-pole reclose cycles are executed in the network, particular attention must be paid to sequential faults.

Sequential faults are faults which occur during the dead time after clearance of the first fault.

There are various ways of handling sequential faults in the 7SD5 depending on the requirements of the network:

For the **Detection** of an evolving fault you can select whether the trip command of a protective function during the dead time or every further pickup is the criterion for an evolving fault.

There are also various selectable possibilities for the **response** of the internal auto-reclose function to a detected evolving fault.

- **EV. FLT. MODE Stops AutoRec1:**

The reclosure is blocked as soon as an evolving fault is detected. Tripping as a result of the sequential fault is three-pole. This applies irrespective of whether three-pole cycles are permitted or not. There are no further reclosure attempts; the auto-reclosure is blocked dynamically (see also margin heading „Reclose Block“, above).

- **EV. FLT. MODE starts 3p AR:**

As soon as a sequential fault is detected the recloser switches over to a three-pole reclose cycle. All trip commands are now three-pole. The separately settable dead time for sequential faults starts with the clearance of the sequential fault; after the dead time the circuit breaker receives a close command. The further sequence is the same as for single and three-pole cycles.

The complete dead time in this case consists of the portion of the single-pole dead time up to clearance of the sequential fault plus the dead time for the sequential fault. This makes sense because the duration of the three-pole dead time is most important for the stability of the network.

If reclosure is blocked due to a sequential fault without the protection issuing a three-pole trip command (e.g. for sequential fault detection with starting), the device can send a three-pole trip command so that the circuit breaker does not remain open with one pole (forced three-pole coupling).

Forced Three-pole Trip

If reclosure is blocked during the dead time of a single-pole cycle without a three-pole trip command having been initiated, the breaker would remain open at one pole. In most cases, the circuit breaker is equipped with a pole discrepancy supervision which will trip the remaining poles after a few seconds. You can achieve by a setting parameter that the tripping logic of the device sends immediately a three-pole trip command in this case. This forced three-pole trip pre-empt the pole discrepancy supervision of the CB because the forced three-pole trip of the device is initiated as soon as the reclosure is blocked following a single-pole trip or if the CB auxiliary contacts report an implausible breaker state.

When different internal protection functions of the device initiate a single-pole trip in different phases, the device will issue a three-pole trip command due to the tripping logic of the entire device (Section 2.23.1), independent of this forced three-pole trip function. This is true also for trip commands given via the direct local trip inputs (Sec-

tion 2.11) or the reception of a remote trip (Section 2.12) since these signals are passed through the tripping logic of the entire device.

But when the device issues a single-pole trip command while an external single-pole trip signal reaches the device via one of the binary inputs, e.g. „>Trip L1 AR“, then this is not routed to the tripping logic, but only to the auto-reclosure function. In this case, three-pole trip is ensured only if the forced three-pole trip is effective.

The forced three-pole coupling is also activated when only three-pole cycles are allowed, but a single-pole trip is signalled externally via a binary input.

Dead Line Check (DLC)

If the voltage of a disconnected phase does not disappear following a trip, reclosure can be prevented. A prerequisite for this function is that the voltage transformers are connected on the line side of the circuit breaker. To select this function the dead line check must be activated. The automatic reclosure function then checks the disconnected line for no-voltage: the line must have been without voltage for at least an adequate measuring time during the dead time. If this was not the case, the reclosure is blocked dynamically.

This no-voltage check on the line is of advantage if a small generator (e.g. wind generator) is connected along the line.

Adaptive Dead Time (ADT)

In all the previous alternatives it was assumed that defined and equal dead times were set at both line ends, if necessary for different fault types and/or reclose cycles.

It is also possible to set the dead times (if necessary different for various fault types and/or reclose cycles) at one line end only and to configure the adaptive dead time at the other end (or ends). This can be done provided that the voltage transformers are located on the line side of the circuit breaker or that facilities for transfer of a close command to the remote line end exists.

Figure 2-123 shows an example with voltage measurement. It is assumed that the device I is operating with defined dead times whereas the adaptive dead time is configured at position II. It is important that the line is at least fed from busbar A, i.e. the side with the defined dead times.

With the adaptive dead time the automatic reclosure function at line end II decides independently if and when reclosure is sensible and allowed and when it is not. The criterion is the line voltage at end II, which was re-applied from end I following reclosure there. Reclosure therefore takes place at end II as soon as it is apparent that voltage has been re-applied to the line from end I.

In the illustrated example, the lines are disconnected at positions I, II and III. At I reclosure takes place after the parameterized dead time. At III a reduced dead time can take place (see above) if there is also an infeed on busbar B.

If the fault has been cleared (successful reclosure), line A - B is re-connected to the voltage at busbar A through position I. Device II detects this voltage and also recloses after a short delay (to ensure a sufficient voltage measuring time). The fault is cleared.

If the fault has not been cleared after reclosure at I (unsuccessful reclosure), a switch on to fault occurs at I, no healthy voltage appears at II. The device there detects this and does not reclose.

In the case of multiple reclosure the sequence may be repeated several times following an unsuccessful reclosure until one of the reclosures attempts is successful or a final trip takes place.




Figure 2-123 Example of adaptive dead time (ADT)

As is shown by the example, the adaptive dead time has the following advantages:

- The circuit breaker at position II is not reclosed at all if the fault persists and is not unnecessarily stressed as a result.
- With non-selective tripping on an external fault by an overreaching time-graded protection, no further auto-reclosure attempts can be generated there because the fault current path via busbar B and position II remains interrupted even after several reclosure attempts.
- At position I overreach is allowed in the case of multiple reclosures and even in the event of final tripping because the line remains open at position II and therefore no actual overreach can occur at I.

CLOSE-Command Transmission (Remote-CLOSE)

With close command transmission, the dead times are only set at one line end. The other (or the others in lines with more than two ends) are set to „Adaptive Dead Time (ADT)“. The latter only react to the received close commands from the transmitting end. An adaptive dead time is thus possible even without a voltage.

At the sending line end, the transmission of the close command is delayed until it is sure that the local reclosure was successful. This means that after reclosure still a possible local pickup is waited for. This delay prevents unnecessary closing at the remote end on the one hand but also increases the time until reclosure takes place there. This is not critical for a single-pole interruption or in radial or meshed networks if no stability problems are expected under these conditions.

The existing protection data interfaces are used to transmit the close command.

Connecting an External Auto-Reclosure Device

If the 7SD5 has to work with an external reclosure device, the binary inputs and outputs provided for this purpose must be taken into consideration. The following inputs and outputs are recommended:

Binary inputs:

- 383 „>Enable ARzones“ With this binary input, the external reclosure device controls stages of the individual short-circuit protection functions which are active before reclosure (e.g. overreaching zone in the distance protection). This input is not required if no overreaching stage is used (e.g. differential protection or comparison mode with distance protection, see also above margin heading „Selectivity before Reclosure“).
- 382 „>Only 1ph AR“ The external reclosure device is only programmed for one pole; the stages of the individual protection functions that are activated before reclosure via No. 383 only do so in the case of single-phase faults; in the event of multiple-phase faults these stages of the individual short-circuit functions do not operate. This input is not required if no overreaching stage is used (e.g. differential protection or comparison mode with distance protection, see also above margin heading „Selectivity before Reclosure“).
- 381 „>1p Trip Perm“ The external reclosure device allows one-pole tripping (logic inversion or three-pole coupling). If this input is not assigned or not routed (matrix), the protection functions trip three-pole for all faults. If the external reclosure device cannot supply this signal but supplies a „three-pole coupling“ signal instead, this must be taken into account in the allocation of the binary inputs: the signal must be inverted in this case (L-active = active without voltage).

Binary outputs:

- 501 „Relay PICKUP“ Start of protection device, general (if required by external recloser device).
- 512 „Relay TRIP 1pL1“ Trip of the device 1-pole L1.
- 513 „Relay TRIP 1pL2“ Trip of the device 1-pole L2.
- 514 „Relay TRIP 1pL3“ Trip of the device 1-pole L3.
- 515 „Relay TRIP 3ph.“ Trip protective device 3-pole.

In order to obtain a phase-segregated trip indication, the respective single-pole trip commands must be combined with the three-pole trip command on one output.

Figure 2-124 for example, shows the interconnection between a 7SD5 and an external reclosure device with a mode selector switch.

Depending on what the external recloser device requires, the three single-pole outputs (No. 512, 513, 514) may also be combined to one „single-pole tripping“ output; the No. 515 provides the „three-pole tripping“ signal to the external device.

- For exclusively three-pole auto-reclosure cycles, the general pickup (No. 501, if required by the external reclosure device) and general trip signal (No. 511) from 7SD5 (see Figure 2-125) usually suffice.




Figure 2-124 Connection example with external auto-reclosure device for 1-/3-pole AR with mode selector switch




Figure 2-125 Connection example with external reclosure device for 3-pole AR

Controlling the Internal Automatic Reclosure by an External Protection Device

If the 7SD5 is equipped with the internal automatic reclosure function, it may also be controlled by an external protection device. This is of use, for example, on line ends with redundant protection or additional back-up protection when the second protection is used for the same line end and has to work with the automatic reclosure function integrated in the 7SD5.

The binary inputs and outputs provided for this functionality must be considered in this case. It must be decided whether the internal auto-reclosure is to be controlled by the starting (pickup) or by the trip command of the external protection (see also above under „Control Mode of the Automatic Reclosure“).

If the auto-reclosure is controlled by the **trip command**, the following inputs and outputs are recommended to be used:

The automatic reclosure function is started via the Binary inputs:

2711 „>AR Start“	General fault detection for the automatic reclosure circuit (only required for action time),
2712 „>Trip L1 AR“	Trip command L1 for the automatic reclosure circuit,
2713 „>Trip L2 AR“	Trip command L2 for the automatic reclosure circuit,
2714 „>Trip L3 AR“	Trip command L3 for the automatic reclosure circuit.

The general fault detection determines the starting of the action times. It is also necessary if the automatic reclosure circuit is to detect sequential faults by fault detection. In other cases this input information is superfluous.

The trip commands decide whether the dead time for single-pole or three-pole reclose cycles is activated or whether the reclosure is blocked in the event of a three-pole trip (depending on the set dead times).

Figure 2-126 shows the interconnection between the internal automatic reclosure of 7SD5 and an external protection device, as a connection example for single-pole cycles.

To achieve three-pole coupling of the external protection and to release, if necessary, its accelerated stages before reclosure the following output functions are suitable:

2864 „AR 1p Trip Perm“	Internal automatic reclosure function ready for single-pole reclose cycle, i.e. allows single-pole tripping (logic inversion of the three-pole coupling).
2889 „AR 1.CycZoneRel“	Internal automatic reclosure function ready for the first reclose cycle, i.e. releases the stage of the external protection device for reclosure, the corresponding outputs can be used for other cycles. This output can be omitted if the external protection does not require an overreaching stage (e.g. differential protection or comparison mode with distance protection).
2820 „AR Program1pole“	Internal automatic reclosure function is programmed for one pole, i.e. only recloses after single-pole tripping. This output can be omitted if no overreaching stage is required (e.g. differential protection or comparison mode with distance protection).

Instead of the three-phase-segregated trip commands, the single-pole and three-pole tripping may also be signalled to the internal automatic reclosure function — provided that the external protection device is capable of this. In that case, the following binary inputs of the 7SD5 are assigned:

2711 „>AR Start“	General fault detection for the internal automatic reclosure function (only required for action time),
2715 „>Trip 1pole AR“	Trip command single-pole for the internal automatic reclosure,
2716 „>Trip 3pole AR“	Trip command three-pole for the internal automatic reclosure function,

If only three-pole reclosure cycles are to be executed, it is sufficient to assign the binary input „>Trip 3pole AR“ (No. 2716) for the trip signal. Figure 2-127 shows an example. Any overreaching stages of the external protection are enabled again by „AR 1.CycZoneRel“ (No. 2889) and of further cycles, if applicable.




Figure 2-126 Connection example with external protection device for 1-/3-pole reclosure; AR control mode = with TRIP




Figure 2-127 Connection example with external protection device for 3-pole reclosure; AR control mode = with TRIP

But if the internal automatic reclose function is controlled by the **pickup** (only possible for three-pole tripping: 110 Trip mode = **3pole only**), the phase-dedicated pickup signals of the external protection must be connected if distinction shall be made between different types of fault. The general trip command then suffices for tripping (No. 2746). Figure 2-128 shows a connection example.





Figure 2-128 Connection example with external protection device for fault detection dependent dead time — dead time control by pickup signals of the protection device; AR control mode = with PICKUP

2 Protection Relays with 2 Automatic Reclosure Circuits

If redundant protection is provided for a line and each protection operates with its own automatic reclosure function, a certain signal exchange between the two combinations is necessary. The connection example in Figure 2-129 shows the necessary cross-connections.

If phase segregated auxiliary contacts of the circuit breaker are connected, a three-pole coupling by the 7SD5 is guaranteed when more than one CB pole is tripped. This requires activation of the forced three-pole trip (see Section 2.15.2 at margin heading „Forced Three-Pole Trip“). An external automatic three-pole coupling is therefore not necessary when the above conditions are satisfied. This rules out two-pole tripping under all circumstances.



BI — Binary Inputs
M — Signal Output
C — Commands
*) — For all Protection Functions which Operate with the AR Function

Figure 2-129 Connection example for 2 protection devices with 2 automatic reclosure functions

2.15.2 Setting Notes

General

If no reclosure is required on the feeder to which the 7SD5 universal line protection is applied (e.g. for cables, transformers, motors or similar), the automatic reclosure function must be inhibited during configuration of the device (see Section 2.1.1.3, address 133). The auto reclose function is then totally disabled, i.e. the automatic reclosure is not processed in the 7SD5. No signals regarding the auto reclose function are generated, and the binary inputs for the auto reclose function are ignored. All parameters for setting the auto reclose function are inaccessible and of no significance.

If, on the other hand, the internal automatic reclosure function is to be used, the type of reclosure must be selected during the configuration of the functions (see Section 2.1.1.3) in address 133 **Auto Reclose** the AR control mode and in address 134 the **AR control mode**.

Up to 8 reclosure attempts are allowed with the integrated automatic reclosure function in the 7SD5. Whereas the settings in address 3401 to 3441 are common to all reclosure cycles, the individual settings of the cycles are made from address 3450 on-

wards. It is possible to set different individual parameters for the first four reclose cycles. From the fifth cycle onwards the parameters of the fourth cycle apply.

The automatic reclosing function can be turned **ON** or **OFF** under address 3401 **AUTO RECLOSE**.

A prerequisite for automatic reclosure taking place after a trip due to a short-circuit is that the circuit breaker is ready for at least one TRIP-CLOSE-TRIP cycle at the time the automatic reclosure circuit is started, i.e. at the time of the first trip command. The readiness of the circuit breaker is signalled to the device through the binary input „>CB1 Ready“ (No. 371). If no such signal is available, leave the setting under address 3402 **CB? 1. TRIP = NO** because no automatic reclosure would be possible at all otherwise. If circuit breaker interrogation is possible, you should set **CB? 1. TRIP = YES**.

Furthermore, the circuit breaker ready state can also be interrogated prior to every reclosure. This is set when setting the individual reclose cycles (see below).

To check that the ready status of the circuit breaker is regained during the dead times, you can set a circuit breaker ready monitor time under address 3409 **CB TIME OUT**. The time is set slightly longer than the recovery time of the circuit breaker after a TRIP-CLOSE-TRIP cycle. If the circuit breaker is not ready again by the time this timer expires, no reclosure takes place, the automatic reclosure function is blocked dynamically.

Waiting for the circuit breaker to be ready can lead to an increase of the dead times. Interrogation of a synchro-check (if used) can also delay reclosure. To avoid uncontrolled prolongation, it is possible to set a maximum prolongation of the dead time in this case in address 3411 **T-DEAD EXT.**. This prolongation is unlimited if the setting ∞ is applied. This parameter can only be altered with DIGSI® under **Additional Settings**. Remember that longer dead times are only permissible after three-pole tripping when no stability problems arise or when a synchro-check takes place before reclosure.

The blocking time **T-RECLAIM** (address 3403) defines the time that must elapse, after a successful reclosing attempt, before the automatic reclosing function is reset. Re-tripping of a protection function within this time initiates the next reclose cycle in the event of multiple reclosure; if no further reclosure is permitted, the last reclosure is treated as unsuccessful. The reclaim time must therefore be longer than the longest response time of a protective function which can start the automatic reclosure circuit.

A few seconds are generally sufficient. In areas with frequent thunderstorms or storms, a shorter blocking time may be necessary to avoid feeder lockout due to sequential lightning strikes or cable flashovers.

A longer reclaim time should be chosen where circuit breaker supervision is not possible (see above) during multiple reclosures, e.g. because of missing auxiliary contacts and information on the circuit breaker ready status. In this case, the reclaim time should be longer than the time required for the circuit breaker mechanism to be ready.

The blocking duration following Manual-Close-detection **T-BLOCK MC** (address 3404) must guarantee the circuit breaker to open and close reliably (0.5 s to 1 s). If a fault is detected by a protection function within this time after closing of the circuit breaker was detected, no reclosure takes place and a final three-pole trip command is issued. If this is not desired, set address 3404 to **0**.

The options for handling evolving faults are described in Section 2.15 under margin heading „Handling Evolving Faults“. The treatment of sequential faults is not necessary on line ends where the adaptive dead time is applied (address 133 **Auto Reclose = ADT**). The addresses 3406 and 3407 are then of no consequence and therefore not accessible.

The detection of an evolving fault can be defined under address 3406 **EV. FLT. RECOG.. EV. FLT. RECOG. with PICKUP** means that, during a dead time, every **pickup** of a protective function will be interpreted as an evolving fault. With **EV. FLT. RECOG. with TRIP** a fault during a dead time is only interpreted as an evolving fault if it has led to a **trip command** by a protection function. This may also include trip commands which are coupled in from external via a binary input or which have been transmitted from an opposite end of the protected object. If an external protection device operates together with the auto-reclosure, evolving fault detection with pickup presupposes that a pickup signal from the external device is also connected to the 7SD5; otherwise an evolving fault can only be detected with the external trip command even if **with PICKUP** was set here.

The reaction in response to sequential faults can be selected under address 3407. **EV. FLT. MODE Stops AutoRec1** means that no reclosure takes place after detection of a sequential fault. This is always useful when only single-pole reclosure is to take place or when stability problems are expected due to the subsequent three-pole dead time. If a three-pole reclose cycle is to be initiated by tripping of the evolving fault, set **EV. FLT. MODE = starts 3p AR**. In this case, a separately adjustable three-pole dead time is started with the three-pole trip command due to the sequential fault. This is only useful if three-pole reclosure is also permitted.

Address 3408 **T-Start MONITOR** monitors the reaction of the circuit breaker after a trip command. If the CB has not opened during this time (from the beginning of the trip command), the automatic reclosure is blocked dynamically. The criterion for circuit breaker opening is the position of the circuit breaker auxiliary contact or the disappearance of the trip command. If a circuit breaker failure protection (internal or external) is used on the feeder, this time should be shorter than the delay time of the circuit breaker failure protection so that no reclosure takes place if the circuit breaker fails.

If the reclosure command is transmitted to the opposite end, this transmission can be delayed by the time setting in address 3410 **T RemoteClose**. This transmission is only possible if the device operates with adaptive dead time at the remote end (address 133 **Auto Reclose = ADT**). This parameter is otherwise irrelevant. On the one hand, this delay serves to prevent the remote end device from reclosing unnecessarily when local reclosure is unsuccessful. On the other hand, it should be noted that the line is not available for energy transport until the remote end has also closed. This delay must therefore be added to the dead time for consideration of the network stability.

Configuration of Auto-Reclosure

This configuration concerns the interaction between the protection and supplementary functions of the device and the auto reclose function. The selection of device functions which are to start the automatic reclosure circuit and which are not to, is made here.

Address 3420	AR WITH DIFF, i.e. with differential protection
Address 3421	AR w/ SOTF-O/C, i.e. with high-current switch-onto-fault function
Address 3422	AR w/ DIST., i.e. with distance protection
Address 3423	AR WITH I.TRIP, i.e. with permissive underreach transfer trip (PUTT)
Address 3424	AR w/ DTT, i.e. with direct transfer trip
Address 3425	AR w/ BackUpO/C, i.e. with time overcurrent protection
Address 3426	AR w/ W/I, with weak-infeed trip function
Address 3427	AR w/ EF-O/C, i.e. with earth fault protection for earthed systems

For the functions which are to start the auto-reclosure function, the corresponding address is set to **YES**, for the others to **NO**. The other functions cannot start the automatic reclosure because reclosure is of little use here.

Forced Three-pole Trip

If reclosure is blocked during the dead time of a single-pole cycle without a three-pole trip command having been initiated, the breaker remains open at one pole. With address 3430 **AR TRIP 3pole** it is possible to determine that the tripping logic of the device issues a three-pole trip command in this case (pole discrepancy prevention for the CB poles). Set this address to **YES** if the CB can be tripped single-pole and has no pole discrepancy protection itself. Nevertheless, the device pre-empt the pole discrepancy supervision of the CB because the forced three-pole trip of the device is immediately initiated as soon as the reclosure is blocked following a single-pole trip or if the CB auxiliary contacts report an implausible breaker state (see also Section 2.15 at margin heading „Processing the Circuit Breaker Auxiliary Contacts“). The forced three-pole coupling is also activated when only three-pole cycles are allowed, but a single-pole trip is signalled externally via a binary input.

The forced three-pole coupling is unnecessary if only a common three-pole control of the CB is possible.

Dead Line Check

Under address 3431 the dead line check can be switched active. It presupposes that voltage transformers are installed on the line side of the feeder and connected to the device. If this is not the case or the function is not used, set **DLC / RDT = WITHOUT**.

DLC / RDT = DLC means that the dead line check of the line voltage is used. This only enables reclosure after it becomes apparent that the line is dead. In this case, the phase-earth voltage limit is set in address 3441 **U-dead** below which the line is considered voltage-free (disconnected). The setting is applied in Volts secondary. This value can be entered as a primary value when parameterizing with a PC and DIGSI®. Address 3438 **T U-stable** determines the measuring time available for determining the no-voltage condition. Address 3440 is irrelevant here.

Adaptive Dead Time (ADT)

When operating with adaptive dead time, it must be ensured in advance that **one** end per line operates with defined dead times and has an infeed. The other (or the others in multi-branch lines) may operate with adaptive dead time. It is essential that the voltage transformers are located on the line side of the circuit breaker. Details about this function can be found in Section 2.15 at margin heading „Adaptive Dead Time (ADT) and Close Command-transfer (Remote-CLOSE)“.

For the line end with defined dead times the number of desired reclose cycles must be set during the configuration of the protective functions (Section 2.1.1) in address 133 **Auto Reclose**. Additionally, the intertrip command of the differential protection should be activated (see Section 2.4, address 1301 **I-TRIP SEND = YES**). For the devices operating with adaptive dead time, address 133 **Auto Reclose** must have been set to **ADT** during the configuration of the protective functions (Section 2.1.1). Only the parameters described below are interrogated in the latter case. No settings are then made for the individual reclosure cycles.

The adaptive dead time may be voltage-controlled or Remote-CLOSE-controlled. Both are possible at the same time. In the first case, reclosure takes place as soon as the returning voltage, after reclosure at the remote end, is detected. For this purpose, the device must be connected to voltage transformers located on the line side of the circuit breaker. In the case of remote-close, the device waits until the remote-close command is received before issuing the reclose command.

The action time **T-ACTION ADT** (address 3433) is the timeframe after initiation (fault detection) by any protective function which can start the automatic reclosure function within which the trip command must appear. If no trip command is issued until the action time has expired, there is no reclosure. Depending on the configuration of the protective functions (see Section 2.1.1.3), the action time may also be omitted; this applies especially when an initiating protective function has no fault detection signal.

The dead times are determined by the reclosure command of the device at the line end with the defined dead times. In cases where this reclosure command does not appear, e.g. because the reclosure was in the meantime blocked at this end, the readiness of the local device must return to the quiescent state at some time. This takes place after the maximum wait time **T-MAX ADT** (address 3434). This must be long enough to include the last reclosure of the remote end. In the case of single cycle reclosure, the sum total of maximum dead time plus reclaim time of the other device is sufficient. In the case of multiple reclosure the worst case is that all reclosures of the other end except the last one are unsuccessful. The time of all these cycles must be taken into account. To save having to make exact calculations, it is possible to use the sum of all dead times and all protection operating times plus one reclaim time.

Under address 3435 **ADT 1p allowed** it can be determined whether single-pole tripping is allowed (on condition that single-pole tripping is possible). If **NO**, the protection trips three-pole for all fault types. If **YES**, the possible tripping situations of the starting protective functions are decisive.

Under address 3436 **ADT CB? CLOSE** it can be determined whether circuit breaker ready is interrogated before reclosure after an adaptive dead time. With the setting **YES**, the dead time may be extended if the circuit breaker is not ready for a CLOSE–OPEN–cycle when the dead time expires. The maximum extension that is possible is the circuit breaker monitoring time; this was set for all reclosure cycles under address 3409 (see above). Details about the circuit breaker monitoring can be found in the function description, Section 2.15, at margin heading „Interrogation of the Circuit Breaker Ready State“.

If there is a danger of stability problems in the network during a three-pole reclosure cycle, you should set address 3437 **ADT SynRequest** to **YES**. In this case, the voltages from line and busbar are checked after a three-pole trip and before reclosure to determine if sufficient synchronism exists. This is only done on condition that either the internal synchronism and voltage check functions are available, or that an external device is available for synchronism check. If only single-pole reclose cycles are executed or no stability problems are expected during three-pole dead times (e.g. due to closely meshed networks or in radial networks), set address 3437 to **NO**.

Addresses 3438 and 3440 are only significant if the voltage-controlled adaptive dead time is used. 3440 **U-live>** is the phase-earth voltage limit above which the line is considered to be fault-free. The setting must be smaller than the lowest expected operating voltage. The setting is applied in Volts secondary. This value can be entered as a primary value when parameterizing with a PC and DIGSI®. Address 3438 **T U-stable** establishes the measuring time used to determine that the line is fault-free with this returning voltage. It should be longer than any transient oscillations resulting from line energization.

1st Reclosure Cycle

If working on a line with adaptive dead time, no further parameters are needed for the individual reclose cycles in this case. All the following parameters assigned to the individual cycles are then superfluous and inaccessible.

Address 3450 **1.AR: START** is only available if the automatic reclosure is configured with action time in the operating mode, i. e. if during configuration of the protection functions (see Section 2.1.1.3) address 134 **AR control mode = Pickup w/ Tact** or **Trip w/ Tact** was set (the first setting only applies to three-pole tripping). It determines whether automatic reclosure should be started at all with the first cycle. This address is included mainly for the sake of uniformity of the parameters for every reclosure attempt and is set to **YES** for the first cycle. If several cycles are performed, you can (at **AR control mode = Pickup ...**) set this parameter and different action times to control the effectiveness of the individual cycles. Notes and examples can be found in Section 2.15 at margin heading „Action Times“.

The action time **1.AR: T-ACTION** (address 3451) is the timeframe after initiation (fault detection) by any protective function which can start the automatic reclosure function within which the trip command must appear. If no trip command is issued until the action time has expired, there is no reclosure. Depending on the configuration of the protective functions, the action time may also be omitted; this applies especially when an initiating protective function has no fault detection signal.

Depending on the configured operating mode of the automatic reclosure (address 134 **AR control mode**) only address 3456 and 3457 (if **AR control mode = with TRIP...**) are available or address 3453 to 3455 (if **AR control mode = with PICKUP ...**).

If **AR control mode = with TRIP ...**, you can set different dead times for single-pole and three-pole reclose cycles. Whether single-pole or three-pole tripping takes place depends solely on the initiating protection functions. Single-pole tripping is only possible of course if the device and the corresponding protective function are also capable of single-pole tripping.

Table 2-13 AR control mode = **with TRIP...**

3456	1.AR Tdead1Trip	is the dead time after single-pole tripping,
3457	1.AR Tdead3Trip	is the dead time after three-pole tripping.

If only single-pole reclosure cycles are required, set the dead time for three-pole tripping to ∞ . If only three-pole reclosure cycles are required, set the dead time for single-pole tripping to ∞ ; the protection then trips three-pole for every fault type.

The dead time after single-pole tripping (if set) **1.AR Tdead1Trip** (address 3456) should be long enough for the short-circuit arc to be extinguished and the surrounding air to be de-ionized so that the reclosure promises to be successful. The longer the line, the longer is this time due to the charging of the conductor capacitances. Conventional values are 0.9 s to 1.5 s.

For three-pole tripping (address 3457 **1.AR Tdead3Trip**), the stability of the network is the main concern. Since the de-energized line cannot transfer synchronizing energy, only short dead times are allowed. The usual values are 0.3 s to 0.6 s. If the device is operating with a synchronism check device, a longer dead time may be tolerated under certain circumstances. Longer three-pole dead times are also possible in radial networks.

For **AR control mode = with PICKUP ...** it is possible to make the dead times dependent on the type of fault detected by the initiating protection function(s).

Table 2-14 AR control mode = **with PICKUP ...**

3453	1.AR Tdead 1Fit	is the dead time after single-phase pickup,
3454	1.AR Tdead 2Fit	is the dead time after two-phase pickup,
3455	1.AR Tdead 3Fit	is the dead time after three-phase pickup.

If the dead time is to be the same for all types of faults, set all three parameters the same. Note that these settings only cause different dead times for different pickups. The tripping can only be three-pole.

With the setting in address 3407 **EV. FLT. MODE starts 3p AR**, it is possible to apply a separate dead time **1.AR: Tdead EV.** (address 3458) for the three-pole dead time after clearance of the sequential fault (see above at heading „General“). Stability aspects are also decisive here. Normally the setting constraints are similar to address 3457 **1.AR Tdead3Trip**.

Under address 3459 **1.AR: CB? CLOSE** it can be determined whether the readiness of the circuit breaker ("circuit breaker ready") is interrogated before this first reclosure. With the setting **YES**, the dead time may be extended if the circuit breaker is not ready for a CLOSE–TRIP–cycle when the dead time expires. The maximum extension that is possible is the circuit breaker monitoring time; this time was set for all reclosure cycles under address 3409 **CB TIME OUT** (see above). Details about the circuit breaker monitoring can be found in the function description, Section 2.15, at margin heading „Interrogation of the Circuit Breaker Ready State“.

If there is a danger of stability problems in the network during a three-pole reclosure cycle, you should set address 3460 **1.AR SynRequest** to **YES**. In this case, a check is made before every reclosure following three-phase tripping to verify that voltages from feeder and busbar are synchronized sufficiently. This is only done on condition that either the internal synchronism and voltage check functions are available, or that an external device is available for synchronism check. If only single-pole reclose cycles are executed or no stability problems are expected during three-pole dead times (e.g. due to closely meshed networks or in radial networks), set address 3460 to **NO**.

2nd to 4th Reclosure Cycle

If several cycles have been set in the configuration of the scope of protection functions, you can set individual reclosure parameters for the 2nd to 4th cycles. The same options are available as for the first cycle. Again, only some of the parameters shown below will be available depending on the selections made during configuration of the scope of protection functions.

For the 2nd cycle:

3461 2.AR: START	Start in 2nd cycle generally allowed
3462 2.AR: T-ACTION	Action time for the 2nd cycle
3464 2.AR Tdead 1Fit	Dead time after single-phase pickup
3465 2.AR Tdead 2Fit	Dead time after two-phase pickup
3466 2.AR Tdead 3Fit	Dead time after three-phase pickup
3467 2.AR Tdead1Trip	Dead time after single-pole tripping
3468 2.AR Tdead3Trip	Dead time after three-pole tripping
3469 2.AR: Tdead EV.	Dead time after evolving fault
3470 2.AR: CB? CLOSE	CB ready interrogation before reclosing
3471 2.AR SynRequest	Sync. check after three-pole tripping

For the 3rd cycle:

3472 3.AR: START	Start in 3rd cycle generally allowed
3473 3.AR: T-ACTION	Action time for the 3rd cycle
3475 3.AR Tdead 1Fit	Dead time after single-phase pickup
3476 3.AR Tdead 2Fit	Dead time after two-phase pickup
3477 3.AR Tdead 3Fit	Dead time after three-phase pickup
3478 3.AR Tdead1Trip	Dead time after single-pole tripping
3479 3.AR Tdead3Trip	Dead time after three-pole tripping
3480 3.AR: Tdead EV.	Dead time after evolving fault
3481 3.AR: CB? CLOSE	CB ready interrogation before reclosing
3482 3.AR SynRequest	Sync. check after three-pole tripping

For the 4th cycle:

3483	4.AR: START	Start in 4th cycle generally allowed
3484	4.AR: T-ACTION	Action time for the 4th cycle
3486	4.AR Tdead 1Flt	Dead time after single-phase pickup
3487	4.AR Tdead 2Flt	Dead time after two-phase pickup
3488	4.AR Tdead 3Flt	Dead time after three-phase pickup
3489	4.AR Tdead1Trip	Dead time after single-pole tripping
3490	4.AR Tdead3Trip	Dead time after three-pole tripping
3491	4.AR: Tdead EV.	Dead time after evolving fault
3492	4.AR: CB? CLOSE	CB ready interrogation before reclosing
3493	4.AR SynRequest	Sync. check after three-pole tripping

5th to 8th Reclosure Cycle

If more than four cycles were set during configuration of the functional scope, the dead times preceding the fifth (5th) through the ninth (9th) reclosing attempts are equal to the open breaker time which precedes the fourth (4th) reclosing attempt.

Notes on the Information Overview

The most important information about automatic reclosure is briefly explained insofar as it was not mentioned in the following lists or described in detail in the preceding text.

„>BLK 1.AR-cycle“ (No. 2742) to „>BLK 4.-n. AR“ (No. 2745)

The respective auto-reclose cycle is blocked. If the blocking state already exists when the automatic reclosure function is initiated, the blocked cycle is not executed and may be skipped (if other cycles are permitted). The same applies if the automatic reclosure function is started (running), but not internally blocked. If the block signal of a cycle appears while this cycle is being executed (in progress), the automatic reclosure function is blocked dynamically; no further automatic reclosures cycles are then executed.

„AR 1.CycZoneRel“ (No. 2889) to „AR 4.CycZoneRel“ (No. 2892)

The automatic reclosure is ready for the respective reclosure cycle. This information indicates which cycle will be run next. For example, external protection functions can use this information to release accelerated or overreaching trip stages prior to the corresponding reclose cycle.

„AR is blocked“ (No. 2783)

The automatic reclosure is blocked (e.g. circuit breaker not ready). This information indicates to the operational information system that in the event of an upcoming system fault there will be a final trip, i.e. without reclosure. If the automatic reclosure has been started, this information does not appear.

„AR not ready“ (No. 2784)

The automatic reclosure is not ready for reclosure at the moment. In addition to the „AR is blocked“ (No. 2783) mentioned above there are also obstructions during the course of the auto-reclosure cycles such as „action time run out“ or „last reclaim time running“. This information is particularly helpful during testing because no protection test cycle with reclosure may be initiated during this state.

„AR in progress“ (No. 2801)

This information appears following starting of the auto reclose function, i.e. with the first trip command that can start the auto reclose function. If this reclosure was successful (or any in the case of multiple cycles), this information resets with the expiry of the last reclaim time. If no reclosure was successful or if reclosure was blocked, it ends with the last – the final – trip command.

„AR Sync.Request“ (No. 2865)

Measuring request to an external synchronism check device. The information appears at the end of a dead time subsequent to three-pole tripping if a synchronism request was parameterized for the corresponding cycle. Reclosure only takes place when the synchronism check device has provided release signal „>Sync.release“ (No 2731).

„>Sync.release“ (No. 2731)

Release of reclosure by an external synchronism check device if this was requested by the output information „AR Sync.Request“ (No. 2865).

2.15.3 Settings

Addresses which have an appended "A" can only be changed with DIGSI, under Additional Settings.

Addr.	Parameter	Setting Options	Default Setting	Comments
3401	AUTO RECLOSE	OFF ON	ON	Auto-Reclose Function
3402	CB? 1.TRIP	YES NO	NO	CB ready interrogation at 1st trip
3403	T-RECLAIM	0.50 .. 300.00 sec	3.00 sec	Reclaim time after successful AR cycle
3404	T-BLOCK MC	0.50 .. 300.00 sec; 0	1.00 sec	AR blocking duration after manual close
3406	EV. FLT. RECOG.	with PICKUP with TRIP	with TRIP	Evolving fault recognition
3407	EV. FLT. MODE	Stops AutoRecl starts 3p AR	starts 3p AR	Evolving fault (during the dead time)
3408	T-Start MONITOR	0.01 .. 300.00 sec	0.50 sec	AR start-signal monitoring time
3409	CB TIME OUT	0.01 .. 300.00 sec	3.00 sec	Circuit Breaker (CB) Supervision Time
3410	T RemoteClose	0.00 .. 300.00 sec; ∞	0.20 sec	Send delay for remote close command
3411A	T-DEAD EXT.	0.50 .. 300.00 sec; ∞	∞ sec	Maximum dead time extension
3420	AR WITH DIFF	YES NO	YES	AR with differential protection ?
3421	AR w/ SOTF-O/C	YES NO	YES	AR with switch-onto-fault overcurrent ?

Addr.	Parameter	Setting Options	Default Setting	Comments
3422	AR w/ DIST.	YES NO	YES	AR with distance protection ?
3423	AR WITH I.TRIP	YES NO	YES	AR with intertrip ?
3424	AR w/ DTT	YES NO	YES	AR with direct transfer trip ?
3425	AR w/ BackUpO/C	YES NO	YES	AR with back-up overcurrent ?
3426	AR w/ W/I	YES NO	YES	AR with weak infeed tripping ?
3427	AR w/ EF-O/C	YES NO	YES	AR with earth fault overcurrent prot. ?
3430	AR TRIP 3pole	YES NO	YES	3pole TRIP by AR
3431	DLC / RDT	WITHOUT DLC	WITHOUT	Dead Line Check / Reduced Dead Time
3433	T-ACTION ADT	0.01 .. 300.00 sec; ∞	0.20 sec	Action time
3434	T-MAX ADT	0.50 .. 3000.00 sec	5.00 sec	Maximum dead time
3435	ADT 1p allowed	YES NO	NO	1pole TRIP allowed
3436	ADT CB? CLOSE	YES NO	NO	CB ready interrogation before re-closing
3437	ADT SynRequest	YES NO	NO	Request for synchro-check after 3pole AR
3438	T U-stable	0.10 .. 30.00 sec	0.10 sec	Supervision time for dead/live voltage
3440	U-live>	30 .. 90 V	48 V	Voltage threshold for live line or bus
3441	U-dead<	2 .. 70 V	30 V	Voltage threshold for dead line or bus
3450	1.AR: START	YES NO	YES	Start of AR allowed in this cycle
3451	1.AR: T-ACTION	0.01 .. 300.00 sec; ∞	0.20 sec	Action time
3453	1.AR Tdead 1Flt	0.01 .. 1800.00 sec; ∞	1.20 sec	Dead time after 1phase faults
3454	1.AR Tdead 2Flt	0.01 .. 1800.00 sec; ∞	1.20 sec	Dead time after 2phase faults
3455	1.AR Tdead 3Flt	0.01 .. 1800.00 sec; ∞	0.50 sec	Dead time after 3phase faults
3456	1.AR Tdead1Trip	0.01 .. 1800.00 sec; ∞	1.20 sec	Dead time after 1pole trip
3457	1.AR Tdead3Trip	0.01 .. 1800.00 sec; ∞	0.50 sec	Dead time after 3pole trip
3458	1.AR: Tdead EV.	0.01 .. 1800.00 sec	1.20 sec	Dead time after evolving fault
3459	1.AR: CB? CLOSE	YES NO	NO	CB ready interrogation before re-closing
3460	1.AR SynRequest	YES NO	NO	Request for synchro-check after 3pole AR

Addr.	Parameter	Setting Options	Default Setting	Comments
3461	2.AR: START	YES NO	NO	AR start allowed in this cycle
3462	2.AR: T-ACTION	0.01 .. 300.00 sec; ∞	0.20 sec	Action time
3464	2.AR Tdead 1Flt	0.01 .. 1800.00 sec; ∞	1.20 sec	Dead time after 1phase faults
3465	2.AR Tdead 2Flt	0.01 .. 1800.00 sec; ∞	1.20 sec	Dead time after 2phase faults
3466	2.AR Tdead 3Flt	0.01 .. 1800.00 sec; ∞	0.50 sec	Dead time after 3phase faults
3467	2.AR Tdead1Trip	0.01 .. 1800.00 sec; ∞	∞ sec	Dead time after 1pole trip
3468	2.AR Tdead3Trip	0.01 .. 1800.00 sec; ∞	0.50 sec	Dead time after 3pole trip
3469	2.AR: Tdead EV.	0.01 .. 1800.00 sec	1.20 sec	Dead time after evolving fault
3470	2.AR: CB? CLOSE	YES NO	NO	CB ready interrogation before re-closing
3471	2.AR SynRequest	YES NO	NO	Request for synchro-check after 3pole AR
3472	3.AR: START	YES NO	NO	AR start allowed in this cycle
3473	3.AR: T-ACTION	0.01 .. 300.00 sec; ∞	0.20 sec	Action time
3475	3.AR Tdead 1Flt	0.01 .. 1800.00 sec; ∞	1.20 sec	Dead time after 1phase faults
3476	3.AR Tdead 2Flt	0.01 .. 1800.00 sec; ∞	1.20 sec	Dead time after 2phase faults
3477	3.AR Tdead 3Flt	0.01 .. 1800.00 sec; ∞	0.50 sec	Dead time after 3phase faults
3478	3.AR Tdead1Trip	0.01 .. 1800.00 sec; ∞	∞ sec	Dead time after 1pole trip
3479	3.AR Tdead3Trip	0.01 .. 1800.00 sec; ∞	0.50 sec	Dead time after 3pole trip
3480	3.AR: Tdead EV.	0.01 .. 1800.00 sec	1.20 sec	Dead time after evolving fault
3481	3.AR: CB? CLOSE	YES NO	NO	CB ready interrogation before re-closing
3482	3.AR SynRequest	YES NO	NO	Request for synchro-check after 3pole AR
3483	4.AR: START	YES NO	NO	AR start allowed in this cycle
3484	4.AR: T-ACTION	0.01 .. 300.00 sec; ∞	0.20 sec	Action time
3486	4.AR Tdead 1Flt	0.01 .. 1800.00 sec; ∞	1.20 sec	Dead time after 1phase faults
3487	4.AR Tdead 2Flt	0.01 .. 1800.00 sec; ∞	1.20 sec	Dead time after 2phase faults
3488	4.AR Tdead 3Flt	0.01 .. 1800.00 sec; ∞	0.50 sec	Dead time after 3phase faults
3489	4.AR Tdead1Trip	0.01 .. 1800.00 sec; ∞	∞ sec	Dead time after 1pole trip
3490	4.AR Tdead3Trip	0.01 .. 1800.00 sec; ∞	0.50 sec	Dead time after 3pole trip
3491	4.AR: Tdead EV.	0.01 .. 1800.00 sec	1.20 sec	Dead time after evolving fault
3492	4.AR: CB? CLOSE	YES NO	NO	CB ready interrogation before re-closing
3493	4.AR SynRequest	YES NO	NO	Request for synchro-check after 3pole AR

2.15.4 Information List

No.	Information	Type of Information	Comments
127	AR ON/OFF	IntSP	Auto Reclose ON/OFF (via system port)
2701	>AR on	SP	>AR: Switch on auto-reclose function
2702	>AR off	SP	>AR: Switch off auto-reclose function
2703	>AR block	SP	>AR: Block auto-reclose function
2711	>AR Start	SP	>External start of internal Auto reclose
2712	>Trip L1 AR	SP	>AR: External trip L1 for AR start
2713	>Trip L2 AR	SP	>AR: External trip L2 for AR start
2714	>Trip L3 AR	SP	>AR: External trip L3 for AR start
2715	>Trip 1pole AR	SP	>AR: External 1pole trip for AR start
2716	>Trip 3pole AR	SP	>AR: External 3pole trip for AR start
2727	>AR RemoteClose	SP	>AR: Remote Close signal
2731	>Sync.release	SP	>AR: Sync. release from ext. sync.-check
2737	>BLOCK 1pole AR	SP	>AR: Block 1pole AR-cycle
2738	>BLOCK 3pole AR	SP	>AR: Block 3pole AR-cycle
2739	>BLK 1phase AR	SP	>AR: Block 1phase-fault AR-cycle
2740	>BLK 2phase AR	SP	>AR: Block 2phase-fault AR-cycle
2741	>BLK 3phase AR	SP	>AR: Block 3phase-fault AR-cycle
2742	>BLK 1.AR-cycle	SP	>AR: Block 1st AR-cycle
2743	>BLK 2.AR-cycle	SP	>AR: Block 2nd AR-cycle
2744	>BLK 3.AR-cycle	SP	>AR: Block 3rd AR-cycle
2745	>BLK 4.-n. AR	SP	>AR: Block 4th and higher AR-cycles
2746	>Trip for AR	SP	>AR: External Trip for AR start
2747	>Pickup L1 AR	SP	>AR: External pickup L1 for AR start
2748	>Pickup L2 AR	SP	>AR: External pickup L2 for AR start
2749	>Pickup L3 AR	SP	>AR: External pickup L3 for AR start
2750	>Pickup 1ph AR	SP	>AR: External pickup 1phase for AR start
2751	>Pickup 2ph AR	SP	>AR: External pickup 2phase for AR start
2752	>Pickup 3ph AR	SP	>AR: External pickup 3phase for AR start
2781	AR off	OUT	AR: Auto-reclose is switched off
2782	AR on	IntSP	AR: Auto-reclose is switched on
2783	AR is blocked	OUT	AR: Auto-reclose is blocked
2784	AR not ready	OUT	AR: Auto-reclose is not ready
2787	CB not ready	OUT	AR: Circuit breaker not ready
2788	AR T-CBreadyExp	OUT	AR: CB ready monitoring window expired
2796	AR on/off BI	IntSP	AR: Auto-reclose ON/OFF via BI
2801	AR in progress	OUT	AR: Auto-reclose in progress
2809	AR T-Start Exp	OUT	AR: Start-signal monitoring time expired
2810	AR TdeadMax Exp	OUT	AR: Maximum dead time expired
2818	AR evolving Flt	OUT	AR: Evolving fault recognition
2820	AR Program1pole	OUT	AR is set to operate after 1p trip only
2821	AR Td. evol.Flt	OUT	AR dead time after evolving fault
2839	AR Tdead 1pTrip	OUT	AR dead time after 1pole trip running
2840	AR Tdead 3pTrip	OUT	AR dead time after 3pole trip running
2841	AR Tdead 1pFlt	OUT	AR dead time after 1phase fault running

No.	Information	Type of Information	Comments
2842	AR Tdead 2pFlt	OUT	AR dead time after 2phase fault running
2843	AR Tdead 3pFlt	OUT	AR dead time after 3phase fault running
2844	AR 1stCyc. run.	OUT	AR 1st cycle running
2845	AR 2ndCyc. run.	OUT	AR 2nd cycle running
2846	AR 3rdCyc. run.	OUT	AR 3rd cycle running
2847	AR 4thCyc. run.	OUT	AR 4th or higher cycle running
2848	AR ADT run.	OUT	AR cycle is running in ADT mode
2851	AR CLOSE Cmd.	OUT	AR: Close command
2852	AR Close1.Cyc1p	OUT	AR: Close command after 1pole, 1st cycle
2853	AR Close1.Cyc3p	OUT	AR: Close command after 3pole, 1st cycle
2854	AR Close 2.Cyc	OUT	AR: Close command 2nd cycle (and higher)
2861	AR T-Recl. run.	OUT	AR: Reclaim time is running
2862	AR successful	OUT	AR successful
2863	Definitive Trip	OUT	Definitive TRIP
2864	AR 1p Trip Perm	OUT	AR: 1pole trip permitted by internal AR
2865	AR Sync.Request	OUT	AR: Synchro-check request
2871	AR TRIP 3pole	OUT	AR: TRIP command 3pole
2889	AR 1.CycZoneRel	OUT	AR 1st cycle zone extension release
2890	AR 2.CycZoneRel	OUT	AR 2nd cycle zone extension release
2891	AR 3.CycZoneRel	OUT	AR 3rd cycle zone extension release
2892	AR 4.CycZoneRel	OUT	AR 4th cycle zone extension release
2893	AR Zone Release	OUT	AR zone extension (general)
2894	AR Remote Close	OUT	AR Remote close signal send

2.16 Synchronism and Voltage Check (optional)

The synchronism and voltage check function ensures, when switching a line onto a busbar, that the stability of the network is not endangered. The voltage of the feeder to be energized is compared to that of the busbar to check conformance in terms of magnitude, phase angle and frequency within certain tolerances. Optionally, deenergization of the feeder can be checked before it is connected to an energized busbar (or vice versa).

The synchronism check can either be conducted only for automatic reclosure, only for manual closure (this includes also closing via control command) or in both cases. Different close permission (release) criteria can also be programmed for automatic and manual closure.

Synchronism check is also possible without external matching transformers if a power transformer is located between the measuring points.

Closing is released for synchronous or asynchronous system conditions. In the latter case, the device determines the time for issuing the close command such that the voltages are identical the instant the breaker poles make contact.

2.16.1 Method of Operation

General

The synchronism and voltage check function uses the feeder voltage – designated with U_{Line} – and the bus-bar voltage – designated with U_{Bus} – for comparison purposes. The latter may be any phase-to-earth or phase-to-phase voltage.




Figure 2-130 Synchronism check on closing

If a power transformer is located between the feeder voltage transformers and the bus-bar voltage transformers (Figure 2-131), its vector group can be compensated for by the 7SD5 relay, so that no external matching transformers are necessary.




Figure 2-131 Synchronism check across a transformer

The synchronism check function in the 7SD5 usually operates in conjunction with the integrated automatic reclose, manual close, and the control functions of the relay. It is also possible to employ an external automatic reclosing system. In such a case, signal exchange between the devices is accomplished via binary inputs and outputs.

When closing via the integrated control function, the configured interlocking conditions may have to be verified before checking the conditions for synchronism. After the synchronism check grants the release, the interlocking conditions are not checked a second time.

Furthermore, switching is possible with synchronous or asynchronous system conditions or both. Synchronous switching means that the closing command is issued as soon as the critical values (voltage magnitude difference **Max. Volt. Diff**, angle difference **Max. Angle Diff**, and frequency difference **Max. Freq. Diff**) lie within the set tolerances. For switching with asynchronous system conditions, the device calculates the correct timing of the closing command from the angle difference **Max. Angle Diff** and the frequency difference **Max. Freq. Diff** such that the voltages on the busbar and the feeder circuit have exactly the same phase relationship at the instant that the circuit breaker primary contacts close. For this purpose the device must be informed on the operating time of the circuit breaker for closing. Different frequency limit thresholds apply to switching under synchronism and asynchronous conditions. If closing is permitted exclusively under synchronous system conditions, the frequency difference limit for this condition can be set. If closing is permitted under synchronous as well as under asynchronous system conditions, a frequency difference below 0.01 Hz is treated as a synchronous condition, a higher frequency difference value can then be set for closing under asynchronous system conditions.

The synchro check function only operates when it is requested to do so. Various possibilities exist for this purpose:

- Measuring request from the internal automatic reclosure device. If the internal automatic reclosing function is set accordingly (one or more reclosing attempts set to synchronism check, see also Section 2.15.2), the measuring request is accomplished internally. The release conditions for automatic reclosing apply.
- Measuring request from an external automatic reclosure device. The measuring request must be activated via the binary input „>Sync. Start AR“ (No. 2906). The release conditions for automatic reclosing apply.

- Measuring request from the manual CLOSE detection. The manual CLOSE detection of the central function control (Section 2.23.1) issues a measuring request provided this was configured in the power system data 2 (Section 2.1.4.1, address 1151). This requires the device to be informed of the manual closing via binary input „>Manual Close“ (No 356). The release conditions for manual reclosing apply.
- Request to execute a check synchronism measurement from an external closing command. Binary input „>Sync. Start MC“ (No. 2905) fulfills this purpose. Unlike the „>Manual Close“ (see previous paragraph), this merely affects the measuring request to the synchronism check function, but not other integrated manual CLOSE function such as instantaneous tripping when switching onto a fault (e.g. overreaching zone for distance protection or accelerated tripping of a time overcurrent stage). The release conditions for manual reclosing apply.
- Measuring request from the integrated control function via control keys or via the serial interface using DIGSI® on a PC or from a control center. The release conditions for manual closure apply.

The synchronism-check function gives permission for passage „Sync. release“ (No. 2951) of the closing command to the required function. Furthermore, a separate closing command is available as output indication „Sync. CloseCmd“ (No. 2961).

The check of the release conditions is limited by an adjustable synchronous monitoring time **T-SYN. DURATION**. The configured conditions must be fulfilled within this time. Otherwise synchronism will not be checked. A new synchronism check sequence requires a new request.

The device outputs indications if, after a request to check synchronism, the conditions for release are not fulfilled, i.e. if the absolute voltage difference **Max. Volt. Diff**, the absolute frequency difference **Max. Freq. Diff**, or the absolute phase angle difference **Max. Angle Diff** lie outside the permissible limit values. A precondition for these indications is that voltages within the operating range of the relay are available. When a closing command is handled by the integrated control function and the conditions for synchronism are not fulfilled, the command is cancelled, i.e. the control function outputs „CO-“ (refer also to Section 2.25.1).

Operating Modes

The closing check procedure can be selected from the following operating modes:

SYNC-CHECK =	Release at synchronism, that is, when the critical values Max. Volt. Diff , Max. Freq. Diff and Max. Angle Diff lie within the set limits.
Usync> U-line< =	Release for energized busbar (UBus>) and de-energized line (ULine<).
Usync< U-line> =	Release for de-energized busbar (UBus<) and energized line (ULine>).
Usync< U-line< =	Release for de-energized busbar (UBus<) and de-energized line (ULine).
OVERRIDE =	Release without any check.

Each of these conditions can be enabled or disabled individually; combinations are also possible (e.g., release if **Usync> U-line<** or **Usync< U-line>** are fulfilled). Combination of **OVERRIDE** with other parameters is, of course, not reasonable.

The release conditions can be configured individually either for automatic reclosing or for manual closing or for closing via control commands. For example, manual closing and control closing can be allowed in cases of synchronism or dead line, whilst, before

an automatic reclose attempt dead line conditions are only checked at one line end and after the automatic reclose attempt only synchronism at the other end.

Dead-line or dead-bus Closing

To release the closing command to couple a dead overhead line to a live busbar, the following conditions are checked:

- Does the feeder voltage U_{Line} lie below the set value **Dead Volt. Thr.?**
- Does the busbar voltage U_{Bus} lie above the set value **Live Volt. Thr.**, but below the maximum operating voltage **Umax**?
- Is the frequency f_{bus} within the permitted operating range $f_N \pm 3 \text{ Hz}$?

After successful check the closing command is released.

Corresponding conditions apply when switching a live line onto a dead busbar or a dead line onto a dead busbar.

Closing under synchronous system conditions

Before releasing a closing command at synchronous conditions, the following conditions are checked:

- Does the busbar voltage U_{Bus} lie above the set value **Live Volt. Thr.**, but below the maximum operating voltage **Umax**?
- Does the feeder voltage U_{Line} lie above the set value **Live Volt. Thr.**, but below the maximum operating voltage **Umax**?
- Is the angle difference $|U_{Line} - U_{Bus}|$ within the permissible tolerance **Max. Volt. Diff?**
- Are the two frequencies f_{bus} and f_{line} within the permitted operating range $f_N \pm 3 \text{ Hz}$?
- Does the frequency difference $|f_{line} - f_{bus}|$ lie within the permissible tolerance **Max. Freq. Diff?**
- Is the angle difference $|\phi_{line} - \phi_{bus}|$ within the permissible tolerance **Max. Angle Diff?**

To check whether these conditions are observed for a certain minimum time, you can set this minimum time as **T SYNC-STAB**. Checking the synchronism conditions can also be confined to a maximum monitoring time **T-SYN. DURATION**. This implies that the conditions must be fulfilled within the time **T-SYN. DURATION** for the duration of **T SYNC-STAB**. If this is the case, the closing command is released.

Closing under Asynchronous System Conditions

Before releasing a closing command at asynchronous conditions, the following conditions are checked:

- Does the busbar voltage U_{Bus} lie above the set value **Live Volt. Thr.**, but below the maximum operating voltage **Umax**?
- Does the feeder voltage U_{Line} lie above the set value **Live Volt. Thr.**, but below the maximum operating voltage **Umax**?
- Is the angle difference $|U_{Line} - U_{Bus}|$ within the permissible tolerance **Max. Volt. Diff?**
- Are the two frequencies f_{bus} and f_{line} within the permitted operating range $f_N \pm 3 \text{ Hz}$?
- Does the frequency difference $|f_{line} - f_{bus}|$ lie within the permissible tolerance **Max. Freq. Diff?**

When the check has been terminated successfully, the device determines the next synchronizing time from the angle difference and the frequency difference. The close command is issued at synchronization time minus the operating time of the circuit breaker.

2.16.2 Setting Notes

Preconditions

When setting the general power system data (Power system data 1, refer to Section 2.1.2.1) a number of parameters regarding the measured quantities and the operating mode of the synchronism check function must be applied.

This concerns the following parameters:

203 Unom PRIMARY	Nominal primary voltage of the feeder voltage transformers (phase-to-phase) in kV;
204 Unom SECONDARY	Nominal secondary voltage of the feeder voltage transformers (phase-phase) in V;
210 U4 transformer	Connection of the additional voltage transformer input U_4 of the device; must be Usync transf. and connected to any voltage of the bus-bar;
212 Usync connect.	Type of voltage which is connected to the device from the busbar voltage transformer,
214 φ Usync-Uline	Phase angle displacement between the busbar voltage and the feeder voltage in case a power transformer is installed in between;
215 U-line / Usync	Ratio between secondary feeder voltage and secondary bus-bar voltage under nominal voltage conditions;
230 Rated Frequency	The operating range of the synchronism check refers to the nominal frequency of the power system ($f_N \pm 3$ Hz);
1103 FullScaleVolt.	Nominal operational voltage of the primary power system (phase-phase) in kV;
and, if closing at asynchronous system conditions is allowed,	
239 T-CB close	The closing time of the circuit breaker.

WARNING!

Closing at Asynchronous System Conditions!

Closing under asynchronous system conditions requires the closing time of the circuit breaker to be set correctly in the Power System Data 1 (address 239).

Otherwise, faulty synchronization may occur.

General

The synchronism check function can only operate if it was configured as **Enabled** (address 135) and **U4 transformer** as **Usync transf.** (address 210) during configuration of the functional scope.

The measured values from synchronism check (636 „Udiff =“, 637 „Uline =“, 638 „Ubus =“, 647 „F-diff=“, 649 „F-line=“, 646 „F-bus =“ and 648 „ φ dif=“) are only available, or will only be calculated, if the synchronism check was set to **Enabled** and the parameter **U4 transformer** (address 210) has been set to **Usync transf.**

Different interrogation conditions can be parameterized for automatic reclosure on the one hand and for manual closure on the other hand. Each closing command is considered a manual reclosure if it was initiated via the integrated control function or via a serial interface.

The general limit values for synchronism check are set at address 3501 to 3508. Additionally, addresses 3510 to 3519 are relevant for automatic reclosure, addresses 3530 to 3539 are relevant for manual closure. Moreover, address 3509 is relevant for closure via the integrated control function.

The complete synchronism check function is switched **ON** or **OFF** in address 3501 **FCT Synchronism**. If switched off, the synchronism check does not verify the synchronization conditions and release is not granted. You can also set **ON:w/o CloseCmd**: the CLOSE command is in this case not included in the common device alarm „Relay CLOSE“ (No. 510), but the alarm „Sync.CloseCmd“ (No. 2961) is issued.

Address 3502 **Dead Volt. Thr.** indicates the voltage threshold below which the feeder or the busbar can safely be considered dead (for checking a de-energized feeder or busbar). The setting is applied in Volts secondary. This value can be entered as a primary value when parameterizing with a PC and DIGSI®. Depending on the connection of the voltages these are phase-to-earth voltages or phase-to-phase voltages.

The voltage above which the feeder or busbar is regarded as being definitely live, is set under address 3503 **Live Volt. Thr.** (for energized line or busbar check and for the lower limit of synchronism check). It must be set below the anticipated operational undervoltage. The setting is applied in Volts secondary. This value can be entered as a primary value when parameterizing with a PC and DIGSI®. Depending on the connection of the voltages these are phase-to-earth voltages or phase-to-phase voltages.

The maximum permissible voltage for the operating range of the synchronism check function is set in address 3504 **U_{max}**. The setting is applied in Volts secondary. This value can be entered as a primary value when parameterizing with a PC and DIGSI®. Depending on the VT connection these are phase-to-earth voltages or phase-to-phase voltages.

Verification of the release conditions via synchronism check can be limited to a configurable synchronous monitoring time **T-SYN. DURATION** (address 3507). The configured conditions must be fulfilled within this time. If not, closure will not be released. If this time is set to ∞, the conditions will be checked until they are fulfilled or the measurement request is cancelled.

If the conditions for synchronous operation must be checked to be maintained for a certain duration, this minimum duration **T SYNC-STAB** can be set under address 3508 before closing is released.

Synchronism Check Conditions before Automatic Reclosure

Addresses 3510 to 3519 are relevant to the check conditions before automatic reclosure of the circuit breaker. When setting the parameters for the internal automatic reclosing function (Section 2.15.2), it is decided with which automatic reclosing cycle synchronism and voltage check should be carried out.

Address 3510 **Op.mode with AR** determines whether closing under asynchronous system conditions is allowed for automatic reclosure. Set this parameter to **with T-CB close** to allow asynchronous closing; the relay will then consider the circuit breaker operating time before determining the correct instant for the close command. Remember that closing under asynchronous system conditions is allowed only if the circuit breaker closing time is set correctly (see above under „Preconditions“)! If you wish to permit automatic reclosure only under synchronous system conditions, set this address to **w/o T-CB close**.

The permissible magnitude difference of the voltages is set at address 3511 **Max. Volt. Diff.** The setting is applied in Volts secondary. This value can be entered as a primary value when parameterizing with a PC and DIGSI®. Depending on the connection of the voltages these are phase-to-earth voltages or phase-to-phase voltages.

The permissible frequency difference between the voltages is set at address 3512 **Max. Freq. Diff.**, the permissible phase angle difference at address 3513 **Max. Angle Diff.**

The further release conditions for automatic reclosing are set at addresses 3515 to 3519.

The following addresses mean:

3515 SYNC-CHECK	The busbar (UBus) and the feeder (ULine) must both be live (Live Volt. Thr. , address 3503); the conditions for synchronism are checked, i.e. Max. Volt. Diff (address 3511), Max. Freq. Diff (address 3512) and Max. Angle Diff (address 3513)). This parameter can only be altered with DIGSI® under Additional Settings ;
3516 Usync> U-line<	The busbar (UBus) must be live (Live Volt. Thr. , address 3503), the feeder (ULine) must be dead (Dead Volt. Thr. , address 3502);
3517 Usync< U-line>	The busbar (UBus) must be dead (Dead Volt. Thr. , address 3502), the feeder (ULine) must be live (Live Volt. Thr. , address 3503);
3518 Usync< U-line<	The busbar (UBus) and the feeder (ULine) must both be dead (Dead Volt. Thr. , address 3502);
3519 OVERRIDE	Automatic reclosure is released without any check.

The five possible release conditions are independent from each other and can be combined.

Synchronism Check Conditions before Manual Closing

Addresses 3530 to 3539 are relevant to the check conditions before manual closure and closing via control command of the circuit breaker. When setting the general protection data (Power System Data 2, Section 2.1.4.1) it was already decided at address 1151 whether synchronism and voltage check should be carried out before manual closing. With the following setting in address **MAN. CLOSE = w/o Sync-check**, no checks are performed before manual closing.

Address 3509 **SyncCB** determines for commands via the integrated control function (local, DIGSI, serial interface) whether synchronism check is carried out or not. This address also tells the device for which switching device of the control the synchronism check applies. You can select from the switching devices which are available for the integrated control. Choose the circuit breaker to be operated via the synchronism check. This is usually the circuit breaker which is operated in case of manual closing or automatic reclosure. If you set **SyncCB = none** here, a CLOSE command via the integrated control will be carried out without synchronism check.

Address 3530 **Op.mode with MC** determines whether closing under asynchronous system conditions is allowed for manual closing or reclosure via control command. Set this parameter to **with T-CB close** to allow asynchronous closing; the relay will then consider the circuit breaker closing time before determining the correct instant for the close command. Remember that closing under asynchronous system conditions is allowed only if the circuit breaker closing time is set correctly (see above under „Pre-

conditions“)! If you wish to permit manual closure or closing via control command only under synchronous system conditions, set this address to **w/o T-CB close**.

The permissible difference between the voltages is set in address 3531 **MC maxVolt.Diff**. The setting is applied in Volts secondary. This value can be entered as a primary value when parameterizing with a PC and DIGSI®. Depending on the VT connection these are phase-to-earth voltages or phase-to-phase voltages.

The permissible frequency difference between the voltages is set at address 3532 **MC maxFreq.Diff**, the permissible phase angle difference at address 3533 **MC maxAngleDiff**.

The further release conditions for manual reclosing or reclosure via control command are set under addresses 3535 to 3539.

The following addresses mean:

3535 MC SYNCHR	The busbar (UBus) and the feeder (ULine) must both be live (Live Volt. Thr. , address 3503); the conditions for synchronism are checked, i.e. MC maxVolt.Diff (address 3531), MC maxFreq.Diff (address 3532) and MC maxAngleDiff (address 3533). This parameter can only be altered with DIGSI® under Additional Settings .
3536 MC Usyn> Uline<	The busbar (UBus) must be live (Live Volt. Thr. , address 3503), the feeder (ULine) must be dead (Dead Volt. Thr. , address 3502);
3537 MC Usyn< Uline>	The busbar (UBus) must be dead (Dead Volt. Thr. , address 3502), the feeder (ULine) must be live (Live Volt. Thr. , address 3503);
3538 MC Usyn< Uline<	The busbar (UBus) and the feeder (ULine) must both be dead (Dead Volt. Thr. , address 3502);
3539 MC O/RIDE	Manual closing or closing via control command is released without any check.

The five possible release conditions are independent from each other and can be combined.

Note

The closing functions of the device issue individual output indications for the corresponding close command. Be sure that the output indications are assigned to the correct output relays.

No. 2851 „AR CLOSE Cmd.“ for CLOSE via command of the automatic reclosure,

No. 562 „Man.Close Cmd“ for manual CLOSE via binary input,

No. 2961 „Sync.CloseCmd“ for CLOSE via synchronism check (not required if synchronism check releases the other CLOSE commands),

No. 7329 „CB1 - TEST close“ for CLOSE by circuit breaker test, additionally CLOSE command via control, e.g. „52 Close“.

No. 510 „Relay CLOSE“ general CLOSE command. It comprises all CLOSE commands described above.



Notes on the Information List

The most important information of the device is briefly explained in so far as it cannot be interpreted in the following information lists or described in detail in the foregoing text.

„>Sync. Start MC“ (No. 2905)

Binary input which enables direct initiation of the synchronism check with setting parameters for manual close. This initiation with setting parameter for manual close has always precedence if binary inputs „>Sync. Start MC“ (No. 2905) and „>Sync. Start AR“ (No. 2906, see below) are activated at the same time.

„>Sync. Start AR“ (No 2906)

Measuring request from an external automatic reclosure device. The parameters of synchronism check set for automatic reclosure are valid here.

„Sync. req.CNTRL“ (No 2936)

Measurement request of the control function; this request is evaluated on event-triggered basis and only generated if the control issues a measurement request.

„Sync. release“ (No 2951)

Release signal to an external automatic reclosure device.

2.16.3 Settings

Addresses which have an appended "A" can only be changed with DIGSI, under Additional Settings.

Addr.	Parameter	Setting Options	Default Setting	Comments
3501	FCT Synchronism	ON OFF ON;w/o CloseCmd	ON	Synchronism and Voltage Check function
3502	Dead Volt. Thr.	1 .. 60 V	5 V	Voltage threshold dead line / bus
3503	Live Volt. Thr.	20 .. 125 V	90 V	Voltage threshold live line / bus
3504	Umax	20 .. 140 V	110 V	Maximum permissible voltage
3507	T-SYN. DURATION	0.01 .. 600.00 sec; ∞	1.00 sec	Maximum duration of synchronism-check
3508	T SYNC-STAB	0.00 .. 30.00 sec	0.00 sec	Synchronous condition stability timer
3509	SyncCB	(Setting options depend on configuration)	None	Synchronizable circuit breaker
3510	Op.mode with AR	with T-CB close w/o T-CB close	w/o T-CB close	Operating mode with AR
3511	Max. Volt. Diff	1.0 .. 40.0 V	2.0 V	Maximum voltage difference
3512	Max. Freq. Diff	0.03 .. 2.00 Hz	0.10 Hz	Maximum frequency difference
3513	Max. Angle Diff	2 .. 80 °	10 °	Maximum angle difference

Addr.	Parameter	Setting Options	Default Setting	Comments
3515A	SYNC-CHECK	YES NO	YES	Live bus / live line and Sync before AR
3516	Usync> U-line<	YES NO	NO	Live bus / dead line check before AR
3517	Usync< U-line>	YES NO	NO	Dead bus / live line check before AR
3518	Usync< U-line<	YES NO	NO	Dead bus / dead line check before AR
3519	OVERRIDE	YES NO	NO	Override of any check before AR
3530	Op.mode with MC	with T-CB close w/o T-CB close	w/o T-CB close	Operating mode with Man.CI
3531	MC maxVolt.Diff	1.0 .. 40.0 V	2.0 V	Maximum voltage difference
3532	MC maxFreq.Diff	0.03 .. 2.00 Hz	0.10 Hz	Maximum frequency difference
3533	MC maxAngleDiff	2 .. 80 °	10 °	Maximum angle difference
3535A	MC SYNCHR	YES NO	YES	Live bus / live line and Sync before MC
3536	MC U syn> Uline<	YES NO	NO	Live bus / dead line check before Man.CI
3537	MC U syn< Uline>	YES NO	NO	Dead bus / live line check before Man.CI
3538	MC U syn< Uline<	YES NO	NO	Dead bus / dead line check before Man.CI
3539	MC O/RIDE	YES NO	NO	Override of any check before Man.CI

2.16.4 Information List

No.	Information	Type of Information	Comments
2901	>Sync. on	SP	>Switch on synchro-check function
2902	>Sync. off	SP	>Switch off synchro-check function
2903	>BLOCK Sync.	SP	>BLOCK synchro-check function
2905	>Sync. Start MC	SP	>Start synchro-check for Manual Close
2906	>Sync. Start AR	SP	>Start synchro-check for AR
2907	>Sync. synch	SP	>Sync-Prog. Live bus / live line / Sync
2908	> U syn< U-line>	SP	>Sync-Prog. Dead bus / live line
2909	> U syn> U-line<	SP	>Sync-Prog. Live bus / dead line
2910	> U syn< U-line<	SP	>Sync-Prog. Dead bus / dead line
2911	>Sync. o/ride	SP	>Sync-Prog. Override (bypass)
2930	Sync. on/off BI	IntSP	Synchro-check ON/OFF via BI
2931	Sync. OFF	OUT	Synchro-check is switched OFF
2932	Sync. BLOCK	OUT	Synchro-check is BLOCKED
2934	Sync. faulty	OUT	Synchro-check function faulty
2935	Sync. Tsup.Exp	OUT	Synchro-check supervision time expired

No.	Information	Type of Information	Comments
2936	Sync. req.CNTRL	OUT	Synchro-check request by control
2941	Sync. running	OUT	Synchronization is running
2942	Sync.Override	OUT	Synchro-check override/bypass
2943	Synchronism	OUT	Synchronism detected
2944	Usyn< U-line>	OUT	Sync. dead bus / live line detected
2945	Usyn> U-line<	OUT	Sync. live bus / dead line detected
2946	Usyn< U-line<	OUT	Sync. dead bus / dead line detected
2947	Sync. Udiff>	OUT	Sync. Voltage diff. greater than limit
2948	Sync. fdiff>	OUT	Sync. Freq. diff. greater than limit
2949	Sync. ϕ -diff>	OUT	Sync. Angle diff. greater than limit
2951	Sync. release	OUT	Synchronism release (to ext. AR)
2961	Sync.CloseCmd	OUT	Close command from synchro-check
2970	Sync. f-bus>>	OUT	Sync. Bus frequency > (fn + 3Hz)
2971	Sync. f-bus<<	OUT	Sync. Bus frequency < (fn - 3Hz)
2972	Sync. f-line>>	OUT	Sync. Line frequency > (fn + 3Hz)
2973	Sync. f-line<<	OUT	Sync. Line frequency < (fn - 3Hz)
2974	Sync. U-syn>>	OUT	Sync. Bus voltage > Umax (P.3504)
2975	Sync. U-syn<<	OUT	Sync. Bus voltage < U> (P.3503)
2976	Sync. U-line>>	OUT	Sync. Line voltage > Umax (P.3504)
2977	Sync. U-line<<	OUT	Sync. Line voltage < U> (P.3503)

2.17 Undervoltage and Overvoltage Protection (optional)

Voltage protection has the function of protecting electrical equipment against under-voltage and overvoltage. Both operational states are unfavourable as overvoltage may cause, for example, insulation problems or undervoltage may cause stability problems.

The overvoltage protection in the 7SD5 detects the phase voltages U_{L1-E} , U_{L2-E} and U_{L3-E} , the phase-to-phase voltages U_{L1-L2} , U_{L2-L3} and U_{L3-L1} , as well as the displacement voltage $3U_0$. Instead of the displacement voltage any other voltage that is connected to the fourth voltage input U_4 of the device can be detected. Furthermore, the device calculates the positive sequence system voltage and the negative sequence system voltage so that the symmetrical components are also monitored. Here compounding is also possible which calculates the voltage at the remote line end.

The undervoltage protection can also use the phase voltages U_{L1-E} , U_{L2-E} and U_{L3-E} , the phase-to-phase voltages U_{L1-L2} , U_{L2-L3} and U_{L3-L1} , as well as the positive sequence system.

These voltage protection functions can be combined according to the user's requirements. They can be switched on or off separately, or used for alarm purposes only. In the latter case the respective trip commands do not appear. Each voltage protection function is two-stage, i.e. it is provided with two threshold setting stages, each one with its respective time delay.

Abnormally high voltages often occur e.g. in low loaded, long distance transmission lines, in islanded systems when generator voltage regulation fails, or after full load shutdown of a generator from the system. Even if compensation reactors are used to avoid line overvoltages by compensation of the line capacitance and thus reduction of the overvoltage, the overvoltage will endanger the insulation if the reactors fail (e.g. due to fault clearance). The line must be deenergized within very short time.

The undervoltage protection can be applied, for example, for disconnection or load shedding tasks in a system. Furthermore, this protection scheme can detect menacing stability problems. With induction machines undervoltages have an effect on the stability and permissible torque thresholds.

2.17.1 Overvoltage Protection

Overvoltage Phase–Earth

Figure 2-132 depicts the logic diagram of the phase voltage stages. The fundamental frequency is numerically filtered from each of the three measuring voltages so that harmonics or transient voltage peaks are largely eliminated. Two threshold stages **Uph-e>** and **Uph-e>>** are compared with the voltages. If a phase voltage exceeds these thresholds it is indicated phase-segregated. Furthermore, a general pickup indication „Uph-e> Pickup“ „Uph-e>> Pickup“ is given. The drop-out to pickup ratio can be set (**Uph-e>(>) RESET**).

Every stage starts a time delay which is common to all phases. Expiry of the respective time delay **T Uph-e>** or **T Uph-e>>** is signalled and usually results in the trip command „Uph-e>(>) TRIP“.

The overvoltage protection phase–earth can be blocked via a binary input „>Uph-e>(>) BLK“.




Figure 2-132 Logic diagram of the overvoltage protection for phase voltage

Phase-phase Over-voltage

The phase–phase overvoltage protection operates just like the phase–earth protection except that it detects phase–to–phase voltages. Accordingly, phase–to–phase voltages which have exceeded one of the stage thresholds **Uph - ph>** or **Uph - ph>>** are also indicated. Beyond this, Figure 2-132 applies in principle.

The phase–phase overvoltage protection can also be blocked via a binary input „>Uph - ph> (>) BLK“.

Overvoltage Positive Sequence System U_1

The device calculates the positive sequence system according to its defining equation

$$\underline{U}_1 = 1/3 \cdot (\underline{U}_{L1} + \underline{a} \cdot \underline{U}_{L2} + \underline{a}^2 \cdot \underline{U}_{L3})$$

where $\underline{a} = e^{j120^\circ}$.

The resulting single–phase AC voltage is fed to the two threshold stages **U1>** and **U1>>** (see Figure 2-133). Combined with the associated time delays **T U1>** and **T U1>>** these stages form a two-stage overvoltage protection for the positive sequence system. Here too, the drop-out to pickup ratio can be set.

The overvoltage protection for the positive sequence system can also be blocked via a binary input „>U1> (>) BLK“.




Figure 2-133 Logic diagram of the overvoltage protection for the positive sequence voltage system

Overvoltage Protection U_1 with Configurable Compounding

The overvoltage protection for the positive sequence system may optionally operate with compounding. The compounding calculates the positive sequence system of the voltages at the remote line end. This option is thus particularly well suited for detecting a steady-state voltage increase caused by long transmission lines operating at weak load or no load due to the capacitance per unit length (Ferranti effect). In this case the overvoltage condition exists at the other line end but it can only be removed by switching off the local line end.

For calculating the voltage at the opposite line end, the device requires the line data (inductance per unit length, capacitance per unit length, line angle, line length) which were entered in the Power System Data 2 (Section 2.1.4.1) during configuration.

Compounding is only available if address 137 is set to **Enabl. w. comp.**. In this case the calculated voltage at the other line end is also indicated in the operational measured values.



Note

Compounding is not suited for lines with series capacitors.

The voltage at the remote line end is calculated from the voltage measured at the local line end and the flowing current by means of a PI equivalent circuit diagram (refer also to Figure 2-134).

$$\underline{U}_{\text{End}} = \underline{U}_{\text{Meas}} - \left(\underline{I}_{\text{Meas}} - \frac{j\omega C_L}{2} \cdot \underline{U}_{\text{Meas}} \right) \cdot (R_L + j\omega L_L)$$

with

$\underline{U}_{\text{End}}$ the calculated voltage at the remote line end,

$\underline{U}_{\text{Measuring}}$ the measured voltage at the local line end,

I_{Meas} the measured current at the local line end,
 C_L the line capacitance,
 R_L the ohmic line resistance,
 L_L the line inductance.




Figure 2-134 PI equivalent diagram for compounding


Overvoltage Negative Sequence System U_2

The device calculates the negative sequence system voltages according to its defining equation:

$$U_2 = \frac{1}{3} \cdot (U_{L1} + \underline{a}^2 \cdot U_{L2} + \underline{a} \cdot U_{L3})$$

where $\underline{a} = e^{j120^\circ}$.

The resulting single-phase AC voltage is fed to the two threshold stages **U2>** and **U2>>**. Figure 2-135 shows the logic diagram. By combining the associated time delays **T U2>** and **T U2>>** a two-stage overvoltage protection for the negative sequence system is formed. Here too, the drop-out to pickup ratio can be set.

Figure 2-135 Logic diagram of the overvoltage protection for the negative sequence voltage system U_2

The overvoltage protection for the negative sequence system can also be blocked via a binary input „>U2> (>) BLK“. The stages of the negative sequence voltage protection are automatically blocked as soon as an asymmetrical voltage failure was detected („Fuse-Failure-Monitor“, also see Section 2.22.1, margin heading „Fuse Failure Monitor (Non-symmetrical Voltages)“) or when the trip of the mcb for voltage transformers has been signalled via the binary input „>FAIL:Feeder VT“ (internal indication „internal blocking“).

Overvoltage Zero Sequence System $3U_0$

Even during single-pole dead time (with internal automatic reclosure function) the stages of the negative sequence overvoltage protection are automatically blocked since arising negative sequence values are only influenced by the asymmetrical power flow, not by the fault in the system. If the device cooperates with an external automatic reclosure function, or if a single-pole tripping can be triggered by a different protection system (working in parallel), the overvoltage protection for the negative sequence system must be blocked via a binary input during single-pole tripping.

Figure 2-136 depicts the logic diagram of the zero sequence voltage stage. The fundamental frequency is numerically filtered from the measuring voltage so that the harmonics or transient voltage peaks remain largely harmless.

The triple zero sequence voltage $3 \cdot U_0$ is fed to the two threshold stages **3U0>** and **3U0>>**. Combined with the associated time delays **T 3U0>** and **T 3U0>>** these stages form a two-stage overvoltage protection for the zero sequence system. Here too, the drop-off to pickup ratio can be set (**3U0> (>) RESET**). Furthermore, a restraint delay can be configured which is implemented by repeated measuring (approx. 3 periods).

The overvoltage protection for the zero sequence system can also be blocked via a binary input „>3U0> (>) BLK“. The stages of the zero sequence voltage protection are automatically blocked as soon as an asymmetrical voltage failure was detected („Fuse-Failure-Monitor“, also see Section 2.22.1, margin heading „Fuse Failure Monitor (Non-symmetrical Voltages)“) or when the trip of the mcb for voltage transformers has been signalled via the binary input „>FAIL: Feeder VT“ (internal indication „internal blocking“).

The stages of the zero sequence voltage protection are automatically blocked (with the internal automatic reclosure function) during single-pole automatic reclose dead time to avoid pickup with the asymmetrical power flow arising during this state. If the device operates with an external automatic reclosure function or if single-pole tripping can be triggered by a different protection system (operating in parallel), the overvoltage protection for the zero sequence system must be blocked via a binary input during single-pole tripping.

According to Figure 2-136 the device calculates the voltage to be monitored:

$$3 \cdot U_0 = \underline{U}_{L1} + \underline{U}_{L2} + \underline{U}_{L3}$$

This applies if no suitable voltage is connected to the fourth measuring input U_4 .

However, if the displacement voltage U_{Delta} of the voltage transformer set is directly connected to the fourth measuring input U_4 of the device and this information was entered during configuration, the device will automatically use this voltage and calculate the triple zero sequence voltage.

$$3 \cdot U_0 = \mathbf{Uph} / \mathbf{Udelta} \cdot U_4$$

Since the voltage transformation ratio of the voltage transformer set is usually

$$\frac{U_{N \text{ prim}}}{\sqrt{3}} / \frac{U_{N \text{ sec}}}{\sqrt{3}} / \frac{U_{N \text{ sec}}}{3}$$

the factor is set to $\mathbf{Uph} / \mathbf{Udelta} = 3/\sqrt{3} = \sqrt{3} = 1.73$. For more details, refer to **General Power System Data (Power System Data 1)** in Section 2.1.4.1 at margin heading „Voltage Connections“ via address 211.




Figure 2-136 Logic diagram of the overvoltage protection for zero sequence voltage

Freely Selectable Single-phase Voltage

As the zero sequence voltage stages operate separately and independent from the other protective overvoltage functions they can be used for any other single-phase voltage. Therefore the fourth voltage input U_4 of the device must be assigned accordingly (also see Section 2.1.2, „Voltage Transformer Connection“).

The stages can be blocked via a binary input „>3U0> (>) BLK“. Internal blocking is not accomplished in this application case.

2.17.2 Undervoltage Protection

Undervoltage Phase–Earth

Figure 2-137 depicts the logic diagram of the phase voltage stages. The fundamental frequency is numerically filtered from each of the three measuring voltages so that harmonics or transient voltage peaks are largely harmless. Two threshold stages **Uph-e<** and **Uph-e<<** are compared with the voltages. If phase voltage falls below a threshold it is indicated phase-segregated. Furthermore, a general pickup indication „Uph-e< Pickup“ „Uph-e<< Pickup“ is given. The drop-out to pickup ratio can be set ().

Every stage starts a time delay which is common to all phases. Expiry of the respective time delay **T Uph-e<** or **T Uph-e<<** is signalled and results in the trip command „Uph-e<(<) TRIP“.

Depending on the configuration of the substations, the voltage transformers are located on the busbar side or on the outgoing feeder side. This results in a different

behaviour of the undervoltage protection when the line is deenergized. While the voltage usually remains present or reappears at the busbar side after a trip command and opening of the circuit breaker, it is switched on at the outgoing side. For the undervoltage protection this results in a pickup state being present if the voltage transformers are on the outgoing side. If this pickup must be reset, the current can be used as an additional criterion (current supervision **CURR.SUP. Uphe<**) to achieve this result. Undervoltage will then only be detected if, together with the undervoltage condition, the minimum current **PoleOpenCurrent** of the corresponding phase is also exceeded. This condition is communicated by the central function control of the device.

The undervoltage protection phase-earth can be blocked via a binary input „Uph-e<(<) BLK“. The stages of the undervoltage protection are then automatically blocked if a voltage failure is detected („Fuse-Failure-Monitor“, also see Section 2.22.1) or if the trip of the mcb of the voltage transformers is indicated (internal blocking) via the binary input „>FAIL:Feeder VT“.

Also during a single-pole automatic reclose dead time (using the internal autoreclosure function) the stages of the undervoltage protection are automatically blocked in the pole open state. If necessary, the current criterion will be considered, so that they do not respond to the undervoltage of the disconnected phase when voltage transformers are located on the outgoing side.




Figure 2-137 Logic diagram of the undervoltage protection for phase voltages

Phase-phase Undervoltage

Basically, the phase-phase undervoltage protection operates like the phase-earth protection except that it detects phase-to-phase voltages. Accordingly, both phases are indicated during pickup of an undervoltage stage if one of the stage thresholds **Uph-ph<** or **Uph-ph<<** was undershot. Beyond this, Figure 2-137 applies in principle.

It is sufficient for the current criterion that current flow is detected in one of the involved phases.

The phase-phase undervoltage protection can also be blocked via a binary input „>Uphph(<) BLK“. There is an automatic blocking if the measuring voltage failure was detected or voltage mcb tripping was indicated (internal blocking of the phases affected by the voltage failure).

During single-pole dead time for automatic reclosure (using the internal automatic reclosure function) the stages of the undervoltage protection are automatically blocked in the disconnected phase so that it does not respond to the undervoltage of the dis-

connected phase provided that the voltage transformers are located on the outgoing side.

Undervoltage Positive Sequence System U_1

The device calculates the positive sequence system according to its defining equation

$$\underline{U}_1 = \frac{1}{3} \cdot (\underline{U}_{L1} + \underline{a} \cdot \underline{U}_{L2} + \underline{a}^2 \cdot \underline{U}_{L3})$$

where $\underline{a} = e^{j120^\circ}$.

The resulting single-phase AC voltage is fed to the two threshold stages $U1<$ and $U1<<$ (see Figure 2-138). Combined with the associated time delays $T U1<$ and $T U1<<$ these stages form a two-stage undervoltage protection for the positive sequence system.

Current can be used as an additional criterion for the undervoltage protection of the positive sequence system (current supervision $CURR.SUP.U1<$). An undervoltage is only detected if the current flow is detected in at least one phase together with the undervoltage criterion.

The undervoltage protection for the positive sequence system can be blocked via the binary input „ $>U1<(<) BLK$ “. The stages of the undervoltage protection are automatically blocked if voltage failure is detected („Fuse-Failure-Monitor“, also see Section 2.22.1) or, if the trip of the mcb for the voltage transformer is indicated via the binary input „ $>FAIL:Feeder VT$ “ (internal blocking).




Figure 2-138 Logic diagram of the undervoltage protection for positive sequence voltage system

During single-pole dead time for automatic reclosure (using the internal automatic reclosure function) the stages of the undervoltage protection are automatically blocked in the positive sequence system so that they do not respond to the reduced voltage caused by the disconnected phase in case the voltage transformers are located on the outgoing side.

2.17.3 Setting Notes

General

The voltage protection can only operate if it has been set to **Enabled** during the configuration of the device scope (address 137). Compounding is only available if address 137 is set to **Enabl. w. comp.**

The overvoltage and undervoltage stages can detect phase-to-earth voltages, phase-to-phase voltages or the symmetrical positive sequence system of the voltages; for overvoltage also the symmetrical negative sequence system, zero sequence voltage or a different single-phase voltage can be used. Any combination is possible. Detection procedures that are not required are switched **OFF**.



Note

For overvoltage protection it is particularly important to observe the setting hints: NEVER set an overvoltage stage (U_{L-E} , U_{L-L} , U_1) lower than an undervoltage stage. This would put the device immediately into a state of permanent pickup which cannot be reset by any measured value operation. As a result, the device would remain out of service!

Overvoltage Phase–Earth

The phase voltage stages can be switched **ON** or **OFF** in address 3701 **Uph-e>(>)**. In addition to this, you can set **Alarm Only**, i.e. these stages operate and send alarms but do not generate any trip command. The setting creates in addition also a trip command for these stages.

The settings of the voltage threshold and the timer values depend on the type of application. If steady-state overvoltages are to be detected on long unloaded lines, the **Uph-e>** stage (address 3702) is set to at least 5 % above the maximum stationary phase-to-earth voltage that is to be expected in operation. Additionally, a high drop-off to pick-up ratio is required (address 3709 **Uph-e>(>) RESET** = 0.98 = presetting). This setting is only possible via DIGSI® at "**Additional Settings**". The delay time **T Uph-e>** (address 3703) should be a few seconds so that overvoltages with short duration may not result in tripping.

The **Uph-e>>** stage (address 3704) is provided for high overvoltages with short duration. Here an adequately high pickup value is set, e.g. the $1\frac{1}{2}$ -fold of the nominal phase-earth voltage. 0.1 s to 0.2 s are sufficient for the delay time **T Uph-e>>** (address 3705).

Overvoltage Phase–Phase

Basically, the same considerations apply as for the phase voltage stages. These stages may be used instead of the phase voltage stages or be used additionally. Depending on your choice, set address 3711 **Uph-ph>(>)** to **ON**, **OFF**, **Alarm Only** or .

As phase-to-phase voltages are monitored, the phase-to-phase values are used for the settings **Uph-ph>** (address 3712) and **Uph-ph>>** (address 3714).

For the delay times **T Uph-ph>** (address 3713) and **T Uph-ph>>** (address 3715) the same considerations apply as above. The same is true for the dropout ratios (address 3719 **Uphph>(>) RESET**). This parameter can only be altered with DIGSI® under **Additional Settings**.

Overvoltage Positive Sequence System U_1

You can use the positive sequence voltage stages instead of or in addition to previously mentioned overvoltage stages. Depending on your choice, set address 3731 **U1>(>)** to **ON**, **OFF**, **Alarm Only** or .

For symmetrical voltages an increase of the positive sequence system corresponds to an AND gate of the voltages. These stages are particularly suited to the detection of steady-state overvoltages on long, weak-loaded transmission lines (Ferranti effect). Here too, the **U1>** stage (address 3732) with a longer delay time **T U1>** (address 3733) is used for the detection of steady-state overvoltages (some seconds), the **U1>>** stage (address 3734) with the short delay time **T U1>>** (address 3735) is used for the detection of high overvoltages that may jeopardize insulation.

Note that the positive sequence system is established according to its defining equation $U_1 = \frac{1}{3} \cdot |U_{L1} + \underline{a} \cdot U_{L2} + \underline{a}^2 \cdot U_{L3}|$. For symmetrical voltages this is equivalent to a phase-to-earth voltage.

If you want the voltage at the remote line end to be decisive for overvoltage detection, you use the compounding feature. To do so, you must have set during the configuration of the protective functions (Section 2.1.1.3) address 137 **U/O VOLTAGE** to **Enabl. w. comp.** (enabled with compounding).

In addition, the compounding feature needs the line data, which have been set in the **General Protection Data (Power System Data 2)** (Section 2.1.4.1): Address 1111 **x'**, address 1112 **c'** and address 1113 **Line Length**, as well as address 1105 **Line Angle**. These data are vital for a correct compounding calculation. If the values provided here do not correspond to real conditions, the compounding may calculate a too high voltage at the remote end, which will cause immediate pickup as soon as the measured values are applied. In such a case, the pickup state can only be reset by switching off the measuring voltage.

Compounding can be switched **ON** or **OFF** separately for each of the U1 stages: for the **U1>** stage at address 3736 **U1> Compound** and for the **U1>>** stage at address 3737 **U1>> Compound**.

The dropout to pickup ratio (address 3739 **U1>(>) RESET**) is set as high as possible with regard to the detection of even small steady-state overvoltages. This parameter can only be altered with DIGSI® under **Additional Settings**.

Overvoltage Negative Sequence System U₂

The negative sequence system voltage stages detect asymmetrical voltages. If such voltages shall cause tripping, set address 3741 **U2>(>)** to **ON**. If you want only an alarm to be generated, set address 3741 **U2>(>)** to **Alarm Only**. If you want to create for these stages a trip command in addition to the alarms, choose the setting , in all other cases **OFF**.

This protective function also has two stages, one being **U2>** (address 3742) with a greater time delay **T U2>** (address 3743) for steady-state asymmetrical voltages and the other being **U2>>** (address 3744) with a short delay time **T U2>>** (address 3745) for high asymmetrical voltages.

Note that the negative sequence system is established according to its defining equation $U_2 = \frac{1}{3} \cdot |U_{L1} + \underline{a}^2 \cdot U_{L2} + \underline{a} \cdot U_{L3}|$. For symmetrical voltages and two swapped phases this is equivalent to the phase-to-earth voltage value.

The dropout to pickup ratio **U2>(>) RESET** can be set in address 3749. This parameter can only be altered with DIGSI® under **Additional Settings**.

Zero Sequence System Overvoltage

The zero sequence voltage stages can be switched **ON** or **OFF** in address 3721 **3U0>(>) (or Ux)**. They can also be set to **Alarm Only**, i.e. these stages operate and send alarms but do not generate any trip commands. If you want a trip command to be created anyway, the setting must be . This protection function can be used for any other single-phase voltage which is connected to the fourth voltage measurement input U₄. Also refer to Section 2.1.2.1 and see margin heading „Voltage Transformer Connection“.

This protective function also has two stages. The settings of the voltage threshold and the timer values depend on the type of application. Here no general guidelines can be established. The stage **3U0>** (address 3722) is usually set with a high sensitivity and a longer delay time **T 3U0>** (address 3723). The **3U0>>** stage (address 3724) and its delay time **T 3U0>>** (address 3725) allow you to implement a second stage with less sensitivity and a shorter delay time.

Similar considerations apply if this voltage stage is used for a different voltage at the measuring input U_4 .

Since the time delays of the zero sequence voltage stages are very stable due to the measurement repetition, the sensitivity can be set quite high. This stabilization can be deactivated at address 3728 **3U0>(>) Stab11**. if a shorter pickup time is required. This setting is only possible via DIGSI® at "**Additional Settings**". Please keep in mind that it does not make sense to combine a sensitive setting with a short pickup time.

The dropout to pickup ratio **3U0>(>) RESET** can be set in address 3729. This parameter can only be altered with DIGSI® under **Additional Settings**.

When setting the voltage values please observe the following:

- If the U_{en} voltage of the set of voltage transformers is connected to U_4 and if this was already set in the Power System Data 1 (refer also to Section 2.1.2.1 under margin heading „Voltage Connection“, address 210 **U4 transformer = Udelta transf.**), the device multiplies this voltage by the matching ratio **Uph / Udelta** (address 211), usually with 1.73. Therefore the voltage measured is $\sqrt{3} \cdot U_{en} = 3 \cdot U_0$. When the voltage triangle is fully displaced, the voltage will be $\sqrt{3}$ times the phase-to-phase voltage.
- If any other voltage is connected to U_4 , which is not used for voltage protection, and if this was already set in the Power System Data 1 (refer also to Section 2.1.2.1 under margin heading „Voltage Connection“, e.g. **U4 transformer = Usync transf.** or **U4 transformer = Not connected**), the device calculates the zero sequence voltage from the phase voltages according to its definition $3 \cdot U_0 = |U_{L1} + U_{L2} + U_{L3}|$. When the voltage triangle is fully displaced, the voltage will be $\sqrt{3}$ times the phase-to-phase voltage.
- If any other voltage is connected to U_4 , which is used for voltage protection, and if this was already set in the Power System Data 1 (refer also to Section 2.1.2.1, under margin heading „Voltage Connection“, **U4 transformer = Ux transformer**), this voltage will be used for the voltage stages without any further factors. This „zero sequence voltage protection“ then is, in reality, a single-phase voltage protection for any kind of voltage at U_4 . Note that with a sensitive setting, i.e. close to operational values that are to be expected, not only the time delay **T 3U0>** (address 3723) must be greater, but also the reset ratio **3U0>(>) RESET** (address 3729) must be set as high as possible.

Undervoltage Phase–Earth

The phase voltage stages can be switched **ON** or **OFF** in address 3751 **Uph-e<(<)**. In addition to this, you can set **Alarm Only**, i.e. these stages operate and send alarms but do not generate any trip command. You can generate a trip command in addition to the alarm by setting .

This undervoltage protection function has two stages. The **Uph-e<** stage (address 3752) with a longer setting of the time **T Uph-e<** (address 3753) operates in the case of minor undervoltages. However, the value set here must not be higher than the undervoltage permissible in operation. In the presence of higher voltage dips, the **Uph-e<<** stage (address 3754) with the delay **T Uph-e<<** (address 3755) becomes active.

The dropout to pickup ratio can be set in address . This parameter can only be altered with DIGSI® under **Additional Settings**.

The settings of the voltages and times depend on the intended use; therefore no general recommendations for the settings can be given. For load shedding, for example, the values are often determined by a priority grading coordination chart. In case of stability problems, the permissible levels and durations of overvoltages must be observed. With induction machines undervoltages have an effect on the permissible torque thresholds.

If the voltage transformers are located on the line side, the measuring voltages will be missing when the line is disconnected. To avoid that the undervoltage levels in these cases are or remain picked up, the current criterion **CURR.SUP.Uphe<** (address 3758) is switched **ON**. With busbar side voltage transformers it can be switched **OFF**. However, if the busbar is dead, the undervoltage protection will pick up and expire and then remain in a picked-up state. It must therefore be ensured in such cases that the protection is blocked by a binary input.

Undervoltage Phase–Phase

Basically, the same considerations apply as for the phase voltage stages. These stages may replace the phase voltage stages or be used additionally. Depending on your choice, set address 3761 **Uph-ph< (<)** to **ON**, **OFF**, **Alarm Only** or .

As phase-to-phase voltages are monitored, the phase-to-phase values are used for the settings **Uph-ph<** (address 3762) and **Uph-ph<<** (address 3764).

The corresponding times delay are **T Uph-ph<** (address 3763) and **T Uphph<<** (address 3765).

The dropout to pickup ratio can be set in address . This parameter can only be altered with DIGSI® under **Additional Settings**.

If the voltage transformers are located on the line side, the measuring voltages will be missing when the line is disconnected. To avoid that the undervoltage levels in these cases are or remain picked up, the current criterion **CURR.SUP.Uphph<** (address 3768) is switched **ON**. With busbar side voltage transformers it can be switched **OFF**. However, if the busbar is dead, the undervoltage protection will pick up and expire and then remain in a picked-up state. It must therefore be ensured in such cases that the protection is blocked by a binary input.

Undervoltage Positive Sequence System U_1

The positive sequence undervoltage stages can be used instead of or in addition to previously mentioned undervoltage stages. Depending on your choice, set address 3771 **U1< (<)** to **ON**, **OFF**, **Alarm Only** or .

Basically, the same considerations apply as for the other undervoltage stages. Especially in case of stability problems, the positive sequence system is advantageous, since the positive sequence system is relevant for the limit of the stable energy transmission.

To achieve the two-stage condition, the **U1<** stage (address 3772) is combined with a greater time delay **T U1<** (address 3773), and the **U1<<** stage (address 3774) with a shorter time delay **T U1<<** (address 3775).

Note that the positive sequence system is established according to its defining equation $U_1 = \frac{1}{3} \cdot |U_{L1} + \underline{a} \cdot U_{L2} + \underline{a}^2 \cdot U_{L3}|$. For symmetrical voltages this is equivalent to a phase-earth voltage.

The dropout to pickup ratio can be set in address . This parameter can only be altered with DIGSI® under **Additional Settings**.

If the voltage transformers are located on the line side, the measuring voltages will be missing when the line is disconnected. To avoid that the undervoltage levels in these cases are or remain picked up, the current criterion **CURR.SUP.U1<** (address 3778) is switched **ON**. With busbar side voltage transformers it can be switched **OFF**. However, if the busbar is dead, the undervoltage protection will pick up and expire and then remain in a picked-up state. It must therefore be ensured in such cases that the protection is blocked by a binary input.

2.17.4 Settings

Addresses which have an appended "A" can only be changed with DIGSI, under Additional Settings.

Addr.	Parameter	Setting Options	Default Setting	Comments
3701	Uph-e>(>)	OFF Alarm Only ON	OFF	Operating mode Uph-e overvoltage prot.
3702	Uph-e>	1.0 .. 170.0 V; ∞	85.0 V	Uph-e> Pickup
3703	T Uph-e>	0.00 .. 100.00 sec; ∞	2.00 sec	T Uph-e> Time Delay
3704	Uph-e>>	1.0 .. 170.0 V; ∞	100.0 V	Uph-e>> Pickup
3705	T Uph-e>>	0.00 .. 100.00 sec; ∞	1.00 sec	T Uph-e>> Time Delay
3709A	Uph-e>(>) RESET	0.30 .. 0.98	0.98	Uph-e>(>) Reset ratio
3711	Uph-ph>(>)	OFF Alarm Only ON	OFF	Operating mode Uph-ph overvoltage prot.
3712	Uph-ph>	2.0 .. 220.0 V; ∞	150.0 V	Uph-ph> Pickup
3713	T Uph-ph>	0.00 .. 100.00 sec; ∞	2.00 sec	T Uph-ph> Time Delay
3714	Uph-ph>>	2.0 .. 220.0 V; ∞	175.0 V	Uph-ph>> Pickup
3715	T Uph-ph>>	0.00 .. 100.00 sec; ∞	1.00 sec	T Uph-ph>> Time Delay
3719A	Uph-ph>(>) RESET	0.30 .. 0.98	0.98	Uph-ph>(>) Reset ratio
3721	3U0>(>) (or Ux)	OFF Alarm Only ON	OFF	Operating mode 3U0 (or Ux) overvoltage
3722	3U0>	1.0 .. 220.0 V; ∞	30.0 V	3U0> Pickup (or Ux>)
3723	T 3U0>	0.00 .. 100.00 sec; ∞	2.00 sec	T 3U0> Time Delay (or T Ux>)
3724	3U0>>	1.0 .. 220.0 V; ∞	50.0 V	3U0>> Pickup (or Ux>>)
3725	T 3U0>>	0.00 .. 100.00 sec; ∞	1.00 sec	T 3U0>> Time Delay (or T Ux>>)
3728A	3U0>(>) Stabil.	ON OFF	ON	3U0>(>): Stabilization 3U0-Measurement
3729A	3U0>(>) RESET	0.30 .. 0.98	0.95	3U0>(>) Reset ratio (or Ux)
3731	U1>(>)	OFF Alarm Only ON	OFF	Operating mode U1 overvoltage prot.
3732	U1>	2.0 .. 220.0 V; ∞	150.0 V	U1> Pickup
3733	T U1>	0.00 .. 100.00 sec; ∞	2.00 sec	T U1> Time Delay

Addr.	Parameter	Setting Options	Default Setting	Comments
3734	U1>>	2.0 .. 220.0 V; ∞	175.0 V	U1>> Pickup
3735	T U1>>	0.00 .. 100.00 sec; ∞	1.00 sec	T U1>> Time Delay
3736	U1> Compound	OFF ON	OFF	U1> with Compounding
3737	U1>> Compound	OFF ON	OFF	U1>> with Compounding
3739A	U1>(>) RESET	0.30 .. 0.98	0.98	U1>(>) Reset ratio
3741	U2>(>)	OFF Alarm Only ON	OFF	Operating mode U2 overvoltage prot.
3742	U2>	2.0 .. 220.0 V; ∞	30.0 V	U2> Pickup
3743	T U2>	0.00 .. 100.00 sec; ∞	2.00 sec	T U2> Time Delay
3744	U2>>	2.0 .. 220.0 V; ∞	50.0 V	U2>> Pickup
3745	T U2>>	0.00 .. 100.00 sec; ∞	1.00 sec	T U2>> Time Delay
3749A	U2>(>) RESET	0.30 .. 0.98	0.98	U2>(>) Reset ratio
3751	Uph-e<(<)	OFF Alarm Only ON	OFF	Operating mode Uph-e undervoltage prot.
3752	Uph-e<	1.0 .. 100.0 V; 0	30.0 V	Uph-e< Pickup
3753	T Uph-e<	0.00 .. 100.00 sec; ∞	2.00 sec	T Uph-e< Time Delay
3754	Uph-e<<	1.0 .. 100.0 V; 0	10.0 V	Uph-e<< Pickup
3755	T Uph-e<<	0.00 .. 100.00 sec; ∞	1.00 sec	T Uph-e<< Time Delay
3758	CURR.SUP. Uphe<	ON OFF	ON	Current supervision (Uph-e)
3761	Uph-ph<(<)	OFF Alarm Only ON	OFF	Operating mode Uph-ph undervoltage prot.
3762	Uph-ph<	1.0 .. 175.0 V; 0	50.0 V	Uph-ph< Pickup
3763	T Uph-ph<	0.00 .. 100.00 sec; ∞	2.00 sec	T Uph-ph< Time Delay
3764	Uph-ph<<	1.0 .. 175.0 V; 0	17.0 V	Uph-ph<< Pickup
3765	T Uph-ph<<	0.00 .. 100.00 sec; ∞	1.00 sec	T Uph-ph<< Time Delay
3768	CURR.SUP. Uphph<	ON OFF	ON	Current supervision (Uph-ph)
3771	U1<(<)	OFF Alarm Only ON	OFF	Operating mode U1 undervoltage prot.
3772	U1<	1.0 .. 100.0 V; 0	30.0 V	U1< Pickup
3773	T U1<	0.00 .. 100.00 sec; ∞	2.00 sec	T U1< Time Delay
3774	U1<<	1.0 .. 100.0 V; 0	10.0 V	U1<< Pickup
3775	T U1<<	0.00 .. 100.00 sec; ∞	1.00 sec	T U1<< Time Delay
3778	CURR.SUP. U1<	ON OFF	ON	Current supervision (U1)

2.17.5 Information List

No.	Information	Type of Information	Comments
10201	>Uph-e>(>) BLK	SP	>BLOCK Uph-e>(>) Overvolt. (phase-earth)
10202	>Uph-ph>(>) BLK	SP	>BLOCK Uph-ph>(>) Overvolt (phase-phase)
10203	>3U0>(>) BLK	SP	>BLOCK 3U0>(>) Overvolt. (zero sequence)
10204	>U1>(>) BLK	SP	>BLOCK U1>(>) Overvolt. (positive seq.)
10205	>U2>(>) BLK	SP	>BLOCK U2>(>) Overvolt. (negative seq.)
10206	>Uph-e<(<) BLK	SP	>BLOCK Uph-e<(<) Undervolt (phase-earth)
10207	>Uphph<(<) BLK	SP	>BLOCK Uphph<(<) Undervolt (phase-phase)
10208	>U1<(<) BLK	SP	>BLOCK U1<(<) Undervolt (positive seq.)
10215	Uph-e>(>) OFF	OUT	Uph-e>(>) Overvolt. is switched OFF
10216	Uph-e>(>) BLK	OUT	Uph-e>(>) Overvolt. is BLOCKED
10217	Uph-ph>(>) OFF	OUT	Uph-ph>(>) Overvolt. is switched OFF
10218	Uph-ph>(>) BLK	OUT	Uph-ph>(>) Overvolt. is BLOCKED
10219	3U0>(>) OFF	OUT	3U0>(>) Overvolt. is switched OFF
10220	3U0>(>) BLK	OUT	3U0>(>) Overvolt. is BLOCKED
10221	U1>(>) OFF	OUT	U1>(>) Overvolt. is switched OFF
10222	U1>(>) BLK	OUT	U1>(>) Overvolt. is BLOCKED
10223	U2>(>) OFF	OUT	U2>(>) Overvolt. is switched OFF
10224	U2>(>) BLK	OUT	U2>(>) Overvolt. is BLOCKED
10225	Uph-e<(<) OFF	OUT	Uph-e<(<) Undervolt. is switched OFF
10226	Uph-e<(<) BLK	OUT	Uph-e<(<) Undervolt. is BLOCKED
10227	Uph-ph<(<) OFF	OUT	Uph-ph<(<) Undervolt. is switched OFF
10228	Uph-ph<(<) BLK	OUT	Uphph<(<) Undervolt. is BLOCKED
10229	U1<(<) OFF	OUT	U1<(<) Undervolt. is switched OFF
10230	U1<(<) BLK	OUT	U1<(<) Undervolt. is BLOCKED
10231	U</> ACTIVE	OUT	Over-/Under-Voltage protection is ACTIVE
10240	Uph-e> Pickup	OUT	Uph-e> Pickup
10241	Uph-e>> Pickup	OUT	Uph-e>> Pickup
10242	Uph-e>(>) PU L1	OUT	Uph-e>(>) Pickup L1
10243	Uph-e>(>) PU L2	OUT	Uph-e>(>) Pickup L2
10244	Uph-e>(>) PU L3	OUT	Uph-e>(>) Pickup L3
10245	Uph-e> TimeOut	OUT	Uph-e> TimeOut
10246	Uph-e>> TimeOut	OUT	Uph-e>> TimeOut
10247	Uph-e>(>) TRIP	OUT	Uph-e>(>) TRIP command
10255	Uphph> Pickup	OUT	Uph-ph> Pickup
10256	Uphph>> Pickup	OUT	Uph-ph>> Pickup
10257	Uphph>(>)PU L12	OUT	Uph-ph>(>) Pickup L1-L2
10258	Uphph>(>)PU L23	OUT	Uph-ph>(>) Pickup L2-L3
10259	Uphph>(>)PU L31	OUT	Uph-ph>(>) Pickup L3-L1
10260	Uphph> TimeOut	OUT	Uph-ph> TimeOut
10261	Uphph>> TimeOut	OUT	Uph-ph>> TimeOut
10262	Uphph>(>) TRIP	OUT	Uph-ph>(>) TRIP command
10270	3U0> Pickup	OUT	3U0> Pickup
10271	3U0>> Pickup	OUT	3U0>> Pickup
10272	3U0> TimeOut	OUT	3U0> TimeOut

No.	Information	Type of Information	Comments
10273	3U0>> TimeOut	OUT	3U0>> TimeOut
10274	3U0>(>) TRIP	OUT	3U0>(>) TRIP command
10280	U1> Pickup	OUT	U1> Pickup
10281	U1>> Pickup	OUT	U1>> Pickup
10282	U1> TimeOut	OUT	U1> TimeOut
10283	U1>> TimeOut	OUT	U1>> TimeOut
10284	U1>(>) TRIP	OUT	U1>(>) TRIP command
10290	U2> Pickup	OUT	U2> Pickup
10291	U2>> Pickup	OUT	U2>> Pickup
10292	U2> TimeOut	OUT	U2> TimeOut
10293	U2>> TimeOut	OUT	U2>> TimeOut
10294	U2>(>) TRIP	OUT	U2>(>) TRIP command
10300	U1< Pickup	OUT	U1< Pickup
10301	U1<< Pickup	OUT	U1<< Pickup
10302	U1< TimeOut	OUT	U1< TimeOut
10303	U1<< TimeOut	OUT	U1<< TimeOut
10304	U1<(<) TRIP	OUT	U1<(<) TRIP command
10310	Uph-e< Pickup	OUT	Uph-e< Pickup
10311	Uph-e<< Pickup	OUT	Uph-e<< Pickup
10312	Uph-e<(<) PU L1	OUT	Uph-e<(<) Pickup L1
10313	Uph-e<(<) PU L2	OUT	Uph-e<(<) Pickup L2
10314	Uph-e<(<) PU L3	OUT	Uph-e<(<) Pickup L3
10315	Uph-e< TimeOut	OUT	Uph-e< TimeOut
10316	Uph-e<< TimeOut	OUT	Uph-e<< TimeOut
10317	Uph-e<(<) TRIP	OUT	Uph-e<(<) TRIP command
10325	Uph-ph< Pickup	OUT	Uph-ph< Pickup
10326	Uph-ph<< Pickup	OUT	Uph-ph<< Pickup
10327	Uphph<(<)PU L12	OUT	Uphph<(<) Pickup L1-L2
10328	Uphph<(<)PU L23	OUT	Uphph<(<) Pickup L2-L3
10329	Uphph<(<)PU L31	OUT	Uphph<(<) Pickup L3-L1
10330	Uphph< TimeOut	OUT	Uphph< TimeOut
10331	Uphph<< TimeOut	OUT	Uphph<< TimeOut
10332	Uphph<(<) TRIP	OUT	Uphph<(<) TRIP command

2.18 Frequency Protection (optional)

The frequency protection function detects abnormally high and low frequencies in the system or in electrical machines. If the frequency lies outside the allowable range, appropriate actions are initiated, such as load shedding or separating a generator from the system.

Underfrequency is caused by increased real power demand or by a reduction of the generated power, e.g. in the event of disconnection from the network, generator failure or faulty operation of the power frequency control. Underfrequency protection is also applied for generators which operate (temporarily) to an island network. This is due to the fact that the reverse power protection cannot operate in case of a drive power failure. The generator can be disconnected from the power system by means of the underfrequency protection. Underfrequency results also in increased reactive power demand of inductive consumers.

Overfrequency is caused for instance in case of load shedding, system disconnection or malfunction of the power-frequency control. This includes also a risk of self-excitation for generators feeding long lines under no-load conditions.

2.18.1 Method of Operation

Frequency Stages Frequency protection consists of the four frequency elements f1 to f4. Each element can be set as overfrequency stage (f>) or as underfrequency stage (f<) with individual thresholds and time delays. This ensures variable matching to the application purpose.

- If an element is set to a value above the rated frequency, it is automatically interpreted to be an overfrequency stage f>.
- If an element is set to a value below the rated frequency, it is automatically interpreted to be an underfrequency stage f<.
- If an element is set exactly to the rated frequency, it is inactive.

Each element can be blocked via binary input and also the entire frequency protection function can be blocked.

Frequency Measurement The largest of the 3 phase-earth currents is used for frequency measurement. This value must be at least 6 V (secondary). Below that value frequency measurement will not take place.

Numerical filters are employed to calculate from the measured voltage a quantity that is proportional to the frequency which is virtually linear in the specified range ($f_N \pm 10\%$). Filters and repeated measurements ensure that the frequency evaluation is virtually free from harmonic influences and phase jumps.

An accurate and quick measurement result is obtained by considering also the frequency change. When changing the frequency of the power system, the sign of the quotient $\Delta f / \Delta t$ remains unchanged during several repeated measurements. If, however, a phase jump in the measured voltage temporarily simulates a frequency deviation, the sign of $\Delta f / \Delta t$ will subsequently reverse. Thus the measurement results corrupted by a phase jump are quickly discarded.

The dropout value of each frequency element is approximately 20 mHz below (for f>) or above (for f<) of the pickup value.

Operating Ranges

Frequency evaluation requires a measured quantity that can be processed. This implies that at least a sufficiently high voltage is available and that the frequency of this voltage is within the working range of the frequency protection.

The frequency protection selects automatically the largest of the phase-earth voltages. If all three voltages are below the operating range of approx. 6 V (secondary), the frequency cannot be determined. If the voltage sinks below this minimum value after a frequency stage has picked up, the picked up element will drop out. This implies also that all frequency stages will drop out after a line has been switched off (with voltage transformers on line side).

When connecting a measuring voltage with a frequency outside the configured threshold of a frequency element, the frequency protection is immediately ready to operate. Since the filters of the frequency measurement must first go through a transient state, the command output time may increase slightly (approx. 1 period). This is because a frequency element picks up only if the frequency was outside the configured threshold in five consecutive measurements.

The frequency range is from 25 Hz to 70 Hz. If the frequency leaves this operating range, the frequency elements will drop out. If the frequency returns into the working range, the measurement can be resumed provided that the measuring voltage too is inside the working range. But if the measuring voltage is switched off, the picked up element will drop out immediately.

Power Swings

In interconnected networks, frequency deviations may also be caused by power swings. Depending on the power swing frequency the mounting location of the device and the setting of the frequency elements, power swings may cause the frequency protection to pickup and even to trip. In such cases out-of-step trips can not be prevented by operating the distance protection with power swing blocking (see also Section 2.6). Rather, it is reasonable to block the frequency protection once power swings are detected. This can be accomplished via binary inputs and binary outputs or by corresponding logic operations using the user-defined logic (CFC). If, however, the power swing frequencies are known, tripping of the frequency protection function can also be avoided by adapting the delay times of the frequency protection correspondingly.

Pickup/Tripping

Figure 2-139 shows the logic diagram for the frequency protection function.

Once the frequency was reliably detected to be outside the configured thresholds of a stage (above the setting value for $f >$ elements or below for $f <$ elements), a pickup signal of the corresponding stage is generated. The decision is considered reliable if 5 measurements taken in intervals of $1/2$ period yield one frequency outside the set threshold.

After pickup, a delay time per element can be started. When the associated time has elapsed, a trip command is issued. A picked up element drops out if the cause of the pickup is no longer valid after 5 measurements or if the measuring voltage was switched off or the frequency leaves the working range. When a frequency element drops out, the tripping signal of the corresponding frequency element is immediately terminated, but the trip command is maintained for at least the minimum command duration which was set for all tripping functions of the device.

Each of the four frequency elements can be blocked individually by binary inputs. The blocking takes immediate effect. It is also possible to block the entire frequency protection function via binary input.




Figure 2-139 Logic diagram of the frequency protection

2.18.2 Setting Notes

General

Frequency protection is only in effect and accessible if address 136 **FREQUENCY Prot.** is set to **Enabled** during configuration of protective functions. If the function is not required, **Disabled** is to be set.

The frequency protection function features 4 frequency stages f1 to f4 each of which can function as overfrequency stage or underfrequency stage. Each zone can be set active or inactive. This is set in addresses:

- 3601 **O/U FREQ. f1** for frequency stage f1,
- 3611 **O/U FREQ. f2** for frequency stage f2,
- 3621 **O/U FREQ. f3** for frequency stage f3,
- 3631 **O/U FREQ. f4** for frequency stage f4,

The following 3 options are available:

- Stage **OFF**: The stage is ineffective;
- Stage **ON: with Trip**: The stage is effective and issues an alarm and a trip command (after time has expired) following irregular frequency deviations;
- Stage **ON: Alarm only**: The stage is effective and issues an alarm but no trip command following irregular frequency deviations.

Pickup Values, Delay Time

The configured pickup value determines whether a frequency element is to respond to overfrequency or underfrequency.

- If a stage is set to a value above the rated frequency, it is automatically interpreted to be an overfrequency stage $f>$.
- If a stage is set to a value below the rated frequency, it is automatically interpreted to be an underfrequency stage $f<$.
- If a stage is set exactly to the rated frequency, it is inactive.

A pickup value can be set for each stage according to above rules. The addresses and possible setting ranges are determined by the nominal frequency as configured in the Power System Data 1 (Section 2.1.2.1) in **Rated Frequency** (address 230).

Please note that none of the frequency stages is set to less than 30 mHz above (for $f>$) or below (for $f<$) of the nominal frequency. Since the frequency stages have a hysteresis of approx. 20 mHz, it may otherwise happen that the element does not drop out when returning to the nominal frequency.

Only those addresses are accessible that match the configured nominal frequency. For each element, a trip delay time can be set:

- Address 3602 **f1 PICKUP** pickup value for frequency stage f1 at $f_N = 50$ Hz,
Address 3603 **f1 PICKUP** pickup value for frequency stage f1 at $f_N = 60$ Hz,
Address 3604 **T f1** trip delay for frequency stage f1;
- Address 3612 **f2 PICKUP** pickup value for frequency stage f2 at $f_N = 50$ Hz,
Address 3613 **f2 PICKUP** pickup value for frequency stage f2 at $f_N = 60$ Hz,
Address 3614 **T f2** trip delay for frequency element f2;
- Address 3622 **f3 PICKUP** pickup value for frequency stage f3 at $f_N = 50$ Hz,
Address 3623 **f3 PICKUP** pickup value for frequency stage f3 at $f_N = 60$ Hz,
Address 3624 **T f3** trip delay for frequency stage f3;
- Address 3632 **f4 PICKUP** pickup value for frequency stage f4 at $f_N = 50$ Hz,
Address 3633 **f4 PICKUP** pickup value for frequency stage f4 at $f_N = 60$ Hz,
Address 3634 **T f4** trip delay for frequency element f4.

The set times are additional delay times not including the operating times (measuring time, dropout time) of the protective function.

If underfrequency protection is used for load shedding purposes, then the frequency settings relative to other feeder relays are generally based on the priority of the customers served by the protective relay. Normally, it is required for load shedding a frequency / time grading that takes into account the importance of the consumers or consumer groups.

In interconnected networks, frequency deviations may also be caused by power swings. Depending on the power swing frequency, the mounting location of the device and the setting of the frequency stages, it is reasonable to block the entire frequency protection function or single stages once a power swing has been detected. The delay times must then be co-ordinated thus that a power swing is detected before the frequency protection trips.

Further application examples exist in the field of power stations. The frequency values to be set mainly depend, also in these cases, on the specifications of the power system/power station operator. In this context, the underfrequency protection also ensures the power station's own demand by disconnecting it from the power system on time. The turbo regulator regulates the machine set to the nominal speed. Consequently, the station's own demands can be continuously supplied at nominal frequency.

Since the dropout threshold is 20 mHz below or above the trip frequency, the resulting „minimum“ trip frequency is 30 mHz above or below the nominal frequency.

A frequency increase can, for example, occur due to a load shedding or malfunction of the speed regulation (e.g. in a stand-alone system). In this way, the frequency protection can, for example, be used as overspeed protection.

2.18.3 Settings

Addr.	Parameter	Setting Options	Default Setting	Comments
3601	O/U FREQ. f1	ON: Alarm only ON: with Trip OFF	ON: Alarm only	Over/Under Frequency Protection stage f1
3602	f1 PICKUP	45.50 .. 54.50 Hz	49.50 Hz	f1 Pickup
3603	f1 PICKUP	55.50 .. 64.50 Hz	59.50 Hz	f1 Pickup
3604	T f1	0.00 .. 600.00 sec	60.00 sec	T f1 Time Delay
3611	O/U FREQ. f2	ON: Alarm only ON: with Trip OFF	ON: Alarm only	Over/Under Frequency Protection stage f2
3612	f2 PICKUP	45.50 .. 54.50 Hz	49.00 Hz	f2 Pickup
3613	f2 PICKUP	55.50 .. 64.50 Hz	57.00 Hz	f2 Pickup
3614	T f2	0.00 .. 600.00 sec	30.00 sec	T f2 Time Delay
3621	O/U FREQ. f3	ON: Alarm only ON: with Trip OFF	ON: Alarm only	Over/Under Frequency Protection stage f3
3622	f3 PICKUP	45.50 .. 54.50 Hz	47.50 Hz	f3 Pickup
3623	f3 PICKUP	55.50 .. 64.50 Hz	59.50 Hz	f3 Pickup
3624	T f3	0.00 .. 600.00 sec	3.00 sec	T f3 Time Delay
3631	O/U FREQ. f4	ON: Alarm only ON: with Trip OFF	ON: Alarm only	Over/Under Frequency Protection stage f4
3632	f4 PICKUP	45.50 .. 54.50 Hz	51.00 Hz	f4 Pickup
3633	f4 PICKUP	55.50 .. 64.50 Hz	62.00 Hz	f4 Pickup
3634	T f4	0.00 .. 600.00 sec	30.00 sec	T f4 Time Delay

2.18.4 Information List

No.	Information	Type of Information	Comments
5203	>BLOCK Freq.	SP	>BLOCK frequency protection
5206	>BLOCK f1	SP	>BLOCK frequency protection stage f1
5207	>BLOCK f2	SP	>BLOCK frequency protection stage f2
5208	>BLOCK f3	SP	>BLOCK frequency protection stage f3
5209	>BLOCK f4	SP	>BLOCK frequency protection stage f4
5211	Freq. OFF	OUT	Frequency protection is switched OFF
5212	Freq. BLOCKED	OUT	Frequency protection is BLOCKED
5213	Freq. ACTIVE	OUT	Frequency protection is ACTIVE
5232	f1 picked up	OUT	Frequency protection: f1 picked up
5233	f2 picked up	OUT	Frequency protection: f2 picked up
5234	f3 picked up	OUT	Frequency protection: f3 picked up
5235	f4 picked up	OUT	Frequency protection: f4 picked up
5236	f1 TRIP	OUT	Frequency protection: f1 TRIP
5237	f2 TRIP	OUT	Frequency protection: f2 TRIP
5238	f3 TRIP	OUT	Frequency protection: f3 TRIP
5239	f4 TRIP	OUT	Frequency protection: f4 TRIP
5240	Time Out f1	OUT	Frequency protection: TimeOut Stage f1
5241	Time Out f2	OUT	Frequency protection: TimeOut Stage f2
5242	Time Out f3	OUT	Frequency protection: TimeOut Stage f3
5243	Time Out f4	OUT	Frequency protection: TimeOut Stage f4

2.19 Fault Locator

The measurement of the distance to a fault is an important supplement to the protection functions. Availability of the line for power transmission within the system can be increased when the fault is located and cleared faster.

2.19.1 Functional Description

General

The fault locator is an autonomous and independent function which uses the line and power system parameters set in other functions. In the event of a fault, it is addressed by the protection functions provided in the 7SD5 device. For lines with two ends, the 7SD5 provides as an option a double-ended fault locator functionality, which allows better fault locating especially in the case of double-ended infeed, faults involving earth currents, and high fault resistances. In the event of a fault, both line ends exchange their local measured values (phase current and phase-to-earth voltages) via the protection data interface. For this function, the 7SD5 of both line ends must be equipped with the option „double-ended fault locator“. If there are more than two line ends, single-ended fault locator will be used.

When double-ended fault locating is used, the single-ended (conventional) fault locator may be invoked simultaneously, depending on the information from the remote end, if

- double-ended fault locating is switched off or blocked,
- no values from the opposite end are available, or
- no fault locating is possible because of heavily distorted measuring signals or faults outside the protected object.

When double-ended fault locating is used, the results of single-ended fault locating are output in any case in additional indications.

The protected object can be an inhomogenous line. For calculation purposes, the line can be divided into different sections, such as a short cable followed by an overhead line. In such protected objects, you can configure each section individually. Without this information, the fault locator uses the general line data (refer to Section 2.1.4).

For the internal decision of whether the single-ended or the double-ended fault locating method will be used, the device calculates, on the basis of the line's known voltage profile, a distance difference from measurement errors, line asymmetry and line geometry. If this distance difference is too great in proportion to the length of the line section considered, the result of the double-ended fault locating is discarded, and the distance output is calculated on a single-end basis. With increasing accuracy, this calculated quality index is output as an indication with a value ranging from 0 to 10.

Double earth faults with different base points, reverse faults and faults that extend beyond the opposite device are calculated and output with single-ended fault locator only.

The fault locating function can be triggered by the trip command of the short-circuit protection, or also by each fault detection. In the latter case, a fault locating calculation is also possible if a different protection device clears the fault.

Fault Locating Using the Single-Ended Fault Locator

The measuring principle of the fault locator is rather similar to that of the distance protection function. Here, too, the device calculates the impedances.

The measured value pairs of fault currents and fault voltages (in intervals of 1/20 period) are stored in a cyclic buffer and frozen shortly after the trip command is issued before any distortion of the measured values occurs due to the opening of the circuit breaker even with very fast circuit breakers. The filtering of the measured values and the number of impedance calculations are automatically adapted to the number of stabilized measured value pairs in the determined data window. If no sufficient data window with stabilized values could be determined for fault location, the alarm „Flt.Loc.invalid“ is issued.

The evaluation of the measured values in the short-circuit loops is carried out after the short-circuit has been cleared. Short-circuit loops are those which caused the trip. In the event of tripping by the earth fault protection, the three phase-to-earth loops are also evaluated.

Double-ended fault locator

The double-ended fault locator method also considers line capacitance and line resistance. It adapts the fault locating for an optimum matching between the voltages calculated for the fault locating and the values measured at the line ends. It is assumed in this context that voltages on a line cannot leap. The voltage at the presumed fault location is calculated once with the values measured on the left side and once with those from the right side. The actual fault location is where there is no or hardly any difference between the voltage characteristics from the left and the right side.

The double-ended fault locating method is based on the assumption that in a line without branches, with known currents and voltages at the inputs, the voltage can be calculated for any location x of the line. This is true for both the left and the right line side. Since the fault location voltage calculated from both sides must be the same, the fault is located at the intersection of the two voltage characteristics. These characteristics are calculated with the telegraph equation from the locally measured currents and voltages, and the reactances per line unit. Figure 2-140 shows a simplified schematic in which linear voltage characteristics are assumed.




Figure 2-140 Curves of voltages on a faulty line (simplified)

The double-ended fault locating method used here has the following advantages over the single-ended method:

- Correct fault locating is possible even with power flowing in the line, with double-sided infeed and high fault resistances.
- The precision of fault locating is not affected by an inaccurate setting of the earth impedance compensation.
- The method is stable against the influence of a parallel line, so parallel line compensation is not required.
- The accuracy can be increased if the line asymmetry (selection of the central conductor) is taken into account.

Output of the Fault Locator

The fault locating issues the following results:

- The short-circuit loop which was used to determine the fault reactance,
- The reactance X in Ω primary and Ω secondary,
- The resistance R in Ω primary and Ω secondary,
- The distance to fault d in kilometers or miles of the line proportional to the reactance, converted on the basis of the set line reactance per unit line length,
- The distance to fault d in % of the line length, calculated on the basis of the set reactance per unit length and the set line length.

The additional indications always show the results of single-ended fault locating.

- Where double-ended fault locating is configured, the results of single-ended fault locating are output in any case in additional indications
 - „Rpri single.“ (No.1135),
 - „Xpri single.“ (No.1136),
 - „Rsec single.“ (No.1137) and
 - „Xsec single.“ (No.1138)
- If the double-ended fault locator fails, they are output as „main results“ in the indications
 - „Rpri =“ (No.1114),
 - „Xpri =“ (No.1115),
 - „Rsec =“ (No.1117) and
 - „Xsec =“ (No.1118)

The fault location indicated in per cent can, at the same time, be output as BCD-code (Binary Coded Decimal). This, however, must have been preset in address 138 during the configuration of the protection functions (Section 2.1.1.3). A further prerequisite is that the required number of binary outputs is allocated for this purpose.

10 output relays are needed. They are classified as follows:

- 4 outputs for the units ($1 \cdot 2^0 + 1 \cdot 2^1 + 1 \cdot 2^2 + 1 \cdot 2^3$),
- 4 outputs for the tens ($10 \cdot 2^0 + 10 \cdot 2^1 + 10 \cdot 2^2 + 10 \cdot 2^3$),
- 1 output for the hundreds ($100 \cdot 2^0$),
- 1 output for the ready-state annunciation „BCD dist. VALID“ (No. 1152).

Once a fault was located, the corresponding binary outputs pick up. Then the output „BCD dist. VALID“ signals that the data are now valid. The duration can be selected. In the event of a new fault, the data of the former fault are cleared automatically.

The output range extends from 0% to 195%. Output „197“ means that a negative fault was detected. Output „199“ describes an overflow, i. e. the calculated value is higher than the maximum possible value of 195 %.



Note

Where the line is not divided into sections, the distance output in kilometers, miles or percent is only accurate for homogeneous lines. If the line is composed of line sections with different reactance per unit length characteristics, e.g. overhead line–cable sections, the reactance calculated by the fault location function can be subjected to a separate computation to derive the distance to fault, or different line sections can be set.

Line Sections

The line type is determined by the line section settings. If, for instance, the line includes a cable and an overhead line, two different types must be configured. The system can distinguish between up to three different line types. When configuring these line data, please note that DIGSI will only show you two or three different tabs for setup if you have first configured that number of line sections.

Line Symmetry (only for Double- Ended Fault Locator)

The asymmetry of a line can be taken into account in order to achieve greater accuracy of the double-ended fault locator. The asymmetry is estimated on the basis of the phase arrangement. You must set the central phase. If you do not wish an estimation of the asymmetry, it can be switched off. The system assumes lines having a high degree of symmetry with respect to the central phase, in particular a single-level arrangement. Figure 2-141 shows possible phase arrangements.




Figure 2-141 Single-level arrangement with central phase

Parallel Line Measured Value Correction (Single-ended Fault Locator)

In the case of earth faults on double circuit lines, the measured values obtained for calculation of the impedance are influenced by the mutual coupling of the earth impedance of **both** parallel lines. This causes measuring errors in the result of the impedance computation unless special measures are taken. The device is therefore provided with a parallel line compensation function. This function takes the earth current of the parallel line into consideration when solving the line equation, thereby compensating for the coupling influence as was the case with the derivation of the distance by the distance protection (refer to Section 2.5.1 under „Parallel Line Measured Value Correction“). The earth current of the parallel line must, of course, be connected to the

device and the current input I_4 must be configured accordingly during the setting of the **General Power System Data (Power System Data 1)** (Section 2.1.2.1 under „Current Transformer Connection“).

The parallel line compensation only applies to faults on the protected feeder. For external faults, including those on the parallel line, compensation is impossible.


Correction of Measured Values for Load Current on Double-end Fed Lines (Single-ended Fault Locator)

When faults occur on loaded lines fed from both ends (Figure 2-142), the fault voltage $\underline{U}_{F1}$ is influenced not only by the source voltage $\underline{E}_1$, but also by the source voltage $\underline{E}_2$, when both voltages are applied to the common earth resistance R_F . This causes measuring errors in the result of the impedance computation unless special measures are taken, since the current component $\underline{I}_{F2}$ cannot be seen at the measuring point M. For long heavily loaded lines, this can give a significant error in the X-component of the fault impedance (the determining factor for the distance calculation).

For single-ended fault location calculation, a load compensation feature is provided in the 7SD5 which corrects this measurement inaccuracy. Correction for the R-component of the fault impedance is not possible; but the resultant inaccuracy is not critical, since only the X-component is critical for the distance to fault indication.

Load compensation is effective for single-phase faults. For single-phase to earth faults, positive and zero phase sequence components of the symmetrical components are used in the compensation.

Load compensation can be switched on or off. Off-switching is useful, for example, during relay testing, in order to avoid influences caused by the test quantities.



Legend

M	Measuring Location	ZS1, ZS2	Source Impedances
E1, E2	Source Voltage (EMF)	ZS1E, ZS2E	Earth Source Impedances
IF1, IF2	Part Fault Currents	ZF1, ZF2	Fault Impedances
IF1 + IF2	Total Fault Currents	ZF1E, ZF2E	Earth Fault Impedances
UF1	Fault Voltage at the Measuring Location	RF	Common Fault Resistance

Figure 2-142 Fault currents and voltages on double-end fed lines

2.19.2 Setting Notes

General

The fault location function is only in service if it was selected to **Enabled** during the configuration of the device functions (Section 2.1.1.3, address 138).

In address 160 **L-sections FL** you can set the number of line sections. If you set the number to **2 Sections** or **3 Sections**, a number of additional tabs for setup will appear in DIGSI. The default setting of this address is **1 Section**, which means

that the line parameters addresses 1116, 1117, 1120 and 1121 are also relevant (refer also to Section 2.1.4).

If the fault location calculation is to be started by the trip command of the protection, set address 3802 **START = TRIP**. In this case a fault location is only output if the device has also issued a trip. The fault location calculation can however also be started with each fault detection of the device (address 3802 **START = Pickup**). In this case the fault location is also calculated if for example a different protection device cleared the fault. If the fault is located outside the protected line, only single-ended fault location is possible.

To calculate the distance to fault in kilometers or miles, the device needs the reactance per unit length in Ω/km or Ω/mile , and in the case of double-ended fault location the capacitance per unit length in $\mu\text{F}/\text{km}$ or $\mu\text{F}/\text{mile}$. For correct indication of the fault location in % of line length, the correct line length has also to be entered. For the double-ended fault locator this information is mandatory. These setting parameters were already applied with the Power System Data 2 (Section 2.1.4.1 at „General Line Data“).

A prerequisite for the correct indication of the fault location is furthermore that the other parameters that influence the calculation of the distance to fault have also been set correctly.

If only one line section (address 160 = **1 Section**) is set, these parameters are:

- 1116 **RE/RL (Z1)**,
- 1117 **XE/XL (Z1)** or
- 1120 **K0 (Z1)**,
- 1121 **Angle K0 (Z1)**.

If multiple line sections (address 160 = **2 Sections** or **3 Sections**) are set, you must set the following parameters.

For line section 1 set the addresses:

- 6009 **S1: XE/XL**,
- 6010 **S1: RE/RL** or
- 6011 **S1: K0**,
- 6012 **S1: angle K0**.

For line section 2 set the addresses:

- 6029 **S2: XE/XL**,
- 6030 **S2: RE/RL** or
- 6031 **S2: K0**,
- 6032 **S2: angle K0**.

For line section 3 set the addresses:

- 6049 **S3: XE/XL**,
- 6050 **S3: RE/RL** or
- 6051 **S3: K0**,
- 6052 **S3: angle K0**.

**Note**

For double-ended fault locating, the devices at the ends must be configured with the same data, i.e. if there is more than one line section, the values configured for device B must mirror the data of device A. This means for two line types that line section 1 and 2 configured for device A must be line section 2 and 1 of device B.

If the devices are correctly configured, indication no. 1111 „FL active“ will be output as ON.

If address 160 is set to **2 Sections** or **3 Sections**, the line impedance angle of the first line section must be set at address 6001 **S1: Line angle**, the reactance per unit length at address 6002 **S1: x'**, and the capacitance per unit length at address 6003 **S1: c'**. The line section length is entered at address 6004 **S1: Line length**. All values refer to kilometer as distance measuring unit. If you want to use miles as reference values, the addresses relevant for you are 6002, 6003 and 6004.

The central phase of your transmission tower layout is specified at address 6008 **S1: center ph.**. Setting 6008 = **unknown / sym.** assumes a symmetrical layout.

Line sections 2 (A2) and 3 (A3) are configured in the same way as described above. For setting values please refer to Table 2-15.

Table 2-15 Additional line section parameters

Addr.	Setting Title	C	Setting Options	Default Settings	Description
6001	S1: Line angle		30-89 °; ohne 0	85 °	A1: Line impedance angle
6002	S1: x'	1 A	0.0010-1.9000 Ω/km; ohne 0	0.0300 Ω/km	A1: Line reactance per unit length: x' in Ω/km
		5 A	0.0050-9.5000 Ω/km; without 0	0.1500 Ω/km	
		1 A	0.0010-3.0000 Ω/mi; ohne 0	0.0484 Ω/mi	A1: Line reactance per unit length: x' in Ω/mile
		5 A	0.0050-15.0000 Ω/mile; without 0	0.2420 Ω/mile	
6003	S1: c'	1 A	0.000-500.000 μF/km; 0	0.050 μF/km	A1: Capacitance per unit length C' in μF/km
		5 A	0.000-100.000 μF/km; 0	0.010 μF/km	
		1 A	0.000-800.000 μF/mi; 0	0.080 μF/mi	A1: Capacitance per unit length C' in μF/mile
		5 A	0.000-160.000 μF/mile; 0	0.016 μF/mile	
6004	S1: Line length		0.1-1000.0 km; ohne 0	100.0 km	A1: Line length in kilometers
			0.1-650.0 Miles; ohne 0	62.1 Miles	A1: Line length in miles
6008	S1: center ph.		unknown/sym. Phase 1 Phase 2 Phase 3	unknown/sym.	A1: Central phase
6021	S2: Line angle		30-89 °; ohne 0	85 °	A2: Line impedance angle
6022	S2: x'	1 A	0.0010-1.9000 Ω/km; ohne 0	0.0300 Ω/km	A2: Line reactance per unit length: x' in Ω/km
		5 A	0.0050-9.5000 Ω/km; without 0	0.1500 Ω/km	
		1 A	0.0010-3.0000 Ω/mi; ohne 0	0.0484 Ω/mi	A2: Line reactance per unit length: x' in Ω/mile
		5 A	0.0050-15.0000 Ω/mile; without 0	0.2420 Ω/mile	

Addr.	Setting Title	C	Setting Options	Default Settings	Description
6023	S2: c'	1 A	0.000-500.000 $\mu\text{F}/\text{km}$; 0	0.050 $\mu\text{F}/\text{km}$	A2: Capacitance per unit length C' in $\mu\text{F}/\text{km}$
		5 A	0.000-100.000 $\mu\text{F}/\text{km}$; 0	0.010 $\mu\text{F}/\text{km}$	
		1 A	0.000-800.000 $\mu\text{F}/\text{mi}$; 0	0.080 $\mu\text{F}/\text{mi}$	A2: Capacitance per unit length C' in $\mu\text{F}/\text{mile}$
		5 A	0.000-160.000 $\mu\text{F}/\text{mile}$; 0	0.016 $\mu\text{F}/\text{mile}$	
6024	S2: Line length		0.1-1000.0 km; ohne 0	100.0 km	A2: Line length in kilometers
			0.1-650.0 Miles; ohne 0	62.1 Miles	A2: Line length in miles
6028	S2: center ph.		unknown/sym. Phase 1 Phase 2 Phase 3	unknown/sym.	A2: Central phase
6041	S3: Line angle		30-89 °; ohne 0	85 °	A3: Line impedance angle
6042	S3: x'	1 A	0.0010-1.9000 Ω/km ; ohne 0	0.0300 Ω/km	A3: Line reactance per unit length: x' in Ω/km
		5 A	0.0050-9.5000 Ω/km ; without 0	0.1500 Ω/km	
		1 A	0.0010-3.0000 Ω/mi ; ohne 0	0.0484 Ω/mi	A3: Line reactance per unit length: x' in Ω/mile
		5 A	0.0050-15.0000 Ω/mile ; without 0	0.2420 Ω/mile	
6043	S3: c'	1 A	0.000-500.000 $\mu\text{F}/\text{km}$; 0	0.050 $\mu\text{F}/\text{km}$	A3: Capacitance per unit length C' in $\mu\text{F}/\text{km}$
		5 A	0.000-100.000 $\mu\text{F}/\text{km}$; 0	0.010 $\mu\text{F}/\text{km}$	
		1 A	0.000-800.000 $\mu\text{F}/\text{mi}$; 0	0.080 $\mu\text{F}/\text{mi}$	A3: Capacitance per unit length C' in $\mu\text{F}/\text{mile}$
		5 A	0.000-160.000 $\mu\text{F}/\text{mile}$; 0	0.016 $\mu\text{F}/\text{mile}$	
6044	S3: Line length		0.1-1000.0 km; ohne 0	100.0 km	A3: Line length in kilometers
			0.1-650.0 Miles; ohne 0	62.1 Miles	A3: Line length in miles
6048	S3: center ph.		unknown/sym. Phase 1 Phase 2 Phase 3	unknown/sym.	A3: Central phase

If the parallel line compensation is used, set address 3805 **Paral. Line Comp** to **YES** (presetting for devices with parallel line compensation). Further prerequisites are that

- the earth current of the parallel line has been connected to the fourth current input I_4 with the correct polarity and
- the current transformer ratio **I4/Iph CT** (address 221) in the Power System Data 1 has been set correctly (refer also to Section 2.1.2.1 under „Current Transformer Connection“) and
- the parameter for the fourth current input **I4 transformer** has been set to **In paral. line** (address 220) in the Power System Data 1 (Section 2.1.2.1 under „Current Transformer Connection“) and
- the mutual impedances **RM/RL ParalLine** and **XM/XL ParalLine** (addresses 1126 and 1127) have been set correctly in the general protection data (plant data 2, Section 2.1.4.1).

If load compensation is applied to single-phase faults in double-fed lines of an earthed system, set 3806 in address **Load Compensat.** **YES**. In case high fault resistances are expected for single-phase faults, e.g. at overhead lines without overhead earth wire or unfavourable footing of the towers, this will improve the accuracy of the distance calculation.

If double-ended fault locating is not desired, set address 3807 **two ended** = **OFF**. The default setting is **ON**.

If the fault location is required to be output as BCD-code, set the maximum time period the data should be available at the outputs using address 3811 **Tmax OUTPUT BCD**. If a new fault occurs, the data are terminated immediately even when it occurs before this time has expired. Allocate the corresponding output relays as stored if a longer time period is desired for the output. Once a fault occurred the data will be latched until the memory is reset or a new fault is registered.

2.19.3 Settings

Addr.	Parameter	Setting Options	Default Setting	Comments
3802	START	Pickup TRIP	Pickup	Start fault locator with
3805	Paral.Line Comp	NO YES	YES	Mutual coupling parall.line compensation
3806	Load Compensat.	NO YES	NO	Load Compensation
3807	two ended	ON OFF	ON	two ended fault location
3811	Tmax OUTPUT BCD	0.10 .. 180.00 sec	0.30 sec	Maximum output time via BCD

2.19.4 Information List

No.	Information	Type of Information	Comments
1111	FL active	OUT	Fault locator active
1113	quality=	VI	Quality of the fault location
1114	Rpri =	VI	Flt Locator: primary RESISTANCE
1115	Xpri =	VI	Flt Locator: primary REACTANCE
1117	Rsec =	VI	Flt Locator: secondary RESISTANCE
1118	Xsec =	VI	Flt Locator: secondary REACTANCE
1119	dist =	VI	Flt Locator: Distance to fault
1120	d[%] =	VI	Flt Locator: Distance [%] to fault
1122	dist =	VI	Flt Locator: Distance to fault
1123	FL Loop L1E	OUT_Ev	Fault Locator Loop L1E
1124	FL Loop L2E	OUT_Ev	Fault Locator Loop L2E
1125	FL Loop L3E	OUT_Ev	Fault Locator Loop L3E
1126	FL Loop L1L2	OUT_Ev	Fault Locator Loop L1L2
1127	FL Loop L2L3	OUT_Ev	Fault Locator Loop L2L3
1128	FL Loop L3L1	OUT_Ev	Fault Locator Loop L3L1
1131	RFpri=	VI	Flt Locator: primary FAULT RESISTANCE
1132	Flt.Loc.invalid	OUT	Fault location invalid
1133	Flt.Loc.ErrorK0	OUT	Fault locator setting error K0,angle(K0)
1134	two ended FO	OUT_Ev	Two ended fault location
1135	Rpri single. =	VI	R (primary, single ended)

No.	Information	Type of Information	Comments
1136	Xpri single. =	VI	X (primary, single ended)
1137	Rsec single. =	VI	R (secondary single ended)
1138	Xsec single. =	VI	X (secondary single ended)
1143	BCD d[1%]	OUT	BCD Fault location [1%]
1144	BCD d[2%]	OUT	BCD Fault location [2%]
1145	BCD d[4%]	OUT	BCD Fault location [4%]
1146	BCD d[8%]	OUT	BCD Fault location [8%]
1147	BCD d[10%]	OUT	BCD Fault location [10%]
1148	BCD d[20%]	OUT	BCD Fault location [20%]
1149	BCD d[40%]	OUT	BCD Fault location [40%]
1150	BCD d[80%]	OUT	BCD Fault location [80%]
1151	BCD d[100%]	OUT	BCD Fault location [100%]
1152	BCD dist. VALID	OUT	BCD Fault location valid

2.20 Circuit Breaker Failure Protection

The circuit breaker failure protection provides rapid back-up fault clearance, in the event that the circuit breaker fails to respond to a trip command from a protective function of the local circuit breaker.

2.20.1 Functional Description

General

Whenever e.g. a short-circuit protection relay of a feeder issues a trip command to the circuit breaker, this is repeated to the breaker failure protection (Figure 2-143). A timer T-BF in the breaker failure protection is started. The timer runs as long as a trip command is present and current continues to flow through the breaker poles.




Figure 2-143 Simplified function diagram of circuit breaker failure protection with current flow monitoring

Normally, the breaker will open and interrupt the fault current. The current monitoring stage quickly resets (typical 10 ms) and stops the timer T-BF.

If the trip command is not carried out (breaker failure case), current continues to flow and the timer runs to its set limit. The breaker failure protection then issues a command to trip the back-up breakers and interrupt the fault current.

The reset time of the feeder protection is not relevant because the breaker failure protection itself recognizes the interruption of the current.

For protection functions where the tripping criteria is not dependent on current (e.g. Buchholz protection), current flow is not a reliable criterion for proper operation of the breaker. In such cases, the circuit breaker position can be derived from the auxiliary contacts of the breaker. Therefore, instead of monitoring the current, the condition of the auxiliary contacts is monitored (see Figure 2-144). For this purpose, the outputs from the auxiliary contacts must be fed to binary inputs on the relay (refer also to Section 2.23.1).




Figure 2-144 Simplified function diagram of circuit breaker failure protection controlled by circuit breaker auxiliary contact

Current Flow Monitoring

Each of the phase currents and an additional plausibility current (see below) are filtered by numerical filter algorithms so that only the fundamental component is used for further evaluation.

Special measures are taken in order to detect a current interruption. In case of sinusoidal currents the current interruption is detected after approximately 10 ms. With aperiodic DC current components in the fault current and/or in the current transformer secondary circuit after interruption (e.g. current transformers with linearized core), or saturation of the current transformers caused by the DC component in the fault current, it can take one AC cycle before the interruption of the primary current is reliably detected.

The currents are monitored and compared with the set threshold. Besides the three phase currents, two further current detectors are provided in order to allow a plausibility check (see Figure 2-145).

As plausibility current, the earth current (residual current I_E ($3 \cdot I_0$)) is preferably used. If the residual current from the starpoint of the current transformer set is connected to the device it is used. If the residual current is not available, the device calculates it with the formula:

$$3 \cdot I_0 = I_{L1} + I_{L2} + I_{L3}$$


Additionally, the value calculated by 7SD5 of three times the negative sequence current $3 \cdot I_2$ is used for plausibility check. This is calculated according to the equation:

$$3 \cdot I_2 = I_{L1} + a^2 \cdot I_{L2} + a \cdot I_{L3}$$

where

$$a = e^{j120^\circ}$$

These plausibility currents do not have any direct influence on the basic functionality of the breaker failure protection but they allow a plausibility check in that at least two current thresholds must have been exceeded before any of the breaker failure delay times can be started, thus providing high security against false operation.

Figure 2-145 Current flow monitoring with plausibility currents $3 \cdot I_0$ and $3 \cdot I_2$

Processing of the Circuit Breaker Auxiliary Contacts

The position of the circuit breaker is derived from the central function control of the device (refer also to Section 2.23.1). Evaluation of the breaker auxiliary contacts is carried out in the breaker failure protection function only when the current flow monitoring has not picked up. Once the current flow criterion has picked up during the trip signal from the feeder protection, the circuit breaker is assumed to be open as soon as the current disappears, even if the associated auxiliary contact does not (yet) indicate that the circuit breaker has opened (Figure 2-146). This gives preference to the more reliable current criterion and avoids overfunctioning due to a defect e.g. in the auxiliary contact mechanism or circuit. This interlock feature is provided for each individual phase as well as for three-pole trip.

It is possible to disable the auxiliary contact criterion. If you set the parameter switch **chk BRK CONTACT** (Figure 2-148 top) to **NO**, the breaker failure protection can only be started when current flow is detected. The position of the auxiliary contacts is then not evaluated even if the auxiliary contacts are connected to the device.




Figure 2-146 Interlock of the auxiliary contact criterion - example for phase L1

On the other hand, current flow is not a reliable criterion for proper operation of the circuit breaker for faults which do not cause detectable current flow (e.g. Buchholz protection). Information regarding the position of the circuit breaker auxiliary contacts is required in these cases to check the correct response of the circuit breaker. For this

purpose, the binary input „>BF Start w/o I“ No. 1439 is provided (Figure 2-148 left). This input initiates the breaker failure protection even if no current flow is detected.

Common Phase Initiation

Common phase initiation is used, for example, for lines without automatic reclosure, for lines with only three-pole automatic reclosure, for transformer feeders, or if the busbar protection trips. This is the only available initiation mode if the actual 7SD5 model is able to trip three-pole only.

If the breaker failure protection is intended to be initiated by further external protection devices, it is recommended, for security reasons, to connect two starting criteria to the device. Besides the trip command of the external relay to the binary input „>BF Start 3pole“ No. 1415 it is recommended to connect also the general device pickup to binary input „>BF release“ No. 1432. For Buchholz protection it is recommended that the trip command is connected to the device by two separate wire pairs.

Nevertheless, it is possible to initiate the breaker failure protection in single-channel mode should a separate release criterion not be available. The binary input „>BF release“ (No. 1432) must then not be assigned to any physical input of the device during configuration.

Figure 2-148 shows the operating principle. When the trip signal appears from any internal or external feeder protection and at least one current flow criterion (according to Figure 2-145) is present, the breaker failure protection is initiated and the corresponding delay time(s) is (are) started.

If the current criterion is not fulfilled for any of the phases, the position of the circuit breaker auxiliary contact(s) is queried provided that this is available according to Figure 2-147. If the circuit breaker poles have individual auxiliary contacts, the series connection of the three normally closed (NC) auxiliary contacts is used. The circuit breaker has operated correctly after a three-pole trip command only when none of the phases carries current or when all three NC auxiliary contacts have closed.




Figure 2-147 Creation of signal "CB $\geq$ any pole closed"

If an internal protection function or an external protection device trips without current flow, the internal input „Start internal w/o I“ or the external input „>BF Start w/o I“

is used to initiate the breaker failure protection. In this case the start signal is maintained until the circuit breaker is reported to be open by the auxiliary contact criterion.

Initiation can be blocked via the binary input „>BLOCK BkrFail“ (e.g. during test of the feeder protection relay).




Figure 2-148 Breaker failure protection with common phase initiation

Phase Segregated Initiation

Phase segregated initiation of the breaker failure protection is necessary if the circuit breaker poles can be operated individually, e.g. if single-pole automatic reclosure is used. This is possible if the device is able to trip single-pole.

If the breaker failure protection is intended to be initiated by further external protection devices, it is recommended, for security reasons, to connect two binary inputs to the device. Besides the three trip commands of the external relay to the binary input „>BF Start L1“, „>BF Start L2“ and „>BF Start L3“ it is recommended to connect also, for example, the general device pickup to binary input „>BF release“. Figure 2-149 shows this connection.

Nevertheless, it is possible to initiate the breaker failure protection in single-channel mode should a separate release criterion not be available. The binary input „>BF release“ must then not be assigned to any physical input of the device during configuration.

If the external protection device does not provide a general fault detection signal, a general trip signal can be used instead. Alternatively, the parallel connection of a separate set of trip contacts can produce such a release signal as shown in Figure 2-150.

The starting condition logic for the delay times is shown in Figure 2-151. In principle, it is designed similar to that for the common phase initiation, but individually for each of the three phases. Thus, current flow and initiation conditions are processed for each phase. In case of single-pole interruption before an automatic reclose cycle, current disappearance is reliably monitored for the tripped breaker pole only.




Figure 2-149 Breaker failure protection with phase segregated initiation — example for initiation by an external protection device with release by a fault detection signal




Figure 2-150 Breaker failure protection with phase segregated initiation — example for initiation by an external protection device with release by a separate set of trip contacts

Initiation of a single-phase, e.g. „Start L1 only“ is valid when the starting input (= trip command of any feeder protection) appears for only this phase and current flow is detected in at least this phase. If current flow is not detected, the auxiliary contact position can be interrogated according to Figure 2-146, dependent on the setting (**Chk BRK CONTACT = YES**).

The auxiliary contact criterion is also processed for each individual breaker pole. If, however, the breaker auxiliary contacts are not available for each individual breaker pole, then a single-pole trip command is assumed to be executed only once the series connection of the normally open (NO) auxiliary contacts is interrupted. This information is provided to the breaker failure protection by the central function control of the device (refer to Section 2.23.1).

The three-phase starting signal „Start L123“ is generated if trip signals appear in more than one pole (regardless from which protection function). Phase segregated initiation is then blocked. The input „BF Start w/o I“ (e.g. from Buchholz protection) operates in three-phase mode as well. The function is the same as with common phase initiation.

The additional release-signal „>BF release“ (if assigned to a binary input) affects all initiation conditions. Initiation can be blocked via the binary input „>BLOCK BkrFail“ (e.g. during test of the feeder protection relay).




Figure 2-151 Initiation conditions with phase segregated initiation

Delay Times

When the initiate conditions are fulfilled, the associated timers are started. The circuit breaker pole(s) must open before the associated time has elapsed.

Different delay timers are provided for operation after common phase initiation and phase segregated initiation. A third time stage can be used for two-stage breaker failure protection.

With single-stage breaker failure protection, the trip command is routed to the adjacent circuit breakers should the local feeder breaker fail (refer to Figure 2-143 or 2-144). The adjacent circuit breakers are those which must trip in order to interrupt the fault current, i.e. the breakers which feed the busbar or the busbar section to which the

feeder under consideration is connected. The possible initiation conditions for the breaker failure protection are those discussed above. Depending on the application of the feeder protection, common phase or phase segregated initiation conditions may occur. Tripping by the breaker failure protection is always three-pole.

The simplest solution is to start the delay timer **T2** (Figure 2-152). The phase-segregated initiation signals are omitted if the feeder protection always trips three-pole or if the circuit breaker is not capable of single-pole tripping.

If different delay times are required after a single-pole trip or three-pole trip it is possible to use the timer stages **T1-1pole** and **T1-3pole** according to Figure 2-153.




Figure 2-152 Single-stage breaker failure protection with common phase initiation




Figure 2-153 Single-stage breaker failure protection with different delay timers

With two-stage breaker failure protection, the trip command of the feeder protection is usually repeated, after a first time stage, to the feeder circuit breaker, often via a second trip coil or set of trip coils, if the breaker has not responded to the original trip command. A second time stage monitors the response to this repeated trip command and trips the breakers of the relevant bus-bar section, if the fault has not yet been cleared after this second time.

For the first time stage, a different time delay **T1-1pole** can be selected for a single-pole trip than for a three-pole trip by the feeder protection. Additionally, you can select (parameter **1p-RETRIP (T1)**) whether this repeated trip should be single-pole or three-pole.




Figure 2-154 Two-stage breaker failure protection with phase segregated initiation

Circuit Breaker not Operational

There may be cases when it is already obvious that the circuit breaker associated with a feeder protection relay cannot clear a fault, e.g. when the tripping voltage or the tripping energy is not available.

In such a case it is not necessary to wait for the response of the feeder circuit breaker. If provision has been made for the detection of such a condition (e.g. control voltage monitor or air pressure monitor), the monitor alarm signal can be fed to the binary input „>CB faulty“ of the 7SD5. On occurrence of this alarm and a trip command by the feeder protection, a separate timer **T3-BkrDefective**, which is normally set to 0, is started (Figure 2-155). Thus, the adjacent circuit breakers (bus-bar) are tripped immediately in case the feeder circuit breaker is not operational.




Figure 2-155 Circuit breaker not operational

Transfer Trip to the Remote End Circuit Breaker

The device has the facility to provide an additional intertrip signal to the circuit breaker at the remote line end in the event that the local feeder circuit breaker fails. For this, the transmission of the trip command is used.

To perform this intertrip, the desired command — usually the trip command which is intended to trip the adjacent breakers — is assigned in the 7SD5 to the input function for intertrip of the devices. This can be achieved by external wiring: the command output is connected to the binary input at the opposite side „>Intertrip 3pol“

(No. 3504) (Refer also to Section 2.4). An easier procedure is to combine the command output with the intertrip input via the user definable logic functions (CFC).

Stub Fault Protection

An end fault is defined here as a short-circuit which has occurred at the end of a line or protected object, between the circuit breaker and the current transformer set.

This situation is shown in Figure 2-156. The fault is located — as seen from the current transformers (= measurement location) — on the bus-bar side, thus, it will not be regarded by the feeder protection relay as a feeder fault. It can only be detected by either a reverse stage of the feeder protection or by a busbar protection. Nevertheless, a trip command given to the feeder circuit breaker cannot clear the fault since the opposite end continues to feed the fault. Thus, the fault current does not stop flowing even though the feeder circuit breaker has properly responded to the trip command.




Figure 2-156 End fault between circuit breaker and current transformers

The end fault protection has the task to recognize this situation and to transmit a trip signal to the remote end(s) of the protected object to clear the fault. For this purpose, the output command „BF EndF1t TRIP“ (No. 1495) is available to trigger the intertrip input of the differential protection — if applicable, together with other commands that need to be transferred. This can be achieved by external connection or via CFC.

The end fault is recognized when the current continues flowing although the circuit breaker auxiliary contacts indicate that the breaker is open. An additional criterion is the presence of any breaker failure protection initiate signal. Figure 2-157 illustrates the functional principle. If the breaker failure protection is initiated and current flow is detected (current criteria „L*>“ according to Figure 2-145), but no circuit breaker pole is closed (auxiliary contact criterion „any pole closed“), then the timer **T-EndFault** is started. At the end of this time an intertrip signal is transmitted to the opposite end(s) of the protected object.




Figure 2-157 Operation scheme of end fault protection

Pole Discrepancy Supervision

The pole discrepancy supervision has the task to detect discrepancies in the position of the three circuit breaker poles. Under steady-state operating conditions, either all three poles of the breaker must be closed, or all three poles must be open. Discrep-

ancy is permitted only for a short time interval during a single-pole automatic reclose cycle.

The scheme functionality is shown in Figure 2-158. The signals which are processed here are the same as those used for the breaker failure protection. The pole discrepancy condition is established when at least one pole is closed („≥any pole closed“) and at the same time not all three poles are closed („≥any pole open“).

Additionally, the current criteria (from Figure 2-145) are processed. Pole discrepancy can only be detected when current is not flowing through all three poles (<3), i.e. through only one or two poles. When current is flowing through all three poles, all three poles must be closed even if the breaker auxiliary contacts indicate a different status.

If pole discrepancy of the breaker poles is detected, this is indicated in each phase by a „fault detection signal“. This signal identifies the pole which was open before the trip command of the pole discrepancy supervision occurred.




Figure 2-158 Function diagram of pole discrepancy supervision

2.20.2 Setting Notes

General

The breaker failure protection and its ancillary functions (end fault protection, pole discrepancy supervision) can only operate if they were configured as **Enabled** during configuration of the scope of functions (address 139 **BREAKER FAILURE**).

Breaker Failure Protection

The breaker failure protection is switched **ON** or **OFF** at address 3901 **FCT BreakerFail**.

The current threshold **I> BF** (address 3902) should be selected such that the protection will operate with the smallest expected short-circuit current. A setting of 10 % below the minimum fault current for which breaker failure protection must operate is recommended. On the other hand, the value should not be set lower than necessary.

Normally, the breaker failure protection evaluates the current flow criterion as well as the position of the breaker auxiliary contact(s). If the auxiliary contact(s) status is not available in the device, this criterion cannot be processed. In this case, set address 3909 **Chk BRK CONTACT** to **NO**.

Two-stage Breaker Failure Protection

With two-stage operation, the trip command is repeated after a time delay T1 to the local feeder breaker, normally to a different set of trip coils of this breaker. A choice can be made whether this trip repetition shall be single-pole or three-pole if the initial feeder protection trip was single-pole (provided single-pole trip is possible). This

choice is made in address 3903 **1p-RETRIP (T1)**. Set this parameter to **YES** if you wish single-pole trip for the first stage, otherwise to **NO**.

If the breaker does not respond to this trip repetition, the adjacent circuit breakers are tripped after T2, i.e. the circuit breakers of the busbar or of the concerned busbar section and, if necessary, also the circuit breaker at the remote end unless the fault has been cleared.

Separate delay times can be set

- for single- or three-pole trip repetition to the local feeder circuit breaker after a 1-pole trip of the feeder protection **T1-1pole** at address 3904,
- for three-pole trip repetition to the local feeder circuit breaker after 3-pole trip of the feeder protection **T1-3pole** (address 3905),
- for trip of the adjacent circuit breakers (busbar zone and remote end if applicable) **T2** at address 3906.

The delay times are set dependant on the maximum operating time of the feeder circuit breaker and the reset time of the current detectors of the breaker failure protection, plus a safety margin which allows for any tolerance of the delay timers. Figure 2-159 illustrates the timing of a typical breaker failure scenario. The dropout time for sinusoidal currents is ≤ 15 ms. If current transformer saturation is anticipated, the time should be set to 25 ms.




Figure 2-159 Time sequence example for normal clearance of a fault, and with circuit breaker failure, using two-stage breaker failure protection

Single-stage Breaker Failure Protection

With single-stage operation, the adjacent circuit breakers (i.e. the breakers of the busbar zone and, if applicable, the breaker at the remote end) are tripped after a delay time **T2** (address 3906) following initiation, should the fault not have been cleared within this time.

The timers **T1-1pole** (address 3904) and **T1-3pole** (address 3905) are then set to ∞ since they are not needed.

However, you may use the T1-timers for single-stage protection if you wish to utilize the facility of setting different delay times after single-pole trip and three-pole trip of the feeder protection. In this case set **T1-1pole** (address 3904) and **T1-3pole** (address 3905) separately, but address 3903 **1p-RETRIP (T1)** to **NO**, to avoid a single-pole trip to the busbar. Set **T2** (address 3906) to ∞ or equal to **T1-3pole** (address

3905). Be sure that the correct trip commands are assigned to the desired trip relay(s).

The delay times are determined from the maximum operating time of the feeder circuit breaker, the reset time of the current detectors of the breaker failure protection, plus a safety margin which allows for any tolerance of the delay timers. Figure 2-160 illustrates the timing of a typical breaker failure scenario. The dropout time for sinusoidal currents is ≤ 15 ms. If current transformer saturation is anticipated, the time should be set to 25 ms.




Figure 2-160 Time sequence example for normal clearance of a fault, and with circuit breaker failure, using single-stage breaker failure protection

Circuit Breaker not Operational

If the circuit breaker associated with the feeder is not operational (e.g. control voltage failure or air pressure failure), it is apparent that the local breaker cannot clear the fault. If the relay is informed about this disturbance (via the binary input „>CB faulty“), the adjacent circuit breakers (busbar and remote end if applicable) are tripped after the time **T3-BkrDefective** (address 3907) which is usually set to 0.

Address 3908 **Trip BkrDefect** determines to which output the trip command is routed in the event that the breaker is not operational when a feeder protection trip occurs. Select that output which is used to trip the adjacent breakers (bus-bar trip).

End Fault Protection

The end fault protection can be switched separately **ON** or **OFF** in address 3921 **End Flt. stage**. An end fault is a short-circuit between the circuit breaker and the current transformer set of the feeder. The end fault protection presumes that the device is informed about the circuit breaker position via breaker auxiliary contacts connected to binary inputs.

If, during an end fault, the circuit breaker is tripped by a reverse stage of the feeder protection or by the bus-bar protection (the fault is a bus-bar fault as determined from the location of the current transformers), the fault current will continue to flow, because the fault is fed from the remote end of the feeder circuit.

The time **T-EndFault** (address 3922) is started when, during the time of pickup condition of the feeder protection, the circuit breaker auxiliary contacts indicate open poles and, at the same time, current flow is still detected (address 3902). The trip command of the end fault protection is intended for the transmission of an intertrip signal to the remote end circuit breaker.

Thus, the delay time must be set such that it can bridge out short transient apparent stub fault conditions which may occur during switching of the breaker.

Pole Discrepancy Supervision

The pole discrepancy supervision can be switched **ON** or **OFF** independently at address 3931 **PoleDiscrepancy**. It is only useful if the breaker poles can be operated individually. It avoids that only one or two poles of the local breaker are open during steady state. It has to be provided that either the auxiliary contacts of each pole or the series connection of the NO auxiliary contacts and the series connection of the NC auxiliary contacts are connected to the device's binary inputs. If these conditions are not fulfilled, switch address 3931 **OFF**.

The delay time **T-PoleDiscrep.** (address 3932) determines how long a breaker pole discrepancy condition of the feeder circuit breaker, i.e. only one or two poles open, may be present before the pole discrepancy supervision issues a three-pole trip command. This time must clearly be longer than the duration of a single-pole automatic reclose cycle. The time should be less than the permissible duration of an unbalanced load condition which is caused by the unsymmetrical position of the circuit breaker poles. Conventional values are 2 s to 5 s.

2.20.3 Settings

The table indicates region-specific presettings. Column C (configuration) indicates the corresponding secondary nominal current of the current transformer.

Addr.	Parameter	C	Setting Options	Default Setting	Comments
3901	FCT BreakerFail		ON OFF	ON	Breaker Failure Protection is
3902	I> BF	1A	0.05 .. 20.00 A	0.10 A	Pick-up threshold I>
		5A	0.25 .. 100.00 A	0.50 A	
3903	1p-RETRIP (T1)		NO YES	YES	1pole retrip with stage T1 (local trip)
3904	T1-1pole		0.00 .. 30.00 sec; ∞	0.00 sec	T1, Delay after 1pole start (local trip)
3905	T1-3pole		0.00 .. 30.00 sec; ∞	0.00 sec	T1, Delay after 3pole start (local trip)
3906	T2		0.00 .. 30.00 sec; ∞	0.15 sec	T2, Delay of 2nd stage (busbar trip)
3907	T3-BkrDefective		0.00 .. 30.00 sec; ∞	0.00 sec	T3, Delay for start with defective bkr.
3908	Trip BkrDefect.		NO with T1-trip with T2-trip w/ T1/T2-trip	NO	Trip output selection with defective bkr
3909	Chk BRK CONTACT		NO YES	YES	Check Breaker contacts
3921	End Flt. stage		ON OFF	OFF	End fault stage is
3922	T-EndFault		0.00 .. 30.00 sec; ∞	2.00 sec	Trip delay of end fault stage
3931	PoleDiscrepancy		ON OFF	OFF	Pole Discrepancy supervision
3932	T-PoleDiscrep.		0.00 .. 30.00 sec; ∞	2.00 sec	Trip delay with pole discrepancy

2.20.4 Information List

No.	Information	Type of Information	Comments
1401	>BF on	SP	>BF: Switch on breaker fail protection
1402	>BF off	SP	>BF: Switch off breaker fail protection
1403	>BLOCK BkrFail	SP	>BLOCK Breaker failure
1415	>BF Start 3pole	SP	>BF: External start 3pole
1432	>BF release	SP	>BF: External release
1435	>BF Start L1	SP	>BF: External start L1
1436	>BF Start L2	SP	>BF: External start L2
1437	>BF Start L3	SP	>BF: External start L3
1439	>BF Start w/o I	SP	>BF: External start 3pole (w/o current)
1440	BkrFailON/offBI	IntSP	Breaker failure prot. ON/OFF via BI
1451	BkrFail OFF	OUT	Breaker failure is switched OFF
1452	BkrFail BLOCK	OUT	Breaker failure is BLOCKED
1453	BkrFail ACTIVE	OUT	Breaker failure is ACTIVE
1461	BF Start	OUT	Breaker failure protection started
1472	BF T1-TRIP 1pL1	OUT	BF Trip T1 (local trip) - only phase L1
1473	BF T1-TRIP 1pL2	OUT	BF Trip T1 (local trip) - only phase L2
1474	BF T1-TRIP 1pL3	OUT	BF Trip T1 (local trip) - only phase L3
1476	BF T1-TRIP L123	OUT	BF Trip T1 (local trip) - 3pole
1493	BF TRIP CBdefec	OUT	BF Trip in case of defective CB
1494	BF T2-TRIP(bus)	OUT	BF Trip T2 (busbar trip)
1495	BF EndFlt TRIP	OUT	BF Trip End fault stage
1496	BF CBdiscrSTART	OUT	BF Pole discrepancy pickup
1497	BF CBdiscr L1	OUT	BF Pole discrepancy pickup L1
1498	BF CBdiscr L2	OUT	BF Pole discrepancy pickup L2
1499	BF CBdiscr L3	OUT	BF Pole discrepancy pickup L3
1500	BF CBdiscr TRIP	OUT	BF Pole discrepancy Trip

2.21 Thermal Overload Protection

The thermal overload protection prevents damage to the protected object caused by thermal overloading, particularly in case of transformers, rotating machines, power reactors and cables. It is in general not necessary for overhead lines, since no meaningful overtemperature can be calculated because of the great variations in the environmental conditions (temperature, wind). In this case, however, a current-dependent alarm stage can signal an imminent overload.

2.21.1 Method of Operation

The unit computes the overtemperature according to a thermal single-body model as per the following thermal differential equation

$$\frac{d\Theta}{dt} + \frac{1}{\tau_{th}} \cdot \Theta = \frac{1}{\tau_{th}} \cdot \left(\frac{I}{k \cdot I_N} \right)^2$$

with

- Θ – Actual operating temperature expressed in per cent of the operating temperature corresponding to the maximum permissible operating current $k \cdot I_N$
- τ_{th} – Thermal time constant for the heating
- I – Present rms current
- k – k-factor indicating the maximum permissible constant current referred to the nominal current of the current transformers
- I_N – Nominal current of the current transformers

The solution of this equation in steady-state operation is an e-function whose asymptote represents the final temperature Θ_{End} . When the overtemperature reaches the first settable temperature threshold Θ_{alarm} , which is below the overtemperature, a warning alarm is given in order to allow a preventive load reduction. When the second temperature threshold, i.e. the final overtemperature = tripping temperature, is reached, the protected object is disconnected from the network. The overload protection can, however, also be set to **Alarm Only**. If this option is set, the device only outputs an alarm, even if the end temperature is reached.

The temperature rises are calculated separately for each phase in a thermal replica from the square of the associated phase current. This guarantees a true RMS value measurement and also considers the effect of harmonic content. A choice can be made whether the maximum calculated overtemperature of the three phases, the average overtemperature, or the overtemperature calculated from the phase with maximum current should be decisive for evaluation of the thresholds.

The maximum permissible continuous thermal overload current I_{max} is described as a multiple of the nominal current I_N :

$$I_{max} = k \cdot I_N$$

In addition to the k-factor, the time constant τ_{th} as well as the alarm temperature Θ_{alarm} must be entered as settings of the protection.

Overload protection also features a current warning element I_{alarm} in addition to the temperature warning stage. It reports an overload current prematurely, even if the cal-

culated excessive temperature has not yet attained the warning or tripping temperature levels.

The overload protection can be blocked via a binary input. In doing so, the thermal images are also reset to zero.




Figure 2-161 Logic diagram of the thermal overload protection

2.21.2 Setting Notes

General

A prerequisite for the application of the thermal overload function is that during the configuration of the functional scope in address 142 **Therm.Overload = Enabled** was set. The function can be turned **ON** or **OFF** in address 4201 **Ther. OVERLOAD**. Furthermore, **Alarm Only** can be set. With that latter setting, the protection function is active but only outputs an alarm when the tripping temperature is reached, i.e. the output function „Th.O/L TRIP“ is not active.

K- Factor

The nominal device current is taken as a basis for overload detection. The setting factor **k** is set under address 4202 **K-FACTOR**. It is determined by the relation between the permissible thermal continuous current and this nominal current:

$$k = \frac{I_{\max}}{I_N}$$

The permissible continuous current is at the same time the current at which the e-function of the overtemperature has its asymptote. It is not necessary to determine the tripping temperature since it results automatically from the final rise temperature at $k \cdot I_N$. Manufacturers of electrical machines usually state the permissible continuous current. If no data are available, k is set to 1.1 times the nominal current of the protected object. For cables, the permissible continuous current depends on the cross section, the in-

sulation material, the design and the way they are laid, and can be derived from the relevant tables.

Please note that the overload capability of electrical equipment relates to its primary current. This has to be considered if the primary current differs from the nominal current of the current transformers.

Example:

Belted cable 10 kV 150 mm²

Permissible continuous current $I_{\max} = 322 \text{ A}$

Current transformers 400 A / 5 A

$$k = \frac{322 \text{ A}}{400 \text{ A}} = 0.805$$

Setting value **K-FACTOR = 0.80**

Time Constant τ

The thermal time constant τ_{th} is set at address 4203 **TIME CONSTANT**. This is also provided by the manufacturer. Please note that the time constant is set in minutes. Quite often other values for determining the time constant are stated which can be converted into the time constant as follows:

1-s current

$$\frac{\tau_{\text{th}}}{\text{min}} = \frac{1}{60} \cdot \left(\frac{\text{perm. 1-s current}}{\text{perm. contin. current}} \right)^2$$

Permissible current for application time other than 1 s, e.g. for 0.5 s

$$\frac{\tau_{\text{th}}}{\text{min}} = \frac{0.5}{60} \cdot \left(\frac{\text{perm. 0.5-s current}}{\text{perm. contin. current}} \right)^2$$

t_6 -time; this is the time in seconds for which a current of 6 times the nominal current of the protected object may flow

$$\frac{\tau_{\text{th}}}{\text{min}} = 0.6 \cdot t_6$$

Example:

Cable as above with

Permissible 1-s current 13.5 kA

$$\frac{\tau_{\text{th}}}{\text{min}} = \frac{1}{60} \cdot \left(\frac{13500 \text{ A}}{322 \text{ A}} \right)^2 = \frac{1}{60} \cdot 42^2 = 29.4$$

Setting value **TIME CONSTANT = 29.4 min**

Warning Temperature Levels

By setting a thermal alarm stage **Θ ALARM** (address 4204) an alarm can be provided before the tripping temperature is reached, so that a trip can be avoided by preventive load reduction or by switching over. The percentage is referred to the tripping temperature rise.

The current overload alarm setpoint **I ALARM** (address 4205) is stated as a factor of the nominal device current and should be set equal to or slightly below the permissible continuous current $k \cdot I_N$. It can also be used instead of the thermal alarm stage. In this case, the thermal alarm stage is set to 100 % and thus practically ineffective.

Calculating the Overtemperature

The thermal replica is calculated individually for each phase. Address 4206 **CALC. METHOD** decides whether the highest of the three calculated temperatures (**Θ max**) or their arithmetic average (**Average Θ**) or the temperature calculated from the phase with maximum current (**Θ at Imax**) should be decisive for the thermal alarm and tripping stage.

Since an overload usually occurs in a balanced way, this setting is of minor importance. If unbalanced overloads are to be expected, however, these options lead to different results.

Averaging should only be used if a rapid thermal equilibrium is possible in the protected object, e.g. with belted cables. If the three phases are, however, more or less thermally isolated (e.g. single conductor cables or overhead lines), one of the maximum settings should be chosen at any rate.

2.21.3 Settings

The table indicates region-specific presettings. Column C (configuration) indicates the corresponding secondary nominal current of the current transformer.

Addr.	Parameter	C	Setting Options	Default Setting	Comments
4201	Ther. OVERLOAD		OFF ON Alarm Only	OFF	Thermal overload protection
4202	K-FACTOR		0.10 .. 4.00	1.10	K-Factor
4203	TIME CONSTANT		1.0 .. 999.9 min	100.0 min	Time Constant
4204	Θ ALARM		50 .. 100 %	90 %	Thermal Alarm Stage
4205	I ALARM	1A	0.10 .. 4.00 A	1.00 A	Current Overload Alarm Setpoint
		5A	0.50 .. 20.00 A	5.00 A	
4206	CALC. METHOD		Θ max Average Θ Θ at Imax	Θ max	Method of Acquiring Temperature

2.21.4 Information List

No.	Information	Type of Information	Comments
1503	>BLK ThOverload	SP	>BLOCK Thermal Overload Protection
1511	Th.Overload OFF	OUT	Thermal Overload Protection OFF
1512	Th.Overload BLK	OUT	Thermal Overload Protection BLOCKED

No.	Information	Type of Information	Comments
1513	Th.O/L ACTIVE	OUT	Thermal Overload Protection ACTIVE
1515	Th.O/L I Alarm	OUT	Th. Overload: Current Alarm (I alarm)
1516	Th.O/L Θ Alarm	OUT	Th. Overload Alarm: Near Thermal Trip
1517	Th.O/L Pickup	OUT	Th. Overload Pickup before trip
1521	Th.O/L TRIP	OUT	Th. Overload TRIP command

2.22 Monitoring Functions

The device incorporates extensive monitoring functions of both the device hardware and software; the measured values are also continually checked to ensure their plausibility; the current and voltage transformer secondary circuits are thereby substantially covered by the monitoring function. It is also possible to implement trip circuit monitoring, using appropriate binary inputs as available.

2.22.1 Measurement Supervision

2.22.1.1 Hardware Monitoring Functions

The device is monitored from the measuring inputs up to the command relays. Monitoring checks the hardware for malfunctions and disallowed conditions.

Auxiliary and Reference Voltages

The processor voltage of 5 V is monitored by the hardware, and if the voltage decreases below the minimum value, the processor is no longer operative. If it falls below the minimum value, the device will be put out of service. When the normal voltage returns, the processor system is restarted.

Failure of or switching off the supply voltage puts the device out of operation and a message is immediately generated by a normally closed contact. Brief voltage interruptions of up to 50 ms do not disturb the operational readiness of the device (see for the Technical Data).

The processor monitors the offset and reference voltage of the ADC (analog-digital converter). The protection is suspended if the voltages deviate outside an allowable range, and lengthy deviations are reported.

Buffer Battery

The buffer battery, which ensures operation of the internal clock and storage of counters and messages if the auxiliary voltage fails, is periodically checked for charge status. On its undershooting a minimum admissible voltage, the indication „Fail Battery“ (No. 177) is issued.

If the device is not supplied with auxiliary voltage for more than 1 or 2 days, the internal clock is switched off automatically, i.e. the time is not registered any more. The data from message buffers and fault record buffers, however, are kept stored.

Memory Modules

The main memory (RAM) is tested when the system starts up. If a malfunction occurs then, the starting sequence is interrupted, the error LED and LED 1 flash while the other LEDs blink at the same intervals. During operation, the memory is checked using its checksum.

A checksum of the program memory (EPROM) is cyclically generated and compared with the stored program checksum.

A checksum for the parameter memory (FLASH-EPROM) is cyclically generated and compared with the checksum which is computed after each change of the stored parameters.

If a malfunction occurs, the processor system is restarted.

Sampling Frequency

The sampling frequency and the synchronism between the ADCs (analog-to-digital converters) is continuously monitored. If deviations cannot be corrected by another synchronization, the device sets itself out of operation and the red LED „Blocked“ lights up. The Device OK relay drops off and signals the malfunction by its „life contact“.

Measurement Value Acquisition – Currents

Up to four input currents are measured by the device. If the three phase currents and the earth fault current from the current transformer starpoint or a separated earth current transformer of the line to be protected are connected to the device, their digitized sum must be zero. Faults in the current circuit are recognized if

$$I_F = |I_{L1} + I_{L2} + I_{L3} + k_I \cdot I_E| > \Sigma I \text{ THRESHOLD} \cdot I_N + \Sigma I \text{ FACTOR} \cdot \Sigma |I|$$

Factor k_I (address **I4 / Iph CT**) takes into account a possible different ratio of a separate I_E -transformer (e.g. cable core balance current transformer). **$\Sigma I \text{ THRESHOLD}$** and **$\Sigma I \text{ FACTOR}$** are setting parameters. The component **$\Sigma I \text{ FACTOR} \cdot \Sigma |I|$** takes into account the allowable current proportional ratio errors of the input transducers which are particularly prevalent during large fault currents (Figure 2-162). $\Sigma |I|$ is the sum of all currents:

$$\Sigma |I| = |I_{L1}| + |I_{L2}| + |I_{L3}| + |k_I \cdot I_E|$$

As soon as a summation current fault is detected after or before a system disturbance, the differential protection is blocked. This malfunction is signalled as „Failure Σi “ (No. 289). In order to avoid a blocking due to transformation errors (saturation) in case of high fault currents, this monitoring function is not effective during a system fault.



Note

Current sum monitoring can operate properly only when the residual current of the protected line is fed to the fourth current input (I_4) of the relay. The I_4 transformer must have been configured as **In prot. line** via parameter **I4 transformer** (220). Also, the fourth current input must have the ratings of a normal I_4 transformer. With a sensitive transformer type, current sum monitoring is not activated.




Figure 2-162 Current sum monitoring

Measured Value Acquisition Voltages

Four measuring inputs are available in the voltage path: three for phase–earth voltages as well as one input for the displacement voltage (e-n voltage of an open delta connection) or a busbar voltage. If the displacement voltage is connected to the device, the sum of the three digitized phase voltages must equal three times the zero sequence voltage. Errors in the voltage transformer circuits are detected when

$$U_F = |\underline{U}_{L1} + \underline{U}_{L2} + \underline{U}_{L3} + k_U \cdot \underline{U}_{EN}| > 25 \text{ V.}$$

Factor k_U considers the transformation ratio differences between the displacement voltage input and the phase voltage inputs (parameter **Uph** / **Udelta**).

This malfunction is reported as „Fail Σ U Ph-E“.

Note

Voltage sum monitoring can operate properly only when an externally formed open delta voltage is connected to the residual voltage input of the relay.

Voltage sum monitoring can operate properly only if the adaptation factor **Uph** / **Udelta** at address 211 has been correctly configured (see Section 2.1.2.1).




Figure 2-163 Voltage sum monitoring

2.22.1.2 Software Monitoring**Watchdog**

For continuous monitoring of the program sequences, a time monitor is provided in the hardware (watchdog for hardware) that expires upon failure of the processor or an internal program, and causes a reset of the processor system with complete restart.

An additional software watchdog ensures that malfunctions during the processing of programs are discovered. This also initiates a restart of the processor system.

To the extent such a malfunction is not cleared by the restart, an additional restart attempt is begun. Following three failed restarts within 30 s the protection takes itself out of service and the red LED „ERROR“ is illuminated. The device ready relay resets and alarms the device failure state with its normally closed contact („life contact“).

2.22.1.3 Measuring Circuit Monitoring

Interruptions or short-circuits in the secondary circuits of the current and voltage transformers, as well as faults in the connections (important for commissioning!), are detected and reported by the device. The measured quantities are periodically checked in the background for this purpose, as long as no system fault is present.

Current Symmetry

During normal system operation, symmetry among the input voltages is expected. The symmetry is monitored in the device by magnitude comparison. The smallest phase current is compared to the largest phase current. Asymmetry is recognized if:

$$|I_{\min}| / |I_{\max}| < \text{BAL. FACTOR I} \text{ as long as } I_{\max} / I_N > \text{BALANCE I LIMIT} / I_N$$

Thereby $I_{\max}$ is the largest of the three phase currents and $I_{\min}$ the smallest. The symmetry factor **BAL. FACTOR I** represents the allowable asymmetry of the phase currents while the limit value **BALANCE I LIMIT** is the lower limit of the operating range of this monitoring (see Figure 2-164). Both parameters can be set. The dropout ratio is about 97%.

After a settable time (5-100 s) this malfunction is signalled as „Fail I balance“ (No. 163).




Figure 2-164 Current symmetry monitoring

Voltage Symmetry

During normal system operation (i.e. the absence of a short-circuit fault), symmetry among the input voltages is expected. The symmetry is monitored in the device with a magnitude comparison. The smallest phase voltage is compared to the largest. Asymmetry is recognized if:

$$|U_{\min}| / |U_{\max}| < \text{BAL. FACTOR U} \text{ as long as } |U_{\max}| > \text{BALANCE U-LIMIT}$$

Thereby $U_{\max}$ is the largest of the three phase-to-phase voltages and $U_{\min}$ the smallest. The symmetry factor **BAL. FACTOR U** is the measure for the asymmetry of the conductor voltages; the limit value **BALANCE U-LIMIT** is the lower limit of the operating range of this monitoring (see Figure 2-165). Both parameters can be set. The dropout ratio is about 97%.

After a settable time, this malfunction is signalled as „Fail U balance“ (No. 167).




Figure 2-165 Voltage symmetry monitoring

Broken-wire Monitoring

During steady-state operation the broken wire monitoring registers interruptions in the secondary circuit of the current transformers. In addition to the hazardous potential caused by high voltages in the secondary circuit, this kind of interruptions simulates differential currents to the differential protection, such as those evoked by faults in the protected object.

The broken-wire monitor scans the current of each phase and picks up when the current drops abruptly to zero (from $>0.1 I_N$), while no corresponding drop appears in the earth current. The differential protection is blocked immediately in the relevant phase. This blocking has an impact on all ends of the protected object. The device issues the message „Broken wire“ indicating also the affected phase.

The blocking is cancelled as soon as the device is again supplied with current in the relevant phase. It is also suppressed as long as a high fault current is registered by any device of the differential protection system.

Note that electronic test devices do not simulate the correct behaviour of broken wire so that pickup may occur.

Note

Broken wire monitoring can operate properly only when the fourth current input (I_4) of the relay is fed the residual current from a separate current transformer of the protected line, or no residual current at all.

Voltage Phase Sequence

The verification of the faulted phases and the phase preference, direction measurement and polarization with quadrature voltages usually demand clockwise rotation of the measured values. Phase rotation of measured voltages is checked by verifying the phase sequences of the voltages

$\underline{U}_{L1}$ before $\underline{U}_{L2}$ before $\underline{U}_{L3}$

. This check takes place if each measured voltage has a minimum magnitude of

$|\underline{U}_{L1}|, |\underline{U}_{L2}|, |\underline{U}_{L3}| > 40 \text{ V}/\sqrt{3}$

In case of negative phase rotation, the indication „Fail Ph. Seq.“ (No. 171) is issued.

Unsymmetrischer Messspannungsausfall „Fuse-Failure-Monitor“

In the event of measured voltage failure due to a short-circuit or a broken conductor in the voltage transformer secondary circuit, certain measuring loops may mistakenly see a voltage of zero, which due to the load current may result in an unwanted pickup or even trip.

If fuses are used instead of a secondary miniature circuit breaker (VT mcb) with connected auxiliary contacts, then the „fuse failure monitoring“ can detect problems in the voltage transformer secondary circuit. Of course, the miniature circuit breaker and the „fuse failure monitor“ can be used at the same time.

The asymmetrical measured voltage failure is characterized by its voltage asymmetrical with simultaneous current symmetry. Figure 2-166 depicts the logic diagram of the „fuse failure monitors“ during asymmetrical failure of the measured voltage.

If there is substantial voltage asymmetry of the measured values, without asymmetry of the currents being registered at the same time, this indicates the presence of an asymmetrical failure in the voltage transformer secondary circuit.

The asymmetry of the voltage is detected by the fact that either the zero sequence voltage or the negative sequence voltage exceed a settable value **FFM U>(min)**. The current is assumed to be sufficiently symmetrical if both the zero sequence as well as the negative sequence current are below the settable threshold **FFM I<(max)**.

In non-earthed systems, the zero-sequence system quantities are no reliable criterion since a considerable zero-sequence voltage occurs also in case of a simple earth fault where a significant zero-sequence current does not necessarily flow. Therefore, the zero-sequence voltage is not evaluated in such networks but only the negative-sequence voltage (parameter **SystemStarpoint**).

As soon as this state is recognized, the distance protection and all other functions that operate on the basis of undervoltage (e.g. also weak infeed tripping) are blocked. The immediate blocking demands that current flows in at least one of the phases. The distance protection can be switched to differential protection and/or O/C emergency operation, provided that these functions are parameterized accordingly (refer also to Sections 2.3 and 2.14).

The fast blocking may not occur as long as one phase is without voltage due to a single-pole dead time condition, as the non-symmetry of the measured values arising in this state is due to the switching state of the line and not due to a failure in the secondary circuits. Accordingly, the fast blocking is disabled when the line is tripped single-pole (internal information „1 pole open“ in the logic diagram).

If a zero sequence or negative sequence current is detected within approximately 10 s after recognition of this criterion, the protection assumes a short-circuit and removes the blocking by the „fuse failure monitor“ for the duration of the fault. If on the other hand the voltage failure criterion is present for longer than approx. 10 s, the blocking is permanently activated (latching of the voltage criterion after 10 s). Only 10 s after the voltage criterion has been removed by correction of the secondary circuit failure, will the blocking automatically reset, thereby releasing the blocked protection functions again.




Figure 2-166 Logic diagram of the fuse failure monitor with zero and negative sequence system

Three-Phase Measuring Voltage Failure "Fuse Failure Monitor"

A three-phase failure of the secondary measured voltage can be distinguished from an actual system fault by the fact that the currents have no significant change in the event of a failure in the secondary measured voltage. For this reason, the sampled current values are routed to a buffer, so that the difference between the present and stored current values can be analysed to recognize the magnitude of the current differential (current differential criterion). A three-pole voltage failure is detected if

- All three phase-to-earth voltages are smaller than the threshold **FFM U<max (3ph)**,
- The current differential in all three phases is smaller than the threshold **FFM Idelta (3p)**.
- All three phase current amplitudes are greater than the minimum current **Iph>** for impedance measurement by the distance protection.

If no stored current values are present (yet), the current magnitude criterion is resorted to. A three-pole system voltage failure is detected in this case if

- All three phase-to-earth voltages are smaller than the threshold **FFM U<max (3ph)**,
- All three phase current amplitudes are smaller than the minimum current **Iph>** for impedance measurement by the distance protection, and
- All three phase current amplitudes are greater than a fixed set noise threshold (40mA).

If such a voltage failure is recognized, the distance protection and all other functions that operate on the basis of undervoltage (e.g. also weak infeed tripping) are blocked until the voltage failure is removed; thereafter the blocking is automatically removed. Differential protection and O/C emergency operation are possible during the voltage failure, provided that the differential protection and/or the time overcurrent protection are parameterized accordingly (refer also to Sections 2.3 and 2.14).

Additional Measured Voltage Failure Monitoring

If no measuring voltage is available after power-on of the device (e.g. because the voltage transformers are not connected), the absence of the voltage can be detected and reported by an additional monitoring function. Where circuit breaker auxiliary contacts are used, they should be used for monitoring as well. Figure 2-167 shows the logic diagram of the measured voltage failure monitoring. A failure of the measured voltage is detected if the following conditions are met at the same time:

- All three phase-to-earth voltages are smaller than **FFM U<max (3ph)**,
- At least one phase current is larger than **PoleOpenCurrent** or at least one breaker pole is closed (can be set),
- No protection function has picked up,
- This condition persists for a settable time **T V-Supervision** (default setting: 3 s).

This time **T V-Supervision** is required to prevent that a voltage failure is detected before the protection picks up.

If a failure is detected by these criteria, the indication 168 „Fail U absent“ is output, and the device switches to emergency operation (see Section 2.14).




Figure 2-167 Logic diagram of the additional measured voltage failure monitoring

2.22.1.4 Malfunction Responses

Depending on the type of malfunction detected, an indication is sent, a restart of the processor system initiated, or the device is taken out of service. After three unsuccessful restart attempts, the device is also taken out of service. The operational readiness NC contact („life contact“) operates to indicate the device is malfunctioning. The red „ERROR“ LED on the device front lights up, provided that there is an internal auxiliary voltage, and the green „RUN“ LED goes off. If the internal auxiliary voltage fails, then all LEDs are dark. Table 2-16 shows a summary of the monitoring functions and the malfunction responses of the relay.

Table 2-16 Summary of malfunction responses of the device

Monitoring	Possible causes	Malfunction Response	Indication (No.)	Device
AC/DC supply voltage loss	External (aux. voltage) internal (converter)	Device out of operation alarm, if possible	All LEDs dark „Error 5V“ (144)	DOK ²⁾ drops out
Measured value acquisition	Internal (converter or reference voltage)	Protection out of operation, alarm	LED „ERROR“ „Error A/D-conv.“ (181)	DOK ²⁾ drops out
Buffer battery	Internal (battery)	Indication	„Fail Battery“ (177)	As allocated
Hardware watchdog	Internal (processor failure)	Device not in operation	LED „ERROR“	DOK ²⁾ drops out
Software watchdog	Internal (program execution)	Restart attempt ¹⁾	LED „ERROR“	DOK ²⁾ drops out
Main memory	Internal (battery)	Restart attempt ¹⁾ , Restart abort Device not in operation	LED flashes	DOK ²⁾ drops out
Program memory	Internal (EPROM)	Restart attempt ¹⁾	LED „ERROR“	DOK ²⁾ drops out
Settings memory	internal (Flash-EPROM or RAM)	Restart attempt ¹⁾	LED „ERROR“	DOK ²⁾ drops out
Sampling frequency	Internal (clock generator)	Restart attempt ¹⁾	LED „ERROR“	DOK ²⁾ drops out
1 A/5 A setting	Jumper wrong 1/5 A	Indications: Protection out of operation	„Error1A/5Awrong“ (192) „Error A/D-conv.“ (181) LED „ERROR“	DOK ²⁾ drops out
Calibration data	Internal (EEPROM or RAM)	Indication: Using default values	„Alarm adjustm.“ (193)	As allocated
Earth current transformer sensitive/insensitivity	I/O-BG does not comply with the order number (MLFB) of the device	Indications: Protection out of operation	„Error neutralCT“ (194) „Error A/D-conv.“ (181) LED „ERROR“	DOK ²⁾ drops out
Modules	Module does not comply with order number (MLFB)	Indications: Protection out of operation	„Error Board BG1...7“ (183 ... 189) and if applicable „Error A/D-conv.“ (181)	DOK ²⁾ drops out
Current sum	Internal (measured value acquisition)	Indication Total blocking of the differential protection	„Failure Σi “ (289)	As allocated
Current balance	External (power system or current transformer)	Indication	„Fail I balance“ (163)	As allocated
Broken wire	External (power system or current transformer)	Indication Phase-selective blocking of the differential protection	„Broken Iwire L1“ (290), „Broken Iwire L2“ (291), „Broken Iwire L3“ (292)	As allocated
Voltage sum	Internal (measured value acquisition)	Indication	„Fail ΣU Ph-E“ (165)	As allocated
Voltage symmetry	External (power system or voltage transformer)	Indication	„Fail U balance“ (167)	As allocated
Voltage phase sequence	External (power system or connection)	Indication	„Fail Ph. Seq.“ (171)	As allocated

Monitoring	Possible causes	Malfunction Response	Indication (No.)	Device
Voltage failure, three-phase „Fuse-Failure-Monitor“	External (power system or connection)	Indication Distance protection is blocked, Undervoltage protection is blocked, Weak-infeed tripping is blocked, Frequency protection is blocked, and Direction determination of the earth fault protection is blocked	„VT FuseFail>10s“ (169), „VT FuseFail“ (170)	As allocated
Voltage failure, single and two-phase „Fuse-Failure-Monitor“	External (voltage transformers)	Indication Distance protection is blocked, Undervoltage protection is blocked, Weak-infeed tripping is blocked, Frequency protection is blocked, and Direction determination of the earth fault protection is blocked	„VT FuseFail>10s“ (169), „VT FuseFail“ (170)	As allocated
Voltage failure, three-phase	External (power system or connection)	Indication Distance protection is blocked, Undervoltage protection is blocked, Weak-infeed tripping is blocked, Frequency protection is blocked, and Direction determination of the earth fault protection is blocked	„Fail U absent“ (168)	As allocated
Trip circuit supervision	External (trip circuit or control voltage)	Indication	„FAIL: Trip cir.“ (6865)	As allocated

1) After three unsuccessful restarts, the device is taken out of service.

2) DOK = „Device OK“ = Break contact of the readiness relay = Life contact

2.22.1.5 Setting Notes

General

The sensitivity of the measurement supervision function can be modified. Default values are set at the factory, which are sufficient in most cases. If especially high operating asymmetry in the currents and/or voltages is to be expected for the application, or if it becomes apparent during operation that certain monitoring functions activate sporadically, then the setting should be less sensitive.

The measurement supervision can be switched **ON** or **OFF** in address 2901 **MEASURE . SUPERV.**

Symmetry Monitoring

Address 2902 **BALANCE U-LIMIT** determines the limit voltage (phase-to-phase), above which the voltage symmetry monitor is effective. Address 2903 **BAL. FACTOR U** is the associated symmetry factor; that is, the slope of the symmetry characteristic curve. The alarm „Fail U balance“ (No. 167) can be delayed in address 2908 **T BAL. U LIMIT**. These settings can only be changed via DIGSI® at **Additional Settings**.

Address 2904 **BALANCE I LIMIT** determines the limit current, above which the current symmetry monitor is effective. Address 2905 **BAL. FACTOR I** is the associated symmetry factor; that is, the slope of the symmetry characteristic curve. The alarm „Fail I balance“ (No. 163) can be delayed in address 2909 **T BAL. I LIMIT**. These settings can only be changed via DIGSI® at **Additional Settings**.

Summation Monitoring

Address 2906 **ΣI THRESHOLD** determines the limit current, above which the current sum monitor is activated (absolute portion, only relative to I_N). The relative portion (relative to the maximum conductor current) for activating the current sum monitor is set at address 2907 **ΣI FACTOR**. These settings can only be changed via DIGSI® at **Additional Settings**.



Note

Current sum monitoring can operate properly only when the residual current of the protected line is fed to the fourth current input (II_4) of the relay. The I_4 transformer must have been configured as **In prot. line** via parameter **I4 transformer** (220). Also, the fourth current input must have the ratings of a normal I_4 transformer. With a sensitive transformer type, current sum monitoring is not activated.

Asymmetrical Measuring Voltage "Failure Fuse Failure Monitor"

The settings of the „fuse failure monitor“ for asymmetrical measured voltage failure must be selected such that on the other hand reliable pickup of the monitoring is ensured in the case of loss of a single-phase voltage (address 2911 **FFM U>(min)**), while on the other hand a pickup due to earth faults in an earthed system is avoided. In accordance with this requirement, address 2912 **FFM I<(max)** must be set sufficiently sensitive (below the smallest fault current due to earth faults). These settings can only be changed via DIGSI® at **Additional Settings**.

In address 2910 **FUSE FAIL MON.**, the „fuse failure monitor“ can be switched **OFF**, e.g. during asymmetrical testing.

Three-Phase Measuring Voltage Failure "Fuse Failure Monitor"

In address 2913 **FFM U<max (3ph)** the minimum voltage threshold is set. If the measured voltage drops below this threshold and a simultaneous current jump which exceeds the limits according to address 2914 **FFM Idelta (3p)** is not detected while all three phase currents are greater than the minimum current required for the impedance measurement by the distance protection according to address 1502 **Minimum Iph**, a three-phase measured voltage failure is recognized. These settings can only be changed via DIGSI® at **Additional Settings**.

In address 2910 **FUSE FAIL MON.**, the „fuse failure monitor“ can be switched **OFF**, e.g. during asymmetrical testing.

Measured Voltage Failure Supervision

In address 2915 **V-Supervision**, the measured voltage supervision can be switched to **w/ CURR. SUP, w/ I> & CBaux** or **OFF**. Address 2916 **T V-Supervision** is used to set the waiting time of the voltage failure supervision. This setting can only be changed via DIGSI® at **Additional Settings**.

Circuit Breaker for Voltage Transformers

If a circuit breaker for voltage transformers (VT mcb) is installed in the secondary circuit of the voltage transformers, the status is sent, via binary input, to the device informing it about the position of the VT mcb. If a short-circuit in the secondary side initiates the tripping of the VT mcb, the distance protection function has to be blocked immediately, since otherwise it would be spuriously tripped due to the lacking measured voltage during a load current. The blocking must be faster than the first stage of the distance protection. This requires an extremely short reaction time for VT mcb (≤ 4 ms at 50 Hz, ≤ 3 ms at 60 Hz nominal frequency). If this cannot be ensured, the reaction time is to be set under address 2921 **T mcb**; this, however, will delay the response of the protection function.

2.22.1.6 Settings

Addresses which have an appended "A" can only be changed with DIGSI, under Additional Settings.

The table indicates region-specific presettings. Column C (configuration) indicates the corresponding secondary nominal current of the current transformer.

Addr.	Parameter	C	Setting Options	Default Setting	Comments
2901	MEASURE. SUPERV		ON OFF	ON	Measurement Supervision
2902A	BALANCE U-LIMIT		10 .. 100 V	50 V	Voltage Threshold for Balance Monitoring
2903A	BAL. FACTOR U		0.58 .. 0.95	0.75	Balance Factor for Voltage Monitor
2904A	BALANCE I LIMIT	1A	0.10 .. 1.00 A	0.50 A	Current Balance Monitor
		5A	0.50 .. 5.00 A	2.50 A	
2905A	BAL. FACTOR I		0.10 .. 0.95	0.50	Balance Factor for Current Monitor
2906A	Σ I THRESHOLD	1A	0.10 .. 2.00 A	0.25 A	Summated Current Monitoring Threshold
		5A	0.50 .. 10.00 A	1.25 A	
2907A	Σ I FACTOR		0.00 .. 0.95	0.50	Summated Current Monitoring Factor
2908A	T BAL. U LIMIT		5 .. 100 sec	5 sec	T Balance Factor for Voltage Monitor
2909A	T BAL. I LIMIT		5 .. 100 sec	5 sec	T Current Balance Monitor
2910	FUSE FAIL MON.		ON OFF	ON	Fuse Failure Monitor
2911A	FFM U>(min)		10 .. 100 V	30 V	Minimum Voltage Threshold U>
2912A	FFM I<(max)	1A	0.10 .. 1.00 A	0.10 A	Maximum Current Threshold I<
		5A	0.50 .. 5.00 A	0.50 A	
2913A	FFM U<max (3ph)		2 .. 100 V	5 V	Maximum Voltage Threshold U< (3phase)
2914A	FFM Idelta (3p)	1A	0.05 .. 1.00 A	0.10 A	Delta Current Threshold (3phase)
		5A	0.25 .. 5.00 A	0.50 A	

Addr.	Parameter	C	Setting Options	Default Setting	Comments
2915	V-Supervision		w/ CURR.SUP w/ I> & CBaux OFF	w/ CURR.SUP	Voltage Failure Supervision
2916A	T V-Supervision		0.00 .. 30.00 sec	3.00 sec	Delay Voltage Failure Supervision
2921	T mcb		0 .. 30 ms	0 ms	VT mcb operating time
2931	BROKEN WIRE		ON OFF	OFF	Fast broken current-wire supervision
2933	FAST Σ i SUPERV		ON OFF	ON	State of fast current summation supervis

2.22.1.7 Information List

No.	Information	Type of Information	Comments
161	Fail I Superv.	OUT	Failure: General Current Supervision
163	Fail I balance	OUT	Failure: Current Balance
164	Fail U Superv.	OUT	Failure: General Voltage Supervision
165	Fail Σ U Ph-E	OUT	Failure: Voltage summation Phase-Earth
167	Fail U balance	OUT	Failure: Voltage Balance
168	Fail U absent	OUT	Failure: Voltage absent
169	VT FuseFail>10s	OUT	VT Fuse Failure (alarm >10s)
170	VT FuseFail	OUT	VT Fuse Failure (alarm instantaneous)
171	Fail Ph. Seq.	OUT	Failure: Phase Sequence
196	Fuse Fail M.OFF	OUT	Fuse Fail Monitor is switched OFF
197	MeasSup OFF	OUT	Measurement Supervision is switched OFF
289	Failure Σ i	OUT	Alarm: Current summation supervision
290	Broken Iwire L1	OUT	Alarm: Broken current-wire detected L1
291	Broken Iwire L2	OUT	Alarm: Broken current-wire detected L2
292	Broken Iwire L3	OUT	Alarm: Broken current-wire detected L3
295	Broken wire OFF	OUT	Broken wire supervision is switched OFF
296	Σ i superv. OFF	OUT	Current summation superv is switched OFF

2.22.2 Trip Circuit Supervision

The line protection 7SD5 is equipped with an integrated trip circuit supervision function. Depending on the number of available binary inputs (not connected to a common potential), supervision with one or two binary inputs can be selected. If the routing of the binary inputs required for this does not comply with the selected supervision mode, an alarm is given („TripC1 ProgFAIL ...“, with identification of the non-compliant circuit). When using two binary inputs, malfunctions in the trip circuit can be detected under all circuit breaker conditions. When only one binary input is used, malfunctions in the circuit breaker itself cannot be detected. If single-pole tripping is possible, a separate trip circuit supervision can be implemented for each circuit breaker pole provided the required binary inputs are available.

2.22.2.1 Functional Description

Supervision with Two Binary Inputs

When using two binary inputs, these are connected according to Figure 2-168, parallel to the associated trip contact on one side, and parallel to the circuit breaker auxiliary contacts on the other.

A precondition for the use of the trip circuit supervision is that the control voltage for the circuit breaker is higher than the total of the minimum voltages drops at the two binary inputs ($U_{Ctrl} > 2 \cdot U_{Bmin}$). Since at least 19 V are needed for each binary input, the supervision function can only be used with a system control voltage of over 38 V.




Figure 2-168 Principle of the trip circuit supervision with two binary inputs

Supervision with binary inputs not only detects interruptions in the trip circuit and loss of control voltage, it also supervises the response of the circuit breaker using the position of the circuit breaker auxiliary contacts.

Depending on the conditions of the trip contact and the circuit breaker, the binary inputs are activated (logical condition „H“ in the following table), or short-circuited (logical condition „L“).

A state in which both binary inputs are not activated („L“) is only possible in intact trip circuits for a short transition period (trip relay contact closed but circuit breaker not yet open).

A continuous state of this condition is only possible when the trip circuit has been interrupted, a short-circuit exists in the trip circuit, a loss of battery voltage occurs, or malfunctions occur with the circuit breaker mechanism. Therefore, it is used as monitoring criterion.

Table 2-17 Condition table for binary inputs, depending on RTC and CB position

No	Trip contact	Circuit breaker	AuxCont 1	AuxCont 2	BI 1	BI 2
1	Open	ON	Closed	Open	H	L
2	Open	OFF	Open	Closed	H	H
3	Closed	ON	Closed	Open	L	L
4	Closed	OFF	Open	Closed	L	H

The conditions of the two binary inputs are scanned periodically. A query takes place about every 500 ms. If three consecutive conditional checks detect an abnormality, an annunciation is reported (see Figure 2-169). The repeated measurements help to determine the delay of the alarm message and to avoid that an alarm is output during short-time transition periods. After the fault in the trip circuit is removed, the alarm is reset automatically after the same time.




Figure 2-169 Logic diagram of the trip circuit monitoring with two binary inputs

Supervision with One Binary Input

The binary input is connected in parallel to the respective command relay contact of the protection device according to Figure 2-170. The circuit breaker auxiliary contact is bridged with a high-ohm equivalent resistor R.

The control voltage for the circuit breaker should be at least twice as high as the minimum voltage drop at the binary input ($U_{Ctrl} > 2 \cdot U_{Bmin}$). Since at least 19 V are needed for the binary input, the monitor can be used with a system control voltage of over 38 V.

A calculation example for the equivalent resistor R is shown in the configuration notes in Section „Mounting and Connections“, margin heading „Trip Circuit Supervision“.




Figure 2-170 Principle of the trip circuit supervision with one binary input

During normal operation, the binary input is activated (logical condition „H“) when the trip contact is open and the trip circuit is intact, because the supervision circuit is closed either by the circuit breaker auxiliary contact (if the circuit breaker is closed) or through the equivalent resistor R. Only as long as the trip contact is closed, the binary input is short-circuited and thereby deactivated (logical condition „L“).

If the binary input is permanently deactivated during operation, an interruption in the trip circuit or a failure of the (trip) control voltage can be assumed.

The trip circuit supervision does not operate during system faults. A momentary closed tripping contact does not lead to a failure indication. If, however, other trip relay contacts from different devices are connected in parallel in the trip circuit, the fault indication must be delayed by **Alarm Delay** (see also Figure 2-171). After the fault in the trip circuit is removed, the alarm is reset automatically after the same time.




Figure 2-171 Logic diagram for trip circuit supervision with one binary input

2.22.2.2 Setting Notes

General

The number of circuits to be supervised was set during the configuration in address 140 **Trip Cir. Sup.** (Section 2.1.1.3). If the trip circuit supervision is not used at all, the setting **Disabled** must be applied there.

The trip circuit supervision can be switched **ON** or **OFF** in address 4001 **FCT TripSuperv.**. The number of binary inputs that shall be used in each of the supervised circuits is set in address 4002 **No. of BI**. If the routing of the binary inputs required for this does not comply with the selected supervision mode, an alarm is given („TripC1 ProgFAIL ...“, with identification of the non-compliant circuit).

Supervision with One Binary Input

The alarm for supervision with two binary inputs is always delayed by approx. 1 s to 2 s, whereas the delay time of the alarm for supervision with one binary input can be set in address 4003 **Alarm Delay**. 1 s to 2 s are sufficient if only the 7SD5 device is connected to the trip circuits as the trip circuit supervision does not operate during a system fault. If, however, trip contacts from other devices are connected in parallel in the trip circuit, the alarm must be delayed such that the longest trip command duration can be reliably bridged.

2.22.2.3 Settings

Addr.	Parameter	Setting Options	Default Setting	Comments
4001	FCT TripSuperv.	ON OFF	OFF	TRIP Circuit Supervision is
4002	No. of BI	1 .. 2	2	Number of Binary Inputs per trip circuit
4003	Alarm Delay	1 .. 30 sec	2 sec	Delay Time for alarm

2.22.2.4 Information List

No.	Information	Type of Information	Comments
6854	>TripC1 TripRel	SP	>Trip circuit superv. 1: Trip Relay
6855	>TripC1 Bkr.Rel	SP	>Trip circuit superv. 1: Breaker Relay
6856	>TripC2 TripRel	SP	>Trip circuit superv. 2: Trip Relay
6857	>TripC2 Bkr.Rel	SP	>Trip circuit superv. 2: Breaker Relay
6858	>TripC3 TripRel	SP	>Trip circuit superv. 3: Trip Relay
6859	>TripC3 Bkr.Rel	SP	>Trip circuit superv. 3: Breaker Relay
6861	TripC OFF	OUT	Trip circuit supervision OFF
6865	FAIL: Trip cir.	OUT	Failure Trip Circuit
6866	TripC1 ProgFAIL	OUT	TripC1 blocked: Binary input is not set
6867	TripC2 ProgFAIL	OUT	TripC2 blocked: Binary input is not set
6868	TripC3 ProgFAIL	OUT	TripC3 blocked: Binary input is not set

2.23 Function Control and Circuit Breaker Test

2.23.1 Function Control

The function control is the control centre of the device. It coordinates the sequence of the protection and ancillary functions, processes their decisions and the information coming from the power system.

Applications

- Line energization recognition,
- Processing of the circuit breaker position,
- Open Pole Detector,
- Fault detection logic,
- Tripping logic.

2.23.1.1 Line Energization Recognition

During energization of the protected object, several measures may be required or desirable. Following a manual closure onto a short-circuit, immediate trip of the circuit breaker is usually required. This is done, e.g. in the overcurrent protection by bypassing the delay time of specific stages. For every short-circuit protection function which can be delayed, at least one stage can be selected that will operate instantaneously in the event of a manual closing, as mentioned in the relevant sections. Also see Section 2.1.4.1 at margin heading „Circuit Breaker Status“.

The manual closing command must be indicated to the device via a binary input. In order to be independent of the duration that the switch is closed, the command is set to a defined length in the device (adjustable with the address **1150 SI Time Man.C1**). Figure 2-172 shows the logic diagram.




Figure 2-172 Logic diagram of the manual closing procedure

Reclosure via the integrated control functions such as — on-site control, control via DIGSI[®], control via serial interface — can have the same effect as manual reclosure, see parameter 1152.

If the device has an integrated automatic reclosure, the integrated manual closure logic of the 7SD5 automatically distinguishes between an external control command via the binary input and an automatic reclosure by the internal automatic reclosure so that the binary input „>Manual Close“ can be connected directly to the control circuit of the close coil of the circuit breaker (Figure 2-173). Each reclosure that is not initiated by the internal automatic reclosure function is interpreted as a manual reclosure, even it has been initiated by a control command from the device.




Figure 2-173 Manual closure with internal automatic reclosure

If, however, external close commands which should not activate the manual close function are possible (e.g. external reclosure device), the binary input „>Manual Close“ must be triggered by a separate contact at the control discrepancy switch (Figure 2-174).

If in that latter case a manual close command can also be given by means of an internal control command from the device, such a command must be combined with the manual CLOSE function via parameter 1152 **Man.Clos. Imp.** (Figure 2-172).




Figure 2-174 Manual closing with external automatic reclosure device

Besides the manual CLOSE detection, the device records any energization of the line via the integrated line energization detection. This function processes a change-of-state of the measured quantities as well as the position of the breaker auxiliary contacts. The current status of the circuit breaker is detected, as described in the following Section at „Detection of the Circuit Breaker Position“. The criteria for the line energization detection change according to the local conditions of the measuring points and the setting of the parameter address 1134 **Line Closure** (see Section 2.1.4 at margin heading „Circuit Breaker Status“).

The phase-phase currents and the phase-earth voltages are available as measuring quantities. A flowing current excludes that the circuit breaker is open (exception: a fault between current transformer and circuit breaker). If the circuit breaker is closed, it may, however, still occur that no current is flowing. The voltages can only be used as a criterion for the de-energized line if the voltage transformers are installed on the feeder side. Therefore, the device only evaluates those measuring quantities that provide information on the status of the line according to address 1134.

But a change-of-state, such as a voltage jump from zero to a considerable value (address 1131 **PoleOpenVoltage**) or the occurrence of a considerable current (address 1130 **PoleOpenCurrent**) without a line voltage appearing at the same time, can be a reliable indicator for line energization as such changes can neither occur during normal operation nor in case of a fault.

The position of the auxiliary contacts of the circuit breakers indicate directly the position of the circuit breaker. If the circuit breaker is controlled single-pole, the criterion for energization is if at least one contact changes from open to closed.

The detected energization is signalled through the message “Line closure” (No. 590). In order to be independent of the duration that the switch is closed, the signal is set to a defined length in the device (adjustable with the address 1132 **SI Time all Cl.**). Figure 2-175 shows the logic diagramm.




Figure 2-175 Generation of the energization signal

The line energization detection enables the distance protection, earth fault protection, time-overcurrent protection and high-current switch onto fault protection to trip without delay after energization of their line was detected.

Depending on the configuration of the distance protection, an undelayed trip command can be generated after energization for each pickup or for pickup in zone Z1B. The stages of the earth fault protection and of the time-overcurrent protection together generate an undelayed TRIP command if this was provided for in the configuration. The switch onto fault protection is released phase-selectively and three-pole in case of manual closure after energization detection. In order to generate as quickly as possible a trip command after an energization, the fast switch-on-to-fault protection is released selectively for each phase already when the line is open.

In order to avoid that an energization is detected mistakenly, the state „line open“, which precedes any energization, must apply for at least 250 ms.

2.23.1.2 Detection of the Circuit Breaker Position

For Protection Purposes

Information regarding the circuit breaker position is required by various protection and supplementary functions to ensure their optimal functionality. This is, for example, of assistance for

- The echo function in conjunction with the distance protection with teleprotection (refer to Section 2.7),
- The echo function in conjunction with directional earth fault comparison scheme (refer to Section 2.9),
- Weak infeed tripping (refer to Section 2.10.1),
- The high-current instantaneous tripping (refer to Section 2.13),
- The circuit breaker failure protection (refer to Section 2.20),
- Verification of the dropout condition for the trip command (see Section „Terminating the Trip Signal“).

A circuit breaker position logic is incorporated in the device (Figure 2-176). Depending on the type of auxiliary contact(s) provided by the circuit breaker and the method in which these are connected to the device, there are several alternatives of implementing this logic.

In most cases it is sufficient to furnish the status of the circuit breaker with its auxiliary contacts via a binary input to the device. This always applies if the circuit breaker is only switched three-pole. Then the NO auxiliary contact of the circuit breaker is connected to a binary input which must be configured to the input function „>CB 3p Closed“ (No. 379). The other inputs are then not used and the logic is restricted in principle to simply passing of this input information on.

If the circuit breaker poles can be switched individually, and only a parallel connection of the NO individual pole auxiliary contacts is available, the relevant binary input (BI) is allocated to the function „>CB 3p Open“ (No. 380). The remaining inputs are again not used in this case.

If the circuit breaker poles can be switched individually, and the individual auxiliary contacts are available, an individual binary input should be used for each auxiliary contact if this is possible and if the device can and should trip single-pole. With this configuration, the device can process the maximum amount of information. Three binary inputs are used for this purpose:

- „>CB Aux. L1“ (No. 351) for the auxiliary contact of pole L1,
- „>CB Aux. L2“ (No. 352) for the auxiliary contact of pole L2,
- „>CB Aux. L3“ (No. 353) for the auxiliary contact of pole L3.

The inputs No. 379 and No. 380 are not used in this case.

If the circuit breaker can be switched individually, two binary inputs are sufficient if both the parallel as well as series connection of the auxiliary contacts of the three poles are available. In this case, the parallel connection of the auxiliary contacts is routed to the input function „>CB 3p Closed“ (No. 379) and the series connection is routed to the input function „>CB 3p Open“ (No. 380).

Please note that Figure 2-176 shows the complete logic for all connection alternatives. For each particular application, only a portion of the inputs is used as described above.

The eight output signals of the circuit breaker position logic can be processed by the individual protection and supplementary functions. The output signals are blocked if the signals transmitted from the circuit breaker are not plausible: for example, the circuit breaker cannot be open and closed at the same time. Furthermore, no current can flow over an open breaker contact.

The evaluation of the measuring quantities is according to the local conditions of the measuring points (see Section 2.1.4.1 at margin heading „Circuit Breaker Status“).

The phase currents are available as measuring quantities. A flowing current excludes that the circuit breaker is open (exception: a fault between current transformer and circuit breaker). If the circuit breaker is closed, it may, however, still occur that no current is flowing. The decisive setting for the evaluation of the measuring quantities is **PoleOpenCurrent** (address 1130) for the presence of the currents.

In 7SD5 the position of the circuit breaker poles detected by the device is also transmitted to the remote end device(s). This way the position of the circuit breaker poles is also recognized by at all other ends. The high-current switch-on-to-fault protection (see Section 2.13) makes use of this function.




Figure 2-176 Circuit breaker position logic

For Automatic Reclosure and Circuit Breaker Test

Separate binary inputs comprising information on the position of the circuit breaker are available for the automatic reclosure and the circuit breaker test. This is important for

- The plausibility check before automatic reclosure (refer to Section 2.15),
- The trip circuit check with the help of the TRIP–CLOSE–test cycle (refer to Section 2.23.2).

When using $1\frac{1}{2}$ or 2 circuit breakers in each feeder, the automatic reclosure function and the circuit breaker test are referred to **one** circuit breaker. The feedback information of this circuit breaker can be connected separately to the device.

For this, separate binary inputs are available, which should be treated the same and configured additionally if necessary. These have a similar significance as the inputs described above for protection applications and are marked with „CB1 ...“ to distinguish them, i.e.:

- „>CB1 3p Closed“ (No. 410) for the series connection of the NO auxiliary contacts of the CB,
- „>CB1 3p Open“ (No. 411) for the series connection of the NC auxiliary contacts of the CB,
- „>CB1 Pole L1“ (No. 366) for the auxiliary contact of pole L1,
- „>CB1 Pole L2“ (No. 367) for the auxiliary contact of pole L2,
- „>CB1 Pole L3“ (No. 368) for the auxiliary contact of pole L3.

2.23.1.3 Open Pole Detector

Single-pole dead times can be detected and reported via the Open Pole Detector. The corresponding protection and monitoring functions can respond. The following figure shows the logic structure of an Open Pole Detector.




Figure 2-177 Logic diagram of the Open Pole Detector

Single-pole Dead Time

During a single-pole dead time, the load current flowing in the two healthy phases forces a current flow via earth which may cause undesired pickup. The temporarily applying zero-sequence voltage may also prompt undesired responses of the protection functions.

The alarms „1pole open L1“ (No. 591), „1pole open L2“ (No. 592) and „1pole open L3“ (No. 593) are generated in addition if the „Open Pole Detector“ recognizes that current and voltage are absent in one phase – but neither in the other phases current is flowing. In this case, the message will be held up only for as long as the condition is fulfilled. This enables a single-pole automatic reclosure to be detected on an unloaded line.

2.23.1.4 Pickup Logic for the Entire Device**Phase Segregated Fault Detection**

The fault detection logic combines the fault detection (pickup) signals of all protection functions. In the case of those protection functions that allow for phase segregated pickup, the pickup is output in a phase segregated manner. If a protection function detects an earth fault, this is also output as a common device alarm. Thus, the alarms „Relay PICKUP L1“, „Relay PICKUP L2“, „Relay PICKUP L3“ and „Relay PICKUP E“ are available.

The above alarms can be allocated to LEDs or output relays. For the local display of fault annunciations and for the transmission of event messages to a personal computer or a centralized control system, several protection functions provide the possibility to display the faulted phase information in a single annunciation, e.g. „Diff Flt. L12E“ or „Dis.Pickup L12E“ for fault detection in L1-L2-E. Only one such annunciation appears, which represents the complete definition of the fault detection.

General Pickup

The pickup signals are combined with OR and lead to a general pickup of the device. It is signalled with the alarm „Relay PICKUP“. If no protection function of the device has picked up any longer, „Relay PICKUP“ disappears (indication: „OFF“).

General device pickup is a precondition for a series of internal and external functions that occur subsequently. The following are among the internal functions controlled by general device pickup:

- Opening of fault case: from general device pickup to general device dropout, all fault indications are entered in the trip log.
- Initialization of fault storage: the storage and maintenance of fault values can also be made dependent on the occurrence of a trip command.
- Generation of spontaneous indications: certain fault indications can be displayed as so-called spontaneous indications (see „Spontaneous Indications“ below). This indication can also be made dependent on the general device trip.
- Start action time of automatic reclosure (if available and used).

External functions may be controlled by this indication via an output contact. Examples are:

- Automatic reclose devices,
- Channel boost in conjunction with signal transmission by PLC,
- Further additional devices or similar.

Spontaneous Indications

Spontaneous indications are fault indications which appear in the display automatically following a general fault detection or trip command of the device. For the 7SD5, these indications include:

„Relay PICKUP“:	protective function that picked up;
„S/E/F TRIP“:	protection function which tripped (only device with graphic display);
„PU Time“:	the operating time from the general pickup to the dropout of the device, the time is given in ms;
„TRIP Time“:	the operating time from general pickup to the first trip command of the device, in ms;
„dist =“:	Distance to fault in kilometers or miles derived by the distance to fault location function (if possible).

2.23.1.5 Tripping Logic of the Entire Device

Three-pole Tripping

In general, the device trips three-pole in the event of a fault. Depending on the version ordered (see Section A.1, „Ordering Information“), single-pole tripping is also possible. If, in general, single-pole tripping is not possible or desired, the output function „Relay TRIP 3ph.“ is used for the trip command output to the circuit breaker. In these cases the following sections regarding single-pole tripping are not of interest.

Single-pole Tripping

Single-pole tripping only makes sense on overhead lines, on which automatic reclosure shall be carried out and where the circuit breakers at both ends of the line are capable of single-pole tripping. In such cases, the faulted phase may be tripped single-pole and subsequently reclosed; in the case of two-phase and three-phase faults with or without earth, three-pole tripping is usually carried out.

Device prerequisites for phase segregated tripping are:

- Phase segregated tripping is provided by the device (according to the ordering code);
- The tripping protection function is suitable for pole-segregated tripping (for example, not for frequency protection, overvoltage protection or overload protection),
- The binary input „>1p Trip Perm“ is configured and activated or the internal automatic reclosure function is ready for reclosure after single-pole tripping.

In all other cases tripping is always three-pole. The binary input „>1p Trip Perm“ is the logic inversion of a three-pole coupling and is activated by an external auto-reclosure device as long as this is ready for a single-pole auto-reclosure cycle.

With the 7SD5, it is also possible to trip three-pole when only one phase is subjected to the trip conditions, but more than one phase indicates a fault detection. This can be the case, for instance, when two faults at different locations occur simultaneously, but only one of them is within the range of differential protection or, in the case of distance protection, within the fast tripping zone (Z1 or Z1B). This is selected with the setting parameter **3pole coupling** (address 1155), which is set to **with PICKUP** (every multiple-phase fault detection causes three-pole trip) or **with TRIP** (in the event of multiple-phase trip commands the tripping is three-pole).

The tripping logic combines the trip signals from all protection functions. The trip commands of those protection functions that allow single-pole tripping are phase segregated. The corresponding messages are named „Relay TRIP L1“, „Relay TRIP L2“ and „Relay TRIP L3“.

These alarms can be allocated to LEDs or output relays. In the event of three-pole tripping all three alarms pick up.

If single-pole tripping is possible, the protection functions generates a group signal for the local displaying of alarms and for the transmission of the alarms to a PC or a central control system, e.g. „Diff TRIP 1p L1“, „Diff TRIP 1p L2“, „Diff TRIP 1p L3“ for single-pole tripping by the differential protection, „Dis.Trip 1pL1“, „Dis.Trip 1pL2“, „Dis.Trip 1pL3“ for single-pole tripping by the distance protection, and „Diff TRIP L123“ or „Dis.Trip 3p“ for three-pole tripping. Only one of these alarms is displayed at a time. These alarms are also intended for the trip command output to the circuit breaker.

Single-pole Tripping after Two-Phase Fault

Single-pole tripping for two-phase faults is a special feature. If a phase-phase fault without earth occurs in an earthed system, this fault can be cleared by single-pole trip and automatic reclosure in one of the faulted phases, as the short-circuit path is interrupted in this manner. The phase selected for tripping must be the same at both line ends (and should be the same for the entire system).

The setting parameter **Trip2phFlt** (address 1156) allows to select whether this tripping should be **1pole leading Ø**, i.e. single-pole tripping of the leading phase, or **1pole lagging Ø**, i.e. single-pole tripping of the lagging phase. Standard setting is **3pole**, i.e. three-pole tripping after two-phase faults (default setting).

Table 2-18 Single-pole and three-pole trip depending on fault type

Type of Fault (from Protection Function)				Parameter Trip2phFlt	Output signals for trip			
					TRIP 1p.L1	TRIP 1p.L2	TRIP 1p.L3	Relay TRIP 3ph.
L1				(any)	X			
	L2			(any)		X		
		L3		(any)			X	
L1			E	(any)	X			
	L2		E	(any)		X		
		L3	E	(any)			X	
L1	L2			3pole				X
L1	L2			1pole leading Ø	X			
L1	L2			1pole lagging Ø		X		
	L2	L3		3pole				X
	L2	L3		1pole leading Ø		X		
	L2	L3		1pole lagging Ø			X	
L1		L3		3pole				X
L1		L3		1pole leading Ø			X	
L1		L3		1pole lagging Ø	X			
L1	L2		E	(any)				X
	L2	L3	E	(any)				X
L1		L3	E	(any)				X
L1	L2	L3		(any)				X
L1	L2	L3	E	(any)				X
			E	(any)				X

General Trip

All trip signals for the protective functions are connected by OR and generate the message „Relay TRIP“. This can be allocated to LED or output relay.

Terminating the Trip Signal

Once a trip command is initiated, it is phase segregatedly latched (in the event of three-pole tripping for each of the three poles) (refer to Figure 2-178). At the same time, the minimum trip command duration **TMin TRIP CMD** is started. This ensures that the command is transmitted to the circuit breaker for a sufficient amount of time, even if the function which issued the trip signal drops out quickly. The trip commands can only be terminated when the last protection function dropped out (i.e. functions no longer pick up) AND the minimum trip signal duration expired.

A further condition for the reset of the trip command is that the circuit breaker has opened, in the event of single-pole tripping the relevant circuit breaker pole. In the function control of the device, this is checked by means of the circuit breaker position feedback (Section „Detection of the Circuit Breaker Position“) and the flow of current. The residual current **PoleOpenCurrent** that is certainly undershot when the circuit breaker pole is open is set in address 1130. Address 1135 **Reset Trip CMD** determines under which conditions a trip command is reset. If **CurrentOpenPole** is set, the trip command is reset as soon as the current disappears. It is important that the value set in address 1130 **PoleOpenCurrent** (see above) is undershot. If **Current AND CB** is set, the circuit breaker auxiliary contact must send a message that the circuit breaker is open. It is a prerequisite for this setting that the position of the auxiliary contacts is allocated via a binary input.




Figure 2-178 Storage and termination of the trip command

Reclosure Interlocking

When tripping the circuit breaker by a protection function, the manual reclosure must often be blocked until the cause for the protection function operation is found. 7SD5 enables this via the integrated reclosure interlocking.

The interlocking state („LOCKOUT“) is implemented by an RS flipflop which is protected against auxiliary voltage failure (see Figure 2-179). The RS flipflop is set via binary input „>Lockout SET“ (No. 385). With the output alarm „LOCKOUT“ (No. 530), if interconnected correspondingly, a reclosure of the circuit breaker (e.g. for automatic reclosure, manual close signal, synchronization, closing via control) can be blocked. Only once the cause for the protection operation is known, should the interlocking be reset by a manual reset via binary input „>Lockout RESET“ (No. 386).




Figure 2-179 Reclosure interlocking

Conditions which cause reclosure interlocking and control commands which have to be interlocked can be set individually. The two inputs and the output can be wired via the correspondingly allocated binary inputs and outputs or be linked via user-defined logic functions (CFC).

If, for example, each trip by the protection function has to cause a closing lock-out, then combine the tripping command „Relay TRIP“ (No. 511) with the binary input „>Lockout SET“. If automatic reclosure is applied, only the final trip of the protection function should activate reclosing lock-out. Please bear in mind that the message „Final Trip“ (No. 536) applies only for 500 ms. Then combine the output alarm „Final Trip“ (No. 536) with the interlocking input „>Lockout SET“, so that the interlocking function is not established when an automatic reclosure is still expected to come.

In the most simple case, the output alarm „LOCKOUT“ (No. 530) can be allocated to the output which trips the circuit breaker without creating further links. Then the tripping command is maintained until the interlock is reset via the binary reset input. Naturally it has to be ensured in advance that the close coil at the circuit breaker — as is usually done — is blocked as long as a tripping command is maintained.

The output alarm „LOCKOUT“ can also be applied to interlock certain closing commands (externally or via CFC), e.g. by combining the output alarm with the binary input „>CloseCmd.Blo“ (No. 357) or by connecting the inverted alarm with the bay interlocking of the feeder.

The reset input „>Lockout RESET“ (No. 386) resets the interlocking state. This input is initiated by an external device which is protected against unauthorized or unintentional operation. The interlocking state can also be controlled by internal sources using CFC, e.g. a function key, operation of the device or using DIGSI® on a PC.

For each case please make sure that the corresponding logical combinations, security measures, etc. are taken into account for the routing of the binary inputs and outputs and are also considered for the setting of user-defined logic functions, if necessary. See also the SIPROTEC® 4 System Description.

Breaker Tripping Alarm Suppression

While on feeders without automatic reclosure every trip command by a protection function is final, it is desirable, when using automatic reclosure, to prevent the operation detector of the circuit breaker (transient contact on the breaker) from sending an alarm if the trip of the breaker is not final (Figure 2-180).

For this purpose, the signal from the circuit breaker is routed via a correspondingly allocated output contact of the 7SD5 (output alarm „CB Alarm Supp“, No. 563). In the idle state and when the device is turned off, this contact is closed. Therefore an output contact with a normally closed contact (NC contact) has to be allocated. Which contact is to be allocated is dependent on the device version. Refer to the general views in the Appendix.

Prior to the command, with the internal automatic reclosure in the ready state, the contact is opened so that no signal from the circuit breaker is forwarded. This is only the case if the device is equipped with internal automatic reclosure and if the latter was taken into consideration when configuring the protection functions (address 133).

Also when closing the breaker via the binary input „>Manual Close“ (No 356) or via the integrated automatic reclosure the contact is interrupted so that the breaker alarm is inhibited.

Further optional closing commands which are not sent via the device cannot be taken into consideration. Closing commands for control can be linked to the alarm suppression via the user-defined logic functions (CFC).




Figure 2-180 Breaker tripping alarm suppression

If the device issues a final trip command, the contact remains closed. This is the case, during the reclaim time of the automatic reclosure cycle, when the automatic reclosure is blocked or switched off or, due to other reasons is not ready for automatic reclosure (e.g. tripping only occurred after the action time expired).

Figure 2-181 shows time diagrams for manual trip and close as well as for short-circuit tripping with a single, failed automatic reclosure cycle.




Figure 2-181 Breaker tripping alarm suppression — sequence examples

2.23.2 Circuit Breaker Test

The universal line protection 7SD5 allows an easy check of the trip circuits and the circuit breakers.

2.23.2.1 Functional Description

The test programs as shown in Table 2-19 are available. The single-pole tests are naturally only available if the device at hand allows for single-pole tripping.

The output alarms mentioned must be allocated to the relevant command relays that are used for controlling the circuit breaker coils.

The test is started using the operator panel on the front of the device or using the PC with DIGSI®. The procedure is described in detail in the SIPROTEC® 4 System Description. Figure 2-182 shows the chronological sequence of one TRIP–CLOSE test cycle. The set times are those stated in Section 2.1.2.1 for „Trip Command Duration“ and „Circuit Breaker Test“.

Where the circuit breaker auxiliary contacts indicate the status of the circuit breaker or of its poles to the device via binary inputs, the test cycle can only be initiated if the circuit breaker is closed.

The information regarding the position of the circuit breakers is not automatically derived from the position logic according to the above section. For the circuit breaker test function (auto recloser) there are separate binary inputs for the switching status feedback of the circuit breaker position. These must be taken into consideration when allocating the binary inputs as mentioned in the previous section.

The alarms of the device show the respective state of the test sequence.

Table 2-19 Circuit breaker test programs

Serial No.	Test Programs	Circuit Breaker	Output Indications (No.)
1	1-pole TRIP/CLOSE-cycle phase L1	CB 1	CB1-TESTtrip L1 (7325)
2	1-pole TRIP/CLOSE-cycle phase L2		CB1-TESTtrip L2 (7326)
3	1-pole TRIP/CLOSE-cycle phase L3		CB1-TESTtrip L3 (7327)
4	3-pole TRIP/CLOSE-cycle		CB1-TESTtrip 123 (7328)
	Associated close command		CB1-TEST CLOSE (7329)




Figure 2-182 TRIP-CLOSE test cycle

2.23.2.2 Information List

No.	Information	Type of Information	Comments
-	CB1tst L1	-	CB1-TEST trip/close - Only L1
-	CB1tst L2	-	CB1-TEST trip/close - Only L2
-	CB1tst L3	-	CB1-TEST trip/close - Only L3
-	CB1tst 123	-	CB1-TEST trip/close Phases L123
7325	CB1-TESTtrip L1	OUT	CB1-TEST TRIP command - Only L1
7326	CB1-TESTtrip L2	OUT	CB1-TEST TRIP command - Only L2
7327	CB1-TESTtrip L3	OUT	CB1-TEST TRIP command - Only L3
7328	CB1-TESTtrip123	OUT	CB1-TEST TRIP command L123
7329	CB1-TEST close	OUT	CB1-TEST CLOSE command
7345	CB-TEST running	OUT	CB-TEST is in progress
7346	CB-TSTstop FLT.	OUT_Ev	CB-TEST canceled due to Power Sys. Fault
7347	CB-TSTstop OPEN	OUT_Ev	CB-TEST canceled due to CB already OPEN
7348	CB-TSTstop NOTr	OUT_Ev	CB-TEST canceled due to CB was NOT READY
7349	CB-TSTstop CLOS	OUT_Ev	CB-TEST canceled due to CB stayed CLOSED
7350	CB-TST .OK.	OUT_Ev	CB-TEST was successful

2.23.3 Device

The device requires some general information. This may be, for example, the type of indication to be issued in the event a power system fault occurs.

2.23.3.1 Trip-dependent Messages

The indication of messages masked to local LEDs, and the maintenance of spontaneous messages, can be made dependent on whether the device has issued a trip signal. This information is not output if one or more protection functions have picked up due to a fault, but the 7SD5 has not initiated the tripping because the fault was cleared by another device (e.g. on another line). These messages are then limited to faults on the protected line.

The following figure illustrates the creation of the reset command for stored messages. When the relay drops off, stationary conditions (fault display Target on PU / Target on TRIP; Trip / No Trip) decide whether the new fault will be stored or reset.




Figure 2-183 Creation of the reset command for the latched LED and LCD messages

2.23.3.2 Spontaneous Indications on the Display

You can determine whether or not the most important data of a fault event is displayed automatically after the fault has occurred (see also „Fault indications“ in Section 2.24.2 „Ancillary Functions“).

2.23.3.3 Switching Statistics

The number of trips caused by the device 7SD5 is counted. If the device is capable of single-pole tripping, a separate counter for each circuit breaker pole is provided.

Following each trip command the device registers the value of each current phase that was switched off in each pole. This information is then provided in the trip log and summed in a register. The maximum interrupted current is stored as well.

If the device is equipped with the integrated automatic reclosure, the automatic close commands are also counted, separately for reclosure after single-pole tripping, after three-pole tripping as well as separately for the first reclosure cycle and other reclosure cycles.

The counter and memory levels are secured against loss of auxiliary voltage. They can be set to zero or to any other initial value. For more details, refer to the SIPROTEC® 4 System Description.

2.23.3.4 Setting Notes

Fault Annunciations

Pickup of a new protective function generally turns off any previously lit LEDs, so that only the latest fault is displayed at any time. It can be selected whether the stored LED displays and the spontaneous annunciations on the display appear upon renewed pickup, or only after a renewed trip signal is issued. In order to enter the desired type of display, select the submenu General Device Settings in the SETTINGS menu. At address 610 **FltDisp.LED/LCD** the two alternatives **Target on PU** and **Target on TRIP** („No trip - no flag“) are offered.

For devices with graphical display use parameter 615 **Spont. FltDisp.** to specify whether or not a spontaneous annunciation will appear automatically on the display (**YES**) or not (**NO**). For devices with text display such messages will appear after a system fault in any case.

After startup of a device featuring a 4-line display, measured values are displayed by default. Use the arrow keys on the device front to select the different representations of the measured values for the so-called default display. The start page of the default display, which is displayed by default after startup of the device, can be selected via parameter 640 **Start image DD**. The available representation types for the measured values are listed in the appendix .

2.23.3.5 Settings

Addr.	Parameter	Setting Options	Default Setting	Comments
610	FltDisp.LED/LCD	Target on PU Target on TRIP	Target on PU	Fault Display on LED / LCD
615	Spont. FltDisp.	NO YES	NO	Spontaneous display of flt.annunciations
640	Start image DD	image 1 image 2 image 3 image 4 image 5 image 6	image 1	Start image Default Display

2.23.3.6 Information List

No.	Information	Type of Information	Comments
-	Test mode	IntSP	Test mode
-	DataStop	IntSP	Stop data transmission
-	UnlockDT	IntSP	Unlock data transmission via BI
-	SynchClock	IntSP_Ev	Clock Synchronization
-	>Light on	SP	>Back Light on
-	HWTestMod	IntSP	Hardware Test Mode
-	Error FMS1	OUT	Error FMS FO 1
-	Error FMS2	OUT	Error FMS FO 2
-	Brk OPENED	IntSP	Breaker OPENED
-	FdrEARTHED	IntSP	Feeder EARTHED
3	>Time Synch	SP	>Synchronize Internal Real Time Clock

No.	Information	Type of Information	Comments
5	>Reset LED	SP	>Reset LED
11	>Annunc. 1	SP	>User defined annunciation 1
12	>Annunc. 2	SP	>User defined annunciation 2
13	>Annunc. 3	SP	>User defined annunciation 3
14	>Annunc. 4	SP	>User defined annunciation 4
15	>Test mode	SP	>Test mode
16	>DataStop	SP	>Stop data transmission
51	Device OK	OUT	Device is Operational and Protecting
52	ProtActive	IntSP	At Least 1 Protection Funct. is Active
55	Reset Device	OUT	Reset Device
56	Initial Start	OUT	Initial Start of Device
60	Reset LED	OUT_Ev	Reset LED
67	Resume	OUT	Resume
68	Clock SyncError	OUT	Clock Synchronization Error
69	DayLightSavTime	OUT	Daylight Saving Time
70	Settings Calc.	OUT	Setting calculation is running
71	Settings Check	OUT	Settings Check
72	Level-2 change	OUT	Level-2 change
73	Local change	OUT	Local setting change
110	Event Lost	OUT_Ev	Event lost
113	Flag Lost	OUT	Flag Lost
125	Chatter ON	OUT	Chatter ON
126	ProtON/OFF	IntSP	Protection ON/OFF (via system port)
128	TelepONoff	IntSP	Teleprot. ON/OFF (via system port)
140	Error Sum Alarm	OUT	Error with a summary alarm
144	Error 5V	OUT	Error 5V
160	Alarm Sum Event	OUT	Alarm Summary Event
177	Fail Battery	OUT	Failure: Battery empty
181	Error A/D-conv.	OUT	Error: A/D converter
182	Alarm Clock	OUT	Alarm: Real Time Clock
183	Error Board 1	OUT	Error Board 1
184	Error Board 2	OUT	Error Board 2
185	Error Board 3	OUT	Error Board 3
186	Error Board 4	OUT	Error Board 4
187	Error Board 5	OUT	Error Board 5
188	Error Board 6	OUT	Error Board 6
189	Error Board 7	OUT	Error Board 7
190	Error Board 0	OUT	Error Board 0
191	Error Offset	OUT	Error: Offset
192	Error1A/5Awrong	OUT	Error:1A/5Ajumper different from setting
193	Alarm adjustm.	OUT	Alarm: Analog input adjustment invalid
194	Error neutralCT	OUT	Error: Neutral CT different from MLFB
2054	Emer. mode	OUT	Emergency mode
4051	Telep. ON	IntSP	Teleprotection is switched ON

2.24 Ancillary Functions

The additional functions of the 7SD5 universal line protection include:

- Commissioning tools,
- Processing of messages,
- Processing of operational measured values,
- Storage of fault record data.

2.24.1 Commissioning Tools

2.24.1.1 Functional Description

The device is provided with a comprehensive commissioning and monitoring tool that checks the communication and the whole system of the differential protection function. The online help for this tool is available on CD-ROM together with DIGSI®, and in the Web under www.siprotec.com.

To ensure a proper communication between the device and the PC browser, the transmission speed must be equal for both. Furthermore, the user must set an IP address so that the browser can identify the device.

Thanks to the „IBS-Tool“ the user is able to operate the device with the PC. On the PC screen the front panel of the device is emulated, a function that can also be deactivated by the settings. The actual operation of the device can be now simulated with the mouse pointer. This possibility can be disabled.

IBS-Tool

The „IBS-Tool“ is a comprehensive commissioning and visualization tool which enables the user to chart the communication and the most important measurement data of the complete differential protection system on a PC screen by means of an Internet browser. Measured values and the values derived from them are graphically displayed as phasor diagrams. You can also view tripping diagrams. Scalar values are shown in numerical form. For more details refer to the online help for the „IBS-Tool“.

This tool allows to illustrate the measured values, the currents, voltages (if connected to the system) and their phase relationship for all devices connected to the differential protection system. In addition to phasor diagrams, numerical values as well as frequency and device addresses are indicated. Figure 2-184 shows an example.

Additionally, the position of the differential and restraint values can be viewed in the pickup characteristic.




Figure 2-184 Local measured values — example for voltages and currents

2.24.1.2 Setting Notes

The parameters of the „IBS-Tool“ can be set separately for the front operator interface and the service interface. The relevant addresses are those which relate to the interface that is used for communication with the PC and the „IBS-Tool“.

Addresses 4401 to 4406 are to configure the front interface. The valid 12-digit IP address has the format *****.***.***.*****. A three-digit block of the IP address is inserted into each of the addresses 4401 **IP-A (A.x.x.x)**, 4402 **IP-B (x.B.x.x)**, 4403 **IP-C (x.x.C.x)** and 4404 **IP-D (x.x.x.D)**.

The address 4405 **NUM LOCK** determines if the devices of a differential protection system should be operated with the IBS-Tool from the PC. When setting **YES**, the devices cannot be operated by the front panel emulation of the PC. This is the normal state during operation. Once this address is set to NO during commissioning, all device parameters can be changed to correct, for example, false or inconsistent settings.

In address 4406 **LCP/NCP** set if your PC interface supports LCP (Link Control Protocol) and NCP (Network Control Protocol). In the case of a point-to-point connection, the setting must be **YES** (default setting) to allow a data communications link. When using a star coupler, only one device (master device) requires the setting **YES**, the other devices require **NO**.

Addresses 4411 **IP-A (A.x.x.x)**, 4412 **IP-B (x.B.x.x)**, 4413 **IP-C (x.x.C.x)**, 4414 **IP-D (x.x.x.D)**, 4415 **NUM LOCK** and 4416 **LCP/NCP**. are to configure the rear interface.

2.24.1.3 Settings

Addr.	Parameter	Setting Options	Default Setting	Comments
4401	IP-A (A.x.x.x)	0 .. 255	141	IP-address **.xxx.xxx.xxx(Position 1-3)
4402	IP-B (x.B.x.x)	0 .. 255	142	IP-address xxx.**.xxx.xxx(Position 4-6)
4403	IP-C (x.x.C.x)	0 .. 255	255	IP-address xxx.xxx.**.xxx(Position 7-9)
4404	IP-D (x.x.x.D)	0 .. 255	150	IP-address xxx.xxx.xxx.**.(Pos. 10-12)
4405	NUM LOCK	YES NO	YES	Num Lock
4406	LCP/NCP	NO YES	YES	Front interface supports LCP/NCP mode
4411	IP-A (A.x.x.x)	0 .. 255	141	IP-address **.xxx.xxx.xxx(Position 1-3)
4412	IP-B (x.B.x.x)	0 .. 255	142	IP-address xxx.**.xxx.xxx(Position 4-6)
4413	IP-C (x.x.C.x)	0 .. 255	255	IP-address xxx.xxx.**.xxx(Position 7-9)
4414	IP-D (x.x.x.D)	0 .. 255	160	IP-address xxx.xxx.xxx.**.(Pos. 10-12)
4415	NUM LOCK	YES NO	YES	Num Lock
4416	LCP/NCP	NO YES	YES	Service interface supports LCP/NCP mode

2.24.2 Processing of Messages

After the occurrence of a system fault, data regarding the response of the protective relay and the measured quantities should be saved for future analysis. For this reason message processing is done in three ways:

2.24.2.1 Functional Description

Displays and Binary Outputs (output relays)

Important events and statuses are displayed using front panel LEDs. The device furthermore has output relays for remote indication. Most indications and displays can be configured differently from the delivery default settings (for information on the delivery default setting see Appendix). The SIPROTEC® 4 System Description gives a detailed description of the configuration procedure.

The output relays and the LEDs may be operated in a latched or unlatched mode (each may be individually set).

The latched conditions are protected against loss of the auxiliary voltage. They are reset

- On site by pressing the LED key on the relay,
- Remotely using a binary input configured for that purpose,
- Using one of the serial interfaces,
- Automatically at the beginning of a new pickup.

Status messages should not be latched. Also, they cannot be reset until the condition to be reported has been cancelled. This applies to, e.g. indications from monitoring functions, or the like.

A green LED displays operational readiness of the relay („RUN“), and cannot be reset. It goes out if the self-check feature of the microprocessor recognizes an abnormal occurrence, or if the auxiliary voltage fails.

When auxiliary voltage is present but the relay has an internal malfunction, the red LED („ERROR“) lights up and the processor blocks the relay.

DIGSI® enables you to control selectively each output relay and LED of the device and, in doing so, check the correct connection to the system. In a dialog box you can, for instance, cause each output relay to pick up, and thus test the wiring between the 7SD5 and the station, without having to create the indications masked to it.

Information via Display Panel or PC

Events and conditions can be read out on the display on the front panel of the relay. Using the front operator interface or the rear service interface, for instance, a personal computer can be connected, to which the information can be sent.

In the quiescent state, i.e. as long as no system fault is present, the LCD can display selectable operational information (overview of the operational measured values) (default display). In the event of a system fault, information regarding the fault, the so-called spontaneous displays, are displayed instead. After the fault indications have been acknowledged, the quiescent data are shown again. Acknowledgement can be performed by pressing the LED buttons on the front panel (see above).

Figure 2-185 shows the default display in a 4-line display as preset. The default display can be configured in the graphic display. For more information see the SIPROTEC® 4 System Description and the Display Editor manual.

Various default displays can be selected via the arrow keys. Parameter 640 can be set to change the default setting for the default display page shown in idle state. Two examples of possible default display selections are given below.

1	345A	12	121kV
2	341A	23	118kV
3	346A	31	119kV
E	4.7A	U0	2kV

Example:

IL1	= 345 A	UL1-L2	= 121 kV
IL2	= 341 A	UL2-L3	= 118 kV
IL3	= 346 A	UL3-L1	= 119 kV
IE (3I0)	= 4.7 A	U0	= 2 kV

Figure 2-185 Operational measured values in the default display

Default display 3 shows the measured values U_{L1-L2} and I_{L2} .

S:	227MVA	U:	400kV
P:	71MW	I:	401A
Q:	268MVAR		
f:	50.00Hz	cosφ:	0.25

Example:

S	= 227 MVA	UL1-L2	= 400 kV
P	= 71 MW	IL2	= 401 A
Q	= 268 MVAR		
f	= 50.00 Hz	cosφ	= 0.25

Figure 2-186 Operational measured values in the default display

Moreover, the device has several event buffers for operational annunciations, switching statistics, etc., which are saved against loss of auxiliary supply by means of a backup battery. These indications can be displayed on the LCD at any time by selection using the keypad or transferred to a personal computer via the serial service or operator interface. Readout of indications during operation is described in detail in the SIPROTEC® 4 System Description.

After a fault on the system, for example, important information about the progression of the fault can be retrieved, such as the pickup of a protective element or the initiation of a trip signal. The time the initial occurrence of the short-circuit fault occurred is accurately provided via the system clock. The progress of the disturbance is output with a relative time referred to the instant of fault detection, so that the duration of the fault until tripping and up to reset of the trip command can be ascertained. The resolution of the time information is 1 ms.

With a PC and the DIGSI® protection data processing software it is also possible to retrieve and display the events with the convenience of visualization on a monitor and a menu-guided dialog. The data may either be printed or stored for evaluation at a later time and place.

Information to a Control Centre

If the device has a serial system interface, stored information may additionally be transferred via this interface to a centralized control and storage device. Several communication protocols are available for the transfer of this information.

You may test whether the information is transmitted correctly with DIGSI®.

Also, the information transmitted to the control centre can be influenced during operation or tests. The IEC 60870-5-103 protocol allows to identify all messages and measured values transferred to the central control system with an added message „test operation“- bit while the device is being tested on site (test mode). This identification prevents the messages from being incorrectly interpreted as resulting from an actual power system disturbance or event. Alternatively, you may disable the transmission of annunciations to the system interface during tests („transmission block“).

To influence information at the system interface during test mode („test mode“ and „transmission block“), a CFC logic is required. Default settings already include this logic (see Appendix).

The SIPROTEC® 4 System Description describes in detail how to activate and deactivate test mode and blocked data transmission.

Classification of Indications

Indications are classified as follows:

- **Operational indications:** messages generated while the device is in operation. They include information about the status of device functions, measurement data, system data, and similar information.
- **Fault indications:** messages from the last eight network faults that were processed by the device.
- **Statistic indications:** they include a counter for the switching actions of the circuit breakers initiated by the device, maybe reclose commands as well as values of interrupted currents and accumulated fault currents.

A complete list of all indications and output functions that can be generated by the device, with the associated information number (No.), can be found in the Appendix. The lists also indicate where each indication can be sent to. If functions are not present in the specific device version, or if they are set to **Disabled**, then the associated indications cannot appear.

Operational Indications

Operational indications contain information that the device generates during operation and about operational conditions.

Up to 200 operational indications are recorded in chronological order in the device. Newly generated indications are added to those already there. If the maximum capacity of the memory is exhausted, the oldest indication is lost.

Operational indications arrive automatically and can be read out from the device display or a personal computer at any time. Faults in the power system are indicated with „Network Fault“ and the present fault number. The fault indications contain detailed information on the behaviour of the power system fault.

Fault Indications

Following a system fault, it is possible, for example, to retrieve important information regarding its progress, such as pickup and trip. The time the initial occurrence of the short-circuit fault occurred is accurately provided via the system clock. The progress of the disturbance is output with a relative time referred to the instant of fault detection, so that the duration of the fault until tripping and up to reset of the trip command can be ascertained. The resolution of the time information is 1 ms.

A system fault starts with the recognition of the fault by the fault detection, i.e. first pickup of any protection function, and ends with the reset of the fault detection, i.e. dropout of the last protection function. Where fault causes several protective functions to pick up, the fault is considered to include all that occurred between pickup of the first protective function and dropout of the last protective function.

If auto-reclosing occurs, then the network fault ends after the last reclosing shot, which means after a successful reclosing or lockout. Therefore the entire clearing process, including the reclosing shot (or all reclosing shots) occupies only one fault record.

Within a network fault, several fault records can occur (from the first pickup of a protective function to the last dropout of a protective function). Without auto-reclosing each fault record represents a network fault.

Spontaneous Indications

After a fault, automatically and without operator action, the most important fault data from the general device pickup appear on the display in the sequence shown in the following figure.

S/E/F PICKUP
PU - Time
TRIP Time
Fault Locator

Protective Function that Picked up First;
Operating Time from General Pickup to Dropout;
Operating Time from General Pickup to the First Trip Command;

Figure 2-187 Spontaneous fault indication display

Fault Location Options

Besides the display at the device and in DIGSI® there are additional display options available in particular for the fault location. They depend on the device version, the configuration and allocation:

- If the device features the BCD output for the fault location, the transmitted figures mean the following:
0 to 195: the calculated fault location in % (if greater than 100%, the error lies outside the protected line in a forward direction);
197: negative fault location (fault in reverse direction);
199: overflow.

Retrievable Indications

The indications of the last eight network faults can be retrieved and output. In total 600 indications can be recorded. Oldest indications are erased for newest fault indications when the buffer is full.

Spontaneous Indications

Spontaneous indications contain information that new indications have arrived. Each new incoming indication appears immediately, i.e. the user does not have to wait for an update or initiate one. This can be a useful help during operation, testing and commissioning.

Spontaneous indications can be read out via DIGSI®. For more information see the SIPROTEC®4 System Description.

General Interrogation

The present condition of the SIPROTEC® 4 device can be retrieved via DIGSI® by viewing the contents of the General Interrogation. It shows all indications that are subject to general interrogation with their current value.

2.24.3 Statistics

2.24.3.1 Functional Description

Switching Statistics The messages in switching statistics are counters for the accumulation of interrupted currents by each of the breaker poles, the number of control commands issued by the device 7SD5 to the breakers, and the maximum interrupted currents. The indicated measured values are indicated in primary values.

Switching statistics can be viewed on the LCD of the device, or on a PC running DIGSI® and connected to the operator or service interface.

The counters and memories of the statistics are saved by the device. Therefore the information will not get lost in case the auxiliary voltage supply fails. The counters, however, can be reset back to zero or to any value within the setting range.

A password is not required to read counter and stored values but is required to change or delete them. For further information see the SIPROTEC®4 System Description.

Transmission Statistics

In 7SD5 the protection communication is registered in statistics. The transmission times of the information between the devices via interfaces (send and receive) are measured continuously. The values are kept stored in the statistics folder. The availability of the transmission media is also reported. The availability is indicated in % min and % h. This enables an evaluation of the transmission quality.

If GPS synchronization is configured, the transmission times for each direction and each protection data interface are regularly measured and indicated as long as GPS synchronization is intact.

2.24.3.2 Information List

No.	Information	Type of Information	Comments
1000	# TRIPs=	VI	Number of breaker TRIP commands
1001	TripNo L1=	VI	Number of breaker TRIP commands L1
1002	TripNo L2=	VI	Number of breaker TRIP commands L2
1003	TripNo L3=	VI	Number of breaker TRIP commands L3
1027	Σ IL1 =	VI	Accumulation of interrupted current L1
1028	Σ IL2 =	VI	Accumulation of interrupted current L2
1029	Σ IL3 =	VI	Accumulation of interrupted current L3
1030	Max IL1 =	VI	Max. fault current Phase L1
1031	Max IL2 =	VI	Max. fault current Phase L2
1032	Max IL3 =	VI	Max. fault current Phase L3
2895	AR #Close1./1p=	VI	No. of 1st AR-cycle CLOSE commands,1pole
2896	AR #Close1./3p=	VI	No. of 1st AR-cycle CLOSE commands,3pole
2897	AR #Close2./1p=	VI	No. of higher AR-cycle CLOSE commands,1p
2898	AR #Close2./3p=	VI	No. of higher AR-cycle CLOSE commands,3p
7751	PI1 TD	MV	Prot.Interface 1:Transmission delay
7752	PI2 TD	MV	Prot.Interface 2:Transmission delay
7753	PI1A/m	MV	Prot.Interface 1: Availability per min.
7754	PI1A/h	MV	Prot.Interface 1: Availability per hour

No.	Information	Type of Information	Comments
7755	PI2A/m	MV	Prot.Interface 2: Availability per min.
7756	PI2A/h	MV	Prot.Interface 2: Availability per hour
7875	PI1 TD R	MV	Prot.Interface 1:Transmission delay rec.
7876	PI1 TD S	MV	Prot.Interface 1:Transmission delay send
7877	PI2 TD R	MV	Prot.Interface 2:Transmission delay rec.
7878	PI2 TD S	MV	Prot.Interface 2:Transmission delay send

2.24.4 Measurement During Operation

2.24.4.1 Functional Description

A series of measured values and the values derived from them are available for on-site retrieval or for data transfer.

A precondition for a correct display of primary and percentage values is the complete and correct entry of the nominal values of the instrument transformers and the power system as well as the transformation ratio of the current and voltage transformers in the earth paths.

Display and Transmission of Measured Values

Operational measured values and metered values are determined in the background by the processor system. They can be called up at the front of the device, read out via the operator interface using a PC with DIGSI®, or transferred to a central master station via the system interface.

Depending on the ordering code, connection type to the device and the configured protection function, only some of the listed operational measured values in Table 2-20 may be available. Of the current values I_{EE} , I_Y and I_P only the one which is connected to the current measuring input I_4 can apply. Phase-to-earth voltages can only be measured if the phase-to-earth voltage inputs are connected. The displacement voltage $3U_0$ is e-n-voltage multiplied by $\sqrt{3}$ — if U_{en} is connected — or calculated from the phase-to-earth voltages $3U_0 = |\underline{U}_{L1} + \underline{U}_{L2} + \underline{U}_{L3}|$. All three voltage inputs must be phase-earth connected for this.

If multiple devices are interconnected via their protection data interfaces, a common frequency value is calculated across the whole constellation (constellation frequency). This value is displayed as the operational measured value „Frequency“. It allows to display a frequency even in devices in which local frequency measurement is not possible. The constellation frequency is also used by the differential protection for synchronizing the measured values. Locally operating functions such as frequency protection always use the locally measured frequency.

If the device operates in a local mode (device is logged off, in test mode, or protection data interface is not connected), the locally measured frequency is displayed.

For the thermal overload protection, the calculated overtemperatures are indicated in relation to the trip overtemperature. Overload measured values can appear only if the overload protection was configured **Enabled**.

If the device features a synchronism and voltage check function, and provided that these features have been set to 135 during configuration of the scope of the device (address **Enabled**), and that the parameter **U4 transformer** (address 210) has been set to **Usync transf.**, the characteristic values (voltages, frequencies, differences) can be read out.

The power components P, Q are positive, when real power or inductive reactive power are flowing into the protected object, assuming that this direction has been parameterized as forward.

The sign of the power factor $\cos \varphi$ corresponds to the sign of the real power.

The operational measured values are also calculated in the event of a running fault in intervals of approximately 0.5 s.

Table 2-20 Operational measured values of the local device

Measured Values		Primary	Secondary	% Referred to
I_{L1}, I_{L2}, I_{L3}	Phase currents	A	A	Nominal operational current ¹⁾
I_{EE}	Sensitive earth current	A	mA	Nominal operational current ³⁾¹⁾
$3I_0$	Earth current	A	A	Nominal operational current ¹⁾
$\varphi(I_{L1}-I_{L2}), \varphi(I_{L2}-I_{L3}), \varphi(I_{L3}-I_{L1})$	Phase angle of the phase currents towards each other	°	–	–
I_1, I_2	Positive and negative sequence component of currents	A	A	Nominal operational current ¹⁾
I_Y, I_P	Transformer starpoint current or earth current of the parallel line	A	A	Nominal operational current ³⁾¹⁾
$U_{L1-L2}, U_{L2-L3}, U_{L3-L1}$	Phase-to-phase voltages	kV	V	Nominal operational voltage ²⁾
$U_{L1-E}, U_{L2-E}, U_{L3-E}$	Phase-earth voltage	kV	V	Nominal operational voltage / $\sqrt{3}$ ²⁾
$3U_0; U_0$	Displacement voltage	kV	V	Nominal operational voltage / $\sqrt{3}$ ²⁾
$\varphi(U_{L1}-U_{L2}), \varphi(U_{L2}-U_{L3}), \varphi(U_{L3}-U_{L1})$	Phase angle of the phase voltages towards each other	°	–	–
$\varphi(U_{L1}-I_{L1}), \varphi(U_{L2}-I_{L2}), \varphi(U_{L3}-I_{L3})$	Phase angle of the phase voltages towards the phase currents	°	–	–
U_1, U_2	Positive and negative sequence component of the voltages	kV	V	Nominal operational voltage / $\sqrt{3}$ ²⁾
$U_X; U_{EN}$	Voltage at measuring input U_4	–	V	–
$U_{1\text{compound}}$	Positive sequence component of voltages at the remote end (if compounding is active in voltage protection)	kV	V	Operational rated voltage / $\sqrt{3}$ ²⁾
$R_{L1-E}, R_{L2-E}, R_{L3-E}, R_{L1-L2}, R_{L1-L3}, R_{L2-L3}$	Operational resistance of all loops	Ω	Ω	–
$X_{L1-E}, X_{L2-E}, X_{L3-E}, X_{L1-L2}, X_{L2-L3}, X_{L3-L1}$	Operational reactance of all loops	Ω	Ω	–
S, P, Q	Apparent, active and reactive power	MVA, MW, MVAR	–	$\sqrt{3} \cdot U_N \cdot I_N$ Nominal operational quantities ¹⁾²⁾
$\cos \varphi$	Power factor	(abs)	(abs)	–
f	Frequency (constellation frequency)	Hz	Hz	Nominal frequency
$\Theta_{L1}/\Theta_{TRIP}, \Theta_{L2}/\Theta_{TRIP}, \Theta_{L3}/\Theta_{TRIP}$	Thermal value of each phase, referred to the tripping value	%	–	Trip overtemperature
Θ/Θ_{TRIP}	Resulting thermal value, referred to the tripping value, calculated according to the set method	%	–	Trip overtemperature
$U_{Line}, U_{Bus}, U_{Diff}$	Line voltage, busbar voltage and voltage difference (for synchronism check)	kV	–	–
$f_{Line}, f_{Bus}, f_{Diff}$	Line voltage, busbar frequency and voltage difference (for synchronism check)	Hz	–	–
φ_{Diff}	Amount of phase angle difference between line and busbar (for synchronism check)	°	–	–

¹⁾ according to address 1104²⁾ according to address 1103³⁾ considering factor 221 I4/Iph CT

2.24.4.2 Information List

No.	Information	Type of Information	Comments
601	IL1 =	MV	I L1
602	IL2 =	MV	I L2
603	IL3 =	MV	I L3
610	3I0 =	MV	3I0 (zero sequence)
611	3I0sen=	MV	3I0sen (sensitive zero sequence)
612	IY =	MV	IY (star point of transformer)
613	3I0par=	MV	3I0par (parallel line neutral)
619	I1 =	MV	I1 (positive sequence)
620	I2 =	MV	I2 (negative sequence)
621	UL1E=	MV	U L1-E
622	UL2E=	MV	U L2-E
623	UL3E=	MV	U L3-E
624	UL12=	MV	U L12
625	UL23=	MV	U L23
626	UL31=	MV	U L31
627	Uen =	MV	Uen
631	3U0 =	MV	3U0 (zero sequence)
632	U _{sync} =	MV	U _{sync} (synchronism)
633	U _x =	MV	U _x (separate VT)
634	U1 =	MV	U1 (positive sequence)
635	U2 =	MV	U2 (negative sequence)
636	U _{diff} =	MV	U _{diff} (line-bus)
637	U _{line} =	MV	U _{line}
638	U _{bus} =	MV	U _{bus}
641	P =	MV	P (active power)
642	Q =	MV	Q (reactive power)
643	PF =	MV	Power Factor
644	Freq=	MV	Frequency
645	S =	MV	S (apparent power)
646	F-bus =	MV	Frequency (busbar)
647	F-diff=	MV	Frequency (difference line-bus)
648	φ-diff=	MV	Angle (difference line-bus)
649	F-line=	MV	Frequency (line)
679	U1co=	MV	U1co (positive sequence, compounding)
684	U0 =	MV	U0 (zero sequence)
801	Θ/Θtrip =	MV	Temperat. rise for warning and trip
802	Θ/ΘtripL1=	MV	Temperature rise for phase L1
803	Θ/ΘtripL2=	MV	Temperature rise for phase L2
804	Θ/ΘtripL3=	MV	Temperature rise for phase L3
966	R L1E=	MV	R L1E
967	R L2E=	MV	R L2E
970	R L3E=	MV	R L3E
971	R L12=	MV	R L12
972	R L23=	MV	R L23

No.	Information	Type of Information	Comments
973	R L31=	MV	R L31
974	X L1E=	MV	X L1E
975	X L2E=	MV	X L2E
976	X L3E=	MV	X L3E
977	X L12=	MV	X L12
978	X L23=	MV	X L23
979	X L31=	MV	X L31
7731	Φ IL1L2=	MV	PHI IL1L2 (local)
7732	Φ IL2L3=	MV	PHI IL2L3 (local)
7733	Φ IL3L1=	MV	PHI IL3L1 (local)
7734	Φ UL1L2=	MV	PHI UL1L2 (local)
7735	Φ UL2L3=	MV	PHI UL2L3 (local)
7736	Φ UL3L1=	MV	PHI UL3L1 (local)
7737	Φ UIL1=	MV	PHI UIL1 (local)
7738	Φ UIL2=	MV	PHI UIL2 (local)
7739	Φ UIL3=	MV	PHI UIL3 (local)

2.24.5 Differential Protection Values

2.24.5.1 Measured Values of the Differential Protection

The differential, restraint and charging current values of the differential protection which are listed in the following table can be called up at the front of the device, read out via the operator interface using a PC with DIGSI® or transferred to a central master station via the system interface.

Table 2-21 Measured values of the differential protection

Measured Values		% Referred to
IDiff _{L1} , IDiff _{L2} , IDiff _{L3}	Calculated differential currents of the three phases	Nominal operational current ¹⁾
IRest _{L1} , IRest _{L2} , IRest _{L3}	Calculated restraint currents of the three phases	Nominal operational current ¹⁾
IDiff _{3I0}	Calculated differential current of the zero sequence system	Nominal operational current ¹⁾
IC _{L1} , IC _{L2} , IC _{L3}	Measured charging currents of the three phases	Nominal operational current

¹⁾ for lines according to address (see Section 2.1.4), for transformers calculated from address (see Section 2.1.4)

$$I_N = S_N / (\sqrt{3} \cdot U_N)$$

2.24.5.2 Information List

No.	Information	Type of Information	Comments
7742	IDiffL1=	MV	IDiffL1(% Operational nominal current)
7743	IDiffL2=	MV	IDiffL2(% Operational nominal current)
7744	IDiffL3=	MV	IDiffL3(% Operational nominal current)
7745	IRestL1=	MV	IRestL1(% Operational nominal current)
7746	IRestL2=	MV	IRestL2(% Operational nominal current)
7747	IRestL3=	MV	IRestL3(% Operational nominal current)
7748	Diff3I0=	MV	Diff3I0 (Differential current 3I0)
7880	Ic L1 =	MV	Measured value charging current L1
7881	Ic L2 =	MV	Measured value charging current L2
7882	Ic L3 =	MV	Measured value charging current L3

2.24.6 Remote Measured Values

2.24.6.1 Functional Description

During communication, the data of the other ends of the protected object can also be read out. For each of the devices, the currents and voltages involved as well as phase shifts between the local and transfer measured quantities can be displayed. This is especially helpful for checking the correct and coherent phase allocation at the different line ends. Furthermore, the device addresses of the other devices are transmitted so that all important data of all ends are available in the substation. All possible data are listed in Table 2-22.

Table 2-22 Operational measured values transmitted from the other ends and compared with the local values

Data		Primary value
Device ADR	Device address of the remote device	(absolute)
I_{L1}, I_{L2}, I_{L3} remote	Phase currents of the remote device	Nominal operational current ¹⁾
I_{L1}, I_{L2}, I_{L3} local	Phase currents of the local device	Nominal operational current ¹⁾
$\varphi(I_{L1}), \varphi(I_{L2}), \varphi(I_{L3})$	Phase angles between the remote and the local phase currents	°
U_{L1}, U_{L2}, U_{L3} remote	Voltages of the remote device	Nominal operational voltage / $\sqrt{3}$ ²⁾
U_{L1}, U_{L2}, U_{L3} local	Voltages of the local device	Nominal operational voltage / $\sqrt{3}$ ²⁾
$\varphi(U_{L1}), \varphi(U_{L2}), \varphi(U_{L3})$	Phase angles between the remote and the local voltages	°

¹⁾ for lines according to address 1104

²⁾ according to address 1103

The information overviews below show you which information is available for each device.

2.24.7 Measured Values Constellation

2.24.7.1 Functional Description

The measured values constellation of the possible devices 1 to 6 are showed here by evaluating the device (see Table 2-23). Information for further devices is given in the Appendix.

The computation of this measured values constellation is also executed during an existing system fault in an interval of approx. 0.5 s.

Table 2-23 Measured values constellation for device 1

No.	Information	Type of Information	Comments
7761	„Relay ID“	MW	Device address of the device
7762	„IL1_opN=“	MW	IL1 (% of nominal operational current)
7763	„ΦI L1=“	MW	Angle IL1_remote <-> IL1_local
7764	„IL2_opN=“	MW	IL2 (% of nominal operational current)
7765	„ΦI L2=“	MW	Angle IL2_remote <-> IL2_local
7766	„IL3_opN=“	MW	IL3 (% of nominal operational current)
7767	„ΦI L3=“	MW	Angle IL3_remote <-> IL3_local
7769	„UL1_opN=“	MW	UL1 (% of nominal operational voltage)
7770	„ΦU L1=“	MW	Angle UL1_remote <-> UL1_local
7771	„UL2_opN=“	MW	UL2 (% of nominal operational voltage)
7772	„ΦU L2=“	MW	Angle UL2_remote <-> UL2_local
7773	„UL3_opN=“	MW	UL3 (% of nominal operational voltage)
7774	„ΦU L3=“	MW	Angle UL3_remote <-> UL3_local

2.24.8 Oscillographic Fault Records

2.24.8.1 Functional Description

The general line protection 7SD5 is equipped with a fault recording function. The instantaneous values of measured values

i_{L1} , i_{L2} , i_{L3} , $3i_0$, u_{L1} , u_{L2} , u_{L3} , $3u_0$ as well as I_{diffL1} , I_{diffL2} , I_{diffL3} , I_{RestL1} , I_{RestL2} , I_{RestL3}

(voltages depending on the connection) are sampled at intervals of 1 ms (for 50 Hz) and stored in a circulating buffer (20 samples per cycle). During a system fault these data are stored over a time span that can be set (5 s at the longest for each fault record). Up to 8 faults can be stored. The total capacity of the fault record memory is approx. 15 s. The fault recording buffer is updated when a new fault occurs, so that acknowledging is not necessary. In addition to storage of the fault recording by the protection fault detection, this may also be initiated via binary input, the integrated keypad and display, or via the serial operator or service interface.

For the differential protection system of a protected object, all fault records of all ends are synchronized by time management features. This ensures that all fault records operate with exactly the same time basis. Therefore, equal measured values are co-incident at all ends.

The data can be retrieved via the serial interfaces by means of a personal computer and evaluated with the operating software DIGSI® and the graphic analysis software SIGRA 4. The latter graphically represents the data recorded during the system fault and also calculates additional information from the measured values. A selection may be made as to whether the measured quantities are represented as primary or secondary values. Binary signal traces (marks) of particular events, e.g. „fault detection“, „tripping“ are also represented.

If the device has a serial system interface, the fault recording data can be passed on to a central device via this interface. The data is evaluated by applicable programs in the central device. The measured quantities are referred to their maximum values, scaled to their rated values and prepared for graphic representation. Binary signal traces (marks) of particular events, e.g. „fault detection“, „tripping“ are also represented.

Where transfer to a central device is possible, the request for data transfer can be executed automatically. It can be selected to take place after each fault detection by the protection, or only after a trip.

2.24.8.2 Settings

Addresses which have an appended "A" can only be changed with DIGSI, under Additional Settings.

Addr.	Parameter	Setting Options	Default Setting	Comments
402A	WAVEFORMTRIGGER	Save w. Pickup Save w. TRIP Start w. TRIP	Save w. Pickup	Waveform Capture
403A	WAVEFORM DATA	Fault event Pow.Sys.Flt.	Fault event	Scope of Waveform Data
410	MAX. LENGTH	0.30 .. 5.00 sec	2.00 sec	Max. length of a Waveform Capture Record
411	PRE. TRIG. TIME	0.05 .. 0.50 sec	0.25 sec	Captured Waveform Prior to Trigger
412	POST REC. TIME	0.05 .. 0.50 sec	0.10 sec	Captured Waveform after Event
415	BinIn CAPT.TIME	0.10 .. 5.00 sec; ∞	0.50 sec	Capture Time via Binary Input

2.24.8.3 Information List

No.	Information	Type of Information	Comments
-	FltRecSta	IntSP	Fault Recording Start
4	>Trig.Wave.Cap.	SP	>Trigger Waveform Capture
203	Wave. deleted	OUT_Ev	Waveform data deleted

2.24.9 Demand Measurement Setup

Long-term average values are calculated by 7SD5 and can be read out with the time reference (date and time of the last update).

2.24.9.1 Long-term Average Values

The long-term averages of the three phase currents I_{Lx} , the positive sequence components I_1 for the three phase currents, and the real power P, reactive power Q, and apparent power S are calculated within a set period of time and indicated in primary values.

For the long-term average values mentioned above, the length of the time window for averaging and the frequency with which it is updated can be set. The associated minimum and maximum values can be reset, using binary inputs or by using the integrated control panel in the DIGSI® operating program.

2.24.9.2 Settings

Addr.	Parameter	Setting Options	Default Setting	Comments
2801	DMD Interval	15 Min., 1 Sub 15 Min., 3 Subs 15 Min., 15 Subs 30 Min., 1 Sub 60 Min., 1 Sub	60 Min., 1 Sub	Demand Calculation Intervals
2802	DMD Sync.Time	On The Hour 15 After Hour 30 After Hour 45 After Hour	On The Hour	Demand Synchronization Time

2.24.9.3 Information List

No.	Information	Type of Information	Comments
833	I1dmd =	MV	I1 (positive sequence) Demand
834	Pdmd =	MV	Active Power Demand
835	Qdmd =	MV	Reactive Power Demand
836	Sdmd =	MV	Apparent Power Demand
963	IL1dmd=	MV	I L1 demand
964	IL2dmd=	MV	I L2 demand
965	IL3dmd=	MV	I L3 demand
1052	Pdmd Forw=	MV	Active Power Demand Forward
1053	Pdmd Rev =	MV	Active Power Demand Reverse
1054	Qdmd Forw=	MV	Reactive Power Demand Forward
1055	Qdmd Rev =	MV	Reactive Power Demand Reverse

2.24.10 Min/Max Measurement Setup

Minimum and maximum values are calculated by the 7SD5 and can be read out with the time reference (date and time of the last update).

2.24.10.1 Reset

The minimum and maximum values can be reset, using binary inputs or by using the integrated control panel in the DIGSI® 4 operating program. In addition, the reset can also take place cyclically, beginning with a pre-selected point in time.

2.24.10.2 Settings

Addr.	Parameter	Setting Options	Default Setting	Comments
2811	MinMax cycRESET	NO YES	YES	Automatic Cyclic Reset Function
2812	MiMa RESET TIME	0 .. 1439 min	0 min	MinMax Reset Timer
2813	MiMa RESETCYCLE	1 .. 365 Days	7 Days	MinMax Reset Cycle Period
2814	MinMaxRES.START	1 .. 365 Days	1 Days	MinMax Start Reset Cycle in

2.24.10.3 Information List

No.	Information	Type of Information	Comments
-	ResMinMax	IntSP_Ev	Reset Minimum and Maximum counter
395	>I MinMax Reset	SP	>I MIN/MAX Buffer Reset
396	>I1 MiMaReset	SP	>I1 MIN/MAX Buffer Reset
397	>U MiMaReset	SP	>U MIN/MAX Buffer Reset
398	>UphphMiMaRes	SP	>Uphph MIN/MAX Buffer Reset
399	>U1 MiMa Reset	SP	>U1 MIN/MAX Buffer Reset
400	>P MiMa Reset	SP	>P MIN/MAX Buffer Reset
401	>S MiMa Reset	SP	>S MIN/MAX Buffer Reset
402	>Q MiMa Reset	SP	>Q MIN/MAX Buffer Reset
403	>Idmd MiMaReset	SP	>Idmd MIN/MAX Buffer Reset
404	>Pdmd MiMaReset	SP	>Pdmd MIN/MAX Buffer Reset
405	>Qdmd MiMaReset	SP	>Qdmd MIN/MAX Buffer Reset
406	>Sdmd MiMaReset	SP	>Sdmd MIN/MAX Buffer Reset
407	>Frq MiMa Reset	SP	>Frq. MIN/MAX Buffer Reset
408	>PF MiMaReset	SP	>Power Factor MIN/MAX Buffer Reset
837	IL1d Min	MVT	I L1 Demand Minimum
838	IL1d Max	MVT	I L1 Demand Maximum
839	IL2d Min	MVT	I L2 Demand Minimum
840	IL2d Max	MVT	I L2 Demand Maximum
841	IL3d Min	MVT	I L3 Demand Minimum
842	IL3d Max	MVT	I L3 Demand Maximum
843	I1dmdMin	MVT	I1 (positive sequence) Demand Minimum

No.	Information	Type of Information	Comments
844	I1dmdMax	MVT	I1 (positive sequence) Demand Maximum
845	PdMin=	MVT	Active Power Demand Minimum
846	PdMax=	MVT	Active Power Demand Maximum
847	QdMin=	MVT	Reactive Power Demand Minimum
848	QdMax=	MVT	Reactive Power Demand Maximum
849	SdMin=	MVT	Apparent Power Demand Minimum
850	SdMax=	MVT	Apparent Power Demand Maximum
851	IL1Min=	MVT	I L1 Minimum
852	IL1Max=	MVT	I L1 Maximum
853	IL2Min=	MVT	I L2 Minimum
854	IL2Max=	MVT	I L2 Maximum
855	IL3Min=	MVT	I L3 Minimum
856	IL3Max=	MVT	I L3 Maximum
857	I1 Min=	MVT	Positive Sequence Minimum
858	I1 Max=	MVT	Positive Sequence Maximum
859	UL1EMin=	MVT	U L1E Minimum
860	UL1EMax=	MVT	U L1E Maximum
861	UL2EMin=	MVT	U L2E Minimum
862	UL2EMax=	MVT	U L2E Maximum
863	UL3EMin=	MVT	U L3E Minimum
864	UL3EMax=	MVT	U L3E Maximum
865	UL12Min=	MVT	U L12 Minimum
867	UL12Max=	MVT	U L12 Maximum
868	UL23Min=	MVT	U L23 Minimum
869	UL23Max=	MVT	U L23 Maximum
870	UL31Min=	MVT	U L31 Minimum
871	UL31Max=	MVT	U L31 Maximum
874	U1 Min =	MVT	U1 (positive sequence) Voltage Minimum
875	U1 Max =	MVT	U1 (positive sequence) Voltage Maximum
880	SMin=	MVT	Apparent Power Minimum
881	SMax=	MVT	Apparent Power Maximum
882	fMin=	MVT	Frequency Minimum
883	fMax=	MVT	Frequency Maximum
1040	Pmin Forw=	MVT	Active Power Minimum Forward
1041	Pmax Forw=	MVT	Active Power Maximum Forward
1042	Pmin Rev =	MVT	Active Power Minimum Reverse
1043	Pmax Rev =	MVT	Active Power Maximum Reverse
1044	Qmin Forw=	MVT	Reactive Power Minimum Forward
1045	Qmax Forw=	MVT	Reactive Power Maximum Forward
1046	Qmin Rev =	MVT	Reactive Power Minimum Reverse
1047	Qmax Rev =	MVT	Reactive Power Maximum Reverse
1048	PFminForw=	MVT	Power Factor Minimum Forward
1049	PFmaxForw=	MVT	Power Factor Maximum Forward
1050	PFmin Rev=	MVT	Power Factor Minimum Reverse
1051	PFmax Rev=	MVT	Power Factor Maximum Reverse

No.	Information	Type of Information	Comments
10102	3U0min =	MVT	Min. Zero Sequence Voltage 3U0
10103	3U0max =	MVT	Max. Zero Sequence Voltage 3U0

2.24.11 Set Points (Measured Values)

SIPROTEC® 4 devices allow set point limits to be set for some measured and metered values. If during operation a value reaches or exceeds one of these limits, the device generates an alarm which is displayed as an operational indication. This can be configured to LEDs and/or binary outputs, transferred via the interfaces and interconnected in DIGSI® CFC. In addition you can use DIGSI® CFC to configure set points for further measured and metered values and allocate these via the DIGSI® device matrix.

In contrast to the actual protection functions the limit value monitoring function operates in the background; therefore it may not pick up if measured values are changed spontaneously in the event of a fault and if protection functions are picked up. Furthermore, since a message is only issued when the limit value is repeatedly exceeded, the limit value monitoring functions do not react as fast as protection functions trip signals.

2.24.11.1 Limit Value Monitoring

Set points can be set for the following measured and metered values:

- IL1dmd>: Exceeding a preset maximum average value in Phase L1.
- IL2dmd>: Exceeding a preset maximum average value in Phase L2.
- IL3dmd>: Exceeding a preset maximum average value in Phase L3.
- I1dmd>: Exceeding a preset maximum average value of the positive sequence system currents.
- |Pdmd|> : Exceeding a preset maximum average active power.
- |Qdmd|>: Exceeding a preset maximum average reactive power.
- |Sdmd|> : Exceeding a preset maximum average value of the apparent power.
- |cosφ|< Falling below a preset power factor.

2.24.11.2 Information List

No.	Information	Type of Information	Comments
-	IL1dmd>	LV	Upper setting limit for IL1dmd
-	IL2dmd>	LV	Upper setting limit for IL2dmd
-	IL3dmd>	LV	Upper setting limit for IL3dmd
-	I1dmd>	LV	Upper setting limit for I1dmd
-	Pdmd >	LV	Upper setting limit for Pdmd
-	Qdmd >	LV	Upper setting limit for Qdmd
-	Sdmd >	LV	Upper setting limit for Sdmd
-	PF<	LV	Lower setting limit for Power Factor
273	SP. IL1 dmd>	OUT	Set Point Phase L1 dmd>
274	SP. IL2 dmd>	OUT	Set Point Phase L2 dmd>

No.	Information	Type of Information	Comments
275	SP. IL3 dmd>	OUT	Set Point Phase L3 dmd>
276	SP. I1dmd>	OUT	Set Point positive sequence I1dmd>
277	SP. Pdmd >	OUT	Set Point Pdmd >
278	SP. Qdmd >	OUT	Set Point Qdmd >
279	SP. Sdmd >	OUT	Set Point Sdmd >
285	cosφ alarm	OUT	Power factor alarm

2.24.12 Energy

2.24.12.1 Information List

No.	Information	Type of Information	Comments
-	Meter res	IntSP_Ev	Reset meter
888	Wp(puls)	PMV	Pulsed Energy Wp (active)
889	Wq(puls)	PMV	Pulsed Energy Wq (reactive)
916	WpΔ=	-	Increment of active energy
917	WqΔ=	-	Increment of reactive energy
924	Wp+=	MVMV	Wp Forward
925	Wq+=	MVMV	Wq Forward
928	Wp-=	MVMV	Wp Reverse
929	Wq-=	MVMV	Wq Reverse

2.25 Command Processing

A control command process is integrated in the SIPROTEC® 4 7SD5 to coordinate the operation of circuit breakers and other equipment in the power system. Control commands can originate from four command sources:

- Local operation using the keypad on the local user interface of the device,
- Operation using DIGSI®,
- Remote operation via network control center or substation controller (e.g. SICAM®),
- Automatic functions (e.g. using a binary inputs, CFC).

The number of switchgear devices that can be controlled is basically limited by the number of available and required binary inputs and outputs. For the output of control commands it has to be ensured that all the required binary inputs and outputs are configured and provided with the correct properties.

If specific interlocking conditions are needed for the execution of commands, the user can program the device with bay interlocking by means of the user-defined logic functions (CFC). The interlocking conditions of the system can be injected via the system interface and must be allocated accordingly.

The procedure for switching resources is described in the SIPROTEC® 4 System Description under Control of Switchgear.

2.25.1 Control Authorization

2.25.1.1 Command Types

Commands to the System	This type of commands are directly output to the switchgear to change their process state: • Commands for the operation of circuit breakers (asynchronous; or synchronized through integration of the synchronism check and closing control function) as well as commands for the control of isolators and earth switches. • Step commands, e.g. for raising and lowering transformer taps, • Setpoint commands with configurable time settings, e.g. to control Petersen coils.
Device-internal Commands	These commands do not directly operate binary outputs. They serve for initiating internal functions, communicating the detection of status changes to the device or for acknowledging them. • Manual override commands for „manual update“ of information on process-dependent objects such as annunciations and switching states, e.g. if the communication with the process is interrupted. Manually overridden objects are marked as such in the information status and can be displayed accordingly. • Flagging commands (for „setting“) the data value of internal objects, e.g. switching authority (remote/local), parameter switchovers, transmission blockages and deletion and presetting of metered values.

- Acknowledgment and resetting commands for setting and resetting internal buffers or data stocks.
- Information status commands to set/delete the additional „Information Status“ item of a process object, such as
 - Acquisition blocking,
 - Output blocking.

2.25.1.2 Sequence in the Command Path

Security mechanisms in the command path ensure that a switch command can be carried out only if the test of previously established criteria has been successfully completed. Additionally, user-defined interlocking conditions can be configured separately for each device. The actual execution of the command is also monitored after its release. The entire sequence of a command is described briefly in the following.

Checking a Command

Please observe the following:

- Command entry, e.g. using the keypad on the local user interface of the device
 - Check password → access rights;
 - Check switching mode (interlocking activated/deactivated) → selection of deactivated interlocking status.
- User configurable interlocking checks:
 - Switching authority;
 - Device position check (set vs. actual comparison);
 - Zone controlled / bay interlocking (logic using CFC);
 - System interlocking (centrally via SICAM);
 - Double operation (interlocking against parallel switching operation);
 - Protection blocking (blocking of switching operations by protective functions);
 - Check (synchronism check before a close command).
- Fixed commands:
 - Internal process time (software watch dog which checks the time for processing the control action between initiation of the control and final close of the relay contact);
 - Configuration in process (if setting modification is in process, commands are rejected or delayed);
 - Equipment not present at output (if controllable equipment is not assigned to a binary output, then the command is rejected);
 - Output block (if an output block has been programmed for the circuit breaker, and is active at the moment the command is processed, then the command is rejected);
 - Component hardware malfunction;

- Command in progress (only one command can be processed at a time for each circuit breaker or switch);
- 1-of-n check (for multiple allocations such as common contact relays it is checked if a command procedure was already initiated for the output relays concerned).

Command Execution Monitoring

The following is monitored:

- Interruption of a command because of a cancel command,
- Running time monitor (feedback monitoring time).

2.25.1.3 Switchgear Interlocking

Interlocking can be executed by the user-defined logic (CFC). System interlocking checks in a SICAM®/SIPROTEC® system are usually categorized as follows:

- System interlocking checked by a central control system (for interbay interlocking),
- Zone controlled / bay interlocking checked in the bay device (for the feeder).

System interlocking is based on the process replica of the master device Zone controlled / bay interlocking relies on the object database (feedback information) of the bay unit (here the SIPROTEC® 4 relay) as was determined during configuration (see SIPROTEC® 4 System Description).

The extent of the interlocking checks is determined by the configuration and interlocking logic of the relay.

Switching objects that require system interlocking in a central control system are assigned to a specific parameter inside the bay unit (via configuration matrix).

For all commands, operation with interlocking (normal mode) or without interlocking (test mode) can be selected:

- For local commands by reprogramming the settings with password check,
- For automatic commands, via command processing by CFC and Deactivated Interlocking Recognition,
- For local / remote commands, using an additional interlocking disable command via PROFIBUS.

Interlocked/Non-interlocked Switching

The configurable command checks in the SIPROTEC® 4 devices are also called „standard interlocking“. These checks can be activated using DIGSI® (interlocked switching/tagging) or deactivated (non-interlocked).

De-interlocked or non-interlocked switching means that the configured interlock conditions are not tested.

Interlocked switching means that all configured interlocking conditions are checked within the command processing. If a condition could not be fulfilled, the command will be rejected by an indication with a minus added to it, e.g. „CO–“, followed by an operation response information. The command is rejected if a synchronism check is carried out before closing and the conditions for synchronism are not fulfilled. Table 2-24 shows some types of commands and indications. For the device the indications designated with *) are displayed in the event logs, for DIGSI® they appear in spontaneous indications.

Table 2-24 Command types and corresponding indications

Type of Command	Control	Cause	Indication
Control issued	Switching	CO	CO+/-
Manual tagging (positive / negative)	Manual tagging	MT	MT+/-
Information state command, Input blocking	Input blocking	ST	ST+/- *)
Information state command, Output blocking	Output blocking	ST	ST+/- *)
Cancel command	Cancel	CA	CA+/-

The plus sign indicated in the indication is a confirmation of the command execution: The command output has a positive result, as expected. A minus sign means a negative, i.e. an unexpected result; the command was rejected. Figure 2-188 shows an example in the operational indications command and feedback of a positively run switching action of the circuit breaker.

The check of interlocking can be programmed separately for all switching devices and tags that were set with a tagging command. Other internal commands such as overriding or abort are not tested, i.e. are executed independently of the interlockings.

EVENT LOG	
19.06.01 11:52:05,625	Q0 CO+ Close
19.06.01 11:52:06,134	Q0 FB+ Close

Figure 2-188 Example of an operational indication for switching circuit breaker 52

Standard Interlocking

The standard interlocking includes the checks for each switchgear which were set during the configuration of inputs and outputs, see SIPROTEC® 4 System Description.

An overview for processing the interlocking conditions in the relay is shown in Figure 2-189.




Figure 2-189 Standard interlockings

1) Source of Command REMOTE includes LOCAL.

LOCAL Command using substation controller

REMOTE Command via telecontrol station to power system management and from power system management to the device

The display shows the configured interlocking reasons. They are marked by letters explained in Table 2-25.

Table 2-25 Interlocking Commands

Interlocking Commands	Command	Display
Switching Authority	L	L
System Interlocking	S	S
Bay Interlocking	Z	Z
SET = ACTUAL (switch direction check)	P	P
Protection Blockage	B	B

Figure 2-190 shows all interlocking conditions (which usually appear in the display of the device) for three switchgear items with the relevant abbreviations explained in Table 2-25. All parametrized interlocking conditions are shown.

Interlocking	01/03

Q0 Close/Open S - Z P B	
Q1 Close/Open S - Z P B	
Q8 Close/Open S - Z P B	

Figure 2-190 Example of configured interlocking conditions

Control Logic via CFC

For the bay interlocking, an enabling logic can be structured using the CFC. Via specific release conditions the information „released“ or „bay interlocked“ are available, e.g. object „52 Close“ and „52 Open“ with the data values: ON / OFF).

2.25.1.4 Information List

No.	Information	Type of Information	Comments
-	ModeREMOTE	IntSP	Controlmode REMOTE
-	Cntrl Auth	IntSP	Control Authority
-	ModeLOCAL	IntSP	Controlmode LOCAL

2.25.2 Control Device**2.25.2.1 Information List**

No.	Information	Type of Information	Comments
-	Breaker	CF_D12	Breaker
-	Breaker	DP	Breaker
-	Disc.Swit.	CF_D2	Disconnect Switch
-	Disc.Swit.	DP	Disconnect Switch
-	EarthSwit	CF_D2	Earth Switch
-	EarthSwit	DP	Earth Switch
-	52 Open	IntSP	Interlocking: 52 Open
-	52 Close	IntSP	Interlocking: 52 Close
-	Disc.Open	IntSP	Interlocking: Disconnect switch Open
-	Disc.Close	IntSP	Interlocking: Disconnect switch Close
-	E Sw Open	IntSP	Interlocking: Earth switch Open
-	E Sw Cl.	IntSP	Interlocking: Earth switch Close
-	Q2 Op/Cl	CF_D2	Q2 Open/Close
-	Q2 Op/Cl	DP	Q2 Open/Close
-	Q9 Op/Cl	CF_D2	Q9 Open/Close
-	Q9 Op/Cl	DP	Q9 Open/Close
-	Fan ON/OFF	CF_D2	Fan ON/OFF
-	Fan ON/OFF	DP	Fan ON/OFF

2.25.3 Process Data

During the processing of commands, independently of the further allocation and processing of indications, command and process feedbacks are sent to the indication processing. These indications contain information on the cause. With the corresponding allocation (configuration) these indications are entered in the event log, thus serving as a report.

A listing of possible operational indications and their meaning, as well as the command types needed for tripping and closing the switchgear or for raising and lowering of transformer taps and detailed information are described in the SIPROTEC® 4 System Description.

2.25.3.1 Method of Operation

Acknowledgement of Commands to the Device Front

All indications with the source of command LOCAL are transformed into a corresponding response and shown in the display of the device.

Acknowledgement of Commands to Local/Remote/DIGSI

The acknowledgement of indications which relate to commands with the origin "Command Issued = Local/ Remote/DIGSI" are sent back to the initiating point independent of the routing (configuration on the serial digital interface).

The acknowledgement of commands is therefore not executed by a response indication as it is done with the local command but by ordinary command and feedback information recording.

Feedback Monitoring

Command processing time monitors all commands with feedback. Parallel to the command, a monitoring time period (command runtime monitoring) is started which checks whether the switchgear has achieved the desired final state within this period. The monitoring time is stopped as soon as the feedback information arrives. If no feedback information arrives, a response „Time Limit Expired“ appears and the process is terminated.

Commands and their feedbacks are also recorded as operational indications. Normally the execution of a command is terminated as soon as the feedback information (FB+) of the relevant switchgear arrives or, in case of commands without process feedback information, the command output resets.

In the feedback, the plus sign means that a command has been positively completed. The command was as expected, in other words positive. The "minus" is a negative confirmation and means that the command was not executed as expected.

Command Output / Switching Relays

The command types needed for tripping and closing of the switchgear or for raising and lowering of transformer taps have been defined during the configuration, see also SIPROTEC® 4 System Description.

2.25.3.2 Information List

No.	Information	Type of Information	Comments
-	>Door open	SP	>Cabinet door open
-	>CB wait	SP	>CB waiting for Spring charged

No.	Information	Type of Information	Comments
-	>Err Mot U	SP	>Error Motor Voltage
-	>ErrCntrlU	SP	>Error Control Voltage
-	>SF6-Loss	SP	>SF6-Loss
-	>Err Meter	SP	>Error Meter
-	>Tx Temp.	SP	>Transformer Temperature
-	>Tx Danger	SP	>Transformer Danger

2.25.4 Protocol

2.25.4.1 Information List

No.	Information	Type of Information	Comments
-	SysIntErr.	IntSP	Error Systeminterface

www.ElectricalPartManuals.com

Mounting and Commissioning

3

This chapter is intended for experienced commissioning staff. The staff must be familiar with the commissioning of protection and control systems, with the management of power systems and with the relevant safety rules and guidelines. Under certain circumstances particular power system adaptations of the hardware are necessary. Some of the primary tests require the protected line or equipment to carry load.

3.1	Mounting and Connections	446
3.2	Checking Connections	471
3.3	Commissioning	477
3.4	Final Preparation of the Device	516

3.1 Mounting and Connections

General



WARNING!

Warning of improper transport, storage, installation, and application of the device.

Non-observance can result in death, personal injury or substantial property damage.

Trouble free and safe use of this device depends on proper transport, storage, installation, and application of the device according to the warnings in this instruction manual.

Of particular importance are the general installation and safety regulations for work in a high-voltage environment (for example, VDE, IEC, EN, DIN, or other national and international regulations). These regulations must be observed.

3.1.1 Configuration Information

Prerequisites

For installation and connections the following conditions must be met:

The nominal device data has been tested as recommended in the SIPROTEC® 4 System Description and their compliance with these data is verified with the Power System Data.

Connection Variants

General Diagrams are shown in Appendix A.2. Connection examples for current transformer and voltage transformer circuits are provided in Appendix A.3. It must be checked that the setting of the **P.System Data 1**, Section 2.1.2.1, was made in accordance to the device connections.

Currents

In Appendix A.3 examples for the possibilities of the current transformer connections in dependence on network conditions are displayed.

For normal connection, address 220 **I4 transformer = In prot. line** must be set and furthermore, address 221 **I4/Iph CT = 1.000**.

When using separate earth current transformers, address 220 **I4 transformer = In prot. line** must be set. The factor 221 **I4/Iph CT** may deviate from **1**. For calculation hints, please refer to Section 2.1.2.1 at „Current Transformer Connection“. Please observe that 2-CT-connection is permitted only for isolated or compensated networks.

Furthermore, examples for the connection of the earth current of a parallel line (for parallel line compensation) are displayed. Address 220 **I4 transformer** must be set **In paral. line** here. The factor 221 **I4/Iph CT** may deviate from **1**. For calculation hints, please refer to Section 2.1.2.1.

The other figures show examples for the connection of the earth current of a source transformer. Address 220 **I4 transformer** must be set **IY starpoint** here. Hints regarding the factor 221 **I4/Iph CT** can also be found in Section 2.1.2.1.

Voltages

Connection examples for current and voltage transformer circuits are provided in Appendix A.3.

For normal connection the 4th voltage measuring input is not used. Correspondingly, the following setting must be made in address 210 **U4 transformer = Not connected**. Nevertheless, the factor in address 211 **Uph / Udelta** must be set to **1.73** (this factor is used internally for the conversion of measured and fault recording values).

For additional connection of an e-n-winding of a set of voltage transformers, address 210 must be set to **U4 transformer = Udelta transf.**. The factor address 211 **Uph / Udelta** depends on the transformation ratio of the e-n-winding. Instructions - see Section 2.1.2.1 at „Voltage Transformer Connection“.

In further connection examples also the e-n winding of a set of voltage transformers is connected, in this case, however of a central set of transformers at a busbar. For more information refer to the previous paragraph. Observe that 2-CT-connection is permitted only for isolated or compensated networks.

Further figures show examples for the additional connection of a different voltage, in this case the busbar voltage (e.g. for the voltage protection or synchronism check). For voltage protection address 210 **U4 transformer = Ux transformer** must be set, for the synchronism check **U4 transformer = Usync transf.**. The factor address 215 **U-line / Usync** is unequal to **1**, only if the feeder side VT and busbar side VT have a different transformation ratio. The factor in address 211 **Uph / Udelta** must however be set to **1.73** (this factor is used internally for the conversion of measured and fault recording values).

If there is a power transformer between the set of busbar and the feeder VT's, the phase displacement of the voltages caused by the transformer must be considered for the synchronism check (if used). In this case, also check the addresses 212 **Usync connect.**, 214 φ **Usync-Uline** and 215 **U-line / Usync**. You will find detailed hints and an example in Section 2.1.2.1 under „Voltage Transformer Connection“.

Binary Inputs and Outputs

The connections to the system depend on the possible allocation of the binary inputs and outputs, i.e. how they are assigned to the system. The presettings of the device are listed in Tables A.4 in the Appendix. Check also that the labelings on the front correspond to the allocated indication functions.

It is also very important that the feedback components (auxiliary contacts) of the circuit breaker monitored are connected to the correct binary inputs which are assigned for this purpose (if used).

Changing Setting Groups

If binary inputs are used to change setting groups, please observe the following:

- To enable the control of 4 possible setting groups 2 binary inputs have to be available. One binary input must be set for „>Set Group Bit0“, the other input for „>Set Group Bit1“.
- To control two setting groups, one binary input set for „>Set Group Bit0“ is sufficient since the binary input „>Set Group Bit1“, which is not assigned, is considered to be not controlled.
- The status of the signals controlling the binary inputs to activate a particular setting group must remain constant as long as that particular group is to remain active.

The following Table shows the relationship between binary inputs and the setting groups A to D. Principal connection diagrams for the two binary inputs are illustrated in the following Figure 3-1. The Figure illustrates an example in which both Set Group

Bits 0 and 1 are configured to be controlled (actuated) when the associated binary input is energized (high).

Where:

No = not energized

Yes = energized

Table 3-1 Changing setting groups with binary inputs

Binary Input		Active Group
>Set Group Bit 0	>Set Group Bit 1	
No	No	Group A
Yes	No	Group B
No	Yes	Group C
Yes	Yes	Group D




Figure 3-1 Connection diagram (example) for setting group switching with binary inputs

Trip Circuit Supervision

It must be noted that two binary inputs or one binary input and one substitute resistor R must be connected in series. The pickup threshold of the binary inputs must therefore be substantially below half the rated control DC voltage.

If two binary inputs are used for the trip circuit supervision, these binary inputs must be isolated, i.e. not be communed with each other or with another binary input.

If one binary input is used, a bypass resistor R must be used (refer to Figure 3-2). This resistor R is connected in series with the second circuit breaker auxiliary contact (Aux2), to also allow the detection of a trip circuit failure when the circuit breaker auxiliary contact 1 (Aux1) is open, and the command relay contact has reset. The value of this resistor must be such that in the circuit breaker open condition (therefore Aux1 is open and Aux2 is closed) the circuit breaker trip coil (TC) is no longer picked up and binary input (BI1) is still picked up if the command relay contact is open.

This results in an upper limit for the resistance dimension, $R_{\max}$, and a lower limit $R_{\min}$, from which the optimal value of the arithmetic mean R should be selected:

In order that the minimum voltage for controlling the binary input is ensured, $R_{\max}$ is derived as:

To keep the circuit breaker trip coil energized in the above case, $R_{\min}$ is derived as:

I_{BI} (HIGH)	Constant current with activated BI (= 1.8 mA)
$U_{BI \min}$	Minimum control voltage for BI 19 V for delivery setting for nominal voltages of 24/48/60/250 V; 88 V for delivery setting for nominal voltages of 110/125/220/250 V; 176 V for delivery setting for nominal voltages of 220/250 V
U_{SP}	Control voltage for trip circuit
R_{CBTC}	DC resistance of circuit breaker trip coil
U_{CBTC} (LOW)	Maximum voltage on the circuit breaker trip coil that does not lead to tripping

7SD5 Manual
C53000-G1176-C169-1

For the power consumption of the resistance:

$$P_R = I^2 \cdot R = \left(\frac{U_{CTR}}{R + R_{TC}} \right)^2 \cdot R$$

Example:

$I_{BI (HIGH)}$	1.8 mA (from SIPROTEC® 4 7SD5)
$U_{BI min}$	19 V for delivery setting for nominal voltages of 24/48/60 V (from the 7SD5); 88 V for delivery setting for nominal voltages of 110/125/220/250 V (from 7SD5);
U_{CTR}	110 V (system / trip circuit)
R_{TC}	500 Ω (system / trip circuit)
$U_{TC (LOW)}$	2 V (system / trip circuit)

$$R_{max} = \left(\frac{110 \text{ V} - 19 \text{ V}}{1.8 \text{ mA}} \right) - 500 \text{ } \Omega = 50.1 \text{ k}\Omega$$

$$R_{min} = 500 \text{ } \Omega \cdot \left(\frac{110 \text{ V} - 2 \text{ V}}{2 \text{ V}} \right) = 27 \text{ k}\Omega$$

$$R = \frac{R_{max} + R_{min}}{2} = 38.6 \text{ k}\Omega$$

The closest standard value of 39 k Ω is selected; the power is:

$$P_R = \left(\frac{110 \text{ V}}{39 \text{ k}\Omega + 0.5 \text{ k}\Omega} \right)^2 \cdot 39 \text{ k}\Omega \geq 0.3 \text{ W}$$

Pilot Wires for Protection

If the distance protection is supplemented with the transmission scheme **Teleprot. Dist. = Pilot wire comp** (address 121), it has to be secured that the quiescent state loop is supplied with enough auxiliary voltage. The function itself is described in section 2.7.

Please take note that both binary inputs are interconnected and connected in series with the resistor of the pilot wires. Therefore the loop voltage must not be too low and the pickup voltage of the binary inputs must not be too high. In general, the lowest threshold (19 V) must be selected for the auxiliary voltages of 60 V to 125 V, the threshold of 88 V is selected for voltages of 220 V to 250 V.

Due to the low current consumption of the binary inputs it may be necessary to additionally burden the pilot wire loop with an external shunt connected resistor so that the binary inputs are not blocked by the charge of the pilot wire after an interruption of the loop. As an alternative, auxiliary relay combinations (e.g. 7PA5210-2A) can be introduced.

Pilot wires used as cable connections between stations must always be checked on their effect on high voltage. The pilot wires of the pilot cables must stand external strains.

The worst electrical fault that may occur to the pilot cables is generated in the pilot wire system by an earth fault. The short-circuit current induces a longitudinal voltage into the pilot wires lying parallel to the high voltage line. The induced voltage can be

reduced by well-conductive cable jackets and by armouring (low reduction factor, for both high voltage cable and pilot cables).

The induced voltage can be calculated with the following formula:

$$U_i = 2 \pi f \cdot M \cdot I_{k1} \cdot l \cdot r_1 \cdot r_2$$

with

U_i	= induced longitudinal voltage in V,
f	= nominal frequency in Hz,
M	= mutual inductance between power line and pilot wires in mH/km,
I_{k1}	= maximum earth fault current via power line in kA,
l	= distance between energy line and pilot wires in km,
r_1	= reduction factor of power cable ($r_1 = 1$ for overhead lines),
r_2	= reduction factor of pilot wire cable.

The calculated induced voltage should neither exceed the 60% rate of the test voltage of the pilot wires nor of the device connections (binary inputs and outputs). Since the latter were produced for a test voltage of 2kV, only a maximum induced longitudinal voltage of 1.2kV is allowed.

3.1.2 Hardware Modifications

3.1.2.1 General

A subsequent adaptation of hardware to the power system conditions can be necessary for example with regard to the control voltage for binary inputs or termination of bus-capable interfaces. Follow the procedure described in this section, whenever hardware modifications are carried out.

Auxiliary Voltage

There are different power supply voltage ranges for the auxiliary voltage (refer to the Ordering Information in Appendix A.1). The power supplies of the variants for 60/110/125 VDC and 110/125/220 VDC, 115 VAC are largely interchangeable by modifying the position of the jumpers. The assignment of these jumpers to the nominal voltage ranges and the spatial layout on the PCB are described further below at „Input/Output Board C-I/O-1 and C-I/O-10“. When the relays are delivered, these jumpers are set according to the name-plate sticker. Generally, they need not be altered.

Life Contact

The life contact of the device is a changeover contact from which either the NC contact or the NO contact can be connected to the device terminals via a plug-in jumper (X40). The assignment of the jumper to the contact type and the spatial arrangement of the jumper are described in the following section under the margin heading „Input/Output Board(s) C-I/O-1 and C-I/O-10“.

Nominal Currents

The input transformers of the device are set to a nominal current of 1 A or 5 A with jumpers. Jumper settings determine the rating of the current input transducers of the device. The assignments of the jumpers to the nominal current and the spatial layout of the jumpers are described in the following section under the margin heading „Input/Output Board C-I/O -2“.



Note

If nominal current ratings are changed exceptionally, then the new ratings must be registered in addresses 206 **CT SECONDARY** in the power system data (see Section 2.1.2.1).

Control Voltage for BinaryInputs

When the device is delivered the binary inputs are set to operate with a voltage that corresponds to the nominal voltage of the power supply. If the nominal values differ from the power system control voltage, it may be necessary to change the switching threshold of the binary inputs.

Jumper positions can be changed to adjust the pickup voltage of a binary input. The assignments of the jumpers to the binary inputs and the spatial arrangement of the jumpers are described in the following section under the margin heading „Input/Output Board(s) C-I/O-1 and C-I/O-10“.



Note

If binary inputs are used for trip circuit monitoring, note that two binary inputs (or a binary input and an equivalent resistance) are connected in series. The switching threshold must lie clearly below halben of the nominal control voltage.

Contact Mode for BinaryOutputs

Input/output boards can have relays that are equipped with changeover contacts. For this it is necessary to alter a jumper. The following sections at „Switching Elements on Printed Circuit Boards“ explain for which relays on which boards this applies.

Exchanging Interfaces

Only serial interfaces of devices for panel flush and cubicle mounting as well as of mounting devices with detached operator panel are replaceable. In the following section under margin heading „Exchanging Interface Modules“ it is described which interfaces can be exchanged, and how this is done.

Termination of SerialInterfaces

If the device is equipped with a serial RS485 interface or PROFIBUS, they must be terminated with resistors at the last device on the bus to ensure reliable data transmission. For this purpose, terminating resistors are provided on the interface modules that can be connected with jumpers. The spatial arrangement of the jumpers on the interface board is described in the following sections under the margin headings „RS485 Interface“ and „PROFIBUS Interface“.

The terminating resistors are disabled on delivery.

Spare Parts

Spare parts can be the buffer battery that provides for storage of the data in the battery-buffered RAM when the voltage supply fails, and the miniature fuse of the internal power supply. Their spatial arrangement is shown in the figure of the processor board. The ratings of the fuse are printed on the board next to the fuse itself. When replacing the fuse, please observe the guidelines given in the SIPROTEC® 4 System Manual in the chapter „Maintenance“ and „Corrective Action / Repairs“.

3.1.2.2 Disassembly

Work on the Printed Circuit Boards



Note

It is assumed for the following steps that the device is not operative.



Caution!**Caution when changing jumper settings that affect nominal values of the device:**

As a consequence, the ordering number (MLFB) and the ratings that are stated on the nameplate do no longer match the actual device properties.

If such changes are necessary, the changes should be clearly and fully noted on the device. Self-adhesive labels are provided for this which can be used as supplementary nameplates.

To perform work on the printed circuit boards, such as checking or moving switching elements or exchanging modules, proceed as follows:

- Prepare your workplace: prepare a suitable underlay for electrostatically sensitive devices (ESD). Also the following tools are required:
 - screwdriver with a 5 to 6 mm wide tip,
 - a crosstip screwdriver for Pz size 1,
 - a 5 mm socket wrench.
- Unfasten the screw-posts of the D-subminiature connectors on the back panel at location „A“. This activity does not apply if the device is for surface mounting.
- If the device has more communication interfaces on the rear beside the interface at location „A“, the screws located diagonally to the interfaces must be removed. This activity does not apply if the device is designed for surface mounting.
- Remove the covers on the front panel and loosen the screws which can then be accessed.
- Remove the front panel and tilt it to the side.

Work on the Plug Connectors



Caution!

Mind electrostatic discharges:

Non-observance can result in minor personal injury or property damage.

When handling plug connectors, electrostatic discharges may emerge. These must be avoided by previously touching an earthed metal surface.

Do not plug or unplug interface connectors under voltage!

The assembly of the boards for the housing size $1\frac{1}{2}$ is shown in Figure 3-3 and for the housing size $1\frac{1}{4}$ in Figure 3-4.

- Disconnect the plug connector of the ribbon cable between the front cover and the processor board C-CPU-1 (No. 1) at the front cover side. For this purpose push apart the top and bottom latches at the plug connector so that the ribbon cable connector is pressed out.
- Disconnect the ribbon cables between the processor board C-CPU-1 (No. 1 in Figure 3-3 or 3-4) and the input/output board I/O (according to order variant No. 2 to No. 3 in Figure 3-3 or 3-4).
- Remove the boards and place them on a surface suitable for electrostatically sensitive devices (ESD). In the case of the device variant for panel surface mounting, please be aware of the fact a certain amount of force is required in order to remove the C-CPU-1 module due to the existing plug connectors.
- Check the jumpers according to Figures 3-5 to 3-11 and the following information, and as the case may be change or remove them.




Figure 3-3 Front view with housing size $1\frac{1}{2}$ after removal of the front cover (simplified and scaled down)




Figure 3-4 Front view with housing size $1\frac{1}{1}$ after removal of the front cover (simplified and scaled down)

3.1.2.3 Switching Elements on Printed Circuit Boards

Input/Output Board C-I/O-1 and C-I/O-10

The layout of the PCB for the input/output board C-I/O-1 is shown in Figure 3-5, the PCB for the input/output board C-I/O-10 is shown in Figure 3-6.

The power supply is situated

- On the input/output board C-I/O-1 (No. 2 in Figure 3-3, slot 19) for housing size $1\frac{1}{2}$,
- On the input/output board C-I/O-1 (No. 2 in Figure 3-4, slot 33 left) for housing size $1\frac{1}{1}$,

The preset nominal voltage of the integrated power supply is checked according to Table 3-2, the quiescent state of the life contact is checked according to Table 3-3.

Table 3-2 Jumper setting for the nominal voltage of the integrated **Power Supply** on the input/output board C-I/O-1

Jumper	Nominal Voltage		
	60/110/125 VDC	110/125/220/250 VDC 115 VAC	24/48 VDC
X51	1-2	2-3	Jumpers X51 to X53 are not used
X52	1-2 and 3-4	2-3	
X53	1-2	2-3	

Jumper	Nominal Voltage		
	60/110/125 VDC	110/125/220/250 VDC 115 VAC	24/48 VDC
	Interchangeable		Cannot be changed
Fuse	T2H250V		T4H250V

Table 3-3 Jumper settings of the **Life Contact** on the input/output board C-I/O-1

Jumper	Open in Quiescent State (NO)	Closed in Quiescent State (NC)	Factory Setting
X40	1-2	2-3	2-3

Depending on the device version the contacts of some binary outputs can be changed from normally open to normally closed (see Appendix, under Section A.2).

- In versions 7SD5***-***D/H/M** (housing size $\frac{1}{1}$ with 32 binary outputs) this is valid for the binary outputs BO16 and BO24 (Figure 3-4, slot 19 left and right);
- In versions 7SD5***-***C/G/L** (housing size $\frac{1}{1}$ with 24 binary outputs) this is valid for the binary output BO16 (Figure 3-4, slot 19 right);
- In versions 7SD5***-***P/R/T** (housing size $\frac{1}{1}$ with 32 binary outputs and command acceleration) this is valid for the binary output BO24 (Figure 3-4, slot 19 left).

Table 3-4 shows the jumper settings for the contact mode.

Table 3-4 Jumper settings for contact mode of the binary outputs BO16 and BO24 on the input/output board C-I/O-1

Device 7SD5***-*	Printed Circuit Board	For	Jumper	Open in Quiescent State (NO)	Closed in Quiescent State (NC)	Factory Setting
D/H/M	Slot 19 left side	BO 16	X40	1-2	2-3	1-2
	Slot 19 right side	BO 24	X40	1-2	2-3	1-2
C/G/L	Slot 19 right side	BO 16	X40	1-2	2-3	1-2
P/R/T	Slot 19 left side	BO 24	X40	1-2	2-3	1-2




Figure 3-5 Input/output board C-I/O-1 with representation of the jumper settings required for the board configuration




Figure 3-6 Input/output board C-I/O-10 with representation of the jumper settings required for the board configuration

Checking the control voltages of the binary inputs:

BI1 to BI8 (with housing size $1/2$) according to Table3-5.

BI1 to BI24 (with housing size $1/4$) according to Table3-6.

Table 3-5 Jumper settings of the **Control Voltages** of the binary inputs BI1 to BI8 on the input/output board C-I/O-1 with housing size $1\frac{1}{2}$

binary inputs slot 19	Jumper	19 V Threshold ¹⁾	88 V Threshold ²⁾	176 V Threshold ³⁾
BI1	X21/X22	L	M	H
BI2	X23/X24	L	M	H
BI3	X25/X26	L	M	H
BI4	X27/X28	L	M	H
BI5	X29/X30	L	M	H
BI6	X31/X32	L	M	H
BI7	X33/X34	L	M	H
BI8	X35/X36	L	M	H

¹⁾ Factory settings for devices with power supply voltages 24 VDC to 125 VDC

²⁾ Factory settings for devices with power supply voltages of 110 VDC to 250 VDC and 115 VAC

³⁾ Factory settings for devices with power supply voltages of 220 VDC to 250 VDC and 115 VAC

Table 3-6 Jumper settings of the **Control Voltages** of the binary inputs BI1 to BI24 on the input/output board C-I/O-1 or C-I/O-10 with housing size $1\frac{1}{4}$

Binary inputs			Jumper	19 V Threshold ¹⁾	88 V Threshold ²⁾	176 V Threshold ³⁾
Slot 33 left side	Slot 19 right side	Slot 19 left side				
BI1	BI9	BI17	X21/X22	L	M	H
BI2	BI10	BI18	X23/X24	L	M	H
BI3	BI11	BI19	X25/X26	L	M	H
BI4	BI12	BI20	X27/X28	L	M	H
BI5	BI13	BI21	X29/X30	L	M	H
BI6	BI14	BI22	X31/X32	L	M	H
BI7	BI15	BI23	X33/X34	L	M	H
BI8	BI16	BI24	X35/X36	L	M	H

¹⁾ Factory settings for devices with power supply voltages 24 VDC to 125 VDC

²⁾ Factory settings for devices with power supply voltages of 110 VDC to 250 VDC and 115 VAC

³⁾ Factory settings for devices with power supply voltages of 220 VDC to 250 VDC and 115 VAC

Table 3-7 Jumper settings of the **Board Address** of the input/output board C-I/O-1 or C-I/O-10 with housing size $1\frac{1}{4}$

Jumper	Mounting location	
	Slot 19 left side	Slot 19 right side
X71	H	L
X72	L	L
X73	H	H

Board C-I/O-2

The layout of the PCB for the C-I/O-2 board is shown in Figure 3-7.




Figure 3-7 Input/output board C-I/O-2 with representation of jumper settings required for checking configuration settings

The contact of the relay for the binary output BO13 can be configured as NO or NC contact (see also General Diagrams in Appendix A, Section A.2):

with housing size $1\frac{1}{2}$: No. 3 in Figure 3-3, slot 33,

with housing size $1\frac{1}{4}$: No. 3 in Figure 3-4, slot 33 right.

Table 3-8 Jumper setting for contact type of binary output BO13

Jumper	Open in Quiescent State (NO)	Closed in Quiescent State (NC)	Factory Setting
X41	1-2	2-3	1-2

The set nominal current of the current input transformers are checked on the input/output board C-I/O-2. All jumpers must be set for one nominal current, i.e. one jumper (X61 to X64) for each input transformer and additionally the common jumper X60. **But:** In the version with sensitive earth fault current input (input transformer T8) there is no jumper X64.

Jumpers X71, X72 and X73 on the input/output board C-I/O-2 are used to set the bus address and must not be changed. The following table lists the jumper presettings.

Mounting location:

with housing size $1\frac{1}{2}$: No. 3 in Figure 3-3, slot 33,

with housing size $1\frac{1}{4}$: No. 3 in Figure 3-4, slot 33 right.

Table 3-9 Jumper settings of **Board Address** of the input/output board C-I/O-2

Jumper	Factory Setting
X71	1-2 (H)
X72	1-2 (H)
X73	2-3 (L)

3.1.2.4 Interface Modules

Exchanging Interface Modules

The interface modules are located on the processor board C-CPU-1 (No. 1 in Figure 3-3 and 3-4).




Figure 3-8 Processor board C-CPU-1 with interface modules (maximum configuration)

Note

Surface-mounted devices with fibre optics connection have their fibre optics module fitted in the inclined housing on the case bottom. The CPU module has there instead an RS232 interface module which communicates electrically with the FO module in the inclined housing.

Please note the following:

- The interface modules can only be replaced in devices for panel flush mounting and cubicle mounting. Interface modules for devices with surface mounting housing must be retrofitted in our manufacturing centre.
- Use only interface modules that can be ordered ex-factory via the ordering code (see also Appendix, Section A.1).
- You may have to ensure the termination of the interfaces featuring bus capability according to the margin heading „RS485 Interface“.

Table 3-10 Exchangeable interface modules

Interface	Mounting Location / Port	Exchange Module
System interface	B	Only interface modules that can be ordered in our facilities via the ordering code (see also Appendix, Section A.1).
Service interface	C	RS232
		RS485
		FO 820 nm
Protection data interface 1	D	FO5 to FO8; FO17 to FO19
Protection data interface 2	E	FO5 to FO8; FO17 to FO19

The ordering numbers of the exchange modules are listed in Appendix A.1).

RS232 Interface

Interface RS232 can be modified to interface RS485 and vice versa (see Figures 3-9 and 3-10).

Figure 3-8 shows the PCB of the C-CPU-1 with the layout of the boards.

The following figure shows the location of the jumpers of interface RS232 on the interface module.

Devices in surface mounting housing with fibre optics connection have their fibre optics module housed in the console housing. The fibre optics module is controlled via an RS232 interface module at the associated CPU interface slot. For this application type the jumpers X12 and X13 on the RS232 module are plugged in position 2-3.




Figure 3-9 Location of the jumpers for configuration of RS232

Terminating resistors are not required for RS232. They are disconnected.

With jumper X11 the flow control which is important for modem communication.

Table 3-11 Jumper setting for **CTS** (Clear To Send, flow control) on the interface module

Jumper	/CTS from Interface RS232	/CTS controlled by /RTS
X11	1-2	2-3 ¹⁾

¹⁾ Default Setting

Jumper Setting 2-3: The connection to the modem is usually carried out with a star coupler or fibre-optic converter. Therefore the modem control signals according to RS232 standard DIN 66020 are not available. Modem signals are not required since communication to SIPROTEC® 4 devices is always carried out in the half duplex mode. Please use the connection cable with order number 7XV5100-4.

Jumper Setting 1-2: This setting makes the modem signals available, i. e. for a direct RS232-connection between the SIPROTEC® 4 device and the modem this setting can be selected optionally. We recommend to use a standard RS232 modem connection cable (converter 9-pin to 25-pin).

Note

For a direct connection to DIGSI® with Interface RS232, jumper X11 must be plugged in position 2-3.

RS485 Interface

The following figure shows the location of the jumpers of interface RS485 on the interface module.

Interface RS485 can be modified to interface RS232 and vice versa, according to Figure 3-9.

Jumper	Terminating Resistors	
	Connected	Disconnected
X3	2-3	1-2 *)
X4	2-3	1-2 *)

*) Default Setting




Figure 3-10 Position of terminating resistors and the plug-in jumpers for configuration of the RS485 interface

Interface PROFIBUS

Jumper	Terminating Resistors	
	Connected	Disconnected
X3	1-2	2-3 *)
X4	1-2	2-3 *)

*) Default Setting




Figure 3-11 Location of the jumpers for configuring the PROFIBUS and DNP 3.0 interface terminating resistors

Termination

Busbar capable interfaces always require a termination at the last device to the bus, i.e. terminating resistors must be connected. With the 7SD5 device, this concerns the variants with RS485 or PROFIBUS interfaces.

The terminating resistors are on the RS485 or PROFIBUS interface module which is located on the processor board C-CPU-1 (No. 1 in Figure 3-3 and 3-4).

Figure 3-8 shows the PCB of the C-CPU-1 with the layout of the modules.

The board with configuration as RS485 interface is shown in Figure 3-10, the module for the PROFIBUS interface in Figure 3-11.

For the configuration of the terminating resistors both jumpers have to be plugged in the same way.

On delivery the jumpers are set so that the terminating resistors are disconnected.

The terminating resistors can also be implemented outside the device (e.g. at the terminal block), see Figure 3-12. In this case, the terminating resistors located on the RS485 or PROFIBUS interface module must be switched off.




Figure 3-12 Termination of the RS485 interface (external)

3.1.2.5 Reassembly

The reassembly of the device is carried out in the following steps:

- Insert the boards carefully into the housing. The mounting locations of the boards are shown in Figures 3-3 and 3-4. For the model of the device designed for surface mounting, use the metal lever to insert the processor board C-CPU-1. Installation is easier with the lever.
- First plug in the plug connectors of the ribbon cable onto the input/output boards I/O and then onto the processor board C-CPU-1. Be careful not to bend connecting pins! Don't use force!
- Connect the plug connectors of the ribbon cable between the processor board C-CPU-1 and the front panel to the front panel plug connector.
- Press plug connector interlocks together.
- Replace the front panel and screw it tightly to the housing.
- Put the covers back on.
- Re-fasten the interfaces on the rear of the device housing. This activity is not necessary if the device is designed for surface mounting.

3.1.3 Mounting

3.1.3.1 Panel Flush Mounting



Depending on the version, the device housing can be $\frac{1}{2}$ or $\frac{1}{1}$. With housing size $\frac{1}{2}$, there are four covers and four holes, as shown in Figure 3-13. There are six covers and six holes for the full housing size $\frac{1}{1}$, as indicated in Figure 3-14.

- Remove the 4 covers at the corners of the front cover, for housing size $\frac{1}{1}$ the two covers located centrally at the top and bottom also have to be removed. The 4 or 6 elongated holes in the mounting bracket are revealed and can be accessed.
- Insert the device into the panel cut-out and fasten it with four or six screws. For dimensions refer to Section 4.25.
- Mount the four or six covers.
- Connect the earth on the rear plate of the device to the protective earth of the panel. Use at least one M4 screw for the device earth. The cross-sectional area of the earth wire must be equal to the cross-sectional area of any other control conductor connected to the device. The cross-section of the earth wire must be at least 2.5 mm².
- Connect the plug terminals and/or the screwed terminals on the rear side of the device according to the wiring diagram of the panel.

When using forked lugs for direct connections or screw terminal, the screws, before having inserted the lugs and wires, must be tightened in such a way that the screw heads are even with the terminal block.

A ring lug must be centred in the connection chamber, in such a way that the screw thread fits in the hole of the lug.

The SIPROTEC® 4 System Description has pertinent information regarding wire size, lugs, bending radii, etc. You will find hints in the short description included in the device.

Figure 3-13 Example of panel flush mounting of a device (housing size $\frac{1}{2}$)Figure 3-14 Example of panel flush mounting of a device (housing size $\frac{1}{4}$)

3.1.3.2 Rack Mounting and Cubicle Mounting

Two mounting rails are required for installing a device into a frame or cabinet. The ordering codes are stated in the Appendix, Section A.1



For the $\frac{1}{2}$ housing size (Figure 3-15), there are four covers and four holes. For the $\frac{1}{1}$ housing size (Figure 3-16) there are six covers and six holes.

- Screw on loosely the two angle brackets in the rack or cabinet, each with four screws.
- Remove the 4 covers at the corners of the front cover, for housing size $\frac{1}{1}$, the two covers located centrally at the top and bottom also have to be removed. The 4 or 6 elongated holes in the mounting bracket are revealed and can be accessed.
- Fasten the device to the mounting brackets with four or six screws.
- Mount the four or six covers.
- Tighten fast the eight screws of the angle brackets in the rack or cabinet.
- Screw down a robust low-ohmic protective earth or station earth to the rear of the device using at least an M4 screw. The cross-sectional area of the earth wire must be equal to the cross-sectional area of any other conductor connected to the device. The cross-section of the earth wire must be at least 2.5 mm².
- Connections use the plug terminals or screw terminals on the rear side of the device in accordance the wiring diagram.

For screw connections with forked lugs or direct connection, before inserting wires the screws must be tightened so that the screw heads are flush with the outer edge of the connection block.

A ring lug must be centred in the connection chamber so that the screw thread fits in the hole of the lug.

The SIPROTEC® 4 System Description has pertinent information regarding wire size, lugs, bending radii, etc. You will find hints in the short description included in the device.

Figure 3-15 Example of rack or cubicle mounting of a device (housing size $1/2$)Figure 3-16 Example of rack or cubicle mounting of a device (housing size $1/1$)

3.1.3.3 Panel Surface Mounting

For mounting proceed as follows:

- Secure the device to the panel with four screws. For dimensions see the Technical Data in Section 4.25.
- Connect the earth of the device to the protective earth of the panel. The cross-sectional area of the earth wire must be equal to the cross-sectional area of any other conductor connected to the device. The cross-section of the earth wire must be at least 2.5 mm².
- Connect solid, low-impedance operational earthing (cross-sectional area ≥ 2.5 mm²) to the earthing surface on the side. Use at least one M4 screw for the device earth.
- Make the connections according to the circuit diagram via the screwed-type terminals. Fibre-optic cables and electrical communication modules are connected at the inclined housings. The SIPROTEC® 4 System Description has pertinent information regarding wire size, lugs, bending radii, etc. You will find hints in the short description included in the device.

3.2 Checking Connections

3.2.1 Checking Data Connections of Serial Interfaces

The tables of the following margin headings list the pin-assignments for the different serial interfaces of the device and the time synchronization interface. The position of the connections can be seen in the following Figure.




Figure 3-17 9-pin D-subminiature female connectors




Figure 3-18 Ethernet connector

Operator Interface

When using the recommended communication cable (see order no. in the Appendix A.1), the correct connection between the SIPROTEC® 4 device and the PC or Laptop is automatically ensured.

Service Interface

Check the data connection if the service interface (Interface C) for communicating with the device is via fix wiring or a modem.

System Interface

For versions equipped with a serial interface to a control center, the user must check the data connection. The visual check of the assignment of the transmission and reception channels is of particular importance. With RS232 and fibre optic interfaces, each connection is dedicated to one transmission direction. Therefore the output of one device must be connected to the input of the other device and vice versa.

With data cables, the connections are designated according to DIN 66020 and ISO 2110:

- TxD = Data Transmit
- RxD = Data Receive
- RTS = Request to Send

- $\overline{\text{CTS}}$ = Clear to Send
- GND = Signal / Chassis Ground

The cable shield is to be earthed at **both** line ends. For extremely EMC-prone environments, the earth may be connected via a separate individually shielded wire pair to improve immunity to interference.

Table 3-12 The assignments of the D-subminiature connector for the various serial interfaces

Pin No.	Operator Interface	RS232	RS485	PROFIBUS FMS, DP Slave, RS485	DNP 3.0 RS 485
1	Shield (with shield ends electrically connected)				
2	RxD	RxD	-	-	-
3	TxD	TxD	A/A' (RxD/TxD-N)	B/B' (RxD/TxD-P)	A
4	-	-	-	CNTRA-(TTL)	RTS (TTL level)
5	GND	GND	C/C' (GND)	C/C' (GND)	GND1
6	-	-	-	+5 V (max. load < 100 mA)	VCC1
7	RTS	RTS	- ¹⁾	-	-
8	CTS	CTS	B/B' (RxD/TxD-P)	A/A' (RxD/TxD-N)	B
9	-	-	-	-	-

¹⁾ Pin 7 also carries the RTS signal with RS232 level when operated as RS485 Interface. Pin 7 must therefore not be connected!

Termination

The RS485 interface is capable of half-duplex service with the signals A/A' and B/B' with a common relative potential C/C' (GND). It is necessary to check that the terminating resistors are connected to the bus only at the last device, and not at other devices on the bus. The jumpers for the terminating resistors are located on the interface module RS485 (see Figure 3-10) or on the PROFIBUS module RS485 or DNP 3.0 RS485 module (see Figure 3-11). Terminating resistors can also be implemented outside the device (e.g. in the plug connectors) as shown in Figure 3-12. In this case, the terminating resistors located on the module must be disabled.

If the bus is extended, make sure again that only terminating resistors at the last device to the bus are switched in.

Time Synchronization Interface

It is optionally possible to process 5V, 12V or 24V time synchronization signals, provided that these are connected to the inputs named in the following table.

Table 3-13 D-subminiature connector assignment of the time synchronization interface

Pin No.	Designation	Signal Significance
1	P24_TSIG	Input 24 V
2	P5_TSIG	Input 5 V
3	M_TSIG	Return line
4	M_TSYNC ¹⁾	Return line ¹⁾
5	SHIELD	Shield potential
6	-	-
7	P12_TSIG	Input 12 V
8	P_TSYNC ¹⁾	Input 24 V ¹⁾
9	SHIELD	Shield potential

¹⁾ only for PPS signal (GPS)

OpticalFibres

**WARNING!****Warning of laser rays!**

Non-observance of the following measure can result in death, personal injury or substantial property damage.

Do not look directly into the fibre-optic elements, not even with optical devices! Laser Class 3A according to EN 60825-1.

For the protection data communication, refer to the following section.

The transmission via fibre optics is particularly insensitive to electromagnetic interference and thus ensures galvanic isolation of the connection. Send and receive connections are identified with the symbols $\blacktriangleleft \rightarrow$ for Send and $\rightarrow \blacktriangleright$ for Receive.

The character idle state for the optical fibre interface is „Light off“. If the character idle state is to be changed, use the operating program DIGSI[®], as described in the SIPRO-TEC[®] 4 System Description.

3.2.2 Checking the Protection Data Communication

The protection data communication is conducted either directly from device to device via optical fibres or via communication converters and a communication network or a dedicated transmission medium.

**Optical Fibres,
Directly****WARNING!****Warning of laser rays!**

Non-observance of the following measure can result in death, personal injury or substantial property damage.

Do not look directly into the fibre-optic elements, not even with optical devices! Laser Class 3A according to EN 60825-1.

The direct optical fibre connection is visually inspected by means of an optical fibre connector. There is one connection for each direction. The data output of one device must be connected to the data input of the other device and vice versa. Send and receive connections are identified with the symbols $\blacktriangleleft \rightarrow$ for Send and $\rightarrow \blacktriangleright$ for Receive. Important is the visual check of assignment of the send and receive channels.

For short distances, laser class 1 is fulfilled if FO5 modules and the recommended fibres are used. In other cases, the laser output may be higher.

If using more than one device, the connections of all protection data interfaces are checked according to the topology selected.

Communication Converter

Optical fibres are usually used for the connections between the devices and communication converters. The optical fibres are checked in the same manner as the optical fibre direct connection which means for every protection data interface.

Verify in address 4502 **CONNEC. 1 OVER** and/or 4602 **CONNEC. 2 OVER** (see also Section 2.2.2.1) that the right connection type is parameterized.

Further Connections

For further connections a visual inspection is sufficient for the time being. Electrical and functional controls are performed during commissioning (see the following main section).

3.2.3 Power Plant Connections



WARNING!

Warning of dangerous voltages

Non-observance of the following measures can result in death, personal injury or substantial property damage.

Therefore, only qualified people who are familiar with and adhere to the safety procedures and precautionary measures shall perform the inspection steps.



Caution!

Be careful when operating the device on a battery charger without a battery

Non-observance of the following measure can lead to unusually high voltages and consequently, the destruction of the device.

Do not operate the device on a battery charger without a connected battery. (For limit values see also Technical Data, Section 4.1).

Before the device is energized for the first time, it should be in the final operating environment for at least 2 hours to equalize the temperature, to minimize humidity and avoid condensation. Connections are checked with the device at its final location. The plant must first be switched off and earthed.

Connection examples for current transformer connections are provided in the Appendix A.3. Please observe the plant diagrams, too.

Proceed as follows in order to check the system connections:

- Protective switches for the power supply and the measured voltages must be opened.
- Check the continuity of all current and voltage transformer connections against the system and connection diagrams:
 - Are the current transformers earthed correctly?
 - Are the polarities of the current transformers the same?
 - Is the phase relationship of the current transformers correct?
 - Are the voltage transformers earthed correctly (if used)?

- Are the polarities of the voltage transformers correct (if used)?
- Is the phase relationship of the voltage transformers correct (if used)?
- Is the polarity for current input I_4 correct (if used)?
- Is the polarity for voltage input U_4 correct (if used, e.g. with open delta winding or busbar voltage)?
- Check the functions of all test switches that are installed for the purposes of secondary testing and isolation of the device. Of particular importance are test switches in current transformer circuits. Be sure these switches short-circuit the current transformers when they are in the „test mode“.
- The short-circuit feature of the current circuits of the device is to be checked. This may be performed with secondary test equipment or other test equipment for checking continuity. Make sure that terminal continuity is not wrongly simulated in reverse direction via current transformers or their short circuit links.
 - Remove the front cover of the device (see also Figure 3-3 and 3-4).
 - Remove the ribbon cable connected to the C-I/O-2 board and pull the board out until there is no contact between the board and the rear connections of the device.
 - At the terminals of the device, check continuity for each pair of terminals that receives current from the CTs.
 - Firmly re-insert the I/O module. Carefully connect the ribbon cable. Be careful not to bend connecting pins! Do not apply force!
 - At the terminals of the device, again check continuity for each pair of terminals that receives current from the CTs.
 - Attach the front panel and tighten the screws.
- Connect an ammeter in the supply circuit of the power supply. A range of about 2.5 A to 5 A for the meter is appropriate.
- Switch on mcb. for auxiliary voltage (supply protection), check the voltage level and, if applicable, the polarity of the voltage at the device terminals or at the connection modules.
- The measured steady-state current should correspond to the quiescent power consumption of the device. Transient movement of the ammeter merely indicates the charging current of capacitors.
- Remove the voltage from the power supply by opening the mcb.
- Disconnect the measuring equipment; restore the normal power supply connections.
- Apply voltage to the power supply.
- Close the mcb for the voltage transformers.
- Verify that the voltage phase rotation at the device terminals is correct.
- Open the mcb's for the transformer voltage (VT mcb) and the power supply.
- Check the trip circuits to the power system circuit breakers.
- Check the close circuits to the power system circuit breakers.
- Verify that the control wiring to and from other devices is correct.
- Check the signalling connections.
- Close mcb.
- If communication converters are used: check the auxiliary voltages for the communication converters.

- If the communication converter is connected to the communication network, its device-ready relay (DOK = „Device Ok“) picks up. This also signalizes that the clock pulse of the communication network is recognized.
Further checks are performed according to Section „Checking the Protection Data Topology“.
- Please also observe carefully the documentation on the communication converters.

3.3 Commissioning



WARNING!

Warning of dangerous voltages when operating an electrical device

Non-observance of the following measures can result in death, personal injury or substantial property damage.

Only qualified people shall work on and around this device. They must be thoroughly familiar with all warnings and safety notices in this instruction manual as well as with the applicable safety steps, safety regulations, and precautionary measures.

Before making any connections, the device must be earthed at the protective conductor terminal.

Hazardous voltages can exist in the power supply and at the connections to current transformers, voltage transformers, and test circuits.

Hazardous voltages can be present in the device even after the power supply voltage has been removed (capacitors can still be charged).

After removing voltage from the power supply, wait a minimum of 10 seconds before re-energizing the power supply. This wait allows the initial conditions to be firmly established before the device is re-energized.

The limit values given in Technical Data must not be exceeded, neither during testing nor during commissioning.

For tests with a secondary test equipment ensure that no other measurement voltages are connected and the trip and close commands to the circuit breakers are blocked, unless otherwise specified.



DANGER!

Hazardous voltages during interruptions in secondary circuits of current transformers

Non-observance of the following measure will result in death, severe personal injury or substantial property damage.

Short-circuit the current transformer secondary circuits before current connections to the device are opened.

During the commissioning procedure, switching operations must be carried out. The tests described require that they can be done without danger. They are accordingly not meant for operational checks.



WARNING!

Warning of dangers evolving from improper primary tests

Non-observance of the following measure can result in death, personal injury or substantial property damage.

Primary tests may only be carried out by qualified persons who are familiar with commissioning protection systems, with managing power systems and the relevant safety rules and guidelines (switching, earthing etc.).

3.3.1 Test Mode / Transmission Block

Activation and Deactivation

If the device is connected to a central control system or a server via the SCADA interface, then the information that is transmitted can be modified with some of the protocols available (see Table „Protocol-dependent functions“ in the Appendix A.5).

If **Test mode** is set ON, then a message sent by a SIPROTEC® 4 device to the main control system has an additional test bit. This bit allows the message to be recognized as resulting from testing and not an actual fault or power system event. Furthermore, it can be determined by activating the **Transmission block** that no annunciations at all are transmitted via the system interface during a test mode.

The SIPROTEC® 4 System Description describes how to activate and deactivate test mode and blocked data transmission. Note that when DIGSI® is being used, the program must be in the **Online** operating mode for the test features to be used.

3.3.2 Checking the Time Synchronization Interface

If external time synchronization sources are used, the data of the time source (antenna system, time generator) are checked (see Section 4 under „Time Synchronization“). A correct function (IRIG B, DCF77) is recognized in such a way that 3 minutes after the startup of the device the clock status is displayed as „synchronized“, accompanied by the indication „Alarm Clock OFF“.

Table 3-14 Time status

No.	Status text	Status
1	-- -- -- --	synchronized
2	-- -- -- ST	
3	-- -- ER --	not synchronized
4	-- -- ER ST	
5	-- NS ER --	
6	-- NS -- --	
Legend:		
-- NS -- --		time invalid
-- -- ER --		time fault
-- -- -- ST		summertime

Additionally, if GPS synchronization is used, check that the GPS signal is received: approximately 3 seconds after startup of the processor system, the message „>GPS failure“ „OFF“ appears.

3.3.3 Checking the System Interface

Prefacing Remarks

If the device features a system interface and uses it to communicate with the control centre, the DIGSI® device operation can be used to test if annunciations are transmitted correctly. This test option should however definitely not be used while the device is in service on a „live“ system.



DANGER!

Sending or receiving annunciations via the system interface by means of the test function is a real information exchange between the SIPROTEC device and the control centre. Connected operating equipment such as circuit breakers or disconnectors can be operated in this way!

Non-observance of the following measure will result in death, severe personal injury or substantial property damage.

Equipment used to allow switching such as circuit breakers or disconnectors is to be checked only during commissioning. Do not under any circumstances check them by means of the testing mode during „real“ operation performing transmission and reception of messages via the system interface.



Note

After termination of this test, the device will reboot. Thereby, all indication buffers are erased. If required, these buffers should be extracted with DIGSI® prior to the test.

The system interface test is carried out Online using DIGSI®

- Open the **Online** directory by double-clicking; the operating functions for the device appear.
- Click on **Test**; the function selection appears in the right half of the window.
- Double-click in the list view on **Generate indications**. The dialog box **Generate indications** is opened (see Figure 3-19).

Structure of the Dialog Box

In the column **Indication**, all message texts that were configured for the system interface in the matrix will then appear. In the column **Setpoint** you determine a value for the indications that shall be tested. Depending on the type of message different entering fields are available (e.g. **message ON / message OFF**). By clicking on one of the buttons you can select the desired value from the pull-down menu.




Figure 3-19 System interface test with dialog box: Generate indications — example

Changing the Operating State

By clicking one of the buttons in the column **Action** you will be asked for the password No. 6 (for hardware test menus). After you have entered the password correctly you can send the indications individually. To do so, click on the button **Send** on the corresponding line. The corresponding message is issued and can be read out either from the event log of the SIPROTEC® 4 device and from the control centre.

Further tests remain enabled until the dialog box is closed.

Test in Message Direction

For all information that is transmitted to the central station, test in **Setpoint** the desired options in the list which appears:

- Make sure that each checking process is carried out carefully without causing any danger (see above and refer to DANGER!)
- Click Send in the function to be tested and check whether the corresponding information reaches the control center and possibly shows the expected effect. Data which are normally linked via binary inputs (first character „>“) are likewise indicated to the control center with this procedure. The function of the binary inputs itself is tested separately.

Exiting the Test Mode

To end the System Interface Test, click on **Close**. The dialog box closes. The processor system is restarted, then the device is ready for operation.

Test in Command Direction

Data which are normally linked via binary inputs (first character „>“) are likewise checked with this procedure. The information transmitted in command direction must be issued by the substation control system. The correct reaction in the device has to be checked.

3.3.4 Checking the States of the Binary Inputs/Outputs

Prefacing Remarks

The binary inputs, outputs, and LEDs of a SIPROTEC® 4 device can be individually and precisely controlled in DIGSI® 4. This feature is used, for example, to verify control wiring from the device to plant equipment during commissioning. This test option should however definitely not be used while the device is in service on a „live“ system.



DANGER!

A changing of switching states by means of the test function causes a real change of the operating state at the SIPROTEC 4 device. Connected operating equipment such as circuit breakers or disconnectors will be switched in this way!

Non-observance of the following measure will result in death, severe personal injury or substantial property damage.

Equipment used to allow switching such as circuit breakers or disconnectors is to be checked only during commissioning. Do not under any circumstances check them by means of the testing mode during „real“ operation performing transmission and reception of messages via the system interface.



Note

After termination of the hardware test, the device will reboot. Thereby, all annunciation buffers are erased. If required, these buffers should be extracted with DIGSI® prior to the test.

The hardware test can be carried out using DIGSI® in the Online operating mode:

- Open the **Online** directory by double-clicking; the operating functions for the device appear.
- Click on **Test**; the function selection appears in the right half of the window.
- Double-click in the list view on **Device inputs and outputs**. The dialog box with this name is opened (see Figure 3-20).

Structure of the Dialog Box

The dialog box is classified into three groups: **BI** for binary inputs, **REL** for output relays, and **LED** for light-emitting diodes. On the left of each group is an accordingly labelled panel. By double-clicking these panels you can show or hide the individual information of the selected group.

In the column **Ist** the present (physical) state of the hardware component is displayed. Indication is displayed symbolically. The physical actual states of the binary inputs and outputs are indicated by an open or closed switch symbol, the LEDs by switched on or switched off symbol.

The opposite state of each element is displayed in the column **Scheduled**. The display is in plain text.

The right-most column indicates the commands or messages that are configured (masked) to the hardware components.




Figure 3-20 Testing of the binary inputs and outputs — example

Changing the Operating State

To change the operating state of a hardware component, click on the associated switching field in the **Scheduled** column.

Before executing the first change of the operating state the password No. 6 will be requested (if activated during configuration). After entry of the correct password a condition change will be executed. Further state changes remain enabled until the dialog box is closed.

Test of the Binary Outputs

Each individual output relay can be energized allowing a check of the wiring between the output relay of the 7SD5 and the plant, without having to generate the message that is assigned to the relay. As soon as the first change of state for any one of the output relays is initiated, all output relays are separated from the internal device functions, and can only be operated by the hardware test function. This means, for example, a TRIP command coming from a protection function or a control command from the operator panel to an output relay cannot be executed.

Proceed as follows in order to check the output relay :

- Make sure that the switching operations caused by the output relays can be executed without any danger (see above under DANGER!).
- Each output relay must be tested via the corresponding **Scheduled** cell in the dialog box.
- Finish the testing (see margin heading below „Exiting the Procedure“), so that during further testings no unwanted switchings are initiated.

Test of the Binary Inputs

To test the wiring between the plant and the binary inputs of the 7SD5 the condition in the system which initiates the binary input must be generated and the response of the device checked.

To do so, open the dialog box **Hardware Test** again to view the physical position of the binary input. The password is not yet required.

Proceed as follows in order to check the binary inputs:

- Activate in the system each of the functions which cause the binary inputs.
- Check the reaction in the **Ist** column of the dialog box. To do this, the dialog box must be updated. The options may be found below under the margin heading „Aktualisieren der Anzeige“.
- Finish the test sequence (see margin heading below „Exiting the Procedure“).

If, however, the effect of a binary input must be checked without carrying out any switching in the system, it is possible to trigger individual binary inputs with the hardware test function. As soon as the first state change of any binary input is triggered and the password No. 6 has been entered, all binary inputs are separated from the system and can only be activated via the hardware test function.

Test of the LEDs

The LEDs may be tested in a similar manner to the other input/output components. As soon as the first state change of any LED has been triggered, all LEDs are separated from the internal device functionality and can only be controlled via the hardware test function. This means e.g. that no LED is illuminated anymore by a protection function or by pressing the LED reset button.

Updating the Display

When the dialog box **Hardware Test** is opened, the present conditions of the hardware components at that moment are read in and displayed.

An update is made:

- For the particular hardware component, if a command for change to another state was successful,
- For all hardware components if the **Update** button is clicked,
- For all hardware components with cyclical updating (cycle time is 20 sec) if the **Automatic Update (20sec)** field is marked.

Exiting the Procedure

To end the hardware test, click on **Close**. The dialog box closes. Thus, all the hardware components are set back to the operating state specified by the plant states. The processor system is restarted, then the device is ready for operation.

3.3.5 Checking the Protection Data Topology

General

The communication topology can either be checked from the PC using DIGSI® or a Web browser via the „WEB-Monitor“. If you choose to work with the „WEB-Monitor“, please note the Help files referring to the „WEB-Monitor“.

You can either connect the PC to the device locally using the operator interface at the front, or the service interface at the back of the PC (Figure 3-21). Or you can log into the device using a modem via the service interface (example in Figure 3-22).

If you use the „WEB-Monitor“:

- Make sure that the 12-digit IP address valid for the browser is set correctly in the format *****.***.***.*****. A three-digit block of the IP address is inserted into each address from 4401 to 4404, or 4411 to 4414.
- Set the address 4405 or 4415 **NUM LOCK** to **NO**, if you are directly interfaced to the device. You will then have the option to operate the device with the „WEB-Monitor“.
- If you are interfaced to the devices via modem you can set the address 4405 or 4415 **NUM LOCK** to **NO**. You will then have the option to access all devices with the „WEB-Monitor“.



Figure 3-21 PC interfacing directly to one device — schematic example




Figure 3-22 PC interfacing via modem — schematic example

Checking a Connection Using Direct Link

For two devices linked with fibre optical cables (as in Figure 3-21 or 3-22), this connection is checked as follows. If two or more devices are linked, or if two devices have been (double-) linked with a ring topology, first check only one link.

- Both devices at the link ends have to be switched on.
- Check in the operating indications or in the spontaneous indications:
 - If the message „PI1 with“ (protection data interface 1 connected with No. 3243) is provided with the device index of the other device, a link has been established and one device has recognized the other.
 - If the protection data interface 2 has also been connected, a corresponding message will appear (No. 3244).
 - The device also indicates the device index of the device which communicates correctly (e.g. annunciation „Rel2 Login“, No. 3492, when relay 2 has been contacted).
- In case of an incorrect communication link, the message „PI1 Data fault“ (No. 3229) or „PI2 Data fault“ (No. 3231) will appear. In this case, recheck the fibre optical cable link.
 - Have the devices been linked correctly and no cables been mixed up?
 - Are the cables free from mechanical damage, intact and the connectors locked?
 - Otherwise repeat check.

Continue with the margin heading „Consistency of Topology and Parameterization“.

Checking a Link with a Communication Converter

If a communication converter is used, please note the instructions enclosed with the device. The communication converter has a test setting where its outputs are looped back to the inputs.

Links via the communication converter are tested by means of local loop-back (Figure 3-23, left).




Figure 3-23 Protection data communication via communication converter and communication network — schematic example



DANGER!

Opening the Communication Converter

There is danger to life by energized parts.

Before opening the communication converter, it is absolutely necessary to isolate it from the auxiliary supply voltage at all poles!

- Both devices at the link ends have to be switched on.
- First configure the communication converter CC-1:
 - Disconnect the auxiliary supply voltage from both poles.
 - Open the communication converter.
 - Set the jumpers to the matching position for the correct interface type and transmission rate; they must be identical with the parameterization of the 7SD5 (address 4502 **CONNEC. 1 OVER** for protection data interface 1 and, if required, 4602 **CONNEC. 2 OVER**, see also Section 2.2.2.1).
 - Move the communication converter into test position (jumper X32 in position 2-3).
 - Close the communication converter housing.
- Reconnect the supply voltage of the communication converter.
- The communication network (X.21 or G.703.1 or ISDN) must be active and connected to the communication converter. Check this by means of the "device ready" contact of the communication converter (continuity at the NO contact).
 - If the "device ready" relay of the communication converter doesn't close, check the connection between the communication converter and the net (communication device). The communication device must emit the correct transmitter clock to the communication converter.
- Change the interface parameters at the 7SD5 (at the device front or via DIGSI®):
 - Address 4502 **CONNEC. 1 OVER** = **F.optic direct** when you are testing protection data interface 1,
 - Address 4602 **CONNEC. 2 OVER** = **F.optic direct** when you are testing protection data interface 2.
- Check the Event Log or spontaneous annunciations:
 - Message 3217 „PI1 Data refl ec“ (Protection interface 1 data reflection ON) when you test protection data interface 1,
 - Message 3218 „PI2 Data refl ec“ (Protection interface 2 data reflection ON) when you test protection data interface 2,
 - When working with both interfaces, note that the current interface of the 7SD5 is connected to its associated communication converter.
 - If the message is not transmitted check for the following:
 - Has the 7SD5 fibre optical transmitting terminal output been correctly linked with the fibre optical receiving terminal input of the communication converter and vice versa (no erroneous interchanging)?
 - Does the 7SD5 device have the correct interface module and is it working correctly?
 - Are the fibre optic cables intact?
 - Are the parameter settings for interface type and transmission rate at the communication converter correct (see above; note the DANGER instruction!)?
 - Repeat the check after correction, if necessary.

- Reset the interface parameters at the 7SD5 correctly:
 - Address 4502 **CONNEC. 1 OVER** = required setting, if you are testing the protection data interface 1,
 - Address 4602 **CONNEC. 2 OVER** = required setting, if are testing the protection data interface 2.
- Disconnect the auxiliary supply voltage of the communication converter at both poles. Note the above DANGER instruction!
- Reset the the communication converter to normal position (X32 in position 1-2) and close the housing again.
- Reconnect the supply voltage of the communication converter.

Perform the above check at the other end with the device being connected there and its corresponding communication converter.

Continue with the margin heading „Consistency of Topology and Parameterization“.

Consistency of Topology and Configuration

Having performed the above checks, the linking of a device pair, including their communication converters, has been completely tested and connected to auxiliary supply voltage. Now the devices communicate by themselves.

- Check now the Event Log or in the spontaneous annunciations of the device where you are working:
 - Message No. 3243 „PI1 with“ (protection data interface 1 linked with) followed by the device index of the other device, if interface 1 is applying.
 - Message No. 3244 „PI2 with“ (protection data interface 2 linked with) followed by the device index of the other device, if interface 2 is applying.
 - If the devices are at least connected once, the message No. 3458 „Chaintopology“ will appear.
 - If no other devices are involved in the topology as an entity, the message No. 3464 „Topo1 complete“ will then be displayed, too.
 - And if the device configuration is also consistent, i.e. the prerequisites for setting the functional scope (Section 2.1.1), Power System Data 1 (2.1.2.1), Power System Data 2 (2.1.4.1) topology and protection data interface parameters (Section 2.2.2.1) have been considered, the fault message, i.e. No. 3229 „PI1 Data fault“ or FNo. 3231 „PI2 Data fault“ for the interface just checked will disappear. The communication and consistency test has now been completed.
 - If the fault message of the interface being checked does not disappear, however, the fault must be found and eliminated. Table 3-15 lists indications that indicate such faults.

Table 3-15 Indications on inconsistencies

No.	Short Text	State	Meaning / Measures
3233	„DT inconsistent“	ON	„Device table inconsistent“: the indexing of the devices is inconsistent (missing numbers or one number used twice, see Section 2.2.2.1)
3234	„DT unequal“	ON	„Device table unequal“: the ID-numbers of the devices are unequal (see Section 2.2.2.1)

No.	Short Text	State	Meaning / Measures
3235	„Par. different“	ON	„Parameterization inconsistent“: different functional parameters were set for the devices. They have to be equal at both ends: Differential protection available or not (see Section 2.1.1) Transformer in protected zone or not (see Section 2.1.1) Nominal frequency (see Section 2.1.2) Operational power or current (see Section 2.1.4)
3487	„Equal IDs“	ON	„Same device address“: the same parameter 4710 LOCAL RELAY has been set for more than one device.

Finally, there should not be any more fault messages of the protection data interfaces.

Availability of the Protection Data Interfaces

The quality of protection data transmission depends on the availability of the protection data interfaces and the transmission. Therefore, check the statistic information of the device.

Check the following information:

- Message No. 7753 „PI1A/m“ (availability per minute) and message No. 7754 „PI1A/h“ (availability per hour) indicate the availability of protection data interface 1. The value of No. 7753 „PI1A/m“ should attain a minimum availability of 99.85% after two minutes of operation. The value of No. 7754 „PI1A/h“ should attain a minimum availability of 99.85% after one hour of operation.
- If protection data interface 2 is used, the corresponding messages can be found under No. 7755 „PI2A/m“ and No. 7756 „PI2A/h“; the minimum values are the same as for protection data interface 1.

If the values are not attained, the protection communication must be checked.

If GPS synchronization is used, the transmission times can be retrieved separately for each direction:

- Concerning protection data interface 1, No. 7876 „PI1 TD S“ indicates the transmission time in sending direction, No. 7875 „PI1 TD R“ in receiving direction.
- Concerning protection data interface 2, No. 7878 „PI2 TD S“ indicates the transmission time in sending direction, No. 7877 „PI2 TD R“ in receiving direction.

In all other cases, the mean value for both directions will be indicated:

- No. 7751 „PI1 TD“ indicates the transmission time via protection data interface 1.
- No. 7752 „PI2 TD“ indicates the transmission time via protection data interface 2.

Checking Further Links

If more than two devices have been linked, that is if the object to be protected has more than two ends, or, if two devices have been linked via both protection data interfaces to create redundancy, repeat all checks for every possible link as described above including the consistency check.

If all devices involved in the topology communicate properly and all parameters are consistent, the message No. 3464 „Topol complete“ appears.

If there is a ring topology, the message No. 3457 „Ringtopology“ must also appear after closing the ring.

However, if you've got a ring topology which only issues the indication „Ringtopology“ instead of „Chaintopology“ (No. 3458), the protection data communication is functional, but the ring has not yet been closed. Check the missing links as described above including the consistency test until all links to the ring have been made.

Finally, there should be no more fault messages concerning the protection data interfaces.

WEB-Monitor

The topology and the statistical information on the protection data interfaces can be displayed as a graph on the monitor using the „WEB-Monitor“. For this you need a personal computer and a web browser. Figure 3-24 exemplifies a differential protection system for three ends with a ring topology. The devices have been properly linked (green shaded squares) and work as differential protection (status: Differential Mode). The PC has been interfaced to the device with index 2 (PC-connected relay).

Figure 3-25 illustrates the interface data of a 7SD5 with GPS synchronization as an example. The PC has been interfaced to the device with index 3 (PC-connected relay). The transmission between device 2 and device 3 is 0.000 ms, the time between device 3 and device 1 is 0.763 ms for sending and 0.772 ms for receiving.




Figure 3-24 Example of a ring topology with three ends communicating correctly




Figure 3-25 Example of viewing the transmission times and availability of the protection data interfaces

3.3.6 Tests for the Circuit Breaker Failure Protection

General

If the device is equipped with the breaker failure protection and this function is used, the integration of this protection function into the system must be tested under practical conditions.

Because of the manifold application facilities and various configuration possibilities of the plant it is not possible to give a detailed description of the necessary test steps. It is important to consider the local conditions and the protection and plant drawings.

Before starting the circuit breaker tests it is recommended to insulate at both ends the feeder which is to be tested, i.e. line disconnectors and busbar disconnectors should be open so that the breaker can be operated without risk.



Caution!

Also for tests on the local circuit breaker of the feeder a trip command to the surrounding circuit breakers can be issued for the busbar.

Non-observance of the following measure can result in minor personal injury or property damage.

Therefore, primarily it is recommended to interrupt the tripping commands to the adjacent (busbar) breakers, e.g. by interrupting the corresponding pickup voltage supply.

Before the breaker is closed again for normal operation the trip command of the feeder protection routed to the circuit breaker must be disconnected so that the trip command can only be initiated by the breaker failure protection.

Although the following list does not claim to be complete, it may also contain points which are to be ignored in the current application.

Auxiliary Contacts of the CB

The circuit breaker auxiliary contact(s) form an essential part of the breaker failure protection system in case they have been connected to the device. Make sure the correct assignment has been checked.

External Initiation Conditions

If the breaker failure protection can also be started by external protection devices, the external start conditions should be checked. Single-pole or three-pole tripping is possible depending on the setting of the breaker failure protection. Note that the internal pole discrepancy supervision or the pole discrepancy supervision of the breaker itself may lead to a later three-pole trip. Therefore check first how the parameters of the breaker failure protection are set. See Section 2.20.2, addresses 3901 onwards.

In order for the breaker failure protection to be started, a current must flow at least via the monitored phase. This may be a secondary injected current.

After every start, the message „BF Start“ (No. 1461) must appear in the spontaneous or fault indications.

Only if single-pole starting possible:

- Start by single-pole trip command of the external protection: L1
Binary input functions „>BF Start L1“ and, if necessary, „>BF release“ (in spontaneous or fault indications). Trip command (dependent on settings).
- Start by single-pole trip command of the external protection: L2
Binary input functions „>BF Start L2“ and, if necessary, „>BF release“ (in spontaneous or fault indications). Trip command (dependent on settings).
- Start by single-pole trip command of the external protection: L3
Binary input functions „>BF Start L3“ and, if necessary, „>BF release“ (in spontaneous or fault indications). Trip command (dependent on settings).
- Starting by trip command of the external protection via all three binary inputs L1, L2 and L3:
Binary input functions „>BF Start L1“, „>BF Start L2“ and „>BF Start L3“ and, if necessary, „>BF release“ (in spontaneous or fault indications). Trip command three-pole

For three-pole starting:

- Three-pole starting by trip command of the external protection:
Binary input functions „>BF Start 3pole“ and, if necessary, „>BF release“ (in spontaneous or fault indications). Trip command (dependent on settings).

Switch off test current.

If start is possible without current flow:

- Starting by trip command of the external protection without current flow:
Binary input functions „>BF Start w/o I“ and, if necessary, „>BF release“ (in spontaneous or fault indications). Trip command (dependent on settings).

Busbar Tripping

The most important thing is the check of the correct distribution of the trip commands to the adjacent circuit breakers in case of breaker failure.

The adjacent circuit breakers are those of all feeders which must be tripped in order to ensure interruption of the fault current should the local breaker fail. These are therefore the circuit breakers of all feeders which feed the busbar or busbar section to which the feeder with the fault is connected.

A general detailed test guide cannot be specified, because the layout of the surrounding circuit breakers largely depends on the system topology.

In particular with multiple busbars the trip distribution logic for the surrounding circuit breakers must be checked. Here check for every busbar section that all circuit breakers which are connected to the same busbar section as the feeder circuit breaker under observation are tripped, and no other breakers.

Tripping of the Remote End

If the trip command of the circuit breaker failure protection must also trip the circuit breaker at the remote end of the feeder under observation, the transmission channel for this remote trip must also be checked. This is done together with transmission of other signals according to Sections „Testing of the Teleprotection Scheme with ...“ further below.

Termination of the Checks

All temporary measures taken for testing must be undone, e.g. especially switching states, interrupted trip commands, changes to setting values or individually switched off protection functions.

3.3.7 Checking the Instrument Transformer Connections of One Line End

Should secondary test equipment be connected to the device, it is to be removed or, if applying, test switches should be in normal operation position.



Note

It must be taken into consideration that tripping can occur even at the opposite ends of the protected object, if connections were made wrong.

Before energizing the object to be protected at any end, short-circuit protection must be ensured at least at the feeding ends. If a separate back-up protection (e.g. overcurrent protection) is available, this has to be put into operation and switched to alert first.

Voltage and Phase Sequence Check

If the device has been connected to voltage transformers, these connections are checked using primary values. For devices without voltage transformer connection the rest of this margin heading may be omitted.

The voltage transformer connections are individually tested at either end of the object to be protected. At the other end(s) the circuit breaker(s) remain open first.

- Having closed the local circuit breaker, none of the measurement monitoring functions in the device may respond.
 - If there was a fault annunciation, however, the Event Log or spontaneous annunciations could be checked to investigate the reason for it.
 - At the indication of balance monitoring there might actually be asymmetries of the primary system. If they are part of normal operation, the corresponding monitoring function is set less sensitive (see Section 2.22.1 under margin heading „Symmetry Monitoring“).

The voltages can be read on the display at the front, or called up in the PC via the operator or service interface, and compared with the actual measured quantities as primary or secondary values. Besides the magnitudes of the phase-to-phase and the phase-to-earth voltages, the phase angles can be read out, thus enabling to verify the correct phase sequence and polarity of individual voltage transformers. The voltages can also be read with the „WEB-Monitor“ (see below, „Current Test“).

- The voltages should be almost equal. All three angles φ ($U_{Lx}-U_{Ly}$) must be approximately 120° .
 - If the measured quantities are not plausible, the connections must be checked and revised after switching off the line. If the phase difference angle between two voltages is 60° instead of 120° , one voltage must be polarity-reversed. The same applies if there are phase-to-phase voltages which almost equal the phase-to-earth voltages instead of having a value that is $\sqrt{3}$ greater. The measurements are to be repeated after setting the connections right.
 - In general, the phase rotation is a clockwise phase rotation. If the system has a counter-clockwise phase rotation, this must go for all ends of the protected object. The measured value allocation must be checked and corrected, if required, after the line has been isolated. The phase rotation check must then be repeated.
- Open the miniature circuit breaker of the feeder voltage transformers. The measured voltages in the operational measured values appear with a value close to zero (small measured voltages are of no consequence).
 - Check in the Event Log and in the spontaneous annunciations that the VT mcb trip was noticed (indication „>FAIL:Feeder VT“ „ON“, No. 361). It has to be assured beforehand that the position of the VT mcb is connected to the device via a binary input.
- Close the VT mcb again: The above indication appears in the spontaneous annunciations as „OFF“, i.e. „>FAIL:Feeder VT“ „OFF“.
 - If one of the indications does not appear, the connection and allocation of these signals must be checked.
 - If the „ON“ state and the „OFF“ state are swapped, the contact type (H-active or L-active) must be checked and remedied.
- The protected object is switched off.
- The check must be carried out for all ends.

3.3.8 Checking the Instrument Transformer Connections of Two Line Ends

Current Test

The connections of the current transformers are tested with primary values. A load current of at least 5 % of the rated operational current is required. Any direction is possible.

This test cannot replace visual inspection of the correct current transformer connections. Therefore, the inspection according to Section „Plant Connections“ is a prerequisite.

- The current transformer connections are tested at each end of the protected object. The current flows through the protected object. For more than two ends, one current path (i.e. two ends) is tested first.
- After closing the circuit breakers, none of the measured value monitoring functions in the 7SD5 must respond. If there was a fault message, however, the Event Log or spontaneous messages could be checked to investigate the reason for it.
 - If current summation errors occur, check the matching factors (see Section 2.1.2 at margin heading „Connection of the Currents“).
 - Messages from the symmetry monitoring could occur because there actually are asymmetrical conditions in the primary system. If they are part of normal operation, the corresponding monitoring function is set less sensitive (see Section 2.22.1 under margin heading „Symmetry Monitoring“).

Currents can be viewed as primary or secondary measured values in the front display panel or via the operator or service interface with a personal computer, and compared with the actually measured values. The absolute values as well as the phase differences of the currents are indicated so that the correct phase sequence and polarity of individual transformers can also be seen.

The „WEB-Monitor“ provides comfortable read-out possibilities for all measured values with visualization using phasor diagrams (Figure 3-26).

- The current amplitudes must be approximately the same. All three angles $\varphi (I_{Lx}-I_{Ly})$ must be approximately 120° .
 - If the measured values are not plausible, the connections must be checked and corrected after switching off the protected object and short-circuiting the current transformers. If, for example, the phase difference between two currents is 60° instead of 120° , one of the currents must have a reversed polarity. The same is the case, if a substantial earth current $3I_0$ occurs:
 - $3I_0 \approx \text{phase current} \rightarrow$ one or two phase currents are missing;
 - $3I_0 \approx \text{twice the phase current} \rightarrow$ one or two phase currents have a reversed polarity.
- The measurements are to be repeated after setting the connections right.
- The above described tests of the measured values also have to be performed at the other end of the tested current path. The current value of the other end can also be read out locally as percentage values as well as the phase angles.

In the „WEB-Monitor“ the local and remote measured values can be shown graphically. The following figures show an example.




Figure 3-26 Local measured values in the WEB-Monitor — examples for plausible measured values




Figure 3-27 Local and remote measured values in the WEB-Monitor — examples for plausible measured values

Polarity Check

If the device is connected with voltage transformers, the local measured values already provide a polarity test.

For more than two ends, one current path is continued to be tested first. A load current of at least 5% of the rated operational current is required. Any direction is possible but must be known.

- With closed circuit breaker, the power values can be viewed as primary and secondary measured values in the front display panel or via the operator or service interface with a personal computer.

Here, again, the „WEB-Monitor“ is a comfortable help as the vector diagrams also show the correlation between the currents and voltages (Figure 3-27). Cyclically and acyclically swapped phases can easily be detected.

- With the aid of the measured power values you are able to verify that they correlate to the load direction, reading either at the device itself or in DIGSI® (Figure 3-28).

P positive, if active power flows into the protected object,

P negative, if active power flows towards the busbar,

Q positive, if (inductive) reactive power flows into the protected object,

Q negative, if (inductive) reactive power flows toward the busbar.

Therefore, the power results and their components must have opposite signs at both ends.

It must be taken into consideration that high charging currents, which might occur with long overhead lines or with cables, are capacitive, i.e. correspond to a negative reactive power into the line. In spite of a resistive-inductive load, this may lead to a slightly negative reactive power at the feeding end whereas the other end shows an increased negative reactive power. The lower the load current for the test, the higher the significance of this influence. In order to get unambiguous results, you should increase the load current if necessary.




Figure 3-28 Apparent load power

- The power measurement provides an initial indication as to whether the measured values of one end have the correct polarity.
 - If the reactive power is correct but the active power has the wrong sign, cyclic phase swapping of the currents (right) or of the voltages (left) might be the cause.
 - If the active power direction is correct but the reactive power has the wrong sign, cyclic phase swapping of the currents (left) or of the voltages (right) might be the cause.
 - If both the real power as well as the reactive power have the wrong sign, the polarity in address 201 **CT Starpoint** must be checked and rectified.

The phase angles between currents and voltages must also be conclusive. Each one of the three phase angles φ ($U_{LX}-I_{LX}$) must be approximately the same and must represent the operating status. In the event of power in the direction of the protected object, they represent the current phase displacement ($\cos \varphi$ positive); in the event of power in the direction of the busbar they are higher by 180° ($\cos \varphi$ negative). However, charging currents might have to be taken into consideration (see above).

- The measurements may have to be repeated after correction the connections.
- The above described tests of the measured values also have to be performed at the other end of the tested current path. The current and voltage values as well as the phase angles of the other end can also be read out locally as percentage values. Note that currents flowing through the object (without charging currents) ideally have opposite signs at both ends, i.e. turned by 180° . In the „WEB-Monitor“ the local and remote measured values can be shown graphically. One example is illustrated in Figure 3-27.
- The protected object is now switched off, i.e. the circuit breakers are opened.

Polarity Check for the Voltage Input U_4

Depending on the application of the voltage measuring input U_4 , a polarity check may be necessary. If no measuring voltage is connected to this input, this section is irrelevant.

If the input U_4 is used for measuring a voltage for overvoltage protection (**P.System Data 1** address 210 **U4 transformer = Ux transformer**), no polarity check is necessary because the polarity is irrelevant here. The voltage magnitude was checked before.

If the input U_4 is used for the measurement of the displacement voltage U_{en} (**P.System Data 1** address 210 **U4 transformer = Udelta transf.**), the polarity together with the current measurement is checked (see below).

If the input U_4 is used for measuring a busbar voltage for synchronism check (**P.System Data 1** address 210 **U4 transformer = Usync transf.**), the polarity must be checked as follows using the synchronism check function.

Only for Synchronism Check

The device must be equipped with the synchronism and voltage check function which must be configured under address 135 **Enabled** (see section 2.1.1.3).

The voltage U_{bus} connected to the busbar must be specified correctly under address 212 **Usync connect.** (see Section 2.1.2.1).

If there is no transformer between the two measuring points, address 214 φ **Usync-Uline** must be set to 0° (see Section 2.1.2.1).

If the measurement is made across a transformer, this angle setting must correspond to the phase rotation through which the vector group of the transformer as seen from

the feeder in the direction of the busbar rotates the voltage. An example is shown in Section 2.1.2.1.

If necessary, different transformation ratios of the transformers on the busbar and the feeder may have to be considered under address 215 **U-line** / **U_{sync}**.

The synchronism and voltage check must be switched **ON** under address 3501 **FCT Synchronism**.

An additional help for the connection control are the messages 2947 „Sync. Ud_{diff}>“ and 2949 „Sync. ϕ -diff>“ in the spontaneous annunciations.

- Circuit breaker is open. The feeder is isolated (zero voltage). The VT_{mcb}'s of both voltage transformer circuits must be closed.
- For the synchronism check the program **OVERRIDE** = **YES** (address 3519) is set; the other programs (addresses 3515 to 3518) are set to **NO**.
- Via binary input (No. 2906 „>Sync. Start AR“) initiate the measuring request. The synchronism check must release closing (message „Sync. release“, FNo. 2951). If not, check all relevant parameters again (synchrocheck configured and enabled correctly, see Sections 2.1.1.3, 2.1.2.1 and 2.16.2).
- Set address 3519 **OVERRIDE** to **NO**.
- Then the circuit breaker is closed while the line isolator is open (see Figure 3-29). Both voltage transformers therefore measure the same voltage.
- The program **SYNC-CHECK** = **YES** (address 3515) is set for synchronism check.
- Via binary input (No. 2906 „>Sync. Start AR“) initiate the measuring request. The synchronism check must release closing (message „Sync. release“, FNo. 2951).




Figure 3-29 Measuring voltages for the synchronism check

- If not, first check whether one of the before named messages 2947 „Sync. Udifff>“ or 2949 „Sync. ϕ -difff>“ is available in the spontaneous messages. The message „Sync. Udifff>“ indicates that the magnitude (ratio) adaptation is incorrect. Check address 215 **U-line** / **Usync** and recalculate the adaptation factor, if necessary.
The message „Sync. ϕ -difff>“ indicates that the phase relation of the busbar voltage does not match the setting under address 212 **Usync connect**. (see Section 2.1.2.1). When measuring across a transformer, address 214 ϕ **Usync-Uline** must also be checked; this must adapt the vector group (see Section 2.1.2.1). If these are correct, there is probably a reverse polarity of the voltage transformer terminals for Ubus.
- The program **Usync< U-line> = YES** (address 3517) and **SYNC-CHECK = YES** (address 3515) is set for synchronism check.
- Open the VT mcb of the busbar voltage.
- Via binary input (No. 2906 „>Sync. Start AR“) initiate the measuring request. There is no close release. If there is, the VT mcb for the busbar voltage is not allocated. Check whether this is the required state, alternatively check the binary input „>FAIL:Bus VT“ (No.362).
- The VT mcb of the busbar voltage is to be closed again.
- Open the circuit breaker.
- The program **Usync> U-line< = YES** (address 3516) and **Usync> U-line< = NO** (address 3517) is set for synchronism check.
- Via binary input (No. 2906 „>Sync. Start AR“) initiate the measuring request. The synchronism check must release closing (message „Sync. release“, No. 2951). If not, check all voltage connections and the corresponding parameters again carefully as described in Section 2.1.2.1.
- Open the VT mcb of the feeder voltage.
- Via binary input (No. 2906 „>Sync. Start AR“) initiate the measuring request. No close release is given.
- Open the VT mcb of the feeder voltage again.

Addresses 3515 to 3519 must be restored as they were changed for the test. If the allocation of the LEDs or signal relays was changed for the test, this must also be restored.

Polarity Check for the Current Measuring Input I_4

If the standard connection of the device is used whereby current input I_4 is connected in the starpoint of the set of current transformers (refer also to the connection circuit diagram in the Appendix A.3), then the correct polarity of the earth current path in general automatically results.

If, however, the current I_4 is derived from a separate summation CT an additional direction check with this current is necessary.

If the device is provided with the sensitive current input I_4 and it is connected to an isolated or resonant-earthed system, the polarity check for I_4 was already carried out with the earth fault check according to the previous section. Then this section can be ignored.

Otherwise the test is carried out with a disconnected trip circuit and primary load current. It must be noted that during all simulations that do not exactly correspond with situations that may occur in practice, the non-symmetry of measured values may cause the measured value monitoring to pickup. This must therefore be ignored during such tests.



DANGER!

Hazardous voltages during interruptions in secondary circuits of current transformers

Non-observance of the following measure will result in death, severe personal injury or substantial property damage.

Short-circuit the current transformer secondary circuits before current connections to the device are opened.

I_4 from Own Line

To generate a displacement voltage, the e–n winding of one phase in the voltage transformer set (e.g. L1) is bypassed (refer to Figure 3-30). If no connection on the e–n windings of the voltage transformer is available, the corresponding phase is open circuited on the secondary side. Via the current path only the current from the current transformer in the phase from which the voltage in the voltage path is missing, is connected; the other CTs are short-circuited. If the line carries resistive-inductive load, the protection is in principle subjected to the same conditions that exist during an earth fault in the direction of the line.

At least one stage of the earth fault protection must be set to be directional (address 31x 0 of the earth fault protection). The pickup threshold of this stage must be below the load current flowing on the line; if necessary the pickup threshold must be reduced. The parameters that are changed, must be noted.

After switching the line on and off again, the direction indication must be checked: in the fault log the messages „EF Pickup“ and „EF forward“ must at least be present. If the directional pickup is not present, either the earth current connection or the displacement voltage connection is incorrect. If the wrong direction is indicated, either the direction of load flow is from the line toward the busbar or the earth current path has a swapped polarity. In the latter case, the connection must be rectified after the line has been isolated and the current transformers short-circuited.

In the event that the pickup alarms were not even generated, the measured earth (residual) current may be too small.




Figure 3-30 Polarity check for I_4 , example with current transformer configured in a Holmgreen connection

Note

If parameters were changed for this test, they must be returned to their original state after completion of the test !

I_4 from Parallel Line

If I_4 is the current measured on a parallel line, the above procedure is done with the set of current transformers on the parallel line (Figure 3-31). The same method as above is used here, except that a single phase current from the parallel feeder is measured. The parallel line must carry load while the protected line should carry load. The line remains switched on for the duration of the measurement.

If the polarity of the parallel line earth current measurement is correct, the impedance measured in the tested loop (in the example of Figure 3-31 this is L1-E) should be reduced by the influence of the parallel line. The impedances can be read out as primary or secondary quantities in the list of operational measured values.

If, on the other hand, the measured impedance increases when compared to the value without parallel line compensation, the current measuring input I_4 has a swapped polarity. After isolation of both lines and short-circuiting of the current transformer secondary circuits, the connections must be checked and rectified. Subsequently the measurement must be repeated.




Figure 3-31 Polarity check of I_4 , example with earth current of a parallel line

I_4 from a Power Transformer Starpoint

If I_4 is the earth current measured in the starpoint of a power transformer and intended for the earth fault protection direction determination (for earthed networks), then the polarity check can only be carried out with a zero sequence current flowing through the transformer. A test voltage source is required for this purpose (single-phase low voltage source).



Caution!

Feeding of zero sequence currents via a transformer without broken delta winding. Inadmissible heating of the transformer is possible!

Zero sequence current should only be routed via a transformer if it has a delta winding, therefore e.g. Yd, Dy or Yy with a compensating winding.



DANGER!

Energized equipment of the power system! Capacitive coupled voltages at disconnected equipment of the power system !

Non-observance of the following measure will result in death, severe personal injury or substantial property damage.

Primary measurements must only be carried out on disconnected and earthed equipment of the power system!

The configuration shown in Figure 3-32 corresponds to an earth current flowing through the line, in other words an earth fault in the forward direction.

At least one stage of the earth fault protection must be set to be directional (address 31xx of the earth fault protection). The pickup threshold of this stage must be below the load current flowing on the line; if necessary the pickup threshold must be reduced. The parameters that have been changed, must be noted.




Figure 3-32 Polarity check of I_4 , example with earth current from a power transformer star point

After switching the test source on and off again, the direction indication must be checked: in the fault log the messages „EF Pickup“ and „EF forward“ must at least be present. If the directional pickup alarm is missing, a connection error of the earth current connection I_4 is present. If the wrong direction is indicated, the earth current connection I_4 has a swapped polarity. In the previous case the connection must be rectified after the test source has been switched off. The measurements must then be repeated.

If the pickup alarm is missing altogether, this may be due to the fact that the test current is too small.

Note

If parameters were changed for this test, they must be returned to their original state after completion of the test !



Measuring Differential and Restraint Currents

The test for two ends is terminated with the reading of the differential, restraint and load currents which simultaneously check that the current transformer connections have been restored correctly after the I_4 test (if performed).

- Read out the differential, restraint and load currents. They are available for every phase at the device display or in DIGSI® amongst the measured values.
 - The differential currents must be low, at least one scale less than the currents flowing through. If high charging currents are to be expected in long overhead lines or cables, these are additionally included in the differential currents.
 - The highest of the measured values of the load current (3 values) is converted to Ampere and entered in **I-DIFF>**. The recommended setting for the pickup threshold is $1 \cdot I_{cN}$.
 - The restraint currents result from the pickup value **I-DIFF>** (address 1210, see Section 2.3.2) in addition to the sum of the current errors to be tolerated: such as the locally permissible current transformer error according to address 253 **E% ALF / ALF_N** (see Section 2.1.2) the permissible current transformer errors at the other ends according to that setting there, as well as the internal estimation of the system errors (frequency, synchronization and delay time difference errors). With the default values for **I-DIFF>** ($0.3I_N$) and **E% ALF / ALF_N** ($5.0\% = 0.05$) there is

$$\frac{I_{\text{Rest}}}{I_{\text{NB}}} = \underbrace{0.3}_{\substack{\text{Setting} \\ \text{Value} \\ \text{IDIFF>}}} + \underbrace{0.05 \cdot \frac{I}{I_{N1}}}_{\substack{\text{Adm. Local} \\ \text{Transformer} \\ \text{Error}}} + \underbrace{0.05 \cdot \frac{I}{I_{N2}}}_{\substack{\text{Adm. Remote} \\ \text{Transformer} \\ \text{Error}}} + \text{System Error}$$

with

- I the actual current flowing,
- I_{NB} the nominal operating current (as configured),
- I_{N1} the primary nominal current of the local current transformers,
- I_{N2} the primary nominal current of the current transformers of the remote end.

In the „WEB-Monitor“, the differential and restraint currents are displayed as a graph in a characteristics diagram. One example is illustrated in Figure 3-33.

- If there is a differential current in the size of twice the through-flowing current, you may assume a polarity reversal of the current transformer(s) at one line end. Check the polarity again and set it right after short-circuiting all the three current transformers. If you have modified these current transformers, also perform a power and angle test.
- Finally, open the circuit breaker again.
- If parameter settings have been changed for the tests, reset them to the values necessary for operation.




Figure 3-33 Differential and restraint currents — example for plausible currents

3.3.9 Checking the Instrument Transformer Connections for More than Two Ends

If there are more than two ends, all tests according to the above Section „Checking the Instrument Transformer Connections for More than Two Ends“ — as far as they are applicable in this case — have to be repeated for other current paths in such a way that all ends of the object to be protected have been included in the current flow test at least once. It is not necessary to test every possible current path.

At the ends not involved in a test the circuit breakers are to remain open. Also pay attention to all safety notes — especially the DANGER warning in the above Section „Checking the Instrument Transformer Connections for More than Two Ends“.

The circuit breakers are reopened after the last test.

In the event that parameters were modified for the tests, they finally have to be set to the values necessary for operation.

3.3.10 Measuring the Operating Time of the Circuit Breaker

Only for Synchronism Check

If the device is equipped with the function for synchronism and voltage check and it is applied, it is necessary - under asynchronous system conditions - that the operating time of the circuit breaker is measured and set correctly when closing. If the synchronism check function is not used or only for closing under synchronous system conditions, this section is irrelevant.

For measuring the operating time a setup as shown in Figure 3-34 is recommended. The timer is set to a range of 1 s and a graduation of 1 ms.

The circuit breaker is closed manually. At the same time the timer is started. After closing the poles of the circuit breaker, the voltage U_{Line} appears and the timer is stopped. The time displayed by the timer is the real circuit breaker closing time.

If the timer is not stopped due to an unfavourable closing moment, the attempt will be repeated.

It is particularly favourable to calculate the mean value from several (3 to 5) successful switching attempts.

Set the calculated time under address 239 as **T-CB close** (under **P.System Data 1**). Select the next lower settable value.



Note

The operating time of the accelerated output relays for command tripping is taken into consideration by the device itself. The tripping command is to be allocated to a such relay. If this is not the case, then add 3 ms to the measured circuit breaker operating time for achieving a greater response time of the „normal“ output relay. If high-speed relays are used, on the other hand, you must deduct 4 ms from the measured circuit breaker operating time.




Figure 3-34 Measuring the circuit breaker closing time

3.3.11 Checking the Teleprotection System with Distance Protection



Note

If the device is intended to operate with teleprotection, all devices used for the transmission of the signals must initially be commissioned according to the corresponding instructions.

The following section applies only for the conventional transmission procedures. It is not relevant for usage with protection data interfaces.

For the functional check of the signal transmission, the earth fault protection should be disabled, to avoid signals from this protection influencing the tests: address 3101 **FCT EarthFlt0/C = OFF**.

Check for Pilot Wire Comparison

The operating mode pilot wire comparison differs considerably from other teleprotection schemes as far as the type of transmission (DC closed circuit-loop) is concerned. The examination is described in the following. If a different transmission scheme is applied, this part can be skipped.

Detailed information on the function of the pilot-wire comparison is available in Section 2.7.

For **Teleprot. Dist.** in address 121 **Pilot wire comp** must be configured and the **FCT Telep. Dis.** must be switched **ON** under address 2101. The protection relays at both line ends must be in operation. Initially, the quiescent current loop of the pilot wire comparison is not yet supplied with auxiliary voltage.

A fault is simulated outside of zone Z1, but within zone Z1B. Since stage Z1B is blocked, the distance protection is only tripped in a higher-leveled zone (usually with T2). This check must be carried out at both line ends.

The direct voltage for the quiescent current loop of the pilot wire comparison is switched to the line. The loop is then fed with quiescent current.

At one line end a fault is simulated outside of the first zone, but within the overreach zone Z1B. The command is tripped to T1B. This check must be carried out at both line ends.

Since the quiescent current loop is part of the nature of the pilot wire comparison, these tests also check if the transmission process is performed correctly. All other tests which are described in this Section can be passed over. However, please observe the last margin heading „Important for All Schemes“!

Checking of Reverse Interlocking

The checking of the reverse interlocking is described below. If a different transmission scheme is applied, this part can be skipped.

For more detailed information about the reverse interlocking see Section 2 2.7.

For **Teleprot. Dist.** address 121 must be set to **Rev. Interlock** and the **FCT Telep. Dis.** must be switched **ON** at address 2101. The distance protection of the infeed and switchgear of all outgoing feeders must be in operation. At the beginning no auxiliary voltage is fed to the line for the reverse interlocking.

The following paragraphs describe the testing in a blocked state, i.e. the pickup signals of the outgoing devices are connected in parallel and block the tested device of the

infeed. In case of release (the NC contacts of the outgoing devices are connected in series) the tests have to be reinterpreted respectively.

A fault is simulated within zone Z1 and overreaching zone Z1B. As a result of the missing blocking signal, the distance protection trips after time delay T1B (slightly delayed).

The direct voltage for reverse interlocking is now switched to the line. The precedent test is repeated, the result will be the same.

At each of the protection devices of the outgoing circuits, a pickup is simulated. Meanwhile, another short-circuit is simulated as described before for the distance protection of the infeed. Now, the distance protection trips after time T1, which has a longer setting.

These tests also check the proper functioning of the transmission path. All other tests which are described in this Section can be passed over. However, please observe the last margin heading „Important for All Schemes“!

Checking with Permissive Schemes

Prerequisites: **Teleprot. Dist.** is configured in address 121 to one of the comparison schemes using blocking signal, i.e. **POTT** or **Dir.Comp.Pickup** or **UNBLOCKING**. Furthermore, is switched in address 2101 **FCT Telep. Dis. ON**. Naturally, the corresponding send and receive signals must also be assigned to the corresponding binary output and input. For the echo function, the echo signal must be allocated separately to the transmit output!

Detailed information on the function of permissive scheme is available in Section 2.7.

A simple check of the signal transmission path from one line end is possible via the echo circuit if these release techniques are used. The echo function must be activated at both line ends, i.e. address 2501 **FCT Weak Infeed = ECHO only**; with the setting **ECHO and TRIP** at the remote end of the check a tripping command may result!

A short-circuit is simulated outside Z1, with **POTT** or **UNBLOCKING** inside Z1B, with **Dir.Comp.Pickup** somewhere in forward direction. This may be done with secondary injection test equipment. As the device at the opposite line end does not pick up, the echo function comes into effect there, and consequently a trip command is issued at the line end being tested.

If no trip command appears, the signal transmission path must be checked again, especially also the assignment of the echo signals to the transmit outputs.

In case of a phase-segregated transmission the above-mentioned checks are carried out for each phase. The correct phase allocation is also to be checked.

This test must be performed at both line ends, in the case of three terminal lines at each end for each signal transmission path.

The functioning of the echo delay time and the derivation of the circuit breaker switching status should also be tested at this time (the functioning of the protection at the opposite line end is tested):

The circuit breaker on the protected feeder must be opened, as must be the circuit breaker at the opposite line end. As described above, a fault is again simulated. A receive signal impulse delayed by somewhat more than twice the signal transmission time appears via the echo function at the opposite line end, and the device issues a trip command.

The circuit breaker at the opposite line end is now closed (while the isolators remain open). After simulation of the same fault, the receive and trip command appear again.

In this case however, they are additionally delayed by the echo delay time of the device at the opposite line end (0.04 s presetting, address 2502 **Trip/Echo DELAY**).

If the response of the echo delay is opposite to the sequence described here, the operating mode of the corresponding binary input (H-active/L-active) at the opposite line end must be rectified.

The circuit breaker must be opened again.

This test must be performed at both line ends, on a three terminal line at each line end for each transmission path. Finally, please observe the last margin heading „Important for All Schemes“!

Checking in Blocking Scheme

Requirements: **Teleprot. Dist.** is configured in address 121 to one of the comparison schemes using blocking signal, i.e. **BLOCKING**. Furthermore, under address 2101 **FCT Telep. Dis. ON** is switched. Naturally, the corresponding send and receive signals must also be assigned to the corresponding binary output and input.

For more details about the function of the blocking scheme refer to Section 2.7. In the case of the blocking scheme, communication between the line ends is necessary.

On the transmitting end, a fault in the reverse direction is simulated, while at the receiving end a fault in Z1B but beyond Z1 is simulated. This can be achieved with a set of secondary injection test equipment at each end of the line. As long as the transmitting end is transmitting, the receiving end may not generate a trip signal, unless this results from a higher distance stage. After the simulated fault at the transmitting line end has been cleared, the receiving line end remains blocked for the duration of the transmit prolongation time of the transmitting line end (**Send Prolong.**, address 2103). If applicable, the transient blocking time of the receiving line end (**TrBlk BlockTime**, address 2110) appears additionally if a finite delay time **TrBlk Wait Time** (address 2109) has been set and exceeded.

In case of a phase-segregated transmission the above-mentioned checks are carried out for each phase. The correct phase allocation is also to be checked.

This test must be performed at both line ends, on a three terminal line at each line end for each transmission path. However, please finally observe the last margin heading „Important for all procedures“!

Checking with Permissive Underreach Transfer Trip

Requirements: **Teleprot. Dist.** is configured in address 121 to a permissive underreach transfer trip scheme, i.e. **PUTT (Z1B)** or **PUTT (Pickup)**. Furthermore, in address 2101 **FCT Telep. Dis. ON** is switched. Naturally, the corresponding send and receive signals must also be assigned to the corresponding binary output and input.

Detailed information on the function of permissive underreach transfer is available in Section 2.7. Communication between the line ends is necessary.

On the transmitting end, a fault in zone Z1 must be simulated. This may be done with secondary injection test equipment.

Subsequently, on the receiving end, at **PUTT (Z1B)** a fault inside Z1B, but outside Z1 is simulated, at **PUTT (Pickup)** any fault is simulated. Tripping takes place immediately, (or in T1B), without signal transmission only in a higher distance stage. In case of direct transfer trip an immediate trip is always executed at the receiving end.

In case of a phase-segregated transmission the above-mentioned checks are carried out for each phase. The correct phase allocation is also to be checked.

This test must be performed at both line ends, on a three terminal line at each line end for each transmission path. However, please finally observe the last margin heading „Important for all procedures“!

Important for all Schemes

If the earth fault protection was disabled for the signal transmission tests, it may be re-enabled now. If setting parameters were changed for the test (e.g. mode of the echo function or timers for unambiguous observation of sequences), these must now be re-set to the prescribed values.

3.3.12 Testing the Signal Transmission with Earth Fault Protection

This section is only relevant if the device is connected to a earthed system and earth fault protection is applied. The device must therefore be provided with the earth fault detection function according to its ordering code (16th MLFB position = 4 or 5 or 6 or 7). Which group of characteristics are to be available must have been preset during configuration to **Earth Fault 0/C** (address 131). Furthermore, the teleprotection must be used for the earth fault protection (address 132 **Teleprot. E/F** configured to one of the optional methods). If none of this is the case, this section is not relevant.

If the signal transmission path for the earth fault protection is the same path that was already tested in conjunction with the distance protection according to the previous Section, then this Section is of no consequence and may be omitted.

For the functional check of the earth fault protection signal transmission, the distance protection should be disabled, to avoid interference of the tests by signals from the distance protection: address 1501 **FCT Distance = OFF**.

Checking with Permissive Schemes

Requirements: **Teleprot. E/F** is configured in address 132 to one of the comparison schemes using permissive signal, i.e. **Dir.Comp.Pickup** or **UNBLOCKING**. Furthermore, **FCT Telep. E/F** is switched **ON** at address 3201. Naturally, the corresponding send and receive signals must also be assigned to the corresponding binary output and input. For the echo function, the echo signal must be assigned separately to the transmit output.

Detailed information on the function of permissive release is available in Section 2.9.

A simple check of the signal transmission path from one line end is possible via the echo circuit if these release techniques are used. The echo function must be activated at both line ends, i.e. address 2501 **FCT Weak Infeed = ECHO only**; with the setting **ECHO and TRIP** at the remote end of the check a tripping command may result!

An earth fault is simulated in the direction of the line. This may be done with secondary injection test equipment. As the device at the opposite line end does not pick up, the echo function comes into effect there, and consequently a trip command is issued at the line end being tested.

If no trip command appears, the signal transmission path must be checked again, especially also the assignment of the echo signals to the transmit outputs.

This test must be carried out at both line ends, in the case of three terminal lines at each end for each signal transmission path.

The functioning of the echo delay time and monitoring of the circuit breaker switching status must also be tested at this time if this has not already been done in the previous section (the operation of the protection at the opposite line end is checked):

The circuit breaker on the protected feeder must be opened, as must be the circuit breaker at the opposite line end. A fault is again simulated as before. A receive signal impulse delayed by somewhat more than twice the signal transmission time appears via the echo function at the opposite line end, and the device issues a trip command.

The circuit breaker at the opposite line end is now closed (while the isolators remain open). After simulation of the same fault, the receive and trip command appear again. In this case however, they are additionally delayed by the echo delay time of the device at the opposite line end (0.04 s presetting, address 2502 **Trip/Echo DELAY**).

If the response of the echo delay is opposite to the sequence described here, the operating mode of the corresponding binary input (H–active/L–active) at the opposite line end must be rectified.

The circuit breaker must be opened again.

This test must also be carried out at both line ends, in the case of three terminal lines at each line end and for each signal transmission path. Finally, please observe the last margin heading „Important for All Schemes“!

Checking in Blocking Scheme

Requirements: **Teleprot. E/F** is configured in address 132 to one of the comparison schemes using blocking signal, i.e. **BLOCKING**. Furthermore, under address 3201 **FCT Telep. E/F ON** is switched. Naturally, the corresponding send and receive signals must also be assigned to the corresponding binary output and input.

For more details about the function of the blocking scheme refer to Section 2.9. In the case of the blocking scheme, communication between the line ends is necessary.

An earth fault in the reverse direction is simulated at the transmitting line end. Subsequently, a fault at the receiving end in the direction of the line is simulated. This can be achieved with a set of secondary injection test equipment at each end of the line. As long as the transmitting end is transmitting, the receiving end may not generate a trip signal, unless this results from a higher distance stage. After the simulated fault at the transmitting line end is switched off, the receiving line end remains blocked for the duration of the transmit prolongation time of the transmitting line end (**Send Prolong.**, address 3203). If applicable, the transient blocking time of the receiving line end (**TrBlk BlockTime**, address 3210) appears additionally if a finite delay time **TrBlk Wait Time** (address 3209) has been set and exceeded.

This test must be performed at both line ends, on a three terminal line at each line end for each transmission path. However, please finally observe the last margin heading „Important for All Schemes“!

Important for all Schemes

If the distance protection was switched off for the signal transmission tests, it may be switched on now. If setting parameters were changed for the test (e.g. mode of the echo function or timers for unambiguous observation of sequences), these must now be re-set to the prescribed values.

3.3.13 Checking the Signal Transmission for Breaker Failure Protection and/or Stub Fault Protection

If the transfer trip command for breaker failure protection or stub fault protection is to be transmitted to the remote end, this transmission must also be checked.

To check the transmission the breaker failure protection function is initiated by a test current (secondary) with the circuit breaker in the open position. Make sure that the correct circuit breaker reaction takes place at the remote end.

Each transmission path must be checked on lines with more than two ends.

3.3.14 Checking the Signal Transmission for Internal and External Remote Tripping

The 7SD5 provides the possibility to transmit a remote trip signal to the opposite line end if a signal transmission path is available for this purpose. This remote trip signal may be derived from both an internally generated trip signal as well as from any signal coming from an external protection or control device.

If an internal signal is used, the initiation of the transmitter must be checked. If the signal transmission path is the same and has already been checked as part of the previous sections, it need not be checked again here. Otherwise the initiating event is simulated and the response of the circuit breaker at the opposite line end is verified.

In the case of the distance protection, the permissive underreach scheme may be used to trip the remote line end. The procedure is then the same as was the case for permissive underreach (under „Checking with Permissive Underreach Transfer Trip“); however the received signal causes a direct trip.

For the remote transmission, the external command input is employed on the receiving line end; it is therefore a prerequisite that: **DTT Direct Trip** is set in address 122 **Enabled** and **FCT Direct Trip** is set in address 2201 **ON**. If the signal transmission path is the same and has already been checked as part of the previous sections, it need not be checked again here. A function check is sufficient, whereby the externally derived command is executed. For this purpose the external tripping event is simulated and the response of the circuit breaker at the opposite line end is verified.

3.3.15 Testing User-Defined Functions

The device has a vast capability for allowing functions to be defined by the user, especially with the CFC logic. Any special function or logic added to the device must be checked.

Naturally, general test procedures cannot be given. Configuration of these functions and the set value conditions must be actually known beforehand and tested. In particular any interlocking conditions of the switch resources (power switches, breakers, earth switches) must be observed and tested.

3.3.16 Trip and Close Test with the Circuit Breaker

The circuit breaker and tripping circuits can be conveniently tested by the device 7SD5.

The procedure is described in detail in the SIPROTEC® 4 System Description.

If the check does not produce the expected results, the cause may be established from the text in the display of the device or the PC. If necessary, the connections of the circuit breaker auxiliary contacts must be checked.

It must be noted that the binary inputs used for the circuit breaker auxiliary contacts must be assigned separately for the CB test. This means it is not sufficient that the auxiliary contacts are allocated to the binary inputs No. 351 to 353, 379 and 380 (according to the possibilities of the auxiliary contacts); additionally, the corresponding No. 366 to 368 or 410 and/or 411 must be allocated (according to the possibilities of the auxiliary contacts). In the CB test only the latter ones are analyzed. See also Section 2.23.1. Furthermore, the ready state of the circuit breaker for the CB test must be indicated to the binary input with No. 371.

3.3.17 Trip/Close Tests for the Configured Operating Devices

Switching by Local Command

If the configured operating devices were not switched sufficiently in the hardware test already described, all configured switching devices must be switched on and off from the device via the integrated control element. The feedback information of the CB position injected via binary inputs should be read out and compared with the actual breaker position. For devices with graphic display this is easy to do with the control display.

The switching procedure is described in the SIPROTEC® 4 System Description. Switching authority must be set in accordance with the command source used. With the switching mode, you can choose between locked and unlocked switching. In this case, you must be aware that unlocked switching is a safety risk.

Switching from a Remote Control Centre

If the device is connected to a remote substation via a system (SCADA) interface, the corresponding switching tests may also be checked from the substation. Please also take into consideration that the switching authority is set in correspondence with the source of commands used.

3.3.18 Triggering Oscillographic Recordings for Test

In order to be able to test the stability of the protection during switchon procedures also, switchon trials can also be carried out at the end. Oscillographic records obtain the maximum information about the behaviour of the protection.

Prerequisite

Along with the capability of storing fault recordings via pickup of the protection function, the 7SD5 also has the capability of initiating a measured value recording using the operator program DIGSI® via the serial interface and via binary inputs. For the latter, event „>Trig.Wave.Cap.“ must be allocated to a binary input. Triggering of the recording is done, e.g. via binary input on switchon of the protection object.

An oscillographic recording that is externally triggered (that is, without a protective element pickup or device trip) is processed by the device as a normal oscillographic recording, and has a number for establishing a sequence. However, these recordings are not displayed in the fault indication buffer, as they are not fault events.

Start Triggering Oscillographic Recording

In order to start a test measurement recording via DIGSI®, select in the left of the window the operator function **Test**. Double-click in the list view the entry **Test Wave Form** (see Figure 3-35).




Figure 3-35 Triggering oscillographic recording with DIGSI® — Example

Oscillographic recording is immediately started. During the recording, an annunciation is output in the left area of the status line. Bar segments additionally indicate the progress of the procedure.

The SIGRA or the Comtrade Viewer program is required to view and analyse the oscillographic data.

3.4 Final Preparation of the Device

The used terminal screws must be tightened, including those that are not used. All the plug connectors are correctly inserted.



Caution!

Don't use force! The tightening torques must not be exceeded as the threads and terminal chambers may otherwise be damaged!

The setting values should be checked again, if they were modified during the tests. Check if protection, control and auxiliary functions to be found with the configuration parameters are set correctly (Section 2.1.1, Functional Scope). All desired elements and functions must be set **ON**. Ensure that a copy of the setting values is stored on the PC.

The user should check the device-internal clock and set/synchronize it if necessary, provided that it is not synchronized automatically. Further details on this subject are described in /1/.

The indication buffers are deleted under **Main Menu** → **Annunciation** → **Set / Reset**, so that in the future they only contain information on actual events and states. The numbers in the switching statistics should be reset to the values that were existing prior to the testing.

The counters of the operational measured values (e.g. operation counter, if available) are reset under **Main Menu** → **Measurement** → **Reset**.

Press the ESC key, several times if necessary, to return to the default display. The default display appears in the display, e.g. the display of operational measured value.

Clear the LEDs on the front panel by pressing the LED key, so that they only show real events and states. In this context, saved output relays are reset, too. Pressing the LED key also serves as a test for the LEDs on the front panel because they should all light when the button is pressed. If the LEDs display states relevant by that moment, these LEDs, of course, stay lit.

The green „RUN“ LED must light up, whereas the red „ERROR“ must not light up.

Close the protective switches. If test switches are available, then these must be in the operating position.

The device is now ready for operation.

■

Technical Data

This chapter presents the technical data of the SIPROTEC 4 7SD5 device and its individual functions, including the limit values that must not be exceeded under any circumstances. The electrical and functional data for the maximum functional scope are followed by the mechanical specifications with dimension diagrams.

4.1	General	519
4.2	Protection Data Interfaces and Differential Protection Topology	531
4.3	Differential Protection	533
4.4	Breaker Intertrip and Remote Tripping -Direct Local Trip	535
4.5	Distance Protection (optional)	536
4.6	System Power Swing (with impedance) (optional)	539
4.7	Teleprotection for Distance Protection (optional)	540
4.8	Earth Fault Protection in Earthed Systems (optional)	541
4.9	Teleprotection for Earth Fault Protection (optional)	550
4.10	Weak-infeed Tripping (classic/optional)	551
4.11	Weak-infeed Tripping (French specif./optional)	552
4.12	Direct Remote Trip and Transmission of Binary Information	553
4.13	Instantaneous High-Current Switch-onto-Fault Protection (SOTF)	554
4.14	Time Overcurrent Protection	555
4.15	Automatic Reclosure Function (optional)	558
4.16	Synchronism and Voltage Check (optional)	559
4.17	Undervoltage and Overvoltage Protection (optional)	561
4.18	Frequency Protection (optional)	564
4.19	Fault Locator	565
4.20	Circuit Breaker Failure Protection	566
4.21	Thermal Overload Protection	567
4.22	Monitoring Function	569
4.23	User Defined Functions (CFC)	571

4.24	Additional Functions	574
4.25	Dimensions	577

4.1 General

4.1.1 Analog Inputs

Nominal frequency	f_N	50 Hz or 60 Hz (adjustable)

Current Inputs

Nominal current	I_N	1 A or 5 A
Power Consumption per Phase and Earth Path		
- at $I_N = 1$ A		Approx. 0.05 VA
- at $I_N = 5$ A		Approx. 0.3 VA
- for sensitive earth fault detection at 1A		Approx. 0.05 VA
Current Overload Capability per Current Input		
- thermal (rms)		$100 \cdot I_N$ for 1 s $30 \cdot I_N$ for 10 s $4 \cdot I_N$ continuous
- dynamic (pulse current)		$250 \cdot I_N$ (half-cycle)
Current Overload Capability for Sensitive Earth Current Input		
- thermal (rms)		300 A for 1 s 100 A for 10 s 15 A continuous
- dynamic (pulse current)		750 A (half-cycle)

Requirements for current transformers

1st Condition: For a maximum fault current the current transformers must not be saturated under <u>steady-state</u> conditions	$n' \geq \frac{I_{kd \max}}{I_{N \text{ prim}}}$
2nd Condition: The operational accuracy limit factor n' must be at least 30 or a non-saturated period of t'_{AL} of at least $\frac{1}{4}$ AC cycle after fault inception must be ensured	$n' \geq 30$ or $t'_{AL} \geq \frac{1}{4} \text{ cycle}$
3rd Condition: Maximum ratio between primary currents of current transformers at the ends of the protected object	$\frac{I_{\text{prim max}}}{I_{\text{prim min}}} \leq 8$

Voltage inputs

Nominal voltage U _N		80 V to 125 V (adjustable)
Measuring range		0 V to 218.5 V (rms)
Power consumption	At 100 V	≤ 0.1 VA
Voltage overload capability per phase		
- thermal (rms)		230 V continuous

4.1.2 Auxiliary voltage

DC voltage

Voltage supply via integrated converter				
Nominal auxiliary voltage DC U_{AUX}	24/48 VDC	60/110/125 V DC	110/125/220/250 VDC	220/250 VDC
Admissible voltage ranges	19 to 58 VDC	48 to 150 VDC	88 to 300 VDC	176 to 300 VDC
Permissible AC ripple voltage, Peak to peak, IEC 60255-11	≤15 % of the nominal auxiliary voltage			
Power input				
- Quiescent			Approx. 5 W	
- Energized	7SD5***-A/E/J		Approx. 12 W	
	7SD5***-C/G/L/N/Q/S		Approx. 15 W	
	7SD5***-D/H/M/P/R/T		Approx. 18 W	
Plus approx. 1.5 W per interface module				
Bridging time for failure/short-circuit of the power supply, IEC 60255-11	≥ 50 ms at $U_{Aux} = 48\text{ V}$ and $U_{Aux} \geq 110\text{ V}$			
	≥ 20 ms at $U_{Aux} = 24\text{ V}$ and $U_{Aux} \geq 60\text{ V}$			

AC voltage

Voltage supply via integrated converter		
Nominal auxiliary voltage AC U_{AUX}	115 VAC	
Admissible voltage ranges	92 to 132 VAC	
Power input		
- Quiescent		Approx. 7 VA
- Energized	7SD5***-A/E/J	Approx. 17 VA
	7SD5***-C/G/L/N/Q/S	Approx. 20 VA
	7SD5***-D/H/M/P/R/T	Approx. 23 VA
plus approx. 1.5 VA per interface module		
Bridging time for failure/short circuit of alternating auxiliary voltage	≥ 50 ms	

4.1.3 Binary Inputs and Outputs

Binary Inputs

Variants	Number	
7SD5***-*A/E/J	8 (configurable)	
7SD5***-*C/G/L/N/Q/S	16 (configurable)	
7SD5***-*D/H/M/P/R/T	24 (configurable)	
Nominal voltage range	24 VDC to 250 VDC, in 3 ranges, bipolar	
Pickup threshold	Adjustable with jumpers	
- For nominal voltages	24/48 VDC 60/110/125 VDC	$U_{high} \geq 19 \text{ VDC (pu = pickup)}$ $U_{low} \leq 10 \text{ VDC}$

- For nominal voltages	110/125/220/250 VDC	$U_{\text{high}} \geq 88 \text{ VDC}$ (pu = pickup) $U_{\text{low}} \leq 44 \text{ VDC}$
- For nominal voltages	220/250 VDC	$U_{\text{high}} \geq 176 \text{ VDC}$ (pu = pickup) $U_{\text{low}} \leq 88 \text{ VDC}$
Current consumption, energized	Approx. 1.8 mA Independent of the control voltage	
Maximum permissible voltage	300 VDC	
Impulse filter on input	220 nF coupling capacitance at 220 V with recovery time > 60 ms	

Binary Outputs

Signalling/Trip Relays (see also terminal assignments in Appendix A)					
Quantity and Data		According to the order variant (allocatable)			
Order variant	UL Listed	NO Contact (normal) ¹⁾	NO Contact (fast) ¹⁾	NO/NC (switch selectable) ¹⁾	NO contact (high-speed) ¹⁾
7SD5***-A/E/J	X	7	7	1	–
7SD5***-C/G/L	X	14	7	2	–
7SD5***-N/Q/S	X	7	10	1	5
7SD5***-D/H/M	X	21	7	3	–
7SD5***-P/R/T	X	14	10	2	5
Switching capability	MAKE	1000 W/VA			1000 W/VA
	OPEN	30 VA 40 W resistive 25 W/VA at L/R ≤ 50 ms			1000 W/VA
Switching voltage					
DC		250 V			
AC		250 V			200 V (max.)
Permissible current per contact (continuous)		5 A			
Admissible current per contact (close and hold) / pulse current		30 A for 0.5 s (NO contact)			
Permissible total current on common path		5 A continuous 30 A for 0.5 s			
Operating time, approx.		8 ms	5 ms	8 ms	1 ms
Alarm relay ¹⁾					
		With 1 NC contact or 1 NO contact (switchable)			
Switching capability	MAKE	1000 W/VA			
	BREAK	30 VA 40 W resistive 25 W at L/R ≤ 50 ms			
Switching voltage		250 V			
Permissible current per contact		5 A continuous 30 A for 0.5 s			
¹⁾ UL-listed with the following nominal data:					

Signalling/Trip Relays (see also terminal assignments in Appendix A)					
Quantity and Data		According to the order variant (allocatable)			
Order variant	UL Listed	NO Contact (normal) ¹⁾	NO Contact (fast) ¹⁾	NO/NC (switch selectable) ¹⁾	NO contact (high-speed) ¹⁾
		120 VAC		Pilot duty, B300	
		240 VAC		Pilot duty, B300	
		240 VAC		5 A General Purpose	
		24 VDC		5 A General Purpose	
		48 VDC		0.8 A General Purpose	
		240 VDC		0.1 A General Purpose	
		120 VAC		1/6 hp (4.4 FLA)	
		240 VAC		1/2 hp (4.9 FLA)	

4.1.4 Communications Interfaces

Protection Data Interfaces

See Section 4.2 „Protection Data Interfaces and Communication Topology“

Operator Interface

Connection	Front side, non-isolated, RS232, 9-pin D-subminiature female connector for connection of a PC
Operation	With DIGSI®
Transmission speed	Min. 4,800 Baud; max. 115,200 Baud; Factory Setting: 38400 Baud; Parity: 8E1
Transmission distance	15 m / 50 feet

Service / Modem Interface (optional)

RS232/RS485	RS232/RS485/FO Acc. to ordered variant	Isolated interface for data transfer
	Operation	With DIGSI®
		RS232/RS485 according to the ordering variant
	Connection for panel flush mounting housing	Rear panel, mounting location „C“, 9-pole D-subminiature female connector Shielded data cable
	Connection for panel surface mounting housing	Shielded data cable
	Up to release .../BB	At two-tier terminal on the housing bottom
	Release .../CC and higher	In the console housing on the case bottom; 9-pole D-subminiature female connector
	Test voltage	500 V; 50 Hz
	Transmission speed	Min. 4800 Baud; max. 115200 Baud Factory setting 38400 Baud
RS232		
	Transmission distance	15 m (50 ft.)

RS485		
	Transmission distance	1.000 m. (3280 ft.)
Fibre optic cable (FO)		
	FO connector type	ST connector
	Connection for panel flush mounting housing	Rear panel, slot „C“
	Connection for panel surface mounting housing	In console housing at device bottom
	Optical wavelength	$\lambda = 820 \text{ nm}$
	Laser class 1 according to EN 60825-1/-2	Using glass fibre 50/125 μm or Using glass fibre 62.5/125 μm
	Permissible optical signal attenuation	Max. 8 dB, with glass fibre 62.5/125 μm
	Transmission distance	Max. 1.5 km (0.93 miles)
	Character idle state	Selectable, factory setting „Light off“

System interface (optional)

RS232/RS485/FO Profibus FMS RS485/Profibus FMS FO Profibus DP RS485/Profibus DP FO DNP 3.0 RS 485 DNP 3.0 FO Acc. to ordered variant		Isolated interface for data transfer to a control terminal
RS232	Connection for panel flush mounting housing	Rear panel, slot „B“, 9-pole D-subminiature female connector
	Connection for panel surface mounting housing	
	Up to .../BB	At two-tier terminal on the housing bottom
	.../CC and higher	In console housing at device bottom 9-pole D-subminiature female connector
	Test voltage	500 V; 50 Hz
	Transmission speed	Min. 4800 Baud; max. 38400 Baud Factory setting 19200 Baud
	Transmission distance	Max. 15 m (0.93 miles)
RS485	Connection for panel flush mounting housing	Rear panel, slot „B“, 9-pole D-subminiature female connector
	Connection for panel surface mounting housing	
	Up to .../BB	At two-tier terminal on the housing bottom
	.../CC and higher	In console housing at device bottom 9-pole D-subminiature female connector
	Test voltage	500 V; 50 Hz
	Transmission speed	Min. 4800 Bd, max. 38400 Bd Factory setting 19200 Bd
	Transmission distance	Max. 1 km (0.93 miles)
Fibre optic cable (FO)	FO connector type	ST connector
	Connection for panel flush mounting housing	Rear panel, mounting location „B“
	Connection for panel surface mounting housing	In console housing at device bottom
	Optical wavelength	$\lambda = 820 \text{ nm}$
	Laser class 1 according to EN 60825-1/-2	Using glass fibre 50/125 μm or Using glass fibre 62.5/125 μm
	Permissible optical signal attenuation	Max. 8 dB, with glass fibre 62.5/125 μm
	Transmission distance	Max. 1.5 km (0.93 miles)
	Character idle state	Selectable, factory setting „Light off“
Profibus RS 485 (FMS and DP) In console housing on bottom 9-pole D-subminiature female connector	Connection for panel flush mounting housing	Rear panel, slot „B“, 9-pole D-subminiature female connector
	Connection for panel surface mounting housing	
	Test voltage	500 V; 50 Hz
	Transmission speed	Up to 12 MBaud
	Transmission distance	1.000 m (1640 ft.) at $\leq 93.75 \text{ kBd}$ 500 m (1640 ft.) at $\leq 187.5 \text{ kBd}$ 200 m (328 ft.) at $\leq 1.5 \text{ MBaud}$ 100 m (328 ft.) at $\leq 12 \text{ MBaud}$

Profibus FO (FMS and DP)		
	FO connector type	ST connector; double ring
	Connection for panel flush mounting housing	Rear panel, mounting location „B“
	Connection for panel surface mounting housing	Please use version with Profibus RS485 in the console housing at the housing bottom as well as separate electrical/optical converter
	Transmission speed	Conversion by means of external OLM ¹⁾ up to 1.5 MBaud
	Recommended speed:	> 500 kBaud
	Optical wavelength	$\lambda = 820 \text{ nm}$
	Laser class 1 according to EN 60825-1/-2	Using glass fibre 50/125 μm or Using glass fibre 62.5/125 μm
	Permissible optical signal attenuation	Max. 8 dB, with glass fiber 62.5/125 μm
	Transmission distance between two modules with redundant optical ring topology and optical fibre 62.5/125 m	2 m (6.6 ft.) with plastic fibre 500 kB/s max. 1.6 km (1 mile) 1500 kB/s 530 m (1738 ft.)
	Character idle state (status for "No character")	Light OFF
	Max. number of modules in optical rings with 500 kB/s or 1500 kB/s	41
DNP 3.0 RS 485		
	Connection for panel flush mounting housing	Rear panel; slot „B“; 9-pole D-subminiature female connector
	Connection for panel surface mounting housing	In console housing on bottom 9-pole D-subminiature female connector
	Test voltage	500 V; 50 Hz
	Transmission speed	Up to 19200 Baud
	Transmission distance	Max. 1 km (0.93 miles)
DNP 3.0 FO		
	FO connector type	ST connector receiver/transmitter
	Connection for panel flush mounting housing	Rear panel, mounting location „B“
	Connection for panel surface mounting housing	Please use version with DNP3.0 RS485 in the console housing at the housing bottom as well as separate electrical/optical converter
	Transmission speed	Up to 19200 Baud
	Optical wavelength	$\lambda = 820 \text{ nm}$
	Laser Class 1 according to EN60825-1/-2	Using glass fibre 50/125 μm or Using glass fibre 62.5/125 μm
	Permissible optical signal attenuation	Max. 8 dB, with glass fibre 62.5/125 μm
	Transmission distance	Max. 1.5 km (0.93 miles)
The OLM converter requires an operating voltage of 24 VDC. If the operating voltage is > 24 VDC the additional power supply 7XV5810-0BA00 is required.		

¹⁾ If the optical interface is required you should order the following: 11. Position 4 (FMS) or L0A (DP) and additionally: SIEMENS OLM 6GK1502-3CB01

Time Synchronization Interface

Time synchronization	DCF 77/IRIG-B-Signal (telegram format IRIG-B000)/GPS		
Connection for panel flush mounting housing	Rear panel, slot „A“ 9-pole D-subminiature female connector		
For panel surface mounting housing	At two-tier terminals on housing bottom		
Nominal signal voltages DCF77/IRIG B	Selectable 5 V, 12 V or 24 V		
Nominal signal voltages GPS	24 V		
Signal levels and burdens DCF77/IRIG-B:			
	Nominal signal input voltage		
	5 V	12 V	24 V
U_{IIHigh}	6.0 V	15.8 V	31 V
U_{ILOw}	1.0 V at $I_{ILOw} = 0.25$ mA	1.4 V at $I_{ILOw} = 0.25$ mA	1.9 V at $I_{ILOw} = 0.25$ mA
I_{IHigh}	4.5 mA to 9.4 mA	4.5 mA to 9.3 mA	4.5 mA to 8.7 mA
R_i	890 Ω at $U_i = 4$ V	1930 Ω at $U_i = 8.7$ V	3780 Ω at $U_i = 17$ V
	640 Ω at $U_i = 6$ V	1700 Ω at $U_i = 15.8$ V	3560 Ω at $U_i = 31$ V
PPS Signal for GPS			
ON/OFF pulse duty factor	1/999 to 1/1		
max. rise/fall time deviation of all receivers	± 3 μ s		
For GPS receiver, antenna and power supply unit please refer to Appendix A1.2, Accessories.			

4.1.5 Electrical Tests

Specifications

Standards:	IEC 60255 (product standards) IEEE Std C37.90.0/1/2 UL 508 VDE 0435 For more standards see also individual functions

Insulation Test

Standards:	IEC 60255-5 and IEC 60870-2-1
High voltage test (routine test) All circuits except power supply, Binary Inputs, High Speed Outputs, Communication Interface and Time Synchronization Interfaces	2.5 kV (rms), 50 Hz
High voltage test (routine test) Auxiliary voltage, binary inputs and high speed outputs	3.5 kVDC
High voltage test (routine test) only isolated communication and time synchronisation interfaces	500 V (rms), 50 Hz
Impulse voltage test (type test) All Circuits Except Communication and Time Synchronization Interfaces, Class III	5 kV (peak), 1.2/50 μ s, 0.5 Ws, 3 positive and 3 negative impulses in intervals of 5 s

EMC Tests for Interference Immunity (type tests)

Standards:	IEC 60255-6 and -22 (product standards) EN 61000-6-2 (generic standard) VDE 0435 Teil 301DIN VDE 0435-110
High frequency test IEC 60255-22-1, Class III and VDE 0435 Section 303, Class III	2.5 kV (Peak); 1 MHz; $\tau = 15 \mu\text{s}$; 400 surges per s; Test Duration 2 s; $R_i = 200 \Omega$
Electrostatic discharge IEC 60255-22-2, Class IV and IEC 61000-4-2, Class IV	8 kV contact discharge; 15 kV air discharge, both polarities; 150 pF; $R_i = 330 \Omega$
Irradiation with HF field, frequency sweep IEC 60255-22-3, Class III IEC 61000-4-3, Class III	10 V/m; 80 MHz to 1000 MHz; 80 % AM; 1 kHz
Irradiation with HF field, single frequencies IEC 60255-22-3 IEC 61000-4-3, Class III –amplitude-modulated –pulse-modulated	10 V/m 80; 160; 450; 900 MHz; 80 % AM 1kHz; duty cycle > 10 s 900 MHz; 50 % PM, repetition frequency 200 Hz
Fast transient disturbances Burst IEC 60255-22-4 and IEC 61000-4-4, Class IV	4 kV; 5/50 ns; 5 kHz; burst length = 15 ms; repetition rate 300 ms; both polarities: $R_i = 50 \Omega$; Test Duration 1 min
High energy surge voltages (SURGE), IEC 61000-4-5 installation Class 3 - Auxiliary voltage – Analog measuring inputs, binary inputs, relay outputs	Impulse: 1.2/50 μs Common mode: 2 kV; 12 Ω ; 9 μF Diff. mode: 1 kV; 2 Ω ; 18 μF Common mode: 2 kV; 42 Ω ; 0.5 μF diff. mode: 1 kV; 42 Ω ; 0.5 μF
Line conducted HF, amplitude modulated IEC 61000-4-6, Class III	10 V; 150 kHz to 80 MHz; 80 % AM; 1 kHz
Power system frequency magnetic field IEC 60255-6, IEC 61000-4-8 Class IV	0.5 mT; 50 Hz 30 A/m; continuous; 300 A/m for 3 s; 50 Hz
Oscillatory surge withstand capability IEEE Std C37.90.1	2.5 kV (Peak); 1 MHz; $\tau = 15 \mu\text{s}$; 400 Surges per s; Test Duration 2 s; $R_i = 200 \Omega$
Fast transient surge withstand cap. IEEE Std C37.90.1	4 kV; 5/50 ns; 5 kHz; burst length = 15 ms; repetition rate 300 ms; both polarities: $R_i = 50 \Omega$; Test duration 1 min
Radiated electromagnetic interference IEEE Std C37.90.2	35 V/m; 25 MHz to 1000 MHz
Damped oscillations IEC 60694, IEC 61000-4-12	2.5 kV (Peak Value), polarity alternating 100 kHz, 1 MHz, 10 MHz and 50 MHz, $R_i = 200 \Omega$

EMC Tests for Noise Emission (type test)

Standard:	EN 50081-* (technical generic standard)
Radio noise voltage to lines, only auxiliary voltage IEC-CISPR 22	150 kHz to 30 MHz Limit class B
Interference field strength IEC-CISPR 22	30 MHz to 1000 MHz Limit class B
Harmonic currents on the network lead at 230 VAC IEC 61000-3-2	Class A limits are observed.
Voltage fluctuations and flicker on the network incoming feeder at 230 V AC IEC 61000-3-3	Limits are observed

4.1.6 Mechanical Stress Tests

Vibration and Shock Stress during Stationary Operation

Standards:	IEC 60255-21 and IEC 60068
Oscillation IEC 60255-21-1, Class 2 IEC 60068-2-6	Sinusoidal 10 Hz to 60 Hz: ± 0.075 mm amplitude; 60 Hz to 150 Hz: 1g acceleration Frequency sweep 1 octave/min 20 cycles in 3 orthogonal axes
Shock IEC 60255-21-2, Class 1 IEC 60068-2-27	Semi-sinusoidal 5 g acceleration, duration 11 ms, each 3 shocks (in both directions of the 3 axes)
Seismic vibration IEC 60255-21-3, Class 1 IEC 60068-3-3	Sinusoidal 1 Hz to 8 Hz: ± 3.5 mm amplitude (horizontal axis) 1 Hz to 8 Hz: ± 1.5 mm amplitude (vertical axis) 8 Hz to 35 Hz: 1 g acceleration (horizontal axis) 8 Hz to 35 Hz: 0.5 g acceleration (vertical axis) Frequency sweep 1 octave/min 1 cycle in 3 orthogonal axes

Vibration and Shock Stress During Transport

Standards:	IEC 60255-21 and IEC 60068
Oscillation IEC 60255-21-1, Class 2 IEC 60068-2-6	Sinusoidal 5 Hz to 8 Hz: ± 7.5 mm Amplitude; 8 Hz to 150 Hz: 2 g acceleration frequency sweep 1 octave/min 20 cycles in 3 orthogonal axes
Shock IEC 60255-21-2, Class 1 IEC 60068-2-27	Semi-sinusoidal 15 g acceleration, duration 11 ms, each 3 shocks (in both directions of the 3 axes)
Continuous shock IEC 60255-21-2, Class 1 IEC 60068-2-29	Semi-sinusoidal 10 g acceleration, duration 16 ms, each 1000 shocks (in both directions of the 3 axes)

4.1.7 Climatic Stress Tests

Climatic Tests

Standards:	IEC 60255-6
Type tested (acc. IEC 60086-2-1 and -2, Test Bd, for 16 h)	–25 °C to +85 °C
Admissible temporary operating temperature (tested for 96 h)	–20 °C to +70 °C or –4 °F to +158 °F (legibility of display may be restricted from +55 °C or 131 °F)
Recommended for permanent operation (according to IEC 60255-6)	–5 °C to +55 °C or 23 °F to +131 °F If max. half of the inputs and outputs are subjected to the max. permissible values
Limit temperatures for storage	–25 °C to +55 °C or –13 °F to +131 °F
Limit temperatures during transport	–25 °C to +70 °C or –13 °F to +158 °F
Storage and transport of the device with factory packaging!	
¹⁾ Limit temperatures for normal operation (i.e. output relays not energized)	–25 °C to +55 °C or –13 °F to +131 °F
¹⁾ Limit temperatures under maximum load (max. cont. admissible input and output values)	–5 °C to +40 °C for 1/2 and 1/1 housing size

¹⁾ UL–certified according to Standard 508 (Industrial Control Equipment)

Humidity

Admissible humidity	Annual average ≤ 75 % relative humidity; on 56 days of the year up to 93% relative humidity. Condensation is to be avoided during operation !
It is recommended that all devices be installed so that they are not exposed to direct sunlight nor subject to large fluctuations in temperature that may cause condensation to occur.	

4.1.8 Service Conditions

The protection device is designed for installation in normal relay rooms and plants, so that electromagnetic immunity is ensured if installation is done properly.	
In addition the following is recommended:	
• Contacts and relays operating within the same cabinet or on the same relay board with digital protection equipment, should be in principle provided with suitable surge suppression components. • For substations with operating voltages of 100 kV and above, all external cables shall be shielded with a conductive shield earthed at both ends. For substations with lower operating voltages, no special measures are normally required. • Do not withdraw or insert individual modules/boards while the protective device is energized. In withdrawn condition, some components are electrostatically endangered; during handling the ESD standards (for Electrostatic Sensitive Devices) must be observed. They are not endangered when inserted into the case.	

4.1.9 Certifications

UL Listed		UL Recognition	
7SD5***-A***-****	Models with threaded terminals	7SD5***-J***-****	Models with plug-in terminals
7SD5***-C***-****		7SD5***-L***-****	
7SD5***-D***-****		7SD5***-M***-****	

4.1.10 Mechanical Design

Housing	7XP20
Dimensions	See dimensional drawings, Section 4.25

Device (for maximum number of components)	Size	Weight
In flush mounting housing	$\frac{1}{2}$	6 kg (13.23 lb)
	$\frac{1}{1}$	10 kg (22.04 lb)
In panel surface mounting housing	$\frac{1}{2}$	11 kg (24.24 lb)
	$\frac{1}{1}$	19 kg (41.88 lb)

Degree of protection according to IEC 60529	
For equipment in surface mounting housing	IP 51
For equipment in flush mounting housing	
Front	IP 51
Back	IP 50
For human safety	IP 2x with cover cap
UL-certification conditions	„For use on a Flat Surface of a Type 1 Enclosure“

4.2 Protection Data Interfaces and Differential Protection Topology

Differential Protection Topology

Number of devices for a protected object (=number of ends of the protected zone limited by CTs)	2 for 7SD5*2
	2 to 6 for 7SD5*3

Protection Data Interfaces

Number	1 or 2
- Connection of optical fibre cable	Mounting location „D“ for one connection or „D“ and „E“ for two connections
For flush mounting housing	On the rear side
For panel surface mounting housing	In console housing at device bottom
Connection modules for protection data interface, depending on the ordering version:	

Module in the Device	Connector Type	Fibre Type	Optical wavelength	Perm. path attenuation	Distance, maximum
FO5 ¹⁾	ST	Multimode 62.5/125µm	820 nm	8 dB	1.5 km (0.93 miles)
FO6 ²⁾	ST	Multimode 62.5/125µm	820 nm	16 dB	3.5 km (2.2 miles)
FO7 ¹⁾	ST	Monomode 9/125 µm	1300 nm	7 dB	10 km (6.25 miles)
FO8 ¹⁾	FC	Monomode 9/125 µm	1300 nm	18 dB	35 km (22 miles)
FO17 ¹⁾	LC	Monomode 9/125 µm	1300 nm	13 dB	24 km
FO18 ^{1) 3)}	LC	Monomode 9/125 µm	1300 nm	29 dB	60 km (37.5 miles)
FO19 ^{1) 3)}	LC	Monomode 9/125 µm	1550 nm	29 dB	100 km (62.5 miles)

¹⁾ Laser class I acc. to EN 60825-1/-2 using glass fibre 62.5/125 µm

²⁾ Laser class 3A acc. to EN 60825-1/-2

³⁾ For direct connection, a suitable optical attenuator should be used to ensure trouble-free functioning and to avoid damage to the device.

- Character Idle State	„Light off“

Protection Data Communication

Direct connection:	
Transmission rate	512 kbit/s
Fibre type	Refer to table above
Optical wavelength	
Permissible link signal attenuation	
Transmission distance	
Connection via communication networks:	
Communication converter	See Appendix A.1, Subsection Accessories

Supported network interfaces	G703.1 with 64 kbit/s;	
	X.21 with 64 or 128 or 512 kbit/s	
	S0 (ISDN) with 64 Kbits or 128 Kbits/s	
	Pilot wires with 128 Kbits/s;	
Connection to communication converter	See table above under module FO 5	
Transmission rate	64 kbit/s with G703.1	
	512 kbit/s or 128 kBit/s or 64 kbit/s with X.21	
	64 Kbits/s or 128 Kbits/s with S0 (ISDN)	
	64 Kbits/s or 128 kBit/s with pilot wires	
Max. runtime time	0.1 ms to 30 ms	Increments 0.1 ms
Max. runtime difference	0.000 ms to 3.000 ms	Increments 0.001 ms
Transmission accuracy	CRC 32 according to CCITT or ITU	

4.3 Differential Protection

Pickup Values

Differential current, I-DIFF>	$I_N = 1 \text{ A}$	0.10 to 20.00 A	Increments 0.01 A
	$I_N = 5 \text{ A}$	0.50 to 100.00 A	
Differential current when switching onto a fault; I-DIF>SWITCH ON	$I_N = 1 \text{ A}$	0.10 to 20.00 A	Increments 0.01 A
	$I_N = 5 \text{ A}$	0.50 to 100.00 A	
Differential current, high set differential current I-DIFF>>	$I_N = 1 \text{ A}$	0.8 to 100.0 A or ∞ (stage disabled)	Increments 0.01 A
	$I_N = 5 \text{ A}$	4.0 to 500.00 A or ∞ (stage disabled)	
Tolerances			
For 2 or 3 ends		5 % of setting value or 1% I_N per end	
For 6 ends		10 % of setting value or 1% I_N per end	

Tripping Times

The operating times depend on the number of ends and the communication speed. The following data presuppose a transmission speed of 512 kBit/s and the output of commands via high-speed output relays (7SD5****-N/P/Q/R/S/T)		
Pickup / trip times of the I-DIFF>> stages at 50 or 60 Hz approx.		
For 2 ends	minimum	9 ms
	typical	12 ms
For 3 ends	minimum	9 ms
	typical	12 ms
For 6 ends	minimum	14 ms
	typical	20 ms
Dropout time of the I-DIFF>> stages approx.		
For all ends	typical	35 ms to 50 ms
Pickup / trip times of the I-DIFF> stages approx.		
For 2 ends	minimum (50/60 Hz)	27/24 ms
	typical (50/60 Hz)	29/26 ms
For 3 ends	minimum (50/60 Hz)	27/24 ms
	typical (50/60 Hz)	31/28 ms
For 6 ends	minimum (50/60 Hz)	32/28 ms
	typical (50/60 Hz)	38/35 ms
Dropout time of the I-DIFF> stages approx.		
For all ends	typical	35 ms to 50 ms

Delay Times

Delay of I-DIFF stage	T-DELAY I-DIFF>	0.00 s to 60.00 s or ∞ (no trip)	Increments 0.01 s
Delay of I-DIFF stage for 1-phase pickup in isolated/compensated net- works	T3I0 1PHAS	0.00 s to 0.50 s or ∞ (stage disabled for 1-phase pickup)	Increments 0.01 s
Expiry tolerances		1 % of set value or 10 ms	
The set times are pure delay times			

Self-Restraint

Current transformer error at each end of the protected object			
Ratio between operating accuracy limit factor and nominal accuracy limit factor n'/n		1 to 10.00	Increments 0.01
Transformer error at n'/n		0.5 % to 50.0 %	Increments 0.1 %
Transformer error at n x I _N (class)		0.5 % to 50.0 %	Increments 0.1 %
Further restraint quantities (adaptive self-restraint)		Frequency deviations, delay time differ- ences, harmonics, synchronous quality, jitter	

Inrush Restraint

Restraint ratio 2. Harmonic I_{2FN}/I_{1N}		0 % to 45 %	Increments 1 %
Max. current for restraint	$I_N = 1 \text{ A}$	1.1 A to 25.0 A	Increments 0.1 A
	$I_N = 5 \text{ A}$	5.5 A to 125.0 A	
Crossblock Function		can be switched on/off	
Max. action time for crossblock CROSSB 2HM		0.00 s to 60.00 s or 0 (crossblock dis- abled) or ∞ (active until dropout)	Increments 0.01 s

Conditioning for Transformers (optional)

Vector group matching		0 to 11 (x 30°)	Increments 1
Star-point conditioning		earthed or non-earthed (for each winding)	

Emergency Operation

In the event of a communication failure, with distance protection out of service	See Section „Time Overcurrent Protection“		

Frequency Operating Range

Frequency	0.8 ≤ f/f _N ≤ 1.2 stable when starting machine

4.4 Breaker Intertrip and Remote Tripping -Direct Local Trip

Breaker Intertrip and Remote Tripping

Intertripping of all opposite ends when single-end tripping	can be switched on/off

External Trip of the Local Tripping

Operating time, total	approx. 6 ms	
Trip time delay Trip Time DELAY	0,00 s to 30,00 s or ∞ (ineffective)	Increments 0.01 s
Expiry tolerances	1 % of setting value or 10 ms	
The set times are pure delay times		
The operating time refers to the output of commands via high-speed output relays (7SD5****-*N/P/Q/R/S/T)		

Remote Tripping

Tripping of remote ends by a command that is coupled into a binary input			
The operating times depend on the number of ends and the communication speed. The following data presuppose a transmission speed of 512 kBit/s and the output of commands via high-speed output relays (7SD5****-*N/P/Q/R/S/T)			
Operating times, total approx.			
For 2 ends	minimum	7 ms	
	typical	12 ms	
For 3 ends	minimum	9 ms	
	typical	13 ms	
For 6 ends	minimum	13 ms	
	typical	18 ms	
Dropout times, total approx.			
For 2 ends	typical	19 ms	
For 3 ends	typical	20 ms	
For 6 ends	typical	26 ms	
Trip time delay	T-ITRIP BI	0.00 s to 30.00 s	Increments 0.01 s
Trip time prolongation	T-ITRIP PROL BI	0.00 s to 30.00 s	Increments 0.01 s
Expiry tolerances		1 % of setting value or 10 ms	
The set times are pure delay times			

4.5 Distance Protection (optional)

Earth Impedance Ratio

R_E/R_L	-0.33 to 7.00	Increments 0.01
X_E/X_L	-0.33 to 7.00	Increments 0.01
	Separate for first and higher zones	
K_0	0.000 to 4.000	Increments 0.001
$PHI (K_0)$	-135.00° to +135.00°	
	Separate for first and higher zones	
The matching factors for earth impedance are valid also for fault locating.		

Mutual Impedance Ratio

R_M/R_L	0.00 to 8.00	Increments 0.01
X_M/X_L	0.00 to 8.00	Increments 0.01
The matching factors for the mutual impedance ratio are valid also for fault locating.		

Phase Preferences

For double earth fault in earthed net	Block leading phase-earth Block lagging phase-earth Release all associated loops Release only phase-to-earth loops Release of phase-to-phase loops
For double earth fault in isolated or resonant-earthed systems	L3(L1) acyclic L1(L3) acyclic L2(L1) acyclic L1(L2) acyclic L3(L2) acyclic L2(L3) acyclic L3(L1) acyclic L1(L3) acyclic All associated loops

Earth Fault Detection

Earth current $3I_0>$	for $I_N = 1\text{ A}$	0.05 A to 4.00 A	Increments 0.01 A
	for $I_N = 5\text{ A}$	0.25 A to 20.00 A	
Earth voltage $3U_0>$		1 V to 100 V; ∞	Increments 1 V
Dropout to pickup ratio		Approx. 0.95	
Measuring tolerances for sinusoidal measured values		$\pm 5\%$	

Pickup (optional)

<u>Overcurrent Pickup</u>			
Overcurrent $I_{ph}>$	for $I_N = 1\text{ A}$	0.25 A to 10.00 A	Increments 0.01 A
	for $I_N = 5\text{ A}$	1.25 A to 50.00 A	
Dropout to pickup ratio		Approx. 0.95	
Measuring tolerances for sinusoidal measured values		$\pm 5\%$	
<u>Voltage and angle-dependent current pickup ($U/I/\phi$) (selectable)</u>			

Characteristic		Different stages with settable inclinations	
Minimum current Iph>	for I _N = 1 A	0.10 A to 4.00 A	Increments 0.01 A
	for I _N = 5 A	0.50 A to 20.00 A	
Current in fault angle range Iφ	for I _N = 1 A	0.10 A to 8.00 A	Increments 0.01 A
	for I _N = 5 A	0.50 A to 40.00 A	
Undervoltage phase-earth Uphe (segregated for Iph>, Iφ> and Iph>>)		20 V to 70 V	Increments 1 V
Undervoltage phase-phase Uphph (segregated for Iph>, Iφ> and Iph>>)		40 V to 130 V	Increments 1 V
Lower threshold angle φ>		30° to 60°	In increments of 1°
Upper threshold angle φ<		90° to 120°	In increments of 1°
Dropout to pickup ratio			
Iph>, Iφ>		Approx. 0.95	
Uphe, Uphph		Approx. 1.05	
Measuring tolerances for sinusoidal measured values			
Values of U, I		± 5 %	
Angle φ		± 3°	
<u>Impedance starting (selectable)</u>			
Minimum current Iph>	for I _N = 1 A	0.05 A to 4.00 A	Increments 0.01 A
	for I _N = 5 A	0.25 A to 20.00 A	
The thresholds of the polygon set to the highest level are relevant taking into consideration the corresponding direction			
Dropout/pickup ratio		Approx. 1.05	

Distance Measurement

Characteristic		Polygonal or MHO characteristic (depending on ordered variant); 5 independent zones and 1 controlled zone	
Setting ranges of polygon:			
$I_{Ph} > \text{min. current, phases}$	for $I_N = 1 \text{ A}$	0.05 A to 4.00 A	Increments 0.01 A
	for $I_N = 5 \text{ A}$	0.25 A to 20.00 A	
$X = \text{reactance reach}$	for $I_N = 1 \text{ A}$	0.050 Ω to 600,000 Ω	Increments 0.001 Ω
	for $I_N = 5 \text{ A}$	0.010 Ω to 120,000 Ω	
$R = \text{resistance tolerance phase-phase}$	for $I_N = 1 \text{ A}$	0.050 Ω to 600,000 Ω	Increments 0.001 Ω
	for $I_N = 5 \text{ A}$	0.010 Ω to 120,000 Ω	
$RE = \text{resistance tolerance phase-earth}$	for $I_N = 1 \text{ A}$	0.050 Ω to 600,000 Ω	Increments 0.001 Ω
	for $I_N = 5 \text{ A}$	0.010 Ω to 120,000 Ω	
$\varphi_{Line} = \text{line angle}$		30° to 89°	Increments 1°
$\varphi_{Dist} = \text{angle of distance protection characteristic}$		30° to 90°	Increments 1°
$\alpha_{Pol} = \text{tilt angle for 1st zone}$		0° to 30°	Increments 1°
Direction determination for polygonal characteristic:			
For all types of faults		With phase-true, memorized or cross-polarized voltages	
Directional sensitivity		Dynamically unlimited Stationary approx. 1V	
Each zone can be set to operate in forward or reverse direction, non-directional or ineffective.			
Setting ranges of the MHO characteristic:			
$I_{Ph} > \text{min. current, phases}$	for $I_N = 1 \text{ A}$	0.05 A to 4.00 A	Increments 0.01 A
	for $I_N = 5 \text{ A}$	0.25 A to 20.00 A	
$Z_r = \text{impedance reach}$	for $I_N = 1 \text{ A}$	0.050 Ω to 200,000 Ω	Increments 0.001 Ω
	for $I_N = 5 \text{ A}$	0.010 Ω to 40,000 Ω	

φ_{Line} = line angle		30° to 89°	Increments 1°
φ_{Dist} = angle of distance protection characteristic		30° to 90°	Increments 1°
Polarization		With memorized or cross-polarized voltages	
Each zone can be set to operate in forward or reverse direction or ineffective.			
Load trapezoid:			
R_{Load} = minimum load resistance	for $I_N = 1 \text{ A}$	0.050 Ω to 600,000 Ω ; ∞	Increments 0.001 Ω
	for $I_N = 5 \text{ A}$	0.010 Ω to 120,000 Ω ; ∞	
φ_{Load} = maximum load angle		20° to 60°	Increments 1°
Dropout ratio			
– Currents		Approx. 0.95	
– Impedances		Approx. 1.06	
Measured value correction		Mutual impedance matching for parallel lines (order option)	
Measuring tolerances for sinusoidal measured values		$\left \frac{\Delta X}{X} \right \leq 5 \%$ for $30^\circ \leq \varphi_k \leq 90^\circ$	
		$\left \frac{\Delta R}{R} \right \leq 5 \%$ for $0^\circ \leq \varphi_k \leq 60^\circ$	
		$\left \frac{\Delta Z}{Z} \right \leq 5 \%$ for $-30^\circ \leq \varphi_k - \varphi_{\text{Line}} \leq 30^\circ$	

Times

Shortest trip time	approx. 17 ms (50 Hz) / 15 ms (60 Hz) with fast relay and approx. 12 ms (50 Hz) /10 ms (60 Hz) with high-speed relay	
Dropout time	Approx. 30 ms	
Stage timers	0.00 s to 30.00 s; ∞ for all zones; separate time setting possibilities for single-phase and multi-phase faults for the zones Z1, Z2, and Z1B	Increments 0.01 s
Time expiry tolerances	1 % of setting value or 10 ms	
The set time is a pure delay time.		

Emergency Operation

If the differential protection and the distance protection operate in parallel in the protective relay, emergency operation will not be activated unless both protection functions have become ineffective.
In case of measured voltage failure, e.g. voltage transformer mcb trip see Section 4.14 „Time Overcurrent Protection“

4.6 System Power Swing (with impedance) (optional)

Power swing detection	Rate of the impedance vector and observation of the path curve	
Maximum power swing frequency	Approx. 7 Hz	
Power swing blocking programs	Block 1st zone only	
	Block higher zones	
	Block 1st and 2nd zone	
	Block all zones	
Power swing trip	Trip following instable power swings (out-of-step)	
Trip time delay after power swing block	0.08 to 5.00 s	Increments 0.01 s

4.7 Teleprotection for Distance Protection (optional)

Mode

For two line ends	With one channel for each direction or with three channels for each direction for phase segregated transmission
For three line ends	With one channel for each direction or connection

Underreach Transfer Trip Schemes

Method	Transfer trip with overreaching zone Z1B PUTT (Pickup) Direct transfer trip
Send signal prolongation	0.00 s to 30.00 s Increments 0.01 s

Comparison Schemes

Method	Permissive Overreach Transfer Trip (POTT) (with overreaching zone Z1B) Dir. Comp. Pickup Unblocking (with overreaching zone Z1B) Blocking (with overreaching zone Z1B) Pilot wire comp. Rev. Interlock	
Send signal prolongation	0.00 s to 30.00 s	Increments 0.01 s
Enable delay	0 s to 30.000 s	Increments 0.001 s
Transient blocking time	0.00 s to 30.00 s	Increments 0.01 s
Wait time for transient blocking	0.00 s to 30.00 s; ∞	Increments 0.01 s
Echo delay time	0.00 s to 30.00 s	Increments 0.01 s
Echo impulse duration	0.00 to 30.00 s	Increments 0.01 s
Time expiry tolerances	1 % of setting value or 10 ms	
The set time is a pure delay time.		

4.8 Earth Fault Protection in Earthed Systems (optional)

Characteristics

Definite Time Stages	$3I_{0>>>}$, $3I_{0>>}$, $3I_{0>}$
Inverse time stage (IDMT)	$3I_{0P}$ one of the characteristics according to Figure 4-1 to Figure 4-4 can be selected
Voltage-dependent stage (U_0 inverse)	Characteristics according to Figure 4-5
Zero-sequence power protection	Characteristics according to Figure 4-6

Very High Set Stage

High current pickup $3I_0>>>$	for $I_N = 1$ A	0.05 A to 25.00 A	Increments 0.01 A
	for $I_N = 5$ A	0.25 A to 125.00 A	
Delay $T_{3I0>>>}$		0.00 s to 30.00 s or ∞ (ineffective)	Increments 0.01 s
Dropout/pickup ratio		Approx. 0.95 for $I/I_N \geq 0.5$	
Pickup time (fast relays/high-speed relays)		approx. 30/25 ms	
Dropout time		Approx. 30 ms	
Tolerances	Current	3 % of setting value or 1 % nominal current	
	Time	1 % of setting value or 10 ms	
The set times are pure delay times			

High Set Stage

Pickup value $3I_{0>>}$	for $I_N = 1$ A	0.05 A to 25.00 A	Increments 0.01 A
	for $I_N = 5$ A	0.25 A to 125.00 A	
Delay $T_{3I0>>}$		0.00 s to 30.00 s or ∞ (ineffective)	Increments 0.01 s
Dropout Ratio		Approx. 0.95 for $I/I_N \geq 0.5$	
Pickup time (fast relays/high-speed relays)		approx. 30/25 ms	
Dropout time		Approx. 30 ms	
Tolerances	Current	3 % of setting value or 1 % nominal current	
	Time	1 % of setting value or 10 ms	
The set times are pure delay times			

Definite Time Overcurrent Stage

Pickup value $3I_{0>}$	for $I_N = 1$ A	0.05 A to 25.00 A or 0.003 A to 25.000 A	Increments 0.01 A Increments 0.001 A
	for $I_N = 5$ A	0.25 A to 125.00 A or 0.015 A to 125.000 A	Increments 0.01 A Increments 0.001 A
Delay $T_{3I_{0>}}$		0.00 s to 30.00 s or ∞ (ineffective)	Increments 0.01 s
Dropout Ratio		Approx. 0.95 for $I/I_N \geq 0.5$	

Pickup time (fast relays/high-speed relays) (1.5 set value) (2.5 set value)		approx. 40/35 ms approx. 30/25 ms
Dropout time		Approx. 30 ms
Tolerances	Current	3 % of setting value or 1 % nominal current
	Time	1 % of setting value or 10 ms
The set times are pure delay times		

Inverse Time Overcurrent Stage (IEC)

Pickup value $3I_{OP}$	for $I_N = 1$ A	0.05 A to 25.00 A or 0.003 A to 25.000 A	Increments 0.01 A Increments 0.001 A
	for $I_N = 5$ A	0.25 A to 125.00 A or 0.015 A to 125.000 A	Increments 0.01 A Increments 0.001 A
Time Factor D_{3IOP}		0.05 s to 3.00 s or ∞ (ineffective)	Increments 0.01 s
Additional time delay $T_{3IOP\ add}$		0.00 s to 30.00 s or ∞ (ineffective)	Increments 0.01 s
Characteristics		See Figure 4-1	
Tolerances	Current	Pickup at $1.05 \leq I/3I_{OP} \leq 1.15$	
	Time	5 % $\pm$ 15 ms for $2 \leq I/3I_{OP} \leq 20$ and $T_{3IOP}/s \geq 1$	

Inverse Time Overcurrent Stage (ANSI)

Pickup value $3I_{OP}$	for $I_N = 1$ A	0.05 A to 25.00 A or 0.003 A to 25.000 A	Increments 0.01 A Increments 0.001 A
	for $I_N = 5$ A	0.25 A to 125.00 A or 0.015 A to 125.000 A	Increments 0.01 A Increments 0.001 A
Time Factor D_{3IOP}		0.50 s to 15.00 s or ∞ (ineffective)	Increments 0.01 s
Additional time delay $T_{3IOP\ add}$		0.00 s to 30.00 s or ∞ (ineffective)	Increments 0.01 s
Characteristics		See Figure 4-2 and 4-3	
Tolerances	Current	Pickup at $1.05 \leq I/3I_{OP} \leq 1.15$	
	Time	5 % $\pm$ 15 ms for $2 \leq I/3I_{OP} \leq 20$ and $D_{3IOP}/s \geq 1$	

Inverse Time Overcurrent Stage with Logarithmic-inverse Characteristic

Pickup value $3I_{OP}$	for $I_N = 1$ A	0.05 A to 25.00 A or 0.003 A to 25.000 A	Increments 0.01 A Increments 0.001 A
	for $I_N = 5$ A	0.25 A to 125.00 A or 0.015 A to 125.000 A	Increments 0.01 A Increments 0.001 A
Start Current Factor $3I_{OP\ FACTOR}$		1.0 to 4.0	Increments 0.1
Time Factor D_{3IOP}		0.05 s to 15.00 s; ∞	Increments 0.01 s
Maximum Time $T_{3IOP\ max}$		0.00 s to 30.00 s	Increments 0.01 s
Minimum Time $T_{3IOP\ min}$		0.00 s to 30.00 s	Increments 0.01 s

Additional time delay $T_{3I_{0P} \text{ add}}$		0.00 s to 30.00 s or ∞ (ineffective)	Increments 0.01 s
Characteristics		See Figure 4-4	
Tolerances Times	inv.	5 % $\pm$ 15 ms for $2 \leq I/3I_{0P} \leq 20$ and $T_{3I_{0P}}/s \geq 1$	
	def.	1 % of setting value or 10 ms	

Zero Sequence Voltage Time Protection Stage (U0-inverse)

Pickup value $3I_{0P}$	for $I_N = 1 \text{ A}$	0.05 A to 25.00 A or 0.003 A to 25.000 A	Increments 0.01 A Increments 0.001 A
	for $I_N = 5 \text{ A}$	0.25 A to 125.00 A or 0.015 A to 125.000 A	Increments 0.01 A Increments 0.001 A
Pickup value $3U_0>$		1.0 V to 10.0 V	Increments 0.1 V
Voltage factor $U_{0 \text{ inv. minimal}}$		0.1 V to 5.0 V	Increments 0.1 V
Additional time delay	$T_{\text{directional}}$	0.00 s to 32.00 s	Increments 0.01 s
	$T_{\text{non-directional}}$	0.00 s to 32.00 s	Increments 0.01 s
Characteristics		See Figure 4-5	
Tolerances times		1 % of setting value or 10 ms	
Dropout Ratio	Current	Approx. 0.95 for $I/I_N \geq 0.5$	
	Voltage	Approx 0.95 for $3U_0 \geq 1 \text{ V}$	
The set times are pure delay times			

Zero Sequence Power Protection Stage


Pickup value $3I_{0P}$	for $I_N = 1 \text{ A}$	0.05 A to 25.00 A 0.003 A to 25.000 A	Increments 0.01 A Increments 0.001 A
	for $I_N = 5 \text{ A}$	0.25 A to 125.00 A 0.015 A to 125.000 A	Increments 0.01 A Increments 0.001 A
Pickup value S FORWARD for $I_N = 1 \text{ A}$ for $I_N = 5 \text{ A}$	0.1 VA to 10.0 VA		Increments 0.1 VA
	0.5 VA to 50.0 VA		
Additional time delay $T_{3I0P \text{ add}}$		0.00 s to 30.00 s; ∞	Increments 0.01 s
Characteristics		See Figure 4-6	
Tolerances pickup values		1 % of set value at sensitive earth current transformer	
Tolerances times		5 % of set value or 15 ms at sensitive earth current transformer 6 % of set value or 15 ms at normal earth current transformer / without earth current transformer	

Inrush Restraint

Second harmonic content for inrush		10 % to 45 %	Increments 1 %
		Referred to fundamental wave	
Inrush blocking is cancelled above	for $I_N = 1 \text{ A}$	0.50 A to 25.00 A	Increments 0.01 A
	for $I_N = 5 \text{ A}$	2.50 A to 125.00 A	
Inrush restraint may be switched effective or ineffective for each individual stage.			


Determination of Direction

Each zone can be set to operate in forward or reverse direction, non-directional or ineffective.			
Direction measurement		With $I_E (= 3 I_0)$ and $3 U_0$ and I_Y or I_2 and U_2	
		with $I_E (= 3 I_0)$ and $3 U_0$ and I_Y	
		With $I_E (= 3 I_0)$ and I_Y (starpoint current of a power transformer)	
		With I_2 and U_2 (negative sequence quantities)	
		With zero-sequence power	
Limit values			
Displacement voltage $3U_0>$		0.5 V to 10.0 V	Increments 0.1 V
Starpoint current of a power transformer $I_Y>$	for $I_N = 1$ A	0.05 A to 1.00 A	Increments 0.01 A
	for $I_N = 5$ A	0.25 A to 5.00 A	
Negative sequence current $3I_2>$	for $I_N = 1$ A	0.05 A to 1.00 A	Increments 0.01 A
	for $I_N = 5$ A	0.25 A to 5.00 A	
Negative sequence voltage $3U_2>$		0.5 V to 10.0 V	Increments 0.1 V
"Forward" angle			
Capacitive alpha		0° to 360°	Increments 1°
Inductive beta		0° to 360°	Increments 1°
Tolerances pickup values		10 % of set value or 5 % of nominal current or 0.5 V	
Tolerance forward angle		5°	
Re-orientation time after direction change		Approx. 30 ms	




Normal inverse:
(Type A)

$$t = \frac{0.14}{(I/I_p)^{0.02} - 1} \cdot T_p \text{ [s]}$$




Very inverse:
(Type B)

$$t = \frac{13.5}{(I/I_p)^1 - 1} \cdot T_p \text{ [s]}$$



Extremely inverse:
(Type C)

$$t = \frac{80}{(I/I_p)^2 - 1} \cdot T_p \text{ [s]}$$




Longtime inverse:

$$t = \frac{120}{(I/I_p)^1 - 1} \cdot T_p \text{ [s]}$$


t Trip time
 T_p Setting value time multiplier
I Fault current
 I_p Setting value current

Note: For earth fault read $3I_{0p}$ instead of I_p and $T_{3I_{0p}}$ instead of T_p


Figure 4-1 Trip time characteristics of inverse time overcurrent stage, acc. IEC (phases and earth)




INVERSE
$$t = \left(\frac{8.9341}{(I/I_p)^{2.0938}} + 0.17966 \right) \cdot D \quad [\text{s}]$$



SHORT INVERSE
$$t = \left(\frac{0.2663}{(I/I_p)^{1.2969}} + 0.03393 \right) \cdot D \quad [\text{s}]$$




LONG INVERSE
$$t = \left(\frac{5.6143}{(I/I_p)^{0.02}} + 2.18592 \right) \cdot D \quad [\text{s}]$$




MODERATELY INVERSE
$$t = \left(\frac{0.0103}{(I/I_p)^{0.02}} + 0.0228 \right) \cdot D \quad [\text{s}]$$


Figure 4-2 Trip time characteristics of inverse time overcurrent stage, acc. ANSI/IEEE (phases and earth)



VERY INVERSE $t = \left(\frac{3.922}{(I/I_p)^2 - 1} + 0.0982 \right) \cdot D \quad [\text{s}]$



EXTREMELY INVERSE $t = \left(\frac{5.64}{(I/I_p)^2 - 1} + 0.02434 \right) \cdot D \quad [\text{s}]$



DEFINITE INVERSE $t = \left(\frac{0.4797}{(I/I_p)^{1.3625} - 1} + 0.21359 \right) \cdot D \quad [\text{s}]$

t Trip time
D Setting value time multiplier
I Fault current
 I_p Setting value current

Note: For earth fault read $3I_{0p}$ instead of I_p and D_{3I0p} instead of D

Figure 4-3 Trip time characteristics of inverse time overcurrent stage, acc. ANSI/IEEE (phases and earth)



Figure 4-4 Trip time characteristic of the inverse time overcurrent stage with logarithmic-inverse characteristic

Logarithmic inverse $t = T_{3IOPmax} - T_{3IOP} \cdot \ln(I/3IOP)$

Note: For $I/3IOP > 35$, the time for $I/3IOP = 35$ applies




Figure 4-5 Trip time characteristics of the zero sequence voltage protection U_0 inverse




Figure 4-6 Tripping characteristics of the zero-sequence power protection

This characteristic applies for: $S_{\text{ref}} = 10 \text{ VA}$ and $T3I_{\text{OPAdd. T\_DELAY}} = 0 \text{ s}$.

4.9 Teleprotection for Earth Fault Protection (optional)

Mode

For two line ends	One channel for each direction or three channels each direction for phase-segregated transmission
For three line ends	With one channel for each direction or connection

Comparison Schemes

Method	Dir. comp. pickup	
	Directional unblocking scheme	
	Directional blocking scheme	
Send signal prolongation	0.00 s to 30.00 s	Increments 0.01 s
Enable delay	0.000 s to 30.000 s	Increments 0.001 s
Transient blocking time	0.00 s to 30.00 s	Increments 0.01 s
Wait time for transient blocking	0.00 s to 30.00 s; ∞	Increments 0.01 s
Echo delay time	0.00 s to 30.00 s	Increments 0.01 s
Echo impulse duration	0.00 s to 30.00 s	Increments 0.01 s
Time expiry tolerances	1 % of setting value or 10 ms	
The set times are pure delay times		

4.10 Weak-infeed Tripping (classic/optional)

Operating mode

Phase segregated undervoltage detection after reception of a carrier signal from the remote end

Undervoltage

Setting value U_{PhE}	2 V to 70 V	Increments 1 V
Dropout to pickup ratio	Approx. 1.1	
Pickup tolerance	$\leq 5\%$ of setting value, or 0.5 V	

Times

Enable delay	0.00 s to 30.00 s	Increments 0.01 s
Enable delay	0.00 s to 30.00 s	Increments 0.01 s
Echo blocking duration after echo	0.00 s to 30.00 s	Increments 0.01 s
Pickup tolerance	1 % of setting value or 10 ms	

4.11 Weak-infeed Tripping (French specif./optional)

Operating Mode

Phase segregated undervoltage detection after reception of a carrier signal from the remote end

Undervoltage

Setting value $U_{PhE}<$	0.10 to 1.00	Increments 0.01
Dropout/pickup ratio	Approx. 1.1	
Pickup tolerance	$\leq 5\%$	

Times

Receive prolongation	0.00 s to 30.00 s	Increments 0.01 s
Extension time $3I0>$	0.00 s to 30.00 s	Increments 0.01 s
Alarm time $3I0>$	0.00 s to 30.00 s	Increments 0.01 s
Delay (single-pole)	0.00 s to 30.00 s	Increments 0.01 s
Delay (multi-pole)	0.00 s to 30.00 s	Increments 0.01 s
Time constant τ	1 to 60 s	Increments 1 s
Pickup tolerance	1 % of setting value or 10 ms	

4.12 Direct Remote Trip and Transmission of Binary Information

Remote Commands

Number of possible remote commands		4
The operating times depend on the number of ends and the communication speed. The following data presuppose a transmission speed of 512 kBit/s and the output of commands via high-speed output relays (7SD5****- *N/P/Q/R/S/T). The operating times refer to the entire signal path from entry via binary inputs until output of commands via output relays.		
Operating times, total approx.		
For 2 ends	minimum	8 ms
	typical	12 ms
For 3 ends	minimum	10 ms
	typical	14 ms
For 6 ends	minimum	15 ms
	typical	18 ms
Dropout times, total approx.		
For 2 ends	typical	19 ms
For 3 ends	typical	20 ms
For 6 ends	typical	26 ms

Remote Indications

Number of possible remote commands		24
The operating times depend on the number of ends and the communication speed. The following data presuppose a transmission speed of 512 kBit/s and the output of commands via high-speed output relays (7SD5****- *N/P/Q/R/S/T). The operating times refer to the entire signal path from entry via binary inputs until output of commands via output relays.		
Operating times, total approx.		
for 2 ends	minimum	9 ms
	typical	16 ms
for 3 ends	minimum	12 ms
	typical	18 ms
for 6 ends	minimum	17 ms
	typical	23 ms
Drop-off times, total approx.		
for 2 ends	typical	24 ms
for 3 ends	typical	25 ms
for 6 ends	typical	32 ms

4.13 Instantaneous High-Current Switch-onto-Fault Protection (SOTF)

Pickup

High current pickup I>>>	for I _N = 1 A	0,10 A bis 15,00 A oder ∞ (unwirksam)	Increments 0.01 A
	for I _N = 5 A	0,50 A bis 75,00 A oder ∞ (unwirksam)	
High current pickup I>>>>	for I _N = 1 A	1.00 A to 25.00 A or ∞ (disabled)	Increments 0.01 A
	for I _N = 5 A	5.00 A to 125.00 A or ∞ (disabled)	
Dropout to pickup ratio		Approx. 90 %	
Pickup tolerance		3 % of setting value or 1 % of I _N	

Times

Shortest trip time (fast relays/high-speed relays)	ca. 10/5 ms

4.14 Time Overcurrent Protection

Operating Modes

As emergency overcurrent protection or back-up overcurrent protection	
Emergency overcurrent protection with differential and distance protection	Effective when the differential protection system is blocked (e.g. because of a failure of the device communication) and the distance protection system is blocked as well, e.g. because of a trip of the voltage transformer mcb (via binary input), a measuring voltage failure or a pickup of the fuse failure monitor
Emergency overcurrent protection with differential protection (distance protection not configured)	Effective when the differential protection system is blocked (e.g. because of a failure of the device communication)
Emergency overcurrent protection with distance protection (differential protection not configured)	Effective when the distance protection system is blocked, e.g. because of a trip of the voltage transformer mcb (via binary input), a measuring voltage failure or a pickup of the fuse failure monitor
Back-up overcurrent protection	operates independent of any events

Characteristics

Definite time stages (definite)	$I_{Ph}>>, 3I_0>>, I_{Ph}>, 3I_0>$
Inverse time stages (IDMT)	$I_P, 3I_{0P}$; one of the characteristics according to Figure 4-1 to 4-3 can be selected

Definite Time High Set Current Stage

Pickup value $I_{ph}>>$ (phases)	for $I_N = 1\text{ A}$	0.10 A to 25.00 A or ∞ (ineffective)	Increments 0.01 A
	for $I_N = 5\text{ A}$	0.50 A to 125.00 A or ∞ (ineffective)	
Pickup value $3I_0>>$ (earth)	for $I_N = 1\text{ A}$	0.05 A to 25.00 A Or ∞ (ineffective)	Increments 0.01 A
	for $I_N = 5\text{ A}$	0.25 A to 125.00 A Or ∞ (ineffective)	
Pickup value $I_{ph}>>$ (phases)		0.00 s to 30.00 s Or ∞ (ineffective)	Increments 0.01 s
Delay $T_{3I_0}>>$ (earth)		0.00 s to 30.00 s Or ∞ (ineffective)	Increments 0.01 s
Dropout Ratio		Approx. 0.95 for $I/I_N \geq 0.5$	
Pickup times (fast relays/high-speed relays)		approx. 30/25 ms	
Dropout times		Approx. 30 ms	
Tolerances	Currents	3 % of setting value or 1 % nominal current	
	Times	1 % of setting value or 10 ms	
The set times are pure delay times			

Definite Time Overcurrent Stage

Pickup value $I_{Ph}>$ (phases)	for $I_N = 1\text{ A}$	0.10 A to 25.00 A Or ∞ (ineffective)	Increments 0.01 A
	for $I_N = 5\text{ A}$	0.50 A to 125.00 A Or ∞ (ineffective)	

Pickup value $3I_{0>}$ (earth)	for $I_N = 1$ A	0.05 A to 25.00 A Or ∞ (ineffective)	Increments 0.01 A
	for $I_N = 5$ A	0.25 A to 125.00 A Or ∞ (ineffective)	
Delay $T_{IPh>}$ (phases)		0.00 s to 30.00 s Or ∞ (ineffective)	Increments 0.01 s
Delay $T_{3I0>}$ (earth)		0.00 s to 30.00 s Or ∞ (ineffective)	Increments 0.01 s
Dropout Ratio		Approx. 0.95 for $I/I_N \geq 0.5$	
Pickup times (fast relays/high-speed relays)		approx. 30/25 ms	
Dropout times		Approx. 30 ms	
Tolerances	Currents	3 % of setting value or 1 % nominal current	
	Times	1 % of setting value or 10 ms	
The set times are pure delay times			

Inverse Time Overcurrent Stage (IEC)

Pickup value I_P (phases)	for $I_N = 1$ A	0.10 A to 4.00 A or ∞ (ineffective)	Increments 0.01 A
	for $I_N = 5$ A	0.50 A to 20.00 A or ∞ (ineffective)	
Pickup value $3I_{0P}$ (earth)	for $I_N = 1$ A	0.05 A to 4.00 A or ∞ (ineffective)	Increments 0.01 A
	for $I_N = 5$ A	0.25 A to 20.00 A or ∞ (ineffective)	
Time factors	T_{IP} (phases)	0.05 s to 3.00 s or ∞ (ineffective)	Increments 0.01 s
	T_{3I0P} (earth)	0.05 s to 3.00 s or ∞ (ineffective)	Increments 0.01 s
Additional time delays	$T_{IP\text{ delayed}}$ (phases)	0.00 s to 30.00 s	Increments 0.01 s
	$T_{3I0P\text{ delayed}}$ (earth)	0.00 s to 30.00 s	Increments 0.01 s
Characteristics		See Figure 4-1	
Tolerances currents		Pickup values at $1.05 \leq I/I_P \leq 1.15$ or $1.05 \leq I/3I_{0P} \leq 1.15$	
Tolerances times		5 % $\pm$ 15 ms for $2 \leq I/I_P \leq 20$ and $T_{IP}/s \geq 1$ or $2 \leq I/3I_{0P} \leq 20$ and $T_{3I0P}/s \geq 1$	
Defined times		1 % of setting value or 10 ms	

Inverse Time Overcurrent Stage (ANSI)

Pickup value I_P (phases)	for $I_N = 1$ A	0.10 A to 4.00 A or ∞ (ineffective)	Increments 0.01 A
	for $I_N = 5$ A	0.50 A to 20.00 A or ∞ (ineffective)	
Pickup value $3I_{0P}$ (earth)	for $I_N = 1$ A	0.05 A to 4.00 A or ∞ (ineffective)	Increments 0.01 A
	for $I_N = 5$ A	0.25 A to 20.00 A or ∞ (ineffective)	

Time factors	D_{IP} (phases)	0.50 s to 15.00 s or ∞ (ineffective)	Increments 0.01 s
	D_{3IOP} (earth)	0.50 s to 15.00 s or ∞ (ineffective)	Increments 0.01 s
Additional time delays	$T_{IP \text{ delayed}}$ (phases)	0.00 s to 30.00 s	Increments 0.01 s
	$T_{3IOP \text{ delayed}}$ (earth)	0.00 s to 30.00 s	Increments 0.01 s
Characteristics		See Figure 4-2 and 4-3	
Tolerances currents		Pickup values at $1.05 \leq I/I_P \leq 1.15$ or $1.05 \leq I/3I_{OP} \leq 1.15$	
Tolerances times		5 % $\pm$ 15 ms for $2 \leq I/I_P \leq 20$ and $D_{IP}/s \geq 1$ or $2 \leq I/3I_{OP} \leq 20$ and $D_{3IOP}/s \geq 1$	
Defined times		1 % of setting value or 10 ms	

Further Definite Stage

Pickup value $I_{Ph}>>>$ (phases)	for $I_N = 1$ A	0.10 A to 25.00 A or ∞ (ineffective)	Increments 0.01 A
	for $I_N = 5$ A	0.50 A to 125.00 A or ∞ (ineffective)	
Pickup value $3I_0>>>$ (earth)	for $I_N = 1$ A	0.05 A to 25.00 A or ∞ (ineffective)	Increments 0.01 A
	for $I_N = 5$ A	0.25 A to 125.00 A or ∞ (ineffective)	
Delays	$T_{I_{Ph}}>>>$	0.00 s to 30.00 s or ∞ (ineffective)	Increments 0.01 s
	$T_{3I_0}>>>$	0.00 s to 30.00 s or ∞ (ineffective)	Increments 0.01 s
Dropout to pickup ratio		Approx. 0.95 for $I/I_N \geq 0.5$	
Pickup times (fast relays/high-speed relays)		approx. 30/25 ms	
Dropout times		Approx. 30 ms	
Tolerances currents	Currents	3 % of setting value or 1 % nominal current	
	Times	1 % of setting value or 10 ms	
The set times are pure delay times.			

4.15 Automatic Reclosure Function (optional)

Automatic Reclosures

Number of reclosures	Max. 8, first 4 with individual settings	
Type (depending on ordered version)	1-pole, 3-pole or 1-/3-pole	
Control	With pickup or trip command	
Action times Initiation possible without pickup and action time	0.01 s to 300.00 s; ∞	Increments 0.01 s
Different dead times before reclosure can be set for all operating modes and cycles	0.01 s to 1800.00 s; ∞	Increments 0.01 s
Dead times after evolving fault recognition	0.01 s to 1800.00 s	Increments 0.01 s
Reclaim time after reclosure	0.50 s to 300.00 s	Increments 0.01 s
Blocking time after dynamic blocking	0.5 sec	
Blocking time after manual closing	0.50 s to 300.00 s; 0	Increments 0.01 s
Start signal monitoring time	0.01 s to 300.00 s	Increments 0.01 s
Circuit breaker monitoring time	0.01 s to 300.00 s	Increments 0.01 s

Adaptive Dead Time / Dead Line Check

Adaptive dead time	With voltage measurement or with close command transmission	
Action times Initiation possible without pickup and action time	0.01 s to 300.00 s; ∞	Increments 0.01 s
Maximum dead time	0.50 s to 3000.00 s	Increments 0.01 s
Voltage measurement dead line or bus	2 V to 70 V (Ph-E)	Increments 1 V
Voltage measurement live or bus	30 V to 90 V (Ph-E)	Increments 1 V
Voltage measuring time	0.10 s to 30.00 s	Increments 0.01 s
Time delay for close command transmission	0.00 to 300.00; ∞	Increments 0.01 s

4.16 Synchronism and Voltage Check (optional)

Operating Modes

Operating modes with automatic reclosure	Synchronism check
	Live bus - dead line
	Dead bus - live line
	Dead bus and dead line
	Bypassing
	Or combination of the above
Synchronism	Closing the circuit breaker under asynchronous power conditions possible (with circuit breaker action time)
Operating modes for manual closure	As for automatic reclosure, independently selectable

Voltages

Maximum operating voltage	20 V to 140 V (phase-to-phase)	Increments 1 V
U< for dead status	1 V to 60 V (phase-to-phase)	Increments 1 V
U> for live status	20 V to 125 V (phase-to-phase)	Increments 1 V
Tolerances	2 % of pickup value or 1 V	
Dropout to pickup ratio	Approx. 0.9 (U>) or 1.1 (U<)	

ΔU -measurement

Voltage difference	1.0 V to 40.0 V (phase-to-phase)	Increments 0.1 V
Tolerance	1 V	
Dropout to pickup ratio	Approx. 1.05	

Synchronous Power Conditions

$\Delta\phi$ -measurement	2° to 80°	Increments 1°
Tolerance	2°	
Δf -measurement	0.03 Hz to 2.00 Hz	Increments 0.01 Hz
Tolerance	15 mHz	
Enable delay	0.00 s to 30.00 s	Increments 0.01 s

Asynchronous Power Conditions

Δf -measurement	0.03 Hz to 2.00 Hz	Increments 0.01 Hz
Tolerance	15 mHz	
Max. angle error	5° for $\Delta f \leq 1$ Hz 10° for $\Delta f > 1$ Hz	
Synchronous/asynchronous limits	0.01 Hz	
Circuit breaker operating time	0.01 s to 0.60 s	Increments 0.01 s

Times

Minimum measuring time	Approx. 80 ms	
Maximum measuring time	0.01 s to 600.00 s; ∞	Increments 0.01 s
Tolerance of all timers	1 % of setting value or 10 ms	

4.17 Undervoltage and Overvoltage Protection (optional)

Phase-earth Overvoltages

Overvoltage $U_{Ph}>>$	1.0 V to 170.0 V; ∞	Increments 0.1 V
Delay $T_{UPh}>>$	0.00 s to 100.00 s; ∞	Increments 0.01 s
Overvoltage $U_{Ph}>$	1.0 V to 170.0 V; ∞	Increments 0.1 V
Delay $T_{UPh}>$	0.00 s to 100.00 s; ∞	Increments 0.01 s
Dropout ratio	0.30 to 0.98	Increments 0.01
Pickup times (fast relays/high-speed relays)	approx. 35/30 ms	
Dropout time	approx. 30 ms	
Tolerances	Voltages	3 % of setting value or 1 V
	Times	1 % of setting value or 10 ms

Phase-phase Overvoltages

Overvoltage $U_{PhPh}>>$	2.0 V to 220.0 V; ∞	Increments 0.1 V
Delay $T_{UPhPh}>>$	0.00 s to 100.00 s; ∞	Increments 0.01 s
Overvoltage $U_{PhPh}>$	2.0 V to 220.0 V; ∞	Increments 0.1 V
Delay $T_{UPhPh}>$	0.00 s to 100.00 s; ∞	Increments 0.01 s
Dropout ratio	0.30 to 0.98	Increments 0.01
Pickup times (fast relays/high-speed relays)	approx. 35/30 ms	
Dropout time	approx. 30 ms	
Tolerances	Voltages	3 % of setting value or 1 V
	Times	1 % of setting value or 10 ms

Overvoltage Positive Sequence System U_1

Overvoltage $U_1>>$	2.0 V to 220.0 V; ∞	Increments 0.1 V
Delay $T_{U1}>>$	0.00 s to 100.00 s; ∞	Increments 0.01 s
Overvoltage $U_1>$	2.0 V to 220.0 V; ∞	Increments 0.1 V
Delay $T_{U1}>$	0.00 s to 100.00 s; ∞	Increments 0.01 s
Dropout ratio	0.30 to 0.98	Increments 0.01
Compounding	Can be switched on/off	
Pickup times (fast relays/high-speed relays)	approx. 35/30 ms	
Dropout time	approx. 30 ms	
Tolerances	Voltages	3 % of setting value or 1 V
	Times	1 % of setting value or 10 ms

Overvoltage Negative Sequence System U_2

Overvoltage $U_2>>$	2.0 V to 220.0 V; ∞	Increments 0.1 V
Delay $T_{U2}>>$	0.00 s to 100.00 s; ∞	Increments 0.01 s
Overvoltage $U_2>$	2.0 V to 220.0 V; ∞	Increments 0.1 V
Delay $T_{U2}>$	0.00 s to 100.00 s; ∞	Increments 0.01 s
Dropout ratio	0.30 to 0.98	Increments 0.01
Pickup times (fast relays/high-speed relays)	approx. 35/30 ms	
Dropout time	approx. 30 ms	

Tolerances	Voltages	3 % of setting value or 1 V
	Times	1 % of setting value or 10 ms

Overvoltage Zero Sequence System $3U_0$ or any Single-Phase Voltage U_x

Overvoltage $3U_{0>>}$	1.0 V to 220.0 V; ∞	Increments 0.1 V
Delay $T_{3U_{0>>}}$	0.00 s to 100.00 s; ∞	Increments 0.01 s
Overvoltage $3U_{0>}$	1.0 V to 220.0 V; ∞	Increments 0.1 V
Delay $T_{3U_{0>}}$	0.00 s to 100.00 s; ∞	Increments 0.01 s
Dropout ratio	0.30 to 0.98	Increments 0.01
Pickup times (fast relays/high-speed relays)		
With repeated measurement		approx. 75/70 ms
Without repeated measurement		approx. 35/30 ms
Dropout time		
With repeated measurement		approx. 75 ms
Without repeated measurement		approx. 30 ms
Tolerances	Voltages	3 % of setting value or 1 V
	Times	1 % of setting value or 10 ms

Phase-earth Undervoltage

Undervoltage $U_{Ph<<}$	1.0 V to 100.0 V	Increments 0.1 V
Delay $T_{U_{Ph<<}}$	0.00 s to 100.00 s; ∞	Increments 0.01 s
Undervoltage $U_{Ph<}$	1.0 V to 100.0 V	Increments 0.1 V
Delay $T_{U_{Ph<}}$	0.00 s to 100.00 s; ∞	Increments 0.01 s
Dropout ratio	approx. 1.05	
Current criterion	Can be switched on/off	
Pickup times (fast relays/high-speed relays)	approx. 35/30 ms	
Dropout time	approx. 30 ms	
Tolerances	Voltages	3 % of setting value or 1 V
	Times	1 % of setting value or 10 ms

Phase-phase Undervoltages

Undervoltage $U_{PhPh<<}$	1.0 V to 175.0 V	Increments 0.1 V
Delay $T_{U_{PhPh<<}}$	0.00 s to 100.00 s; ∞	Increments 0.01 s
Undervoltage $U_{PhPh<}$	1.0 V to 175.0 V	Increments 0.1 V
Delay $T_{U_{PhPh<}}$	0.00 s to 100.00 s; ∞	Increments 0.01 s
Dropout ratio	approx. 1.05	
Current criterion	Can be switched on/off	
Pickup times (fast relays/high-speed relays)	approx. 35/30 ms	
Dropout time	approx. 30 ms	
Tolerances	Voltages	3 % of setting value or 1 V
	Times	1 % of setting value or 10 ms

Undervoltage Positive Sequence System U_1

Undervoltage $U_{1<<}$		1.0 V to 100.0 V	Increments 0.1 V
Delay $T_{U_{1<<}}$		0.00 s to 100.00 s; ∞	Increments 0.01 s
Undervoltage $U_{1<}$		1.0 V to 100.0 V	Increments 0.1 V
Delay $T_{U_{1<}}$		0.00 s to 100.00 s; ∞	Increments 0.01 s
Dropout ratio		approx. 1.05	
Current criterion		Can be switched on/off	
Pickup times (fast relays/high-speed relays)		approx. 35/30 ms	
Dropout time		approx. 30 ms	
Tolerances	Voltages	3 % of setting value or 1 V	
	Times	1 % of setting value or 10 ms	

4.18 Frequency Protection (optional)

Frequency Elements

Quantity	4, depending on setting effective on $f<$ or $f>$

Pickup Values

$f>$ or $f<$ adjustable for each element		
For $f_N = 50$ Hz	45.50 Hz to 54.50 Hz	Increments 0.01 Hz
For $f_N = 60$ Hz	55.50 Hz to 64.50 Hz	Increments 0.01 Hz

Times

Pickup times $f>$, $f<$	Approx. 85 ms	
Dropout times $f>$, $f<$	approx. 30 ms	
Delay times T	0.00 s to 600.00 s	Increments 0.01 s
The set times are pure delay times. Note on dropout times: Dropout was enforced by current = 0 A and voltage = 0 V. Enforcing the dropout by means of a frequency change below the dropout threshold extends the dropout times.		

Dropout Frequency

$\Delta f = \text{pickup value} - \text{dropout value} $	Approx. 20 mHz

Operating Ranges

In voltage range	Approx. 6 V to 230 V (phase-earth)
In frequency range	25 Hz to 70 Hz

Tolerances

Frequencies $f>$, $f<$ in specific range ($f_N \pm 10\%$)	15 mHz in range U_{LE} : 29 to 230 V
Time delays T($f<$, $f>$)	1 % of setting value or 10 ms

4.19 Fault Locator

Start		With trip command or dropout	
Reactance Setting (secondary) in Ω/km or Ω/mile	for $I_N = 1 \text{ A}$	0.0050 Ω/km to 9.5000 Ω/km	Increments 0.001 /km
	for $I_N = 5 \text{ A}$	0.0010 Ω/km to 1.9000 Ω/km	
	for $I_N = 1 \text{ A}$	0.0050 Ω/mile to 15.0000 Ω/mile	Increments 0.001 Ω/mile
	for $I_N = 5 \text{ A}$	0.0010 Ω/mile to 3.0000 Ω/mile	
The other settings can be found in the Power System Data 2.			
When configuring mixed lines, the reactance per unit length must be set for each line section (A1 to A3)			
Parallel line compensation (optional)		Can be switched on/off The setting values are the same as for distance protection (see Section 4.5)	
Taking into consideration the load current in case of single-phase earth faults		Correction of the X-value (can be enabled and disabled)	
Output of the fault distance		In Ω primary and Ω secondary, in km or miles line length ¹⁾ in % of the line length ¹⁾	
Double-ended fault locating		Can be switched on/off	
Measuring tolerances with sinusoidal quantities		2.5 % of the line length at $30^\circ \leq \varphi_k \leq 90^\circ$ and $U_k/U_N \geq 0.1$	
Quality index (double-ended fault location)		0 to 10 (= maximum accuracy)	
Other output options (depending on order variant)		as BCD-code: 4 bit units + 4 bit tens + 1 bit hundreds + data valid bit	
- BCD output time		0.01 s to 180.00 s; ∞	Increments 0.01 s

¹⁾ Output of the fault distance in km, miles, and % requires homogeneous lines or correctly configured line sections

4.20 Circuit Breaker Failure Protection

Circuit Breaker Monitoring

Current flow monitoring	for $I_N = 1 \text{ A}$	0.05 A to 20.00 A	Increments 0.01 A
	for $I_N = 5 \text{ A}$	0.25 A to 100.00 A	
Dropout to pickup ratio		Approx. 0.95	
Tolerance		5 % of setting value or 1 % of nominal current	
Monitoring of circuit breaker auxiliary contact position			
- for three-pole tripping		Binary input for circuit breaker auxiliary contact	
- for single-pole tripping		1 binary input for auxiliary contact per pole or 1 binary input for series connection NO contact and NC contact	
Note: The circuit breaker failure protection can also operate without the indicated circuit breaker auxiliary contacts, but the function range is then reduced. Auxiliary contacts are necessary for the circuit breaker failure protection for tripping without or with a very low current flow (e.g. Buchholz protection, stub fault protection, circuit breaker pole discrepancy monitoring).			

Initiation Conditions

For circuit breaker failure protection	Internal or external single-pole trip ¹⁾ Internal or external three-pole trip ¹⁾ Internal or external three-pole trip without current ¹⁾

¹⁾ Via binary inputs

Times

Pickup time	Approx. 5 ms with measured quantities present Approx. 20 ms after switch-on of measured quantities	
Dropout time, internal (overshoot time)	≤ 15 ms at sinusoidal measured values, ≤ 25 ms maximal	
Delay times for all stages	0.00 s to 30.00 s; ∞	Increments 0.01 s
Tolerance	1 % of setting value or 10 ms	

End Fault Protection

With signal transmission to the opposite line end		
Time delay	0.00 s to 30.00 s; ∞	Increments 0.01 s
Tolerance	1 % of setting value or 10 ms	

Pole Discrepancy Supervision

Initiation criterion	Not all poles are closed or open	
Monitoring time	0.00 s to 30.00 s; ∞	Increments 0.01 s
Tolerance	1 % of setting value or 10 ms	

4.21 Thermal Overload Protection

Setting Ranges

Factor k according to IEC 60255-8	0.10 to 4.00	Increments 0.01
Time Constant τ_{th}	1.0 min to 999.9 min	Increments 0.1 min
Thermal Alarm $\Theta_{Alarm}/\Theta_{Trip}$	50% to 100% of the trip overtemperature	Increments 1 %
Current Overload I_{Alarm}	for $I_N = 1 \text{ A}$	0.10 A to 4.00 A
	for $I_N = 5 \text{ A}$	0.50 A to 20.00 A
		Increments 0.01 A

Calculation Method

Calculation method temperature rise	Maximum temperature rise of 3 phases Average of temperature rise of 3 phases Temperature rise from maximum current

Tripping Characteristic


Tripping characteristic for $(I/k \cdot I_N) \leq 8$	$t = \tau \cdot \ln \frac{\left(\frac{I}{k \cdot I_N}\right)^2 - \left(\frac{I_{pre}}{k \cdot I_N}\right)^2}{\left(\frac{I}{k \cdot I_N}\right)^2 - 1}$
Meaning of abbreviations:	t Tripping time τ Temperature rise time factor I Load current I_{pre} Previous load current k Setting factor according to IEC 60255-8 I_N Rated current of protected object

Dropout to Pickup Ratio

Θ/Θ_{Trip} Θ/Θ_{Alarm} I/I_{Alarm}	Drops out with Θ_{Alarm} Approx. 0.99 Approx. 0.97


Tolerances

Referring to $k \cdot I_N$	2 % or 1 % of nominal current; Class 2 % according to IEC 60255-8
Referring to tripping time	3 % or 1 s for $I/(k \cdot I_N) > 1.25$; class 3 % acc. to IEC 60255-8



without Previous Load Current:

$$t = \tau \cdot \ln \frac{\left(\frac{I}{k \cdot I_N}\right)^2}{\left(\frac{I}{k \cdot I_N}\right)^2 - 1} \quad [\text{min}]$$



with 90 % Previous Load Current:

$$t = \tau \cdot \ln \frac{\left(\frac{I}{k \cdot I_N}\right)^2 - \left(\frac{I_{pre}}{k \cdot I_N}\right)^2}{\left(\frac{I}{k \cdot I_N}\right)^2 - 1} \quad [\text{min}]$$

Figure 4-7 Trip time characteristics of the overload protection

4.22 Monitoring Function

Measured Values

Current sum		$I_F = I_{L1} + I_{L2} + I_{L3} + k_I \cdot I_E > \text{SUM.I Threshold} \cdot I_N + \text{SUM.FactorI} \cdot \Sigma I $	
- SUM.ILimit	for $I_N = 1 \text{ A}$	0.10 A to 2.00 A	Increments 0.01 A
	for $I_N = 5 \text{ A}$	0.50 A to 10.00 A	Increments 0.01 A
- SUM.FACTOR I		0.00 to 0.95	Increments 0.01
Voltage sum		$U_F = U_{L1} + U_{L2} + U_{L3} + k_U \cdot U_{EN} > 25 \text{ V}$	
Current Symmetry		$ I_{\min} / I_{\max} < \text{BAL.FACTOR.I}$ as long as $I_{\max}/I_N > \text{BAL.ILIMIT}/I_N$	
- BAL.FACTOR.I		0.10 to 0.95	Increments 0.01
- BAL.ILIMIT	for $I_N = 1 \text{ A}$	0.10 A to 1.00 A	Increments 0.01 A
	for $I_N = 5 \text{ A}$	0.50 A to 5.00 A	Increments 0.01 A
- T BAL.ILIMIT		5 s to 100 s	Increments 1 s
Broken conductor		One conductor without current, the others with current (monitoring of current transformer circuits on current step change in one phase without residual current)	
Voltage Symmetry		$ U_{\min} / U_{\max} < \text{BAL.FACTOR.U}$ as long as $ U_{\max} > \text{BAL.ULIMIT}$	
- BAL.FACTOR.U		0.58 to 0.95	Increments 0.01
- BAL.ULIMIT		10 V to 100 V	Increments 1 V
- T BAL.ULIMIT		5 s to 100 s	Increments 1 s
Voltage phase sequence		U_{L1} before U_{L2} before U_{L3} as long as $ U_{L1} , U_{L2} , U_{L3} > 40 \text{ V}/\sqrt{3}$	
Non-symmetrical voltages (Fuse failure monitoring)		$3 \cdot U_0 > \text{FFM U} > \text{OR } 3 \cdot U_2 > \text{FFM U} >$ AND at the same time $3 \cdot I_0 < \text{FFM I} < \text{AND } 3 \cdot I_2 < \text{FFM I} <$	
- FFM U>		10 V to 100 V	Increments 1 V
- FFM I<	for $I_N = 1 \text{ A}$	0.10 A to 1.00 A	Increments 0.01 A
	for $I_N = 5 \text{ A}$	0.50 A to 5.00 A	Increments 0.01 A
Three-phase measuring voltage failure (fuse failure monitoring)		All $U_{Ph-E} < \text{FFM UMEAS} <$ AND at the same time all $\Delta I_{Ph} < \text{FFM } I_{\Delta}$ AND All $I_{Ph} > (I_{Ph}) > (\text{Dist.})$ OR All $U_{Ph-E} < \text{FFM UMEAS} <$ AND at the same time All $I_{Ph} < (I_{Ph}) > (\text{Dist.})$ AND All $I_{Ph} > 40 \text{ mA}$	
- FFM UMEAS <		2 V to 100 V	Increments 1 V
- FFM I_{Δ}	for $I_N = 1 \text{ A}$	0.05 A to 1.00 A	Increments 0.01 A
	for $I_N = 5 \text{ A}$	0.25 A to 5.00 A	Increments 0.01 A
- T U-Monitoring (wait time for additional measured voltage failure monitoring)		0.00 s to 30.00 s	Increments 0.01 s
- T UT mcb		0 ms to 30 ms	Increments 1 ms

Trip Circuit Monitoring

Number of monitored circuits	1 to 3	
Operation per circuit	With 1 binary input or with 2 binary inputs	
Pickup and Dropout Time	Approx. 1 to 2 s	
Settable delay time for operation with 1 binary input	1 s to 30 s	Increments 1 s

4.23 User Defined Functions (CFC)

Function Modules and Possible Assignments to Task Levels

Function Module	Explanation	Task Level			
		MW_BEARB	PLC1_BEARB	PLC_BEARB	SFS_BEARB
ABSVALUE	Magnitude calculation	X	–	–	–
ADD	addition	X	X	X	X
AND	AND - Gate	X	X	X	X
BOOL_TO_CO	Boolean to Control (conversion)	–	X	X	–
BOOL_TO_DL	Boolean to Double Point (conversion)	–	X	X	X
BOOL_TO_IC	Bool to internal SI, conversion	–	X	X	X
BUILD_DI	Create Double Point annunciation	–	X	X	X
CMD_CHAIN	Switching sequence	–	X	X	–
CMD_INF	Command information	–	–	–	X
CONNECT	Connection	–	X	X	X
D_FF	D- Flipflop	–	X	X	X
D_FF_MEMO	status memory for restart	X	X	X	X
DI_TO_BOOL	Double Point to Boolean (conversion)	–	X	X	X
DIV	division	X	X	X	X
DM_DECODE	Decode double point	X	X	X	X
DYN_OR	dynamic or	X	X	X	X
LIVE_ZERO		X	–	–	–
LONG_TIMER	Timer (max.1193h)	X	X	X	X
LOOP	Feedback loop	X	X	X	X
LOWER_SETPOINT	Lower limit	X	–	–	–
MUL	multiplication	X	X	X	X
NAND	NAND - Gate	X	X	X	X
NEG	Negator	X	X	X	X
NOR	NOR - Gate	X	X	X	X
OR	OR - Gate	X	X	X	X
RS_FF	RS- Flipflop	–	X	X	X
SQUARE_ROOT	root extractor	X	X	X	X
SR_FF	SR- Flipflop	–	X	X	X
SUB	subtraction	X	X	X	X
TIMER	Timer	–	X	X	–
UPPER_SETPOINT	Upper limit	X	–	–	–
X_OR	XOR - Gate	X	X	X	X
ZERO_POINT	Zero supression	X	–	–	–

General Limits

Description	Limit	Comments
Maximum number of all CFC charts considering all task levels	32	When the limit is exceeded, an error message is output by the device. Consequently, the device starts monitoring. The red ERROR-LED lights up.
Maximum number of all CFC charts considering one task level	16	Only error message (evolving error in processing procedure)
Maximum number of all CFC inputs considering all charts	400	When the limit is exceeded, an error message is output by the device. Consequently, the device starts monitoring. The red ERROR-LED lights up.
Maximum number of inputs of one chart for each task level (number of unequal information items of the left border per task level)	400	Only error message; here the number of elements of the left border per task level is counted. Since the same information is indicated at the border several times, only unequal information is to be counted.
Maximum number of reset-resistant flipflops D_FF_MEMO	50	When the limit is exceeded, an error message is output by the device. Consequently, the device is put into monitoring mode. The red ERROR-LED lights up.

Device-specific Limits

Description	Limit	Comments
Maximum number of synchronous changes of chart inputs per task level	50	When the limit is exceeded, an error message is output by the device. Consequently, the device is put into monitoring mode. The red ERROR-LED lights up.
Maximum number of chart outputs per task level	150	

Additional Limits

Additional limits ¹⁾ for the following 4 CFC blocks:				
Task Level	Maximum Number of Modules in the Task Levels			
	LONG_TIMER	TIMER	CMD_CHAIN	D_FF_MEMO
MW_BEARB	18	9	20	50
PLC1_BEARB				
PLC_BEARB				
SFS_BEARB				

¹⁾ When the limit is exceeded, an error message is output by the device. Consequently, the device is put into monitoring mode. The red ERROR-LED lights up.

Maximum Number of TICKS in the Task Levels

Task Level	Limit in TICKS ¹⁾
MW_BEARB (Measured Value Processing)	10 000
PLC1_BEARB (Slow PLC Processing)	1 900
PLC_BEARB (Fast PLC Processing)	200
SFS_BEARB (switchgear interlocking)	10 000

¹⁾ When the sum of TICKS of all blocks exceeds the limits before-mentioned, an error message is output by CFC.

Processing Times in TICKS required by the Individual Elements

Individual Element		Number of TICKS
Block, basic requirement		5
Each input more than 3 inputs for generic modules		1
Connection to an input signal		6
Connection to an output signal		7
Additional for each chart		1
Operating sequence module	CMD_CHAIN	34
Flipflop	D_FF_MEMO	6
Loop module	LOOP	8
Decoder	DM_DECODE	8
Dynamic OR	DYN_OR	6
Addition	ADD	26
Subtraction	SUB	26
Multiplication	MUL	26
Division	DIV	54
Square root	SQUARE_ROOT	83

4.24 Additional Functions

Measured Values

Operational measured values for currents	$I_{L1}, I_{L2}, I_{L3}, 3I_0, I_1, I_2, I_Y, I_P, I_{EE}$ in A primary and secondary and in % I_N
Tolerance	0.5 % of measured value or 0.5 % of I_N
Phase angles of currents	$\varphi(I_{L1}-I_{L2}), \varphi(I_{L2}-I_{L3}), \varphi(I_{L3}-I_{L1})$ in °
Tolerance	1° at nominal current
Operational measured values for voltages	$U_{L1-E}, U_{L2-E}, U_{L3-E}, 3U_0, U_0, U_1, U_2, U_{1K0}$ in kV primary, in V secondary or in % $U_N/\sqrt{3}$
Tolerance	0.5 % of measured value or 0.5 % of U_N
Operational measured values for voltages	U_{EN}, U_X in V secondary
Tolerance	0.5 % of measured value, or 0.5 % of U_N
Operational measured values for voltages	$U_{L1-L2}, U_{L2-L3}, U_{L3-L1}$ in kV primary, in V secondary or in % U_N
Tolerance	0.5 % of measured value or 0.5 % of U_N
Phase angle of voltages	$\varphi(U_{L1}-U_{L2}), \varphi(U_{L2}-U_{L3}), \varphi(U_{L3}-U_{L1})$ in °
Tolerance	1° at nominal voltage
Phase angle for voltages and currents	$\varphi(U_{L1}-I_{L1}), \varphi(U_{L2}-I_{L2}), \varphi(U_{L3}-I_{L3})$ in °
Tolerance	1° at nominal voltage and nominal current
Operational measured values of impedances	$R_{L1-L2}, R_{L2-L3}, R_{L3-L1}, R_{L1-E}, R_{L2-E}, R_{L3-E},$ $X_{L1-L2}, X_{L2-L3}, X_{L3-L1}, X_{L1-E}, X_{L2-E}, X_{L3-E}$ in Ω primary and secondary
Operational measured values for power	S; P; Q (apparent, active and reactive power) in MVA, MW, Mvar primary and % S_N (operational nominal power) = $\sqrt{3} \cdot U_N \cdot I_N$
Tolerance for S	1 % of S_N at I/I_N and U/U_N in range 50 to 120 %
Tolerance for P	1 % of S_N at I/I_N and U/U_N in the range from 50 to 120 % and
Tolerance for Q	ABS(cos φ) in the range $\geq 0,7$ 1 % of S_N at I/I_N and U/U_N in the range from 50 to 120 % and ABS(cos φ) in the range $\leq 0,7$
Operating measured value for power factor	cos φ
Tolerance	0.02
Counter values for energy	$W_p^+, W_q^+; W_p^-, W_q^-$ (active and reactive energy) in kWh (MWh or GWh) and in kVARh (MVARh or GVARh)
Tolerance at nominal frequency	5 % for $I > 0.5 I_N, U > 0.5 U_N$ and $ \cos \varphi \geq 0.707$
Operational measured values for frequency	f in Hz and % f_N
Range	10 Hz to 75 Hz
Tolerance	20 mHz in range $f_N \pm 10$ % at nominal values
Measured values of the differential protection	$I_{DIFFL1}, I_{DIFFL2}, I_{DIFFL3};$ $I_{RETL1}, I_{RETL2}, I_{RETL3};$ $I_{CL1}, I_{CL2}, I_{CL3};$ $I_{DIFF310}$ in % $I_{NOperation}$
Thermal measured values	$\Theta_{L1}/\Theta_{TRIP}, \Theta_{L2}/\Theta_{TRIP}, \Theta_{L3}/\Theta_{TRIP}, \Theta/\Theta_{TRIP}$ related to tripping temperature rise
Operational measured values of synchro check	$U_{line}, U_{sync}, U_{diff}$ in kV primary $f_{line}, f_{sync}, f_{diff}$ in Hz; φ_{diff} in °

Long-term mean value	I_{L1dmd} ; I_{L2dmd} ; I_{L3dmd} ; I_{1dmd} ; P_{dmd} ; $P_{dmd\ Forw}$; $P_{dmd\ Rev}$; Q_{dmd} ; $Q_{dmd\ Forw}$; $Q_{dmd\ Rev}$; S_{dmd} in primary values
Minimum and maximum values	I_{L1} ; I_{L2} ; I_{L3} ; I_1 ; I_{L1d} ; I_{L2d} ; I_{L3d} ; I_1d ; U_{L1-E} ; U_{L2-E} ; U_{L3-E} ; U_1 ; U_{L1-L2} ; U_{L2-L3} ; U_{L3-L1} ; $3U_0$; $P\ Forw$; $P\ Rev$; $Q\ Forw$; $Q\ Rev$; S ; Pd ; Qd ; Sd ; $\cos \varphi\ Pos$; $\cos \varphi\ Neg$; f in primary values
Remote measured values for currents	I_{L1} ; I_{L2} ; I_{L3} of remote end in % $I_{NOperation}$ $\varphi(I_{L1})$; $\varphi(I_{L2})$; $\varphi(I_{L3})$ (remote versus local) in °
Remote measured values for currents	U_{L1} ; U_{L2} ; U_{L3} of remote end in % $U_{NOperation}/\sqrt{3}$ $\varphi(U_{L1})$; $\varphi(U_{L2})$; $\varphi(U_{L3})$ (remote versus local) in °

Operational Event Log Buffer

Capacity	200 records

Fault Protocol

Capacity	8 faults with a total of max. 600 messages

Fault Recording

Number of stored fault records	Max. 8
Storage time	Max. 5s for each fault approx. 15 s in total
Sampling rate at $f_N = 50\ Hz$	1 ms
Sampling rate at $f_N = 60\ Hz$	0.83 ms

Statistics (serial protection data interface)

Availability of transmission for applications with protection data interface	Availability in %/min and %/h
Delay time of transmission	Resolution 0.01 ms

Statistics

Number of trip events caused by the device	Separately for each breaker pole (if single-pole tripping is possible)
Number of automatic reclosures initiated by the device	Separate for 1-pole and 3-pole AR; Separately for 1st AR cycle and for all further cycles
Total of interrupted currents	Pole segregated
Maximum interrupted current	Pole segregated

Real Time Clock and Buffer Battery

Resolution for operational events	1 ms

Resolution for fault events	1 ms
Buffer battery	Type: 3 V/1 Ah, Type CR 1/2 AA self-discharging time approx. 10 years

Commissioning Tools

Operational Measured Values
Switching device test

Clock

Time Synchronization		DCF 77/IRIG-B-Signal (telegram format IRIG-B000) Binary Input Communication
Operating modes of the clock management		
No.	Operating mode	Explanations
1	Internal	Internal synchronization via RTC (default)
2	IEC 60870-5-103	External via system interface (IEC 60870-5-103)
3	GPS synchronization	External synchronization using GPS interface
4	Time signal IRIG B	External synchronization via IRIG B (telegram format IRIG-B000)
5	Time signal DCF 77	External synchronization via DCF 77
6	Time signal synchro-box	External synchronization using SIMEAS Sync. box
7	Pulse via binary input	External synchronization with pulse via binary input

4.25 Dimensions

4.25.1 Panel Flush and Cubicle Mounting (Housing Size $1\frac{1}{2}$)




Figure 4-8 Dimensions of a device for panel flush or cubicle mounting (size $1\frac{1}{2}$)

4.25.2 Panel Flush and Cubicle Mounting (Housing Size $1\frac{1}{1}$)





Figure 4-9 Dimensions of a device for panel flush or cubicle mounting (size $1\frac{1}{1}$)


4.25.3 Panel Surface Mounting (Housing Size $1/2$)



Dimensions in mm

Figure 4-10 Dimensions of a device for panel surface mounting (size $1/2$)

4.25.4 Panel Surface Mounting (Housing Size $1/1$)



Dimensions in mm

Figure 4-11 Dimensions of a device for panel surface mounting (size $1/1$)

www.ElectricalPartManuals.com

Appendix

A

This appendix is primarily a reference for the experienced user. This section provides ordering information for the models of this device. Connection diagrams for indicating the terminal connections of the models of this device are included. Following the general diagrams are diagrams that show the proper connections of the devices to primary equipment in many typical power system configurations. Tables with all settings and all information available in this device equipped with all options are provided. Default settings are also given.

A.1	Ordering Information and Accessories	582
A.2	Terminal Assignments	590
A.3	Connection Examples	602
A.4	Default Settings	609
A.5	Protocol-dependent Functions	616
A.6	Functional Scope	617
A.7	Settings	619
A.8	Information List	638
A.9	Group Alarms	673
A.10	Measured Values	674

A.1 Ordering Information and Accessories

A.1.1 Ordering Information

A.1.1.1 Ordering Code (MLFB)

Line Differential Protection					5	6	7		8	9	10	11	12		13	14	15	16		
With Distance Protection	7	S	D	5				—						—					+	L/M/N

Function Package/Version	Pos. 5
Line differential protection with 4-line display	2
Line differential protection with graphical display	3

Device Type	Pos. 6
Line differential protection for two-end operation ¹⁾	2
Line differential protection for multi-end operation ²⁾	3

¹⁾ Device with 1 protection data interface for genuine two-end operation OR device with 1 protection data interface for multi-end operation at the ends of a chain topology OR device with 2 protection data interfaces for redundant two-end operation

²⁾ Device with 2 protection data interfaces for multi-end operation

Measured Current Input	Pos. 7
$I_{Ph} = 1\text{ A}$, $I_E = 1\text{ A}$	1
$I_{Ph} = 1\text{ A}$, $I_E = \text{sensitive (min. = 0.005 A)}$	2
$I_{Ph} = 5\text{ A}$, $I_E = 5\text{ A}$	5
$I_{Ph} = 5\text{ A}$, $I_E = \text{sensitive (min. = 0.005 A)}$	6

Auxiliary Voltage (Power Supply, Pickup Threshold of Binary Inputs)	Pos. 8
24 to 48 VDC, binary input threshold 19 V ²⁾	2
60 to 125 VDC ¹⁾ , binary input threshold 19 V ²⁾	4
110 to 250 VDC ¹⁾ , 115 VAC, binary input threshold 88 VDC ²⁾	5
220 to 250 VDC, 115 VAC, binary input threshold 176 VDC ²⁾	6

¹⁾ with plug-in jumper one of the 2 voltage ranges can be selected

²⁾ for each binary input one of 3 pickup threshold ranges can be selected with plug-in jumper

Line Differential Protection					5	6	7		8	9	10	11	12		13	14	15	16		
With Distance Protection	7	S	D	5				—						—					+	L/M/N

Mechanical Design: Housing, Number of Binary Inputs and Outputs	Pos. 9
BI: Binary Inputs, BO: Output Relays	
Flush mounting housing with screwed terminals, $\frac{1}{2}$ x 19", 8 BI, 15 BO, 1 life contact	A
Flush mounting housing with screwed terminals, $\frac{1}{4}$ x 19", 16 BI, 23 BO, 1 life contact	C
Flush mounting housing with screwed terminals, $\frac{1}{4}$ x 19", 24 BI, 31 BO, 1 life contact	D
Surface mounting housing with two-tier terminals, $\frac{1}{2}$ x 19", 8 BI, 15 BO, 1 life contact	E
Surface mounting housing with two-tier terminals, $\frac{1}{4}$ x 19", 16 BI, 23 BO, 1 life contact	G
Surface mounting housing with two-tier terminals, $\frac{1}{4}$ x 19", 24 BI, 31 BO, 1 life contact	H
Flush mounting housing with plug-in terminals, $\frac{1}{2}$ x 19", 8 BI, 15 BO, 1 life contact	J
Flush mounting housing with plug-in terminals, $\frac{1}{4}$ x 19", 16 BI, 23 BO, 1 life contact	L
Flush mounting housing with plug-in terminals, $\frac{1}{4}$ x 19", 24 BI, 31 BO, 1 life contact	M
Flush mounting housing with screw terminals, $\frac{1}{4}$ x 19", 16 BI, 23 BO (5 high-speed relays), 1 life contact	N
Flush mounting housing with screw terminals, $\frac{1}{4}$ x 19", 24 BI, 31 BO (5 high-speed relays), 1 life contact	P
Surface mounting housing with two-tier terminals, $\frac{1}{4}$ x 19", 16 BI, 23 BO (5 high-speed relays), 1 life contact	Q
Surface mounting housing with two-tier terminals, $\frac{1}{4}$ x 19", 24 BI, 31 BO (5 high-speed relays), 1 life contact	R
Flush mounting housing with plug-in terminals, $\frac{1}{4}$ x 19", 16 BI, 23 BO (5 high-speed relays), 1 life contact	S
Flush mounting housing with plug-in terminals, $\frac{1}{4}$ x 19", 24 BI, 31 BO (5 high-speed relays), 1 life contact	T

Region-specific Default / Language Settings and Function Versions	Pos. 10
Region DE, 50 Hz, IEC, language German (language can be changed)	A
Region World, 50/60 Hz, IEC/ANSI, language English (language can be changed)	B
Region USA, 60/50 Hz, ANSI, language American English (language can be changed)	C
Region World, 50/60 Hz, IEC/ANSI, language French (language can be changed)	D
Region World, 50/60 Hz, IEC/ANSI, language Spanish (language can be changed)	E

Line Differential Protection					5	6	7		8	9	10	11	12		13	14	15	16	
With Distance Protection	7	S	D	5				—						—				+	L

System Interfaces (Port B)	Pos. 11
No system interface	0
IEC 60870-5-103 protocol, electrical RS232	1
IEC 60870-5-103 protocol, electrical RS485	2
IEC 60870-5-103 protocol, optical 820 nm, ST connector	3
Profibus FMS Slave, electrical RS485	4
Profibus FMS Slave, optical, 820 nm, double ring, ST connector ¹⁾	6
For more interface options see Additional Specification L	9

Additional Specification L for Further System Interfaces (Port B) (only if Pos. 11 = 9)	Pos. 21	Pos. 22
Profibus DP Slave, electrical RS485	0	A
Profibus DP Slave, optical, 820 nm, double ring, ST connector ¹⁾	0	B
DNP 3.0, electrical RS485	0	G
DNP 3.0, optical, 820 nm, double ring, ST connector ¹⁾	0	H

¹⁾ Not possible for surface mounting housing (pos. 9 = E/G/H/Q/R). For the surface mounted version, please order a device with the appropriate electrical RS485 interface and accessories as stated in Appendix A.1.2 „External converters“.

Line Differential Protection					5	6	7		8	9	10	11	12		13	14	15	16	
With Distance Protection	7	S	D	5				—						—				+	M

Function Interface (Port C and D)	Pos. 12
see Additional Specification M	9

Additional Specification M for DIGSI/modem interface and protection data interface 1 (device rear port C and D) (only if Pos. 12 = 9)	Pos. 23	Pos. 24
No DIGSI/modem interface (device rear)	0	
Port C: DIGSI / Modem / Browser, electrical RS232	1	
Port C: DIGSI / Modem / Browser, electrical RS485	2	
Port C: DIGSI / Modem / Browser, optical, 820 nm, ST connector	3	
Port D: optical, 820 nm, 2 ST connectors, length of optical fibre up to 1.5 km, for direct connection or communication networks using multimode fibre		A
Port D: optical, 820 nm, 2 ST connectors, length of optical fibre up to 3.5 km, for direct connection using multimode fibre		B
Port D: optical, 1300 nm, 2 ST connectors, length of optical fibre up to 10 km, for direct connection using monomode fibre		C
Port D: optical, 1300 nm, 2 FC connectors, length of optical fibre up to 35 km, for direct connection using monomode fibre		D
Port D: optical, 1300 nm, 2 LC duplex connectors, length of optical fibre up to 25 km, for direct connection using monomode fibre		G
Port D: optical, 1300 nm, 2 LC duplex connectors, length of optical fibre up to 60 km, for direct connection using monomode fibre		H
Port D: optical, 1550 nm, 2 LC duplex connectors, length of optical fibre up to 100 km, for direct connection using monomode fibre		J

Line Differential Protection					5	6	7		8	9	10	11	12		13	14	15	16		
With Distance Protection	7	S	D	5				—						—					+	N

Functions 1 and Port E: Protection Data Interface 2	Pos. 13
Three-pole tripping, without automatic reclosure, without synchronism check	0
Three-pole tripping, with automatic reclosure, without synchronism check	1
Single-/three-pole tripping, without automatic reclosure, without synchronism check	2
Single-/three-pole tripping, with automatic reclosure, without synchronism check	3

Functions 1 and Port E: Protection Data Interface 2		Pos. 13
Three-pole tripping, without automatic reclosure, with synchronism check		4
Three-pole tripping, with automatic reclosure, with synchronism check		5
Single-/three-pole tripping, without automatic reclosure, with synchronism check		6
Single-/three-pole tripping, with automatic reclosure, with synchronism check		7
With protection data interface 2, see Additional Specification N		9

Additional Specification N for functions and protection data interface 2 (Port E) (only if Pos. 13 = 9)		Pos. 25	Pos. 26
Three-pole tripping, without automatic reclosure, without synchronism check		0	
Three-pole tripping, with automatic reclosure, without synchronism check		1	
Single-/three-pole tripping, without automatic reclosure, without synchronism check		2	
Single-/three-pole tripping, with automatic reclosure, without synchronism check		3	
Three-pole tripping, without automatic reclosure, with synchronism check		4	
Three-pole tripping, with automatic reclosure, with synchronism check		5	
Single-/three-pole tripping, without automatic reclosure, with synchronism check		6	
Single-/three-pole tripping, with automatic reclosure, with synchronism check		7	
Port E: optical, 820 nm, 2 ST connectors, length of optical fibre up to 1.5 km, for direct connection or communication networks using multimode fibre			A
Port E: optical, 820 nm, 2 ST connectors, length of optical fibre up to 3.5 km, for direct connection using multimode fibre			B
Port E: optical, 1300 nm, 2 ST connectors, length of optical fibre up to 10 km, for direct connection using monomode fibre			C
Port E: optical, 1300 nm, 2 FC connectors, length of optical fibre up to 35 km, for direct connection using monomode fibre			D
Port E: optical, 1300 nm, 2 LC duplex connectors, length of optical fibre up to 25 km, for direct connection using monomode fibre			G
Port E: optical, 1300 nm, 2 LC duplex connectors, length of optical fibre up to 60 km, for direct connection using monomode fibre			H
Port E: optical, 1550 nm, 2 LC duplex connectors, length of optical fibre up to 100 km, for direct connection using monomode fibre			J

Functions				Pos. 14
Overcurrent Protection/ Breaker Failure Protection	Earth Fault Protection	Distance Protection (pickup $Z<$, polygon, parallel line compensation ¹⁾), power swing option with		
		MHO	$I>$, $U/I/\phi$ pickup	
with	without	without	without	C
with	without	without	with	D
with	without	with	without	E
with	with	without	without	F
with	with	without	with	G
with	with	with	without	H

¹⁾ Parallel line compensation only possible if MLFB position 7 = 1 or 5

Additional Functions 1				Pos. 15
Remote Indications	Transformer inside protection zone	Multi-end fault location ¹⁾	Voltage/Frequency Protection	
with	without	without	without	

with	without	without	with	K
with	without	with	without	L
with	without	with	with	M
with	with	without	without	N
with	with	without	with	P
with	with	with	without	Q
with	with	with	with	R

1) The single-ended fault locator is included in the standard scope of functions of all variants.

Additional Functions 2			Pos. 16
Expanded Measured Values (Min, Max, Mean)	External GPS Synchronization of the Differential Protection	Charging Current Compensation	
without	without	without	0
without	with	without	1
with	without	without	2
with	with	without	3
without	without	with	4
without	with	with	5
with	without	with	6
with	with	with	7

A.1.2 Accessories

Communication Converter

Converter for the serial connection of the 7SD5 line protection system to the synchronous communication interfaces X21, G703, to ISDN S0 lines or copper cable CC-CC

Name	Order No.
Optical–electrical communication converter CC-X/G	7XV5662-0AA00
Optical–electrical communication converter CC-S0	7XV5662-0AB01
Optical–electrical communication converter CC-CC	7XV5662-0AC00

Isolating Transformers

Isolating transformers are needed on copper lines if the longitudinal voltage induced in the pilot wires can result in more than 60 % of the test voltage at the communication converter (i.e. 3 kV for CC-CC). They are connected between the communication converter and the communication line.

Name	Order No.
Isolation transformer, test voltage 20 kV	7XR6516

GPS

Name	Order No.
GPS receiver with antenna and cable	7XV5664-0AA0
Power supply	7XV5810-0BA00

Voltage Transformer Miniature Circuit Breaker (VT mcb)

Nominal Values	Order No.
Thermal 1.6 A; magnetic 6 A	3RV1611-1AG14

External Converters

Optical interfaces for Profibus and DNP 3.0 are not possible with surface mounting housings. Please order in this case a device with the appropriate electrical RS485 interface, and the additional converters listed below ¹⁾.

Desired interface; order device with	Additional Converter
Profibus FMS double ring; Profibus DP/FMS RS485	6GK1502-3CB01; 7XV5810-0BA00
DNP 3.0 820 nm; DNP 3.0 RS485	7XV5650-0BA00

¹⁾ The OLM converter 6GK1502-3CB01 requires an operating voltage of 24 VDC. If the operating voltage is > 24 VDC the additional power supply 7XV5810-0BA00 is required.

Exchangeable Interface Modules

Name	Order No.
RS232	C53207-A351-D641-1
RS485	C73207-A351-D642-1
FO 820 nm	C53207-A351-D643-1
Profibus DP RS485	C53207-A351-D611-1
Profibus DP double ring	C53207-A351-D613-1
Profibus FMS RS485	C53207-A351-D603-1
Profibus FMS double ring	C53207-A351-D606-1
DNP 3.0 RS 485	C53207-A351-D631-3
DNP 3.0 820 nm	C53207-A351-D633-3
FO5 with ST-connector; 820 nm; multimode optical fibre - maximum length: 1.5 km ¹⁾	C53207-A351-D651-1
FO6 with ST-connector; 820 nm; multimode optical fibre - maximum length: 3.5 km	C53207-A351-D652-1
FO7 with ST-connector; 1300 nm; monomode optical fibre - maximum length: 10 km	C53207-A351-D653-1
FO8 with ST-connector; 1300 nm; monomode optical fibre - maximum length: 35 km	C53207-A351-D654-1
FO17 with LC duplex connector; 1300 nm; monomode optical fibre - maximum length: 24 km	C53207-A351-D655-1
FO18 with LC duplex connector; 1300 nm; monomode optical fibre - maximum length: 60 km	C53207-A351-D656-1
FO19 with LC duplex connector; 1550 nm; monomode optical fibre - maximum length: 100 km	C53207-A351-D657-1

¹⁾ also used for connection to the optical-electrical communication converter

Terminal Block Covering Caps	For Terminal Type	Order No.
	18 terminal voltage, 12 terminal current block	C73334-A1-C31-1
	12 terminal voltage, 8 terminal current block	C73334-A1-C32-1
Short-Circuit Links	Short-circuit Links as Jumper Kit	Order No.
	3 pcs for current terminals + 6 pcs for voltage terminals	C73334-A1-C40-1
Plug-in Connector	Name	Order No.
	2-pin	C73334-A1-C35-1
	3-pin	C73334-A1-C36-1
Mounting bracket	Name	Order No.
	Mounting bracket	C73165-A63-C200-3
Buffer battery	Lithium Battery 3 V/1 Ah, Type CR 1/2 AA	Order No.
	VARTA	6127 101 501
Interface Cable	Interface cable between PC and SIPROTEC 4 device	Order No.
	Cable with 9-pole male / female connector	7XV5100-4
DIGSI operating software	DIGSI protection operation and configuration software	Order No.
	DIGSI, basic version with licenses for 10 computers	7XS5400-0AA00
	DIGSI, complete version with all option packages	7XS5402-0AA00
Graphical Analysis Program SIGRA	Software for graphical visualization, analysis, and evaluation of fault data. Option package of the complete version of DIGSI	
	Name	Order No.
	SIGRA; Full version with license for 10 computers	7XS5410-0AA0
DIGSI REMOTE 4	Name	Order No.
	Software for remotely operating protective devices via a modem (and possibly a star connector) using DIGSI (option package of the complete version of DIGSI)	7XS5440-1AA0

SIMATIC CFC 4

Name

Order No.

Graphical software for setting interlocking (latching)
control conditions and creating additional functions (option
package of the complete version of DIGSI)

7XS5450-0AA0

A.2 Terminal Assignments

A.2.1 Panel Flush Mounting or Cubicle Mounting

7SD5***-A/J




Figure A-1 General diagram 7SD5***-A/J (panel flush mounting or cubicle mounting; size $1\frac{1}{2}$)

7SD5***-C/L




Figure A-2 General diagram 7SD5***-C/L (panel flush mounting or cubicle mounting; size¹/₁)

7SD5***-N/S




Figure A-3 General diagram 7SD5***-N/S (panel flush mounting or cubicle mounting; size^{1/1})

7SD5***-D/M






Figure A-4 General diagram 7SD5***-D/M (panel flush mounting or cubicle mounting; size^{1/1})

7SD5***-P/T



A.2.2 Panel Surface Mounting

7SD5***-*E

Figure A-6 General diagram 7SD5***-*E (panel surface mounting; size^{1/2})

7SD5***-E (release /CC and higher)




Figure A-7 General diagram 7SD5***-E release /CC and higher (panel surface mounting; size¹/₂)

7SD5***-*G






Figure A-8 General diagram 7SD5***-*G (panel surface mounting; size 1/1)

7SD5***-Q

Figure A-9 General diagram 7SD5***-Q (panel surface mounting; size¹/₁)

7SD5***-H

Figure A-10 General diagram 7SD5***-H (panel surface mounting; size¹/₁)

7SD5***-R




Figure A-11 General diagram 7SD5***-R (panel surface mounting; size 1/1)

7SD5***-*G/H/Q/R
(release /CC and
higher)




Figure A-12 General diagram 7SD5***-*G/H/Q/R release /CC and higher (panel surface mounting, size 1/1)

A.3 Connection Examples

A.3.1 Current Transformer Connection Examples






Figure A-13 Current connections to three current transformers and starpoint current (normal circuit layout)



Important! Cable Shield Grounding must be done on the Cable Side!


Note: Change of Address 0201 Setting Change Polarity of I4 Current Input!




Important! Cable Shield Grounding must be done on the Cable Side!

Note: Change of Address 0201 Setting Change Polarity of I4 Current Input!

Figure A-14 Current connections to 3 current transformers with separate earth current transformer (summation current transformer) preferred for solidly or low-resistive earthed systems.



Housing Size 1/2



Housing Size 1/1

Figure A-15 Current connections to three current transformers and earth current from the star-point connection of a parallel line (for parallel line compensation)




Figure A-16 Current connections to three current transformers and earth current from the star-point current of an earthed power transformer (for directional earth fault protection)

A.3.2 Voltage Transformer Connection Examples




Figure A-17 Voltage connections to three wye-connected voltage transformers (normal circuit layout)





Figure A-18

Voltage connections to three wye-connected voltage transformers with additional open-delta windings (e-n-winding)





Figure A-19 Voltage connections to three wye-connected voltage transformers and additionally to a busbar voltage (for overvoltage protection or synchronism check)

A.4 Default Settings

A.4.1 LEDs

Table A-1 LED Indication Presettings

LEDs	Vorrangierte Funktion	Function No.	Description
LED1	Relay PICKUP L1	503	Relay PICKUP Phase L1
LED2	Relay PICKUP L2	504	Relay PICKUP Phase L2
LED3	Relay PICKUP L3	505	Relay PICKUP Phase L3
LED4	Relay PICKUP E	506	Relay PICKUP Earth
LED5	DT inconsistent	3233	Device table has inconsistent numbers
	DT unequal	3234	Device tables are unequal
	Par. different	3235	Differences between common parameters
	Equal IDs	3487	Equal IDs in constellation
LED6	Relay TRIP	511	Relay GENERAL TRIP command ¹⁾
	Relay TRIP 3ph.	515	Relay TRIP command Phases L123 ²⁾
LED7	no presetting	-	- ¹⁾
	Relay TRIP 1pL1	512	Relay TRIP command - Only Phase L1 ²⁾
	Relay TRIP 1pL2	513	Relay TRIP command - Only Phase L2 ²⁾
	Relay TRIP 1pL3	514	Relay TRIP command - Only Phase L3 ²⁾
LED8	Test Diff.	3190	Diff: Set Teststate of Diff. protection
	TestDiff.remote	3192	Diff: Remote relay in Teststate
LED9	PI1 Data fault	3229	Prot Int 1: Reception of faulty data
LED10	PI2 Data fault	3231	Prot Int 2: Reception of faulty data ³⁾
LED11	Diff block	3148	Diff: Differential protection is blocked
LED12	AR not ready	2784	AR: Auto-reclose is not ready ⁴⁾
LED13	Emer. mode	2054	Emergency mode
LED14	Alarm Sum Event	160	Alarm Summary Event

¹⁾ only devices with three-pole tripping

²⁾ only devices with single-pole and three-pole tripping

³⁾ only devices with 2 protection data interfaces

⁴⁾ only devices with automatic reclosure function

A.4.2 Binary Input

Table A-2 Binary input presettings for all devices and ordering variants

Binary Input	Short Text	Function No.	Description
BI1	>Reset LED	5	>Reset LED
BI2	>Manual Close	356	>Manual close signal
BI3	no presetting	-	-
BI4	>BLOCK O/C I>>	7104	>BLOCK Backup OverCurrent I>>
	>BLOCK O/C I>	7105	>BLOCK Backup OverCurrent I>
	>BLOCK O/C Ip	7106	>BLOCK Backup OverCurrent Ip
	>BLOCK O/C Ie>>	7107	>BLOCK Backup OverCurrent Ie>>
	>BLOCK O/C Ie>	7108	>BLOCK Backup OverCurrent Ie>
	>BLOCK O/C Iep	7109	>BLOCK Backup OverCurrent Iep
	>BLOCK I-STUB	7130	>BLOCK I-STUB
	>BLOCK O/C Ie>>>	7132	>BLOCK Backup OverCurrent Ie>>>
BI5	>CB 3p Open	380	>CB aux. contact 3pole Open
	>CB1 3p Open	411	>CB1 aux. 3p Open (for AR, CB-Test)
BI6	>CB1 Ready	371	>CB1 READY (for AR, CB-Test)
BI7	>Remote Trip1	3541	>Remote Trip 1 signal input

A.4.3 Binary Output

Table A-3 Output relay presettings for all devices and ordering variants

Binary Output	Vorrangierte Funktion	Function No.	Description
BO1	Relay PICKUP	501	Relay PICKUP
BO2	PI1 Data fault	3229	Prot Int 1: Reception of faulty data
BO3	PI2 Data fault	3231	Prot Int 2: Reception of faulty data ¹⁾
BO4	Relay TRIP	511	Relay GENERAL TRIP command ²⁾
	Relay TRIP 1pL1	512	Relay TRIP command - Only Phase L1 ³⁾
	Relay TRIP 3ph.	515	Relay TRIP command Phases L123 ³⁾
BO5	Relay TRIP	511	Relay GENERAL TRIP command ²⁾
	Relay TRIP 1pL2	513	Relay TRIP command - Only Phase L2 ³⁾
	Relay TRIP 3ph.	515	Relay TRIP command Phases L123 ³⁾
BO6	no presetting	-	- ²⁾
	Relay TRIP 1pL3	514	Relay TRIP command - Only Phase L3 ³⁾
	Relay TRIP 3ph.	515	Relay TRIP command Phases L123 ³⁾
BO7	AR CLOSE Cmd.	2851	AR: Close command ⁴⁾
BO8	Diff block	3148	Diff: Differential protection is blocked
BO9	AR not ready	2784	AR: Auto-reclose is not ready ⁴⁾
BO10	Test Diff.	3190	Diff: Set Teststate of Diff. protection
	TestDiff.remote	3192	Diff: Remote relay in Teststate
BO11	Emer. mode	2054	Emergency mode
BO12	Alarm Sum Event	160	Alarm Summary Event
BO13	Relay TRIP	511	Relay GENERAL TRIP command ²⁾
	Relay TRIP 1pL1	512	Relay TRIP command - Only Phase L1 ³⁾
	Relay TRIP 3ph.	515	Relay TRIP command Phases L123 ³⁾
BO14	Relay TRIP	511	Relay GENERAL TRIP command ²⁾
	Relay TRIP 1pL2	513	Relay TRIP command - Only Phase L2 ³⁾
	Relay TRIP 3ph.	515	Relay TRIP command Phases L123 ³⁾
BO15	no presetting	-	- ²⁾
	Relay TRIP 1pL3	514	Relay TRIP command - Only Phase L3 ³⁾
	Relay TRIP 3ph.	515	Relay TRIP command Phases L123 ³⁾

¹⁾ only devices with 2 protection data interfaces

²⁾ only devices with three-pole tripping

³⁾ only devices with single-pole and three-pole tripping

⁴⁾ only devices with automatic reclosure function

A.4.4 Function Keys

Table A-4 Applies to all devices and ordered variants


Function Keys	Vorrangierte Funktion	Function No.	Description
F1	Display of Operational Annunciations	-	-
F2	Display of operational values	-	-
F3	An overview of the last 8 network faults	-	-
F4	none	-	-

A.4.5 Default Display

4-line Display

Table A-5 This selection is available as start page which may be configured.

Page 1	1■ 0.50kA 12■ 6.31kV 2■ 0.50kA 23■ 6.30kV 3■ 0.50kA 31■ 6.29kV E■ 0.0A U0■ 2V
Page 2	% IL ULE ULL L1■ 78.4 99.6 99.5 L2■ 78.1 99.4 99.3 L3■ 78.9 99.8 99.7
Page 3	S: 0.0MVA U: 0kV P: 0.0MW I: 0A Q: 0.0MVAR f: --- cosφ: ---
Page 4	Diff Rest L1■ 0.0% 31.6% L2■ 0.0% 31.6% L3■ 0.0% 31.6%
Page 5	L1■ 78.4A MAX 81.2A L2■ 78.1A MAX 81.0A L3■ 78.9A MAX 81.9A E ■ 0.0A
Page 6	L1■ 78.4A L2■ 78.1A L3■ 78.9A E ■ 0.0A

Graphic Display**Spontaneous Fault Indication of the 4-Line Display**

The spontaneous annunciations on devices with 4-line display serve to display the most important data about a fault. They appear automatically in the display after general interrogation of the device, in the sequence shown in the following Figure.

S/E/F PICKUP
PU - Time
TRIP Time
Fault Locator

Protective Function that Picked up First;
Operating Time from General Pickup to Dropout;
Operating Time from General Pickup to the First Trip Command;

Figure A-20 Spontaneous fault indication display

Spontaneous Fault Annunciations of the Graphic Display

All devices featuring a graphic display allow you to select whether or not to view automatically the most important fault data on the display after a general interrogation.

The information is shown in the display in the following order:

- Relay PICKUP:
- S/E/F TRIP
- PU Time=:
- Trip time=:
- Fault Location

Default Display in the Graphic Editor




Figure A-21 Standard default display after starting the Display Editor - example

A.4.6 Pre-defined CFC Charts

Some CFC charts are already supplied with the SIPROTEC® device. Depending on the variant the following charts may be implemented:

Device and System Logic

The NEGATOR block assigns the input signal „DataStop“ directly to an output. This is not directly possible without the interconnection of this block.




Figure A-22 Logical Link between Input and Output

A.5 Protocol-dependent Functions

Protocol → Function ↓	IEC 60870-5-103	Profibus FMS	Profibus DP	DNP 3.0
Operational Measured Values	Yes	Yes	Yes	Yes
Metered Values	Yes	Yes	Yes	Yes
Fault Recording	Yes	Yes	No	No
Remote Relay Setting				
User-defined Alarms and Switching Objects	Yes	Yes	Predefined „User-defined Alarms“ in CFC	Predefined „User-defined Alarms“ in CFC
Time Synchronization	Via protocol; DCF77/IRIG B/GPS; Interface; Binary Input	Via protocol; DCF77/IRIG B/GPS; Interface; Binary Input	Via DCF77/IRIG B/GPS; Interface; Binary Input	Via protocol; DCF77/IRIG B/GPS; Interface; Binary Input
Messages with Time Stamp	Yes	Yes	No	Yes
Commissioning Tools				
Alarm and Measured Value Transmission Blocking	Yes	Yes	No	No
Generate Test Alarms	Yes	Yes	No	No
Physical Mode	Asynchronous	Asynchronous	Asynchronous	Asynchronous
Transmission Mode	Cyclic/Event	Cyclic/Event	Cyclic	Cyclic/Event
Baud Rate	4800 to 38400	up to 1.5 Mbaud	up to 1.5 Mbaud	2400 to 19200
Type	RS232/RS485 Fibre-optic cables	RS485 Fibre-optic cables Double ring	RS485 Fibre-optic cables Double ring	RS485 Fibre-optic cables

A.6 Functional Scope

Addr.	Parameter	Setting Options	Default Setting	Comments
103	Grp Chge OPTION	Disabled Enabled	Disabled	Setting Group Change Option
110	Trip mode	3pole only 1-/3pole	3pole only	Trip mode
112	DIFF.PROTECTION	Enabled Disabled	Enabled	Differential protection
115	Phase Distance	Quadrilateral MHO Disabled	Quadrilateral	Phase Distance
116	Earth Distance	Quadrilateral MHO Disabled	Quadrilateral	Earth Distance
117	Dis. PICKUP	Z< (quadrilat.) I> (overcurr.) U/I U/I/φ Disabled	Z< (quadrilat.)	Distance protection pickup program
120	Power Swing	Disabled Enabled	Disabled	Power Swing detection
121	Teleprot. Dist.	PUTT (Z1B) PUTT (Pickup) POTT Dir.Comp.Pickup UNBLOCKING BLOCKING Rev. Interlock Pilot wire comp Disabled	Disabled	Teleprotection for Distance prot.
122	DTT Direct Trip	Disabled Enabled	Disabled	DTT Direct Transfer Trip
124	HS/SOTF-O/C	Disabled Enabled	Disabled	Instantaneous HighSpeed/SOTF Overcurrent
125	Weak Infeed	Disabled Enabled Logic no. 2	Disabled	Weak Infeed (Trip and/or Echo)
126	Back-Up O/C	Disabled TOC IEC TOC ANSI	TOC IEC	Backup overcurrent
131	Earth Fault O/C	Disabled TOC IEC TOC ANSI TOC Logarithm. Definite Time U0 inverse Sr inverse	Disabled	Earth fault overcurrent
132	Teleprot. E/F	Dir.Comp.Pickup UNBLOCKING BLOCKING Disabled	Disabled	Teleprotection for Earth fault overcurr.

Addr.	Parameter	Setting Options	Default Setting	Comments
133	Auto Reclose	1 AR-cycle 2 AR-cycles 3 AR-cycles 4 AR-cycles 5 AR-cycles 6 AR-cycles 7 AR-cycles 8 AR-cycles ADT Disabled	Disabled	Auto-Reclose Function
134	AR control mode	Pickup w/ Tact Pickup w/o Tact Trip w/ Tact Trip w/o Tact	Trip w/o Tact	Auto-Reclose control mode
135	Synchro-Check	Disabled Enabled	Disabled	Synchronism and Voltage Check
136	FREQUENCY Prot.	Disabled Enabled	Disabled	Over / Underfrequency Protection
137	U/O VOLTAGE	Disabled Enabled Enabl. w. comp.	Disabled	Under / Overvoltage Protection
138	Fault Locator	Disabled Enabled with BCD-output	Disabled	Fault Locator
139	BREAKER FAILURE	Disabled Enabled	Disabled	Breaker Failure Protection
140	Trip Cir. Sup.	Disabled 1 trip circuit 2 trip circuits 3 trip circuits	Disabled	Trip Circuit Supervision
142	Therm.Overload	Disabled Enabled	Disabled	Thermal Overload Protection
143	TRANSFORMER	NO YES	NO	Transformer inside protection zone
144	V-TRANSFORMER	Not connected connected	connected	Voltage transformers
145	P. INTERFACE 1	Enabled Disabled	Enabled	Protection Interface 1 (Port D)
146	P. INTERFACE 2	Disabled Enabled	Disabled	Protection Interface 2 (Port E)
147	NUMBER OF RELAY	2 relays 3 relays 4 relays 5 relays 6 relays	2 relays	Number of relays
148	GPS-SYNC.	Enabled Disabled	Disabled	GPS synchronization
149	charge I comp.	Enabled Disabled	Disabled	charging current compensation
160	L-sections FL	1 Section 2 Sections 3 Sections	1 Section	Line sections for fault locator

A.7 Settings

Addresses which have an appended "A" can only be changed with DIGSI, under Additional Settings.

The table indicates region-specific presettings. Column C (configuration) indicates the corresponding secondary nominal current of the current transformer.

Addr.	Parameter	Function	C	Setting Options	Default Setting	Comments
201	CT Starpoint	P.System Data 1		towards Line towards Busbar	towards Line	CT Starpoint
203	Unom PRIMARY	P.System Data 1		0.4 .. 1200.0 kV	400.0 kV	Rated Primary Voltage
204	Unom SECONDARY	P.System Data 1		80 .. 125 V	100 V	Rated Secondary Voltage (Ph-Ph)
205	CT PRIMARY	P.System Data 1		10 .. 5000 A	1000 A	CT Rated Primary Current
206	CT SECONDARY	P.System Data 1		1A 5A	1A	CT Rated Secondary Current
207	SystemStarpoint	P.System Data 1		Solid Earthed Peterson-Coil Isolated	Solid Earthed	System Starpoint is
210	U4 transformer	P.System Data 1		Not connected Udelta transf. Usync transf. Ux transformer	Not connected	U4 voltage transformer is
211	Uph / Udelta	P.System Data 1		0.10 .. 9.99	1.73	Matching ratio Phase-VT To Open-Delta-VT
212	Usync connect.	P.System Data 1		L1-E L2-E L3-E L1-L2 L2-L3 L3-L1	L1-E	VT connection for sync. voltage
214A	φ Usync-Uline	P.System Data 1		0 .. 360 °	0 °	Angle adjustment Usync-Uline
215	U-line / Usync	P.System Data 1		0.50 .. 2.00	1.00	Matching ratio U-line / Usync
220	I4 transformer	P.System Data 1		Not connected In prot. line In paral. line IY starpoint	In prot. line	I4 current transformer is
221	I4/Iph CT	P.System Data 1		0.010 .. 5.000	1.000	Matching ratio I4/Iph for CT's
230	Rated Frequency	P.System Data 1		50 Hz 60 Hz	50 Hz	Rated Frequency
236	Distance Unit	P.System Data 1		km Miles	km	Distance measurement unit
237	Format Z0/Z1	P.System Data 1		RE/RL, XE/XL K0	RE/RL, XE/XL	Setting format for zero seq.comp. format
239	T-CB close	P.System Data 1		0.01 .. 0.60 sec	0.06 sec	Closing (operating) time of CB
240A	TMin TRIP CMD	P.System Data 1		0.02 .. 30.00 sec	0.10 sec	Minimum TRIP Command Duration
241A	TMax CLOSE CMD	P.System Data 1		0.01 .. 30.00 sec	1.00 sec	Maximum Close Command Duration
242	T-CBtest-dead	P.System Data 1		0.00 .. 30.00 sec	0.10 sec	Dead Time for CB test-autoreclosure
251	K_ALF/K_ALF_N	P.System Data 1		1.00 .. 10.00	1.00	k_alf/k_alf nominal
253	E% ALF/ALF_N	P.System Data 1		0.5 .. 50.0 %	5.0 %	CT Error in % at k_alf/k_alf nominal
254	E% K_ALF_N	P.System Data 1		0.5 .. 50.0 %	15.0 %	CT Error in % at k_alf nominal
301	ACTIVE GROUP	Change Group		Group A Group B Group C Group D	Group A	Active Setting Group is
302	CHANGE	Change Group		Group A Group B Group C Group D Binary Input Protocol	Group A	Change to Another Setting Group

Addr.	Parameter	Function	C	Setting Options	Default Setting	Comments
402A	WAVEFORMTRIGGER	Osc. Fault Rec.		Save w. Pickup Save w. TRIP Start w. TRIP	Save w. Pickup	Waveform Capture
403A	WAVEFORM DATA	Osc. Fault Rec.		Fault event Pow.Sys.Flt.	Fault event	Scope of Waveform Data
410	MAX. LENGTH	Osc. Fault Rec.		0.30 .. 5.00 sec	2.00 sec	Max. length of a Waveform Capture Record
411	PRE. TRIG. TIME	Osc. Fault Rec.		0.05 .. 0.50 sec	0.25 sec	Captured Waveform Prior to Trigger
412	POST REC. TIME	Osc. Fault Rec.		0.05 .. 0.50 sec	0.10 sec	Captured Waveform after Event
415	BinIn CAPT.TIME	Osc. Fault Rec.		0.10 .. 5.00 sec; ∞	0.50 sec	Capture Time via Binary Input
610	FltDisp.LED/LCD	Device		Target on PU Target on TRIP	Target on PU	Fault Display on LED / LCD
615	Spont. FltDisp.	Device		NO YES	NO	Spontaneous display of flt.an-nunciations
640	Start image DD	Device		image 1 image 2 image 3 image 4 image 5 image 6	image 1	Start image Default Display
1103	FullScaleVolt.	P.System Data 2		0.4 .. 1200.0 kV	400.0 kV	Measurement: Full Scale Voltage (100%)
1104	FullScaleCurr.	P.System Data 2		10 .. 5000 A	1000 A	Measurement: Full Scale Current (100%)
1105	Line Angle	P.System Data 2		30 .. 89 °	85 °	Line Angle
1106	OPERATION POWER	P.System Data 2		0.2 .. 5000.0 MVA	692.8 MVA	Operational power of protection zone
1107	P,Q sign	P.System Data 2		not reversed reversed	not reversed	P,Q operational measured values sign
1111	x'	P.System Data 2	1A	0.0050 .. 9.5000 Ω/km	0.1500 Ω/km	x' - Line Reactance per length unit
			5A	0.0010 .. 1.9000 Ω/km	0.0300 Ω/km	
1111	x'	P.System Data 2	1A	0.0050 .. 15.0000 Ω/mi	0.2420 Ω/mi	x' - Line Reactance per length unit
			5A	0.0010 .. 3.0000 Ω/mi	0.0484 Ω/mi	
1112	c'	P.System Data 2	1A	0.000 .. 100.000 μF/km	0.010 μF/km	c' - capacit. per unit line len. μF/km
			5A	0.000 .. 500.000 μF/km	0.050 μF/km	
1112	c'	P.System Data 2	1A	0.000 .. 160.000 μF/mi	0.016 μF/mi	c' - capacit. per unit line len. μF/mile
			5A	0.000 .. 800.000 μF/mi	0.080 μF/mi	
1113	Line Length	P.System Data 2		0.1 .. 1000.0 km	100.0 km	Line Length
1113	Line Length	P.System Data 2		0.1 .. 650.0 Miles	62.1 Miles	Line Length
1114	Tot.Line Length	P.System Data 2		0.1 .. 1000.0 km	100.0 km	Total Line Length
1114	Tot.Line Length	P.System Data 2		0.1 .. 650.0 Miles	62.1 Miles	Total Line Length
1116	RE/RL(Z1)	P.System Data 2		-0.33 .. 7.00	1.00	Zero seq. comp. factor RE/RL for Z1
1117	XE/XL(Z1)	P.System Data 2		-0.33 .. 7.00	1.00	Zero seq. comp. factor XE/XL for Z1
1118	RE/RL(Z1B...Z5)	P.System Data 2		-0.33 .. 7.00	1.00	Zero seq. comp.factor RE/RL for Z1B...Z5
1119	XE/XL(Z1B...Z5)	P.System Data 2		-0.33 .. 7.00	1.00	Zero seq. comp.factor XE/XL for Z1B...Z5
1120	K0 (Z1)	P.System Data 2		0.000 .. 4.000	1.000	Zero seq. comp. factor K0 for zone Z1
1121	Angle K0(Z1)	P.System Data 2		-135.00 .. 135.00 °	0.00 °	Zero seq. comp. angle for zone Z1
1122	K0 (> Z1)	P.System Data 2		0.000 .. 4.000	1.000	Zero seq.comp.factor K0,higher zones >Z1
1123	Anglel K0(> Z1)	P.System Data 2		-135.00 .. 135.00 °	0.00 °	Zero seq. comp. angle, higher zones >Z1
1124	center phase	P.System Data 2		unknown/sym. Phase 1 Phase 2 Phase 3	unknown/sym.	center phase of feeder
1125	C0/C1	P.System Data 2		0.01 .. 10.00	0.75	Compensation factor C0/C1

Addr.	Parameter	Function	C	Setting Options	Default Setting	Comments
1126	RM/RL ParalLine	P.System Data 2		0.00 .. 8.00	0.00	Mutual Parallel Line comp. ratio RM/RL
1127	XM/XL ParalLine	P.System Data 2		0.00 .. 8.00	0.00	Mutual Parallel Line comp. ratio XM/XL
1128	RATIO Par. Comp	P.System Data 2		50 .. 95 %	85 %	Neutral current RATIO Parallel Line Comp
1130A	PoleOpenCurrent	P.System Data 2	1A	0.05 .. 1.00 A	0.10 A	Pole Open Current Threshold
			5A	0.25 .. 5.00 A	0.50 A	
1131A	PoleOpenVoltage	P.System Data 2		2 .. 70 V	30 V	Pole Open Voltage Threshold
1132A	SI Time all Cl.	P.System Data 2		0.01 .. 30.00 sec	0.10 sec	Seal-in Time after ALL closures
1134	Line Closure	P.System Data 2		only with ManCl I OR U or ManCl CB OR I or M/C I or Man.Close	I or Man.Close	Recognition of Line Closures with
1135	Reset Trip CMD	P.System Data 2		CurrentOpenPole Current AND CB	CurrentOpenPole	RESET of Trip Command
1140A	I-CTsat. Thres.	P.System Data 2	1A	0.2 .. 50.0 A; ∞	20.0 A	CT Saturation Threshold
			5A	1.0 .. 250.0 A; ∞	100.0 A	
1150A	SI Time Man.Cl	P.System Data 2		0.01 .. 30.00 sec	0.30 sec	Seal-in Time after MANUAL closures
1151	MAN. CLOSE	P.System Data 2		with Sync-check w/o Sync-check NO	NO	Manual CLOSE COMMAND generation
1152	Man.Clos. Imp.	P.System Data 2		(Setting options depend on configuration)	None	MANUAL Closure Impulse after CONTROL
1155	3pole coupling	P.System Data 2		with PICKUP with TRIP	with TRIP	3 pole coupling
1156A	Trip2phFlt	P.System Data 2		3pole 1pole leading Ø 1pole lagging Ø	3pole	Trip type with 2phase faults
1161	VECTOR GROUP U	P.System Data 2		0 .. 11	0	Vector group numeral for voltage
1162	VECTOR GROUP I	P.System Data 2		0 .. 11	0	Vector group numeral for current
1163	TRANS STP IS	P.System Data 2		Solid Earthed Not Earthed	Solid Earthed	Transformer starpoint is
1201	STATE OF DIFF.	Diff. Prot		OFF ON	ON	State of differential protection
1210	I-DIFF>	Diff. Prot	1A	0.10 .. 20.00 A	0.30 A	I-DIFF>: Pickup value
			5A	0.50 .. 100.00 A	1.50 A	
1213	I-DIF>SWITCH ON	Diff. Prot	1A	0.10 .. 20.00 A	0.30 A	I-DIFF>: Value under switch on condition
			5A	0.50 .. 100.00 A	1.50 A	
1217A	T-DELAY I-DIFF>	Diff. Prot		0.00 .. 60.00 sec; ∞	0.00 sec	I-DIFF>: Trip time delay
1218	T3I0 1PHAS	Diff. Prot Dis. General		0.00 .. 0.50 sec; ∞	0.04 sec	Delay 1ph-faults (comp/isol. star-point)
1221	Ic-comp.	Diff. Prot		OFF ON	OFF	Charging current compensation
1224	IcSTAB/IcN	Diff. Prot		2.0 .. 4.0	2.5	Ic Stabilising / Ic Nominal
1233	I-DIFF>>	Diff. Prot	1A	0.8 .. 100.0 A; ∞	1.2 A	I-DIFF>>: Pickup value
			5A	4.0 .. 500.0 A; ∞	6.0 A	
1301	I-TRIP SEND	Intertrip		YES NO	NO	State of transmit. the intertrip command
1302	I-TRIP RECEIVE	Intertrip		Alarm only Trip	Trip	Reaction if intertrip command is receiv.
1303	T-ITRIP BI	Intertrip		0.00 .. 30.00 sec	0.02 sec	Delay for intertrip via binary input
1304	T-ITRIP PROL BI	Intertrip		0.00 .. 30.00 sec	0.00 sec	Prolongation for intertrip via bin.input
1501	FCT Distance	Dis. General		ON OFF	ON	Distance protection
1502	Minimum Iph>	Dis. General	1A	0.05 .. 4.00 A	0.10 A	Phase Current threshold for dist. meas.
			5A	0.25 .. 20.00 A	0.50 A	
1503	3I0> Threshold	Dis. General	1A	0.05 .. 4.00 A	0.10 A	3I0 threshold for neutral current pickup
			5A	0.25 .. 20.00 A	0.50 A	

Addr.	Parameter	Function	C	Setting Options	Default Setting	Comments
1504	3U0> Threshold	Dis. General		1 .. 100 V; ∞	5 V	3U0 threshold zero seq. voltage pickup
1505	3U0> COMP/ISOL.	Dis. General		10 .. 200 V	40 V	3U0> pickup (comp/ isol. start-point)
1507A	3I0>/ Iphmax	Dis. General		0.05 .. 0.30	0.10	3I0>-pickup-stabilisation (3I0>/Iphmax)
1508	SER-COMP.	Dis. General		NO YES	NO	Series compensated line
1509A	E/F recognition	Dis. General		3I0> OR 3U0> 3I0> AND 3U0>	3I0> OR 3U0>	criterion for earth fault recognition
1510	Start Timers	Dis. General		on Dis. Pickup on Zone Pickup	on Dis. Pickup	Condition for zone timer start
1515	Paral.Line Comp	Dis. General		NO YES	YES	Mutual coupling parall.line compensation
1520	PHASE PREF.2phe	Dis. General		L3 (L1) ACYCLIC L1 (L3) ACYCLIC L2 (L1) ACYCLIC L1 (L2) ACYCLIC L3 (L2) ACYCLIC L2 (L3) ACYCLIC L3 (L1) CYCLIC L1 (L3) CYCLIC All loops	L3 (L1) ACYCLIC	Phase preference for 2ph-e faults
1521A	2Ph-E faults	Dis. General		Block leading Ø Block lagging Ø All loops Ø-Ø loops only Ø-E loops only	Block leading Ø	Loop selection with 2Ph-E faults
1532	SOTF zone	Dis. General		PICKUP Zone Z1B Inactive Z1B undirect.	Inactive	Instantaneous trip after Switch-OnToFault
1533	Z1 blkd by diff	Dis. General		YES NO	YES	Zone Z1 blocked by diff. active
1540	Distance Angle	P.System Data 2 Dis. General		30 .. 90 °	85 °	Angle of inclination, distance charact.
1541	R load (Ø-E)	Dis. General	1A 5A	0.100 .. 600.000 Ω; ∞ 0.020 .. 120.000 Ω; ∞	∞ Ω ∞ Ω	R load, minimum Load Impedance (ph-e)
1542	φ load (Ø-E)	Dis. General		20 .. 60 °	45 °	PHI load, maximum Load Angle (ph-e)
1543	R load (Ø-Ø)	Dis. General	1A 5A	0.100 .. 600.000 Ω; ∞ 0.020 .. 120.000 Ω; ∞	∞ Ω ∞ Ω	R load, minimum Load Impedance (ph-ph)
1544	φ load (Ø-Ø)	Dis. General		20 .. 60 °	45 °	PHI load, maximum Load Angle (ph-ph)
1601	Op. mode Z1	Dis. Quadril.		Forward Reverse Non-Directional Inactive	Forward	Operating mode Z1
1602	R(Z1) Ø-Ø	Dis. Quadril.	1A 5A	0.050 .. 600.000 Ω 0.010 .. 120.000 Ω	1.250 Ω 0.250 Ω	R(Z1), Resistance for ph-ph faults
1603	X(Z1)	Dis. Quadril.	1A 5A	0.050 .. 600.000 Ω 0.010 .. 120.000 Ω	2.500 Ω 0.500 Ω	X(Z1), Reactance
1604	RE(Z1) Ø-E	Dis. Quadril.	1A 5A	0.050 .. 600.000 Ω 0.010 .. 120.000 Ω	2.500 Ω 0.500 Ω	RE(Z1), Resistance for ph-e faults
1605	T1-1phase	Dis. General Dis. Quadril. Dis. MHO		0.00 .. 30.00 sec; ∞	0.00 sec	T1-1phase, delay for single phase faults
1606	T1-multi-phase	Dis. General Dis. Quadril. Dis. MHO		0.00 .. 30.00 sec; ∞	0.00 sec	T1multi-ph, delay for multi phase faults
1607	Zone Reduction	Dis. Quadril.		0 .. 45 °	0 °	Zone Reduction Angle (load compensation)
1611	Op. mode Z2	Dis. Quadril.		Forward Reverse Non-Directional Inactive	Forward	Operating mode Z2

Addr.	Parameter	Function	C	Setting Options	Default Setting	Comments
1612	R(Z2) Ø-Ø	Dis. Quadril.	1A	0.050 .. 600.000 Ω	2.500 Ω	R(Z2), Resistance for ph-ph-faults
			5A	0.010 .. 120.000 Ω	0.500 Ω	
1613	X(Z2)	Dis. Quadril.	1A	0.050 .. 600.000 Ω	5.000 Ω	X(Z2), Reactance
			5A	0.010 .. 120.000 Ω	1.000 Ω	
1614	RE(Z2) Ø-E	Dis. Quadril.	1A	0.050 .. 600.000 Ω	5.000 Ω	RE(Z2), Resistance for ph-e-faults
			5A	0.010 .. 120.000 Ω	1.000 Ω	
1615	T2-1phase	Dis. General Dis. Quadril. Dis. MHO		0.00 .. 30.00 sec; ∞	0.30 sec	T2-1phase, delay for single phase faults
1616	T2-multi-phase	Dis. General Dis. Quadril. Dis. MHO		0.00 .. 30.00 sec; ∞	0.30 sec	T2multi-ph, delay for multi phase faults
1617A	Trip 1pole Z2	Dis. General Dis. Quadril. Dis. MHO		NO YES	NO	Single pole trip for faults in Z2
1621	Op. mode Z3	Dis. Quadril.		Forward Reverse Non-Directional Inactive	Reverse	Operating mode Z3
1622	R(Z3) Ø-Ø	Dis. Quadril.	1A	0.050 .. 600.000 Ω	5.000 Ω	R(Z3), Resistance for ph-ph-faults
			5A	0.010 .. 120.000 Ω	1.000 Ω	
1623	X(Z3)	Dis. Quadril.	1A	0.050 .. 600.000 Ω	10.000 Ω	X(Z3), Reactance
			5A	0.010 .. 120.000 Ω	2.000 Ω	
1624	RE(Z3) Ø-E	Dis. Quadril.	1A	0.050 .. 600.000 Ω	10.000 Ω	RE(Z3), Resistance for ph-e-faults
			5A	0.010 .. 120.000 Ω	2.000 Ω	
1625	T3 DELAY	Dis. General Dis. Quadril. Dis. MHO		0.00 .. 30.00 sec; ∞	0.60 sec	T3 delay
1631	Op. mode Z4	Dis. Quadril.		Forward Reverse Non-Directional Inactive	Non-Directional	Operating mode Z4
1632	R(Z4) Ø-Ø	Dis. Quadril.	1A	0.050 .. 600.000 Ω	12.000 Ω	R(Z4), Resistance for ph-ph-faults
			5A	0.010 .. 120.000 Ω	2.400 Ω	
1633	X(Z4)	Dis. Quadril.	1A	0.050 .. 600.000 Ω	12.000 Ω	X(Z4), Reactance
			5A	0.010 .. 120.000 Ω	2.400 Ω	
1634	RE(Z4) Ø-E	Dis. Quadril.	1A	0.050 .. 250.000 Ω	12.000 Ω	RE(Z4), Resistance for ph-e-faults
			5A	0.010 .. 50.000 Ω	2.400 Ω	
1635	T4 DELAY	Dis. General Dis. Quadril. Dis. MHO		0.00 .. 30.00 sec; ∞	0.90 sec	T4 delay
1641	Op. mode Z5	Dis. Quadril.		Forward Reverse Non-Directional Inactive	Inactive	Operating mode Z5
1642	R(Z5) Ø-Ø	Dis. Quadril.	1A	0.050 .. 600.000 Ω	12.000 Ω	R(Z5), Resistance for ph-ph-faults
			5A	0.010 .. 120.000 Ω	2.400 Ω	
1643	X(Z5)+	Dis. Quadril.	1A	0.050 .. 600.000 Ω	12.000 Ω	X(Z5)+, Reactance for Forward direction
			5A	0.010 .. 120.000 Ω	2.400 Ω	
1644	RE(Z5) Ø-E	Dis. Quadril.	1A	0.050 .. 600.000 Ω	12.000 Ω	RE(Z5), Resistance for ph-e-faults
			5A	0.010 .. 120.000 Ω	2.400 Ω	
1645	T5 DELAY	Dis. General Dis. Quadril. Dis. MHO		0.00 .. 30.00 sec; ∞	0.90 sec	T5 delay
1646	X(Z5)-	Dis. Quadril.	1A	0.050 .. 600.000 Ω	4.000 Ω	X(Z5)-, Reactance for Reverse direction
			5A	0.010 .. 120.000 Ω	0.800 Ω	
1651	Op. mode Z1B	Dis. Quadril.		Forward Reverse Non-Directional Inactive	Forward	Operating mode Z1B (overreach zone)
1652	R(Z1B) Ø-Ø	Dis. Quadril.	1A	0.050 .. 600.000 Ω	1.500 Ω	R(Z1B), Resistance for ph-ph-faults
			5A	0.010 .. 120.000 Ω	0.300 Ω	

Addr.	Parameter	Function	C	Setting Options	Default Setting	Comments
1653	X(Z1B)	Dis. Quadril.	1A	0.050 .. 600.000 Ω	3.000 Ω	X(Z1B), Reactance
			5A	0.010 .. 120.000 Ω	0.600 Ω	
1654	RE(Z1B) $\emptyset$ -E	Dis. Quadril.	1A	0.050 .. 600.000 Ω	3.000 Ω	RE(Z1B), Resistance for ph-e faults
			5A	0.010 .. 120.000 Ω	0.600 Ω	
1655	T1B-1phase	Dis. General Dis. Quadril. Dis. MHO		0.00 .. 30.00 sec; ∞	0.00 sec	T1B-1phase, delay for single ph. faults
1656	T1B-multi-phase	Dis. General Dis. Quadril. Dis. MHO		0.00 .. 30.00 sec; ∞	0.00 sec	T1B-multi-ph, delay for multi ph. faults
1657	1st AR -> Z1B	Dis. General Dis. Quadril. Dis. MHO		NO YES	YES	Z1B enabled before 1st AR (int. or ext.)
1701	Op. mode Z1	Dis. MHO		Forward Reverse Inactive	Forward	Operating mode Z1
1702	ZR(Z1)	Dis. MHO	1A	0.050 .. 200.000 Ω	2.500 Ω	ZR(Z1), Impedance Reach
			5A	0.010 .. 40.000 Ω	0.500 Ω	
1711	Op. mode Z2	Dis. MHO		Forward Reverse Inactive	Forward	Operating mode Z2
1712	ZR(Z2)	Dis. MHO	1A	0.050 .. 200.000 Ω	5.000 Ω	ZR(Z2), Impedance Reach
			5A	0.010 .. 40.000 Ω	1.000 Ω	
1721	Op. mode Z3	Dis. MHO		Forward Reverse Inactive	Reverse	Operating mode Z3
1722	ZR(Z3)	Dis. MHO	1A	0.050 .. 200.000 Ω	5.000 Ω	ZR(Z3), Impedance Reach
			5A	0.010 .. 40.000 Ω	1.000 Ω	
1731	Op. mode Z4	Dis. MHO		Forward Reverse Inactive	Forward	Operating mode Z4
1732	ZR(Z4)	Dis. MHO	1A	0.050 .. 200.000 Ω	10.000 Ω	ZR(Z4), Impedance Reach
			5A	0.010 .. 40.000 Ω	2.000 Ω	
1741	Op. mode Z5	Dis. MHO		Forward Reverse Inactive	Inactive	Operating mode Z5
1742	ZR(Z5)	Dis. MHO	1A	0.050 .. 200.000 Ω	10.000 Ω	ZR(Z5), Impedance Reach
			5A	0.010 .. 40.000 Ω	2.000 Ω	
1751	Op. mode Z1B	Dis. MHO		Forward Reverse Inactive	Forward	Operating mode Z1B (extended zone)
1752	ZR(Z1B)	Dis. MHO	1A	0.050 .. 200.000 Ω	3.000 Ω	ZR(Z1B), Impedance Reach
			5A	0.010 .. 40.000 Ω	0.600 Ω	
1771A	Mem.Polariz.PhE	Dis. MHO		0.0 .. 100.0 %	15.0 %	Voltage Memory polarization (phase-e)
1772A	CrossPolarizPhE	Dis. MHO		0.0 .. 100.0 %	15.0 %	Cross polarization (phase-e)
1773A	Mem.Polariz.P-P	Dis. MHO		0.0 .. 100.0 %	15.0 %	Voltage Memory polarization (ph-ph)
1774A	CrossPolarizP-P	Dis. MHO		0.0 .. 100.0 %	15.0 %	Cross polarization (phase-phase)
1901	PROGAM U/I	Dis. General		LE:Uphe/LL:Uphp LE:Uphp/LL:Uphp LE:Uphe/LL:Uphe LE:Uphp/LL:Uphp	LE:Uphe/LL:Uphp	Pickup program U/I
1902	DELAY FORW. PU	Dis. General Dis. General		0.00 .. 30.00 sec; ∞	1.20 sec	Trip delay for Forward-PICKUP
1903	DEL. NON-DIR PU	Dis. General Dis. General		0.00 .. 30.00 sec; ∞	1.20 sec	Trip delay for non-directional PICKUP
1910	Iph>>	Dis. General	1A	0.25 .. 10.00 A	1.80 A	Iph>> Pickup (overcurrent)
			5A	1.25 .. 50.00 A	9.00 A	
1911	Iph>	Dis. General	1A	0.10 .. 4.00 A	0.20 A	Iph> Pickup (minimum current)
			5A	0.50 .. 20.00 A	1.00 A	
1912	Uph-e (I>>)	Dis. General		20 .. 70 V	48 V	Undervoltage (ph-e) at Iph>>

Addr.	Parameter	Function	C	Setting Options	Default Setting	Comments
1913	Uph-e (I>)	Dis. General		20 .. 70 V	48 V	Undervoltage (ph-e) at Iph>
1914	Uph-ph (I>>)	Dis. General		40 .. 130 V	80 V	Undervoltage (ph-ph) at Iph>>
1915	Uph-ph (I>)	Dis. General		40 .. 130 V	80 V	Undervoltage (ph-ph) at Iph>
1916	Iphi>	Dis. General	1A	0.10 .. 8.00 A	0.50 A	Iphi> Pickup (minimum current at phi>)
			5A	0.50 .. 40.00 A	2.50 A	
1917	Uph-e (Iphi>)	Dis. General		20 .. 70 V	48 V	Undervoltage (ph-e) at Iphi>
1918	Uph-ph (Iphi>)	Dis. General		40 .. 130 V	80 V	Undervoltage (ph-ph) at Iphi>
1919A	EFFECT φ	Dis. General		forward&reverse Forward	forward&reverse	Effective direction of phi-pickup
1920	$\varphi>$	Dis. General		30 .. 60 °	50 °	PHI> pickup (lower setpoint)
1921	$\varphi<$	Dis. General		90 .. 120 °	110 °	PHI< pickup (upper setpoint)
1930A	1ph FAULTS	Dis. General		PHASE-EARTH PHASE-PHASEONLY	PHASE-EARTH	1ph-pickup loop selection (PU w/o earth)
2002	P/S Op. mode	Power Swing		All zones block Z1/Z1B block Z2 to Z5 block Z1,Z1B,Z2 block	All zones block	Power Swing Operating mode
2006	PowerSwing trip	Power Swing		NO YES	NO	Power swing trip
2007	Trip DELAY P/S	Power Swing		0.08 .. 5.00 sec; 0	0.08 sec	Trip delay after Power Swing Blocking
2101	FCT Telep. Dis.	Teleprot. Dist.		ON OFF	ON	Teleprotection for Distance prot. is
2102	Type of Line	Teleprot. Dist.		Two Terminals Three terminals	Two Terminals	Type of Line
2103A	Send Prolong.	Teleprot. Dist.		0.00 .. 30.00 sec	0.05 sec	Time for send signal prolongation
2107A	Delay for alarm	Teleprot. Dist.		0.00 .. 30.00 sec	10.00 sec	Time Delay for Alarm
2108	Release Delay	Teleprot. Dist.		0.000 .. 30.000 sec	0.000 sec	Time Delay for release after pickup
2109A	TrBlk Wait Time	Teleprot. Dist.		0.00 .. 30.00 sec; ∞	0.04 sec	Transient Block.: Duration external fit.
2110A	TrBlk BlockTime	Teleprot. Dist.		0.00 .. 30.00 sec	0.05 sec	Transient Block.: Blk.T. after ext. fit.
2201	FCT Direct Trip	DTT Direct Trip		ON OFF	OFF	Direct Transfer Trip (DTT)
2202	Trip Time DELAY	DTT Direct Trip		0.00 .. 30.00 sec; ∞	0.01 sec	Trip Time Delay
2301	INRUSH REST.	Diff. Prot		OFF ON	OFF	Inrush Restraint
2302	2nd HARMONIC	Diff. Prot		10 .. 45 %	15 %	2nd. harmonic in % of fundamental
2303	CROSS BLOCK	Diff. Prot		NO YES	NO	Cross Block
2305	MAX INRUSH PEAK	Diff. Prot	1A	1.1 .. 25.0 A	15.0 A	Maximum inrush-peak value
			5A	5.5 .. 125.0 A	75.0 A	
2310	CROSSB 2HM	Diff. Prot		0.00 .. 60.00 sec; ∞	0.00 sec	Time for Crossblock with 2nd harmonic
2401	FCT HS/SOTF-O/C	SOTF Overcurr.		ON OFF	ON	Inst. High Speed/SOTF-O/C is
2404	I>>>	SOTF Overcurr.	1A	0.10 .. 15.00 A; ∞	1.50 A	I>>> Pickup
			5A	0.50 .. 75.00 A; ∞	7.50 A	
2405A	I>>>>	SOTF Overcurr.	1A	1.00 .. 25.00 A; ∞	∞ A	I>>>> Pickup
			5A	5.00 .. 125.00 A; ∞	∞ A	
2501	FCT Weak Infeed	Weak Infeed		OFF ECHO only ECHO and TRIP	ECHO only	Weak Infeed function is
2502A	Trip/Echo DELAY	Weak Infeed		0.00 .. 30.00 sec	0.04 sec	Trip / Echo Delay after carrier receipt
2503A	Trip EXTENSION	Weak Infeed		0.00 .. 30.00 sec	0.05 sec	Trip Extension / Echo Impulse time
2504A	Echo BLOCK Time	Weak Infeed		0.00 .. 30.00 sec	0.05 sec	Echo Block Time
2505	UNDERVOLTAGE	Weak Infeed		2 .. 70 V	25 V	Undervoltage (ph-e)

Addr.	Parameter	Function	C	Setting Options	Default Setting	Comments
2509	Echo:1channel	Weak Infeed		NO YES	NO	Echo logic: Dis and EF on common channel
2510	Uphe< Factor	Weak Infeed		0.10 .. 1.00	0.70	Factor for undervoltage Uphe<
2511	Time const. τ	Weak Infeed		1 .. 60 sec	5 sec	Time constant Tau
2512A	Rec. Ext.	Weak Infeed		0.00 .. 30.00 sec	0.65 sec	Reception extension
2513A	T 3I0> Ext.	Weak Infeed		0.00 .. 30.00 sec	0.60 sec	3I0> exceeded extension
2514	3I0> Threshold	Weak Infeed	1A	0.05 .. 1.00 A	0.50 A	3I0 threshold for neutral current pickup
			5A	0.25 .. 5.00 A	2.50 A	
2515	TM	Weak Infeed		0.00 .. 30.00 sec	0.40 sec	WI delay single pole
2516	TT	Weak Infeed		0.00 .. 30.00 sec	1.00 sec	WI delay multi pole
2517	1pol. Trip	Weak Infeed		ON OFF	ON	Single pole WI trip allowed
2518	1pol. with 3I0	Weak Infeed		ON OFF	ON	Single pole WI trip with 3I0
2519	3pol. Trip	Weak Infeed		ON OFF	ON	Three pole WI trip allowed
2520	T 3I0> alarm	Weak Infeed		0.00 .. 30.00 sec	10.00 sec	3I0> exceeded delay for alarm
2530	WI non delayed	Weak Infeed		ON OFF	ON	WI non delayed
2531	WI delayed	Weak Infeed		ON by receive fail	by receive fail	WI delayed
2601	Operating Mode	Back-Up O/C		ON Only Emer. prot OFF	ON	Operating mode
2610	Iph>>	Back-Up O/C	1A	0.10 .. 25.00 A; ∞	2.00 A	Iph>> Pickup
			5A	0.50 .. 125.00 A; ∞	10.00 A	
2611	T Iph>>	Back-Up O/C		0.00 .. 30.00 sec; ∞	0.30 sec	T Iph>> Time delay
2612	3I0>> PICKUP	Back-Up O/C	1A	0.05 .. 25.00 A; ∞	0.50 A	3I0>> Pickup
			5A	0.25 .. 125.00 A; ∞	2.50 A	
2613	T 3I0>>	Back-Up O/C		0.00 .. 30.00 sec; ∞	2.00 sec	T 3I0>> Time delay
2614	I>> Telep/BI	Back-Up O/C		NO YES	YES	Instantaneous trip via Tele-prot./BI
2615	I>> SOTF	Back-Up O/C		NO YES	NO	Instantaneous trip after Switch-OnToFault
2620	Iph>	Back-Up O/C	1A	0.10 .. 25.00 A; ∞	1.50 A	Iph> Pickup
			5A	0.50 .. 125.00 A; ∞	7.50 A	
2621	T Iph>	Back-Up O/C		0.00 .. 30.00 sec; ∞	0.50 sec	T Iph> Time delay
2622	3I0>	Back-Up O/C	1A	0.05 .. 25.00 A; ∞	0.20 A	3I0> Pickup
			5A	0.25 .. 125.00 A; ∞	1.00 A	
2623	T 3I0>	Back-Up O/C		0.00 .. 30.00 sec; ∞	2.00 sec	T 3I0> Time delay
2624	I> Telep/BI	Back-Up O/C		NO YES	NO	Instantaneous trip via Tele-prot./BI
2625	I> SOTF	Back-Up O/C		NO YES	NO	Instantaneous trip after Switch-OnToFault
2630	Iph> STUB	Back-Up O/C	1A	0.10 .. 25.00 A; ∞	1.50 A	Iph> STUB Pickup
			5A	0.50 .. 125.00 A; ∞	7.50 A	
2631	T Iph STUB	Back-Up O/C		0.00 .. 30.00 sec; ∞	0.30 sec	T Iph STUB Time delay
2632	3I0> STUB	Back-Up O/C	1A	0.05 .. 25.00 A; ∞	0.20 A	3I0> STUB Pickup
			5A	0.25 .. 125.00 A; ∞	1.00 A	
2633	T 3I0 STUB	Back-Up O/C		0.00 .. 30.00 sec; ∞	2.00 sec	T 3I0 STUB Time delay
2634	I-STUB Telep/BI	Back-Up O/C		NO YES	NO	Instantaneous trip via Tele-prot./BI
2635	I-STUB SOTF	Back-Up O/C		NO YES	NO	Instantaneous trip after Switch-OnToFault
2640	Ip>	Back-Up O/C	1A	0.10 .. 4.00 A; ∞	∞ A	Ip> Pickup
			5A	0.50 .. 20.00 A; ∞	∞ A	
2642	T Ip Time Dial	Back-Up O/C		0.05 .. 3.00 sec; ∞	0.50 sec	T Ip Time Dial
2643	Time Dial TD Ip	Back-Up O/C		0.50 .. 15.00 ; ∞	5.00	Time Dial TD Ip
2646	T Ip Add	Back-Up O/C		0.00 .. 30.00 sec	0.00 sec	T Ip Additional Time Delay

Addr.	Parameter	Function	C	Setting Options	Default Setting	Comments
2650	3I0p PICKUP	Back-Up O/C	1A	0.05 .. 4.00 A; ∞	∞ A	3I0p Pickup
			5A	0.25 .. 20.00 A; ∞	∞ A	
2652	T 3I0p TimeDial	Back-Up O/C		0.05 .. 3.00 sec; ∞	0.50 sec	T 3I0p Time Dial
2653	TimeDial TD3I0p	Back-Up O/C		0.50 .. 15.00 ; ∞	5.00	Time Dial TD 3I0p
2656	T 3I0p Add	Back-Up O/C		0.00 .. 30.00 sec	0.00 sec	T 3I0p Additional Time Delay
2660	IEC Curve	Back-Up O/C		Normal Inverse Very Inverse Extremely Inv. LongTimeInverse	Normal Inverse	IEC Curve
2661	ANSI Curve	Back-Up O/C		Inverse Short Inverse Long Inverse Moderately Inv. Very Inverse Extremely Inv. Definite Inv.	Inverse	ANSI Curve
2670	I(3I0)p Tele/BI	Back-Up O/C		NO YES	NO	Instantaneous trip via Tele-prot./BI
2671	I(3I0)p SOTF	Back-Up O/C		NO YES	NO	Instantaneous trip after Switch-OnToFault
2680	SOTF Time DELAY	Back-Up O/C		0.00 .. 30.00 sec	0.00 sec	Trip time delay after SOTF
2801	DMD Interval	Demand meter		15 Min., 1 Sub 15 Min., 3 Subs 15 Min., 15 Subs 30 Min., 1 Sub 60 Min., 1 Sub	60 Min., 1 Sub	Demand Calculation Intervals
2802	DMD Sync.Time	Demand meter		On The Hour 15 After Hour 30 After Hour 45 After Hour	On The Hour	Demand Synchronization Time
2811	MinMax cycRESET	Min/Max meter		NO YES	YES	Automatic Cyclic Reset Function
2812	MiMa RESET TIME	Min/Max meter		0 .. 1439 min	0 min	MinMax Reset Timer
2813	MiMa RESETCYCLE	Min/Max meter		1 .. 365 Days	7 Days	MinMax Reset Cycle Period
2814	MinMaxRES.START	Min/Max meter		1 .. 365 Days	1 Days	MinMax Start Reset Cycle in
2901	MEASURE. SUPERV	Measurerm.Superv		ON OFF	ON	Measurement Supervision
2902A	BALANCE U-LIMIT	Measurerm.Superv		10 .. 100 V	50 V	Voltage Threshold for Balance Monitoring
2903A	BAL. FACTOR U	Measurerm.Superv		0.58 .. 0.95	0.75	Balance Factor for Voltage Monitor
2904A	BALANCE I LIMIT	Measurerm.Superv	1A	0.10 .. 1.00 A	0.50 A	Current Balance Monitor
			5A	0.50 .. 5.00 A	2.50 A	
2905A	BAL. FACTOR I	Measurerm.Superv		0.10 .. 0.95	0.50	Balance Factor for Current Monitor
2906A	ΣI THRESHOLD	Measurerm.Superv	1A	0.10 .. 2.00 A	0.25 A	Summated Current Monitoring Threshold
			5A	0.50 .. 10.00 A	1.25 A	
2907A	ΣI FACTOR	Measurerm.Superv		0.00 .. 0.95	0.50	Summated Current Monitoring Factor
2908A	T BAL. U LIMIT	Measurerm.Superv		5 .. 100 sec	5 sec	T Balance Factor for Voltage Monitor
2909A	T BAL. I LIMIT	Measurerm.Superv		5 .. 100 sec	5 sec	T Current Balance Monitor
2910	FUSE FAIL MON.	Measurerm.Superv		ON OFF	ON	Fuse Failure Monitor
2911A	FFM U>(min)	Measurerm.Superv		10 .. 100 V	30 V	Minimum Voltage Threshold U>
2912A	FFM I<(max)	Measurerm.Superv	1A	0.10 .. 1.00 A	0.10 A	Maximum Current Threshold I<
			5A	0.50 .. 5.00 A	0.50 A	
2913A	FFM U<max (3ph)	Measurerm.Superv		2 .. 100 V	5 V	Maximum Voltage Threshold U< (3phase)
2914A	FFM Idelta (3p)	Measurerm.Superv	1A	0.05 .. 1.00 A	0.10 A	Delta Current Threshold (3phase)
			5A	0.25 .. 5.00 A	0.50 A	
2915	V-Supervision	Measurerm.Superv		w/ CURR.SUP w/ I> & CBaux OFF	w/ CURR.SUP	Voltage Failure Supervision

Addr.	Parameter	Function	C	Setting Options	Default Setting	Comments
2916A	T V-Supervision	Measurem.Superv		0.00 .. 30.00 sec	3.00 sec	Delay Voltage Failure Supervision
2921	T mcb	Measurem.Superv		0 .. 30 ms	0 ms	VT mcb operating time
2931	BROKEN WIRE	Measurem.Superv		ON OFF	OFF	Fast broken current-wire supervision
2933	FAST Σi SUPERV	Measurem.Superv		ON OFF	ON	State of fast current summation supervises
3101	FCT EarthFltO/C	Earth Fault O/C		ON OFF	ON	Earth Fault overcurrent function is
3102	BLOCK for Dist.	Earth Fault O/C		every PICKUP 1phase PICKUP multiph. PICKUP NO	every PICKUP	Block E/F for Distance protection
3103	BLOCK 1pDeadTim	Earth Fault O/C		YES NO	YES	Block E/F for 1pole Dead time
3104A	lph-STAB. Slope	Earth Fault O/C		0 .. 30 %	10 %	Stabilisation Slope with lphase
3105	3IoMin Teleprot	Earth Fault O/C	1A	0.01 .. 1.00 A	0.50 A	3Io-Min threshold for Teleprot. schemes
			5A	0.05 .. 5.00 A	2.50 A	
3105	3IoMin Teleprot	Earth Fault O/C	1A	0.003 .. 1.000 A	0.500 A	3Io-Min threshold for Teleprot. schemes
			5A	0.015 .. 5.000 A	2.500 A	
3109	Trip 1pole E/F	Earth Fault O/C		YES NO	YES	Single pole trip with earth flt.prot.
3110	Op. mode 3I0>>>	Earth Fault O/C		Forward Reverse Non-Directional Inactive	Inactive	Operating mode
3111	3I0>>>	Earth Fault O/C	1A	0.05 .. 25.00 A	4.00 A	3I0>>> Pickup
			5A	0.25 .. 125.00 A	20.00 A	
3112	T 3I0>>>	Earth Fault O/C		0.00 .. 30.00 sec; ∞	0.30 sec	T 3I0>>> Time delay
3113	3I0>>> Telep/BI	Earth Fault O/C		NO YES	NO	Instantaneous trip via Teleprot./BI
3114	3I0>>>SOTF-Trip	Earth Fault O/C		NO YES	NO	Instantaneous trip after Switch-OnToFault
3115	3I0>>>InrushBlk	Earth Fault O/C		NO YES	NO	Inrush Blocking
3120	Op. mode 3I0>>	Earth Fault O/C		Forward Reverse Non-Directional Inactive	Inactive	Operating mode
3121	3I0>>	Earth Fault O/C	1A	0.05 .. 25.00 A	2.00 A	3I0>> Pickup
			5A	0.25 .. 125.00 A	10.00 A	
3122	T 3I0>>	Earth Fault O/C		0.00 .. 30.00 sec; ∞	0.60 sec	T 3I0>> Time Delay
3123	3I0>> Telep/BI	Earth Fault O/C		NO YES	NO	Instantaneous trip via Teleprot./BI
3124	3I0>> SOTF-Trip	Earth Fault O/C		NO YES	NO	Instantaneous trip after Switch-OnToFault
3125	3I0>> InrushBlk	Earth Fault O/C		NO YES	NO	Inrush Blocking
3130	Op. mode 3I0>	Earth Fault O/C		Forward Reverse Non-Directional Inactive	Inactive	Operating mode
3131	3I0>	Earth Fault O/C	1A	0.05 .. 25.00 A	1.00 A	3I0> Pickup
			5A	0.25 .. 125.00 A	5.00 A	
3131	3I0>	Earth Fault O/C	1A	0.003 .. 25.000 A	1.000 A	3I0> Pickup
			5A	0.015 .. 125.000 A	5.000 A	
3132	T 3I0>	Earth Fault O/C		0.00 .. 30.00 sec; ∞	0.90 sec	T 3I0> Time Delay
3133	3I0> Telep/BI	Earth Fault O/C		NO YES	NO	Instantaneous trip via Teleprot./BI
3134	3I0> SOTF-Trip	Earth Fault O/C		NO YES	NO	Instantaneous trip after Switch-OnToFault
3135	3I0> InrushBlk	Earth Fault O/C		NO YES	NO	Inrush Blocking

Addr.	Parameter	Function	C	Setting Options	Default Setting	Comments
3140	Op. mode 3I0p	Earth Fault O/C Earth Fault O/C Earth Fault O/C Earth Fault O/C		Forward Reverse Non-Directional Inactive	Inactive	Operating mode
3141	3I0p PICKUP	Earth Fault O/C Earth Fault O/C Earth Fault O/C Earth Fault O/C	1A	0.05 .. 25.00 A	1.00 A	3I0p Pickup
			5A	0.25 .. 125.00 A	5.00 A	
3141	3I0p PICKUP	Earth Fault O/C Earth Fault O/C Earth Fault O/C Earth Fault O/C	1A	0.003 .. 25.000 A	1.000 A	3I0p Pickup
			5A	0.015 .. 125.000 A	5.000 A	
3142	3I0p MinT-DELAY	Earth Fault O/C		0.00 .. 30.00 sec	1.20 sec	3I0p Minimum Time Delay
3143	3I0p Time Dial	Earth Fault O/C		0.05 .. 3.00 sec; ∞	0.50 sec	3I0p Time Dial
3144	3I0p Time Dial	Earth Fault O/C		0.50 .. 15.00 ; ∞	5.00	3I0p Time Dial
3145	3I0p Time Dial	Earth Fault O/C		0.05 .. 15.00 sec; ∞	1.35 sec	3I0p Time Dial
3146	3I0p MaxT-DELAY	Earth Fault O/C		0.00 .. 30.00 sec	5.80 sec	3I0p Maximum Time Delay
3147	Add.T-DELAY	Earth Fault O/C Earth Fault O/C Earth Fault O/C Earth Fault O/C		0.00 .. 30.00 sec; ∞	1.20 sec	Additional Time Delay
3148	3I0p Telep/BI	Earth Fault O/C Earth Fault O/C Earth Fault O/C Earth Fault O/C		NO YES	NO	Instantaneous trip via Teleprot./BI
3149	3I0p SOTF-Trip	Earth Fault O/C Earth Fault O/C Earth Fault O/C Earth Fault O/C		NO YES	NO	Instantaneous trip after Switch-OnToFault
3150	3I0p InrushBlik	Earth Fault O/C Earth Fault O/C Earth Fault O/C Earth Fault O/C		NO YES	NO	Inrush Blocking
3151	IEC Curve	Earth Fault O/C		Normal Inverse Very Inverse Extremely Inv. LongTimeInverse	Normal Inverse	IEC Curve
3152	ANSI Curve	Earth Fault O/C		Inverse Short Inverse Long Inverse Moderately Inv. Very Inverse Extremely Inv. Definite Inv.	Inverse	ANSI Curve
3153	LOG Curve	Earth Fault O/C		Log. inverse	Log. inverse	LOGARITHMIC Curve
3154	3I0p Startpoint	Earth Fault O/C		1.0 .. 4.0	1.1	Start point of inverse characteristic
3155	k	Earth Fault O/C		0.00 .. 3.00 sec	0.50 sec	k-factor for Sr-characteristic
3156	S ref	Earth Fault O/C	1A	1 .. 100 VA	10 VA	S ref for Sr-characteristic
			5A	5 .. 500 VA	50 VA	
3160	POLARIZATION	Earth Fault O/C		U0 + IY or U2 U0 + IY with IY only with U2 and I2 zero seq. power	U0 + IY or U2	Polarization
3162A	Dir. ALPHA	Earth Fault O/C		0 .. 360 °	338 °	ALPHA, lower angle for forward direction
3163A	Dir. BETA	Earth Fault O/C		0 .. 360 °	122 °	BETA, upper angle for forward direction
3164	3U0>	Earth Fault O/C		0.5 .. 10.0 V	0.5 V	Min. zero seq.voltage 3U0 for polarizing
3165	IY>	Earth Fault O/C	1A	0.05 .. 1.00 A	0.05 A	Min. earth current IY for polarizing
			5A	0.25 .. 5.00 A	0.25 A	
3166	3U2>	Earth Fault O/C		0.5 .. 10.0 V	0.5 V	Min. neg. seq. polarizing voltage 3U2
3167	3I2>	Earth Fault O/C	1A	0.05 .. 1.00 A	0.05 A	Min. neg. seq. polarizing current 3I2
			5A	0.25 .. 5.00 A	0.25 A	

Addr.	Parameter	Function	C	Setting Options	Default Setting	Comments
3168	PHI comp	Earth Fault O/C		0 .. 360 °	255 °	Compensation angle PHI comp. for Sr
3169	S forward	Earth Fault O/C	1A	0.1 .. 10.0 VA	0.3 VA	Forward direction power threshold
			5A	0.5 .. 50.0 VA	1.5 VA	
3170	2nd InrushRest	Earth Fault O/C		10 .. 45 %	15 %	2nd harmonic ratio for inrush restraint
3171	Imax InrushRest	Earth Fault O/C	1A	0.50 .. 25.00 A	7.50 A	Max. Current, overriding inrush restraint
			5A	2.50 .. 125.00 A	37.50 A	
3172	SOTF Op. Mode	Earth Fault O/C		PICKUP PICKUP+DIRECT.	PICKUP+DIRECT.	Instantaneous mode after SwitchOnToFault
3173	SOTF Time DELAY	Earth Fault O/C		0.00 .. 30.00 sec	0.00 sec	Trip time delay after SOTF
3174	BLK for DisZone	Earth Fault O/C		in zone Z1 in zone Z1/Z1B in each zone	in each zone	Block E/F for Distance Protection Pickup
3182	3U0>(U0 inv)	Earth Fault O/C		1.0 .. 10.0 V	5.0 V	3U0> setpoint
3183	U0inv. minimum	Earth Fault O/C		0.1 .. 5.0 V	0.2 V	Minimum voltage U0min for T->oo
3184	T forw. (U0inv)	Earth Fault O/C		0.00 .. 32.00 sec	0.90 sec	T-forward Time delay (U0inv)
3185	T rev. (U0inv)	Earth Fault O/C		0.00 .. 32.00 sec	1.20 sec	T-reverse Time delay (U0inv)
3201	FCT Telep. E/F	Teleprot. E/F		ON OFF	ON	Teleprotection for Earth Fault O/C
3202	Line Config.	Teleprot. E/F		Two Terminals Three terminals	Two Terminals	Line Configuration
3203A	Send Prolong.	Teleprot. E/F		0.00 .. 30.00 sec	0.05 sec	Time for send signal prolongation
3207A	Delay for alarm	Teleprot. E/F		0.00 .. 30.00 sec	10.00 sec	Unblocking: Time Delay for Alarm
3208	Release Delay	Teleprot. E/F		0.000 .. 30.000 sec	0.000 sec	Time Delay for release after pickup
3209A	TrBlk Wait Time	Teleprot. E/F		0.00 .. 30.00 sec; ∞	0.04 sec	Transient Block.: Duration external fit.
3210A	TrBlk BlockTime	Teleprot. E/F		0.00 .. 30.00 sec	0.05 sec	Transient Block.: Blk.T. after ext. fit.
3401	AUTO RECLOSE	Auto Reclose		OFF ON	ON	Auto-Reclose Function
3402	CB? 1.TRIP	Auto Reclose		YES NO	NO	CB ready interrogation at 1st trip
3403	T-RECLAIM	Auto Reclose		0.50 .. 300.00 sec	3.00 sec	Reclaim time after successful AR cycle
3404	T-BLOCK MC	Auto Reclose		0.50 .. 300.00 sec; 0	1.00 sec	AR blocking duration after manual close
3406	EV. FLT. RECOG.	Auto Reclose		with PICKUP with TRIP	with TRIP	Evolving fault recognition
3407	EV. FLT. MODE	Auto Reclose		Stops AutoRecl starts 3p AR	starts 3p AR	Evolving fault (during the dead time)
3408	T-Start MONITOR	Auto Reclose		0.01 .. 300.00 sec	0.50 sec	AR start-signal monitoring time
3409	CB TIME OUT	Auto Reclose		0.01 .. 300.00 sec	3.00 sec	Circuit Breaker (CB) Supervision Time
3410	T RemoteClose	Auto Reclose		0.00 .. 300.00 sec; ∞	0.20 sec	Send delay for remote close command
3411A	T-DEAD EXT.	Auto Reclose		0.50 .. 300.00 sec; ∞	∞ sec	Maximum dead time extension
3420	AR WITH DIFF	Auto Reclose		YES NO	YES	AR with differential protection ?
3421	AR w/ SOTF-O/C	Auto Reclose		YES NO	YES	AR with switch-onto-fault overcurrent ?
3422	AR w/ DIST.	Auto Reclose		YES NO	YES	AR with distance protection ?
3423	AR WITH I.TRIP	Auto Reclose		YES NO	YES	AR with intertrip ?
3424	AR w/ DTT	Auto Reclose		YES NO	YES	AR with direct transfer trip ?
3425	AR w/ BackUpO/C	Auto Reclose		YES NO	YES	AR with back-up overcurrent ?

Addr.	Parameter	Function	C	Setting Options	Default Setting	Comments
3426	AR w/ W/I	Auto Reclose		YES NO	YES	AR with weak infeed tripping ?
3427	AR w/ EF-O/C	Auto Reclose		YES NO	YES	AR with earth fault overcurrent prot. ?
3430	AR TRIP 3pole	Auto Reclose		YES NO	YES	3pole TRIP by AR
3431	DLC / RDT	Auto Reclose		WITHOUT DLC	WITHOUT	Dead Line Check / Reduced Dead Time
3433	T-ACTION ADT	Auto Reclose		0.01 .. 300.00 sec; ∞	0.20 sec	Action time
3434	T-MAX ADT	Auto Reclose		0.50 .. 3000.00 sec	5.00 sec	Maximum dead time
3435	ADT 1p allowed	Auto Reclose		YES NO	NO	1pole TRIP allowed
3436	ADT CB? CLOSE	Auto Reclose		YES NO	NO	CB ready interrogation before re-closing
3437	ADT SynRequest	Auto Reclose		YES NO	NO	Request for synchro-check after 3pole AR
3438	T U-stable	Auto Reclose		0.10 .. 30.00 sec	0.10 sec	Supervision time for dead/live voltage
3440	U-live>	Auto Reclose		30 .. 90 V	48 V	Voltage threshold for live line or bus
3441	U-dead<	Auto Reclose		2 .. 70 V	30 V	Voltage threshold for dead line or bus
3450	1.AR: START	Auto Reclose		YES NO	YES	Start of AR allowed in this cycle
3451	1.AR: T-ACTION	Auto Reclose		0.01 .. 300.00 sec; ∞	0.20 sec	Action time
3453	1.AR Tdead 1Flt	Auto Reclose		0.01 .. 1800.00 sec; ∞	1.20 sec	Dead time after 1phase faults
3454	1.AR Tdead 2Flt	Auto Reclose		0.01 .. 1800.00 sec; ∞	1.20 sec	Dead time after 2phase faults
3455	1.AR Tdead 3Flt	Auto Reclose		0.01 .. 1800.00 sec; ∞	0.50 sec	Dead time after 3phase faults
3456	1.AR Tdead1Trip	Auto Reclose		0.01 .. 1800.00 sec; ∞	1.20 sec	Dead time after 1pole trip
3457	1.AR Tdead3Trip	Auto Reclose		0.01 .. 1800.00 sec; ∞	0.50 sec	Dead time after 3pole trip
3458	1.AR: Tdead EV.	Auto Reclose		0.01 .. 1800.00 sec	1.20 sec	Dead time after evolving fault
3459	1.AR: CB? CLOSE	Auto Reclose		YES NO	NO	CB ready interrogation before re-closing
3460	1.AR SynRequest	Auto Reclose		YES NO	NO	Request for synchro-check after 3pole AR
3461	2.AR: START	Auto Reclose		YES NO	NO	AR start allowed in this cycle
3462	2.AR: T-ACTION	Auto Reclose		0.01 .. 300.00 sec; ∞	0.20 sec	Action time
3464	2.AR Tdead 1Flt	Auto Reclose		0.01 .. 1800.00 sec; ∞	1.20 sec	Dead time after 1phase faults
3465	2.AR Tdead 2Flt	Auto Reclose		0.01 .. 1800.00 sec; ∞	1.20 sec	Dead time after 2phase faults
3466	2.AR Tdead 3Flt	Auto Reclose		0.01 .. 1800.00 sec; ∞	0.50 sec	Dead time after 3phase faults
3467	2.AR Tdead1Trip	Auto Reclose		0.01 .. 1800.00 sec; ∞	∞ sec	Dead time after 1pole trip
3468	2.AR Tdead3Trip	Auto Reclose		0.01 .. 1800.00 sec; ∞	0.50 sec	Dead time after 3pole trip
3469	2.AR: Tdead EV.	Auto Reclose		0.01 .. 1800.00 sec	1.20 sec	Dead time after evolving fault
3470	2.AR: CB? CLOSE	Auto Reclose		YES NO	NO	CB ready interrogation before re-closing
3471	2.AR SynRequest	Auto Reclose		YES NO	NO	Request for synchro-check after 3pole AR
3472	3.AR: START	Auto Reclose		YES NO	NO	AR start allowed in this cycle
3473	3.AR: T-ACTION	Auto Reclose		0.01 .. 300.00 sec; ∞	0.20 sec	Action time
3475	3.AR Tdead 1Flt	Auto Reclose		0.01 .. 1800.00 sec; ∞	1.20 sec	Dead time after 1phase faults
3476	3.AR Tdead 2Flt	Auto Reclose		0.01 .. 1800.00 sec; ∞	1.20 sec	Dead time after 2phase faults
3477	3.AR Tdead 3Flt	Auto Reclose		0.01 .. 1800.00 sec; ∞	0.50 sec	Dead time after 3phase faults
3478	3.AR Tdead1Trip	Auto Reclose		0.01 .. 1800.00 sec; ∞	∞ sec	Dead time after 1pole trip
3479	3.AR Tdead3Trip	Auto Reclose		0.01 .. 1800.00 sec; ∞	0.50 sec	Dead time after 3pole trip
3480	3.AR: Tdead EV.	Auto Reclose		0.01 .. 1800.00 sec	1.20 sec	Dead time after evolving fault
3481	3.AR: CB? CLOSE	Auto Reclose		YES NO	NO	CB ready interrogation before re-closing
3482	3.AR SynRequest	Auto Reclose		YES NO	NO	Request for synchro-check after 3pole AR

Addr.	Parameter	Function	C	Setting Options	Default Setting	Comments
3483	4.AR: START	Auto Reclose		YES NO	NO	AR start allowed in this cycle
3484	4.AR: T-ACTION	Auto Reclose		0.01 .. 300.00 sec; ∞	0.20 sec	Action time
3486	4.AR Tdead 1Fit	Auto Reclose		0.01 .. 1800.00 sec; ∞	1.20 sec	Dead time after 1phase faults
3487	4.AR Tdead 2Fit	Auto Reclose		0.01 .. 1800.00 sec; ∞	1.20 sec	Dead time after 2phase faults
3488	4.AR Tdead 3Fit	Auto Reclose		0.01 .. 1800.00 sec; ∞	0.50 sec	Dead time after 3phase faults
3489	4.AR Tdead1Trip	Auto Reclose		0.01 .. 1800.00 sec; ∞	∞ sec	Dead time after 1pole trip
3490	4.AR Tdead3Trip	Auto Reclose		0.01 .. 1800.00 sec; ∞	0.50 sec	Dead time after 3pole trip
3491	4.AR: Tdead EV.	Auto Reclose		0.01 .. 1800.00 sec	1.20 sec	Dead time after evolving fault
3492	4.AR: CB? CLOSE	Auto Reclose		YES NO	NO	CB ready interrogation before re-closing
3493	4.AR SynRequest	Auto Reclose		YES NO	NO	Request for synchro-check after 3pole AR
3501	FCT Synchronism	Sync. Check		ON OFF ON:w/o CloseCmd	ON	Synchronism and Voltage Check function
3502	Dead Volt. Thr.	Sync. Check		1 .. 60 V	5 V	Voltage threshold dead line / bus
3503	Live Volt. Thr.	Sync. Check		20 .. 125 V	90 V	Voltage threshold live line / bus
3504	Umax	Sync. Check		20 .. 140 V	110 V	Maximum permissible voltage
3507	T-SYN. DURATION	Sync. Check		0.01 .. 600.00 sec; ∞	1.00 sec	Maximum duration of synchronism-check
3508	T SYNC-STAB	Sync. Check		0.00 .. 30.00 sec	0.00 sec	Synchronous condition stability timer
3509	SyncCB	Sync. Check		(Setting options depend on configuration)	None	Synchronizable circuit breaker
3510	Op.mode with AR	Sync. Check		with T-CB close w/o T-CB close	w/o T-CB close	Operating mode with AR
3511	Max. Volt. Diff	Sync. Check		1.0 .. 40.0 V	2.0 V	Maximum voltage difference
3512	Max. Freq. Diff	Sync. Check		0.03 .. 2.00 Hz	0.10 Hz	Maximum frequency difference
3513	Max. Angle Diff	Sync. Check		2 .. 80 °	10 °	Maximum angle difference
3515A	SYNC-CHECK	Sync. Check		YES NO	YES	Live bus / live line and Sync before AR
3516	Usync> U-line<	Sync. Check		YES NO	NO	Live bus / dead line check before AR
3517	Usync< U-line>	Sync. Check		YES NO	NO	Dead bus / live line check before AR
3518	Usync< U-line<	Sync. Check		YES NO	NO	Dead bus / dead line check before AR
3519	OVERRIDE	Sync. Check		YES NO	NO	Override of any check before AR
3530	Op.mode with MC	Sync. Check		with T-CB close w/o T-CB close	w/o T-CB close	Operating mode with Man.Cl
3531	MC maxVolt.Diff	Sync. Check		1.0 .. 40.0 V	2.0 V	Maximum voltage difference
3532	MC maxFreq.Diff	Sync. Check		0.03 .. 2.00 Hz	0.10 Hz	Maximum frequency difference
3533	MC maxAngleDiff	Sync. Check		2 .. 80 °	10 °	Maximum angle difference
3535A	MC SYNCHR	Sync. Check		YES NO	YES	Live bus / live line and Sync before MC
3536	MC U syn> Uline<	Sync. Check		YES NO	NO	Live bus / dead line check before Man.Cl
3537	MC U syn< Uline>	Sync. Check		YES NO	NO	Dead bus / live line check before Man.Cl
3538	MC U syn< Uline<	Sync. Check		YES NO	NO	Dead bus / dead line check before Man.Cl
3539	MC O/RIDE	Sync. Check		YES NO	NO	Override of any check before Man.Cl
3601	O/U FREQ. f1	Frequency Prot.		ON: Alarm only ON: with Trip OFF	ON: Alarm only	Over/Under Frequency Protection stage f1
3602	f1 PICKUP	Frequency Prot.		45.50 .. 54.50 Hz	49.50 Hz	f1 Pickup
3603	f1 PICKUP	Frequency Prot.		55.50 .. 64.50 Hz	59.50 Hz	f1 Pickup
3604	T f1	Frequency Prot.		0.00 .. 600.00 sec	60.00 sec	T f1 Time Delay

Addr.	Parameter	Function	C	Setting Options	Default Setting	Comments
3611	O/U FREQ. f2	Frequency Prot.		ON: Alarm only ON: with Trip OFF	ON: Alarm only	Over/Under Frequency Protection stage f2
3612	f2 PICKUP	Frequency Prot.		45.50 .. 54.50 Hz	49.00 Hz	f2 Pickup
3613	f2 PICKUP	Frequency Prot.		55.50 .. 64.50 Hz	57.00 Hz	f2 Pickup
3614	T f2	Frequency Prot.		0.00 .. 600.00 sec	30.00 sec	T f2 Time Delay
3621	O/U FREQ. f3	Frequency Prot.		ON: Alarm only ON: with Trip OFF	ON: Alarm only	Over/Under Frequency Protection stage f3
3622	f3 PICKUP	Frequency Prot.		45.50 .. 54.50 Hz	47.50 Hz	f3 Pickup
3623	f3 PICKUP	Frequency Prot.		55.50 .. 64.50 Hz	59.50 Hz	f3 Pickup
3624	T f3	Frequency Prot.		0.00 .. 600.00 sec	3.00 sec	T f3 Time Delay
3631	O/U FREQ. f4	Frequency Prot.		ON: Alarm only ON: with Trip OFF	ON: Alarm only	Over/Under Frequency Protection stage f4
3632	f4 PICKUP	Frequency Prot.		45.50 .. 54.50 Hz	51.00 Hz	f4 Pickup
3633	f4 PICKUP	Frequency Prot.		55.50 .. 64.50 Hz	62.00 Hz	f4 Pickup
3634	T f4	Frequency Prot.		0.00 .. 600.00 sec	30.00 sec	T f4 Time Delay
3701	Uph-e>(>)	Voltage Prot.		OFF Alarm Only ON	OFF	Operating mode Uph-e overvoltage prot.
3702	Uph-e>	Voltage Prot.		1.0 .. 170.0 V; ∞	85.0 V	Uph-e> Pickup
3703	T Uph-e>	Voltage Prot.		0.00 .. 100.00 sec; ∞	2.00 sec	T Uph-e> Time Delay
3704	Uph-e>>	Voltage Prot.		1.0 .. 170.0 V; ∞	100.0 V	Uph-e>> Pickup
3705	T Uph-e>>	Voltage Prot.		0.00 .. 100.00 sec; ∞	1.00 sec	T Uph-e>> Time Delay
3709A	Uph-e>(>) RESET	Voltage Prot.		0.30 .. 0.98	0.98	Uph-e>(>) Reset ratio
3711	Uph-ph>(>)	Voltage Prot.		OFF Alarm Only ON	OFF	Operating mode Uph-ph overvoltage prot.
3712	Uph-ph>	Voltage Prot.		2.0 .. 220.0 V; ∞	150.0 V	Uph-ph> Pickup
3713	T Uph-ph>	Voltage Prot.		0.00 .. 100.00 sec; ∞	2.00 sec	T Uph-ph> Time Delay
3714	Uph-ph>>	Voltage Prot.		2.0 .. 220.0 V; ∞	175.0 V	Uph-ph>> Pickup
3715	T Uph-ph>>	Voltage Prot.		0.00 .. 100.00 sec; ∞	1.00 sec	T Uph-ph>> Time Delay
3719A	Uphph>(>) RESET	Voltage Prot.		0.30 .. 0.98	0.98	Uph-ph>(>) Reset ratio
3721	3U0>(>) (or Ux)	Voltage Prot.		OFF Alarm Only ON	OFF	Operating mode 3U0 (or Ux) overvoltage
3722	3U0>	Voltage Prot.		1.0 .. 220.0 V; ∞	30.0 V	3U0> Pickup (or Ux>)
3723	T 3U0>	Voltage Prot.		0.00 .. 100.00 sec; ∞	2.00 sec	T 3U0> Time Delay (or T Ux>)
3724	3U0>>	Voltage Prot.		1.0 .. 220.0 V; ∞	50.0 V	3U0>> Pickup (or Ux>>)
3725	T 3U0>>	Voltage Prot.		0.00 .. 100.00 sec; ∞	1.00 sec	T 3U0>> Time Delay (or T Ux>>)
3728A	3U0>(>) Stabil.	Voltage Prot.		ON OFF	ON	3U0>(>): Stabilization 3U0-Measurement
3729A	3U0>(>) RESET	Voltage Prot.		0.30 .. 0.98	0.95	3U0>(>) Reset ratio (or Ux)
3731	U1>(>)	Voltage Prot.		OFF Alarm Only ON	OFF	Operating mode U1 overvoltage prot.
3732	U1>	Voltage Prot.		2.0 .. 220.0 V; ∞	150.0 V	U1> Pickup
3733	T U1>	Voltage Prot.		0.00 .. 100.00 sec; ∞	2.00 sec	T U1> Time Delay
3734	U1>>	Voltage Prot.		2.0 .. 220.0 V; ∞	175.0 V	U1>> Pickup
3735	T U1>>	Voltage Prot.		0.00 .. 100.00 sec; ∞	1.00 sec	T U1>> Time Delay
3736	U1> Compound	Voltage Prot.		OFF ON	OFF	U1> with Compounding
3737	U1>> Compound	Voltage Prot.		OFF ON	OFF	U1>> with Compounding
3739A	U1>(>) RESET	Voltage Prot.		0.30 .. 0.98	0.98	U1>(>) Reset ratio
3741	U2>(>)	Voltage Prot.		OFF Alarm Only ON	OFF	Operating mode U2 overvoltage prot.
3742	U2>	Voltage Prot.		2.0 .. 220.0 V; ∞	30.0 V	U2> Pickup
3743	T U2>	Voltage Prot.		0.00 .. 100.00 sec; ∞	2.00 sec	T U2> Time Delay

Addr.	Parameter	Function	C	Setting Options	Default Setting	Comments
3744	U2>>	Voltage Prot.		2.0 .. 220.0 V; ∞	50.0 V	U2>> Pickup
3745	T U2>>	Voltage Prot.		0.00 .. 100.00 sec; ∞	1.00 sec	T U2>> Time Delay
3749A	U2>(>) RESET	Voltage Prot.		0.30 .. 0.98	0.98	U2>(>) Reset ratio
3751	Uph-e<(<)	Voltage Prot.		OFF Alarm Only ON	OFF	Operating mode Uph-e under-voltage prot.
3752	Uph-e<	Voltage Prot.		1.0 .. 100.0 V; 0	30.0 V	Uph-e< Pickup
3753	T Uph-e<	Voltage Prot.		0.00 .. 100.00 sec; ∞	2.00 sec	T Uph-e< Time Delay
3754	Uph-e<<	Voltage Prot.		1.0 .. 100.0 V; 0	10.0 V	Uph-e<< Pickup
3755	T Uph-e<<	Voltage Prot.		0.00 .. 100.00 sec; ∞	1.00 sec	T Uph-e<< Time Delay
3758	CURR.SUP. Uph-e<	Voltage Prot.		ON OFF	ON	Current supervision (Uph-e)
3761	Uph-ph<(<)	Voltage Prot.		OFF Alarm Only ON	OFF	Operating mode Uph-ph under-voltage prot.
3762	Uph-ph<	Voltage Prot.		1.0 .. 175.0 V; 0	50.0 V	Uph-ph< Pickup
3763	T Uph-ph<	Voltage Prot.		0.00 .. 100.00 sec; ∞	2.00 sec	T Uph-ph< Time Delay
3764	Uph-ph<<	Voltage Prot.		1.0 .. 175.0 V; 0	17.0 V	Uph-ph<< Pickup
3765	T Uph-ph<<	Voltage Prot.		0.00 .. 100.00 sec; ∞	1.00 sec	T Uph-ph<< Time Delay
3768	CURR.SUP.Uphph<	Voltage Prot.		ON OFF	ON	Current supervision (Uph-ph)
3771	U1<(<)	Voltage Prot.		OFF Alarm Only ON	OFF	Operating mode U1 undervoltage prot.
3772	U1<	Voltage Prot.		1.0 .. 100.0 V; 0	30.0 V	U1< Pickup
3773	T U1<	Voltage Prot.		0.00 .. 100.00 sec; ∞	2.00 sec	T U1< Time Delay
3774	U1<<	Voltage Prot.		1.0 .. 100.0 V; 0	10.0 V	U1<< Pickup
3775	T U1<<	Voltage Prot.		0.00 .. 100.00 sec; ∞	1.00 sec	T U1<< Time Delay
3778	CURR.SUP.U1<	Voltage Prot.		ON OFF	ON	Current supervision (U1)
3802	START	Fault Locator		Pickup TRIP	Pickup	Start fault locator with
3805	Paral.Line Comp	Fault Locator		NO YES	YES	Mutual coupling parall.line compensation
3806	Load Compensat.	Fault Locator		NO YES	NO	Load Compensation
3807	two ended	Fault Locator		ON OFF	ON	two ended fault location
3811	Tmax OUTPUT BCD	Fault Locator		0.10 .. 180.00 sec	0.30 sec	Maximum output time via BCD
3901	FCT BreakerFail	Breaker Failure		ON OFF	ON	Breaker Failure Protection is
3902	I> BF	Breaker Failure	1A	0.05 .. 20.00 A	0.10 A	Pick-up threshold I>
			5A	0.25 .. 100.00 A	0.50 A	
3903	1p-RETRIP (T1)	Breaker Failure		NO YES	YES	1pole retrip with stage T1 (local trip)
3904	T1-1pole	Breaker Failure		0.00 .. 30.00 sec; ∞	0.00 sec	T1, Delay after 1pole start (local trip)
3905	T1-3pole	Breaker Failure		0.00 .. 30.00 sec; ∞	0.00 sec	T1, Delay after 3pole start (local trip)
3906	T2	Breaker Failure		0.00 .. 30.00 sec; ∞	0.15 sec	T2, Delay of 2nd stage (busbar trip)
3907	T3-BkrDefective	Breaker Failure		0.00 .. 30.00 sec; ∞	0.00 sec	T3, Delay for start with defective bkr.
3908	Trip BkrDefect.	Breaker Failure		NO with T1-trip with T2-trip w/ T1/T2-trip	NO	Trip output selection with defective bkr
3909	Chk BRK CONTACT	Breaker Failure		NO YES	YES	Check Breaker contacts
3921	End Flt. stage	Breaker Failure		ON OFF	OFF	End fault stage is
3922	T-EndFault	Breaker Failure		0.00 .. 30.00 sec; ∞	2.00 sec	Trip delay of end fault stage

Addr.	Parameter	Function	C	Setting Options	Default Setting	Comments
3931	PoleDiscrepancy	Breaker Failure		ON OFF	OFF	Pole Discrepancy supervision
3932	T-PoleDiscrep.	Breaker Failure		0.00 .. 30.00 sec; ∞	2.00 sec	Trip delay with pole discrepancy
4001	FCT TripSuperv.	TripCirc.Superv		ON OFF	OFF	TRIP Circuit Supervision is
4002	No. of BI	TripCirc.Superv		1 .. 2	2	Number of Binary Inputs per trip circuit
4003	Alarm Delay	TripCirc.Superv		1 .. 30 sec	2 sec	Delay Time for alarm
4201	Ther. OVERLOAD	Therm. Overload		OFF ON Alarm Only	OFF	Thermal overload protection
4202	K-FACTOR	Therm. Overload		0.10 .. 4.00	1.10	K-Factor
4203	TIME CONSTANT	Therm. Overload		1.0 .. 999.9 min	100.0 min	Time Constant
4204	Θ ALARM	Therm. Overload		50 .. 100 %	90 %	Thermal Alarm Stage
4205	I ALARM	Therm. Overload	1A 5A	0.10 .. 4.00 A 0.50 .. 20.00 A	1.00 A 5.00 A	Current Overload Alarm Setpoint
4206	CALC. METHOD	Therm. Overload		Θ max Average Θ Θ at Imax	Θ max	Method of Acquiring Temperature
4401	IP-A (A.x.x.x)	Commiss. Tool		0 .. 255	141	IP-address ***.xxx.xxx.xxx(Position 1-3)
4402	IP-B (x.B.x.x)	Commiss. Tool		0 .. 255	142	IP-address xxx.***.xxx.xxx(Position 4-6)
4403	IP-C (x.x.C.x)	Commiss. Tool		0 .. 255	255	IP-address xxx.xxx.***.xxx(Position 7-9)
4404	IP-D (x.x.x.D)	Commiss. Tool		0 .. 255	150	IP-address xxx.xxx.xxx.*** (Pos. 10-12)
4405	NUM LOCK	Commiss. Tool		YES NO	YES	Num Lock
4406	LCP/NCP	Commiss. Tool		NO YES	YES	Front interface supports LCP/NCP mode
4411	IP-A (A.x.x.x)	Commiss. Tool		0 .. 255	141	IP-address ***.xxx.xxx.xxx(Position 1-3)
4412	IP-B (x.B.x.x)	Commiss. Tool		0 .. 255	142	IP-address xxx.***.xxx.xxx(Position 4-6)
4413	IP-C (x.x.C.x)	Commiss. Tool		0 .. 255	255	IP-address xxx.xxx.***.xxx(Position 7-9)
4414	IP-D (x.x.x.D)	Commiss. Tool		0 .. 255	160	IP-address xxx.xxx.xxx.*** (Pos. 10-12)
4415	NUM LOCK	Commiss. Tool		YES NO	YES	Num Lock
4416	LCP/NCP	Commiss. Tool		NO YES	YES	Service interface supports LCP/NCP mode
4501	STATE PROT I 1	Prot. Interface		ON OFF	ON	State of protection interface 1
4502	CONNEX. 1 OVER	Prot. Interface		F.optic direct Com conv 64 kB Com conv 128 kB Com conv 512 kB	F.optic direct	Connection 1 over
4505A	PROT 1 T-DELAY	Prot. Interface		0.1 .. 30.0 ms	30.0 ms	Prot 1: Maximal permissible delay time
4506A	PROT 1 UNSYM.	Prot. Interface		0.000 .. 3.000 ms	0.100 ms	Prot 1: Diff. in send and receive time
4509	T-DATA DISTURB	Prot. Interface		0.05 .. 2.00 sec	0.10 sec	Time delay for data disturbance alarm
4510	T-DATAFAIL	Prot. Interface		0.0 .. 60.0 sec	6.0 sec	Time del for transmission failure alarm
4511	PI1 SYNCMODE	Prot. Interface		TEL and GPS TEL or GPS GPS SYNC OFF	TEL and GPS	PI1 Synchronizationmode
4512	Td ResetRemote	Prot. Interface		0.00 .. 300.00 sec; ∞	0.00 sec	Remote signal RESET DELAY for comm.fail
4513A	PROT1 max ERROR	Prot. Interface		0.5 .. 20.0 %	1.0 %	Prot 1: Maximal permissible error rate

Addr.	Parameter	Function	C	Setting Options	Default Setting	Comments
4515A	PI1 BLOCK UNSYM	Prot. Interface		YES NO	YES	Prot.1: Block. due to unsym. delay time
4601	STATE PROT I 2	Prot. Interface		ON OFF	ON	State of protection interface 2
4602	CONNEC. 2 OVER	Prot. Interface		F.optic direct Com conv 64 kB Com conv 128 kB Com conv 512 kB	F.optic direct	Connection 2 over
4605A	PROT 2 T-DELAY	Prot. Interface		0.1 .. 30.0 ms	30.0 ms	Prot 2: Maximal permissible delay time
4606A	PROT 2 UNSYM.	Prot. Interface		0.000 .. 3.000 ms	0.100 ms	Prot 2: Diff. in send and receive time
4611	PI2 SYNCMODE	Prot. Interface		TEL and GPS TEL or GPS GPS SYNC OFF	TEL and GPS	PI2 Synchronizationmode
4613A	PROT2 max ERROR	Prot. Interface		0.5 .. 20.0 %	1.0 %	Prot 1: Maximal permissible error rate
4615A	PI2 BLOCK UNSYM	Prot. Interface		YES NO	YES	Prot.2: Block. due to unsym. delay time
4701	ID OF RELAY 1	Diff.-Topo		1 .. 65534	1	Identification number of relay 1
4702	ID OF RELAY 2	Diff.-Topo		1 .. 65534	2	Identification number of relay 2
4703	ID OF RELAY 3	Diff.-Topo		1 .. 65534	3	Identification number of relay 3
4704	ID OF RELAY 4	Diff.-Topo		1 .. 65534	4	Identification number of relay 4
4705	ID OF RELAY 5	Diff.-Topo		1 .. 65534	5	Identification number of relay 5
4706	ID OF RELAY 6	Diff.-Topo		1 .. 65534	6	Identification number of relay 6
4710	LOCAL RELAY	Diff.-Topo		relay 1 relay 2 relay 3 relay 4 relay 5 relay 6	relay 1	Local relay is
4801	GPS-SYNC.	Prot. Interface		ON OFF	OFF	GPS synchronization
4803A	TD GPS FAILED	Prot. Interface		0.5 .. 60.0 sec	2.1 sec	Delay time for local GPS-pulse loss
6001	S1: Line angle	P.System Data 2		30 .. 89 °	85 °	S1: Line angle
6002	S1: x'	P.System Data 2	1A	0.0050 .. 9.5000 Ω/km	0.1500 Ω/km	S1: feeder reactance per km: x'
			5A	0.0010 .. 1.9000 Ω/km	0.0300 Ω/km	
6002	S1: x'	P.System Data 2	1A	0.0050 .. 15.0000 Ω/mi	0.2420 Ω/mi	S1: feeder reactance per mile: x'
			5A	0.0010 .. 3.0000 Ω/mi	0.0484 Ω/mi	
6003	S1: c'	P.System Data 2	1A	0.000 .. 100.000 μF/km	0.010 μF/km	S1: feeder capacitance c' in μF/km
			5A	0.000 .. 500.000 μF/km	0.050 μF/km	
6003	S1: c'	P.System Data 2	1A	0.000 .. 160.000 μF/mi	0.016 μF/mi	S1: feeder capacitance c' in μF/mile
			5A	0.000 .. 800.000 μF/mi	0.080 μF/mi	
6004	S1: Line length	P.System Data 2		0.1 .. 1000.0 km	100.0 km	S1: Line length in kilometer
6004	S1: line length	P.System Data 2		0.1 .. 650.0 Miles	62.1 Miles	S1: Line length in kilometer
6008	S1: center ph.	P.System Data 2		unknown/sym. Phase 1 Phase 2 Phase 3	unknown/sym.	S1: center phase
6009	S1: XE/XL	P.System Data 2		-0.33 .. 7.00	1.00	S1: Zero seq. compensating factor XE/XL
6010	S1: RE/RL	P.System Data 2		-0.33 .. 7.00	1.00	S1: Zero seq. compensating factor RE/RL
6011	S1: K0	P.System Data 2		0.000 .. 4.000	1.000	S1: Zero seq. compensating factor K0
6012	S1: angle K0	P.System Data 2		-135.00 .. 135.00 °	0.00 °	S1: Zero seq. compensating angle of K0
6021	S2: Line angle	P.System Data 2		30 .. 89 °	85 °	S2: Line angle
6022	S2: x'	P.System Data 2	1A	0.0050 .. 9.5000 Ω/km	0.1500 Ω/km	S2: feeder reactance per km: x'
			5A	0.0010 .. 1.9000 Ω/km	0.0300 Ω/km	
6022	S2: x'	P.System Data 2	1A	0.0050 .. 15.0000 Ω/mi	0.2420 Ω/mi	S2: feeder reactance per mile: x'
			5A	0.0010 .. 3.0000 Ω/mi	0.0484 Ω/mi	

Addr.	Parameter	Function	C	Setting Options	Default Setting	Comments
6023	S2: c'	P.System Data 2	1A	0.000 .. 100.000 $\mu\text{F}/\text{km}$	0.010 $\mu\text{F}/\text{km}$	S2: feeder capacitance c' in $\mu\text{F}/\text{km}$
			5A	0.000 .. 500.000 $\mu\text{F}/\text{km}$	0.050 $\mu\text{F}/\text{km}$	
6023	S2: c'	P.System Data 2	1A	0.000 .. 160.000 $\mu\text{F}/\text{mi}$	0.016 $\mu\text{F}/\text{mi}$	S2: feeder capacitance c' in $\mu\text{F}/\text{mile}$
			5A	0.000 .. 800.000 $\mu\text{F}/\text{mi}$	0.080 $\mu\text{F}/\text{mi}$	
6024	S2: Line length	P.System Data 2		0.1 .. 1000.0 km	100.0 km	S2: Line length in kilometer
6024	S2: line length	P.System Data 2		0.1 .. 650.0 Miles	62.1 Miles	S2: line length in miles
6028	S2: center ph.	P.System Data 2		unknown/sym. Phase 1 Phase 2 Phase 3	unknown/sym.	S2: center phase
6029	S2: XE/XL	P.System Data 2		-0.33 .. 7.00	1.00	S2: Zero seq. compensating factor XE/XL
6030	S2: RE/RL	P.System Data 2		-0.33 .. 7.00	1.00	S2: Zero seq. compensating factor RE/RL
6031	S2: K0	P.System Data 2		0.000 .. 4.000	1.000	S2: Zero seq. compensating factor K0
6032	S2: angle K0	P.System Data 2		-135.00 .. 135.00 °	0.00 °	S2: Zero seq. compensating angle of K0
6041	S3: Line angle	P.System Data 2		30 .. 89 °	85 °	S3: Line angle
6042	S3: x'	P.System Data 2	1A	0.0050 .. 9.5000 Ω/km	0.1500 Ω/km	S3: feeder reactance per km: x'
			5A	0.0010 .. 1.9000 Ω/km	0.0300 Ω/km	
6042	S3: x'	P.System Data 2	1A	0.0050 .. 15.0000 Ω/mi	0.2420 Ω/mi	S3: feeder reactance per mile: x'
			5A	0.0010 .. 3.0000 Ω/mi	0.0484 Ω/mi	
6043	S3: c'	P.System Data 2	1A	0.000 .. 100.000 $\mu\text{F}/\text{km}$	0.010 $\mu\text{F}/\text{km}$	S3: feeder capacitance c' in $\mu\text{F}/\text{km}$
			5A	0.000 .. 500.000 $\mu\text{F}/\text{km}$	0.050 $\mu\text{F}/\text{km}$	
6043	S3: c'	P.System Data 2	1A	0.000 .. 160.000 $\mu\text{F}/\text{mi}$	0.016 $\mu\text{F}/\text{mi}$	S3: feeder capacitance c' in $\mu\text{F}/\text{mile}$
			5A	0.000 .. 800.000 $\mu\text{F}/\text{mi}$	0.080 $\mu\text{F}/\text{mi}$	
6044	S3: Line length	P.System Data 2		0.1 .. 1000.0 km	100.0 km	S3: Line length in kilometer
6044	S3: line length	P.System Data 2		0.1 .. 650.0 Miles	62.1 Miles	S3: line length in miles
6048	S3: center ph.	P.System Data 2		unknown/sym. Phase 1 Phase 2 Phase 3	unknown/sym.	S3: center phase
6049	S3: XE/XL	P.System Data 2		-0.33 .. 7.00	1.00	S3: Zero seq. compensating factor XE/XL
6050	S3: RE/RL	P.System Data 2		-0.33 .. 7.00	1.00	S3: Zero seq. compensating factor RE/RL
6051	S3: K0	P.System Data 2		0.000 .. 4.000	1.000	S3: Zero seq. compensating factor K0
6052	S3: angle K0	P.System Data 2		-135.00 .. 135.00 °	0.00 °	S3: Zero seq. compensating angle of K0

A.8 Information List

No.	Description	Function	Type of Information	Log Buffers				Configurable in Matrix					IEC 60870-5-103			
				Event Log ON/OFF	Trip (Fault) Log ON/OFF	Ground Fault Log ON/OFF	Marked in Oscill. Record	LED	Binary Input	Function Key	Relay	Chatter Suppression	Type Information Number	Data Unit	General Interrogation	
-	Test mode (Test mode)	Device	IntSP	ON OFF	*		*	LED			BO		192	21	1	Yes
-	Stop data transmission (DataS-top)	Device	IntSP	ON OFF	*		*	LED			BO		192	20	1	Yes
-	Unlock data transmission via BI (UnlockDT)	Device	IntSP				*									
-	Clock Synchronization (Synch-Clock)	Device	IntSP_Ev	*	*		*	LED			BO					
-	>Back Light on (>Light on)	Device	SP	ON OFF	*				BI							
-	Hardware Test Mode (HWTest-Mod)	Device	IntSP	ON OFF	*		*	LED			BO					
-	Error FMS FO 1 (Error FMS1)	Device	OUT	ON OFF	*	*	*	LED			BO					
-	Error FMS FO 2 (Error FMS2)	Device	OUT	ON OFF	*	*	*	LED			BO					
-	Breaker OPENED (Brk OPENED)	Device	IntSP	*	*		*	LED			BO					
-	Feeder EARTHED (FdrEARTHED)	Device	IntSP	*	*		*	LED			BO					
-	Group A (Group A)	Change Group	IntSP	ON OFF	*		*	LED			BO		192	23	1	Yes
-	Group B (Group B)	Change Group	IntSP	ON OFF	*		*	LED			BO		192	24	1	Yes
-	Group C (Group C)	Change Group	IntSP	ON OFF	*		*	LED			BO		192	25	1	Yes
-	Group D (Group D)	Change Group	IntSP	ON OFF	*		*	LED			BO		192	26	1	Yes
-	Fault Recording Start (FitRecSta)	Osc. Fault Rec.	IntSP	ON OFF	*		m	LED			BO					
-	Reset Minimum and Maximum counter (ResMinMax)	Min/Max meter	IntSP_Ev	ON	*											
-	CB1-TEST trip/close - Only L1 (CB1tst L1)	Testing	-		*											
-	CB1-TEST trip/close - Only L2 (CB1tst L2)	Testing	-		*											
-	CB1-TEST trip/close - Only L3 (CB1tst L3)	Testing	-		*											
-	CB1-TEST trip/close Phases L123 (CB1tst 123)	Testing	-		*											
-	Controlmode REMOTE (ModeR-EMOTE)	Cntrl Authority	IntSP	ON OFF	*			LED								
-	Control Authority (Cntrl Auth)	Cntrl Authority	IntSP	ON OFF	*			LED					101	85	1	Yes
-	Controlmode LOCAL (ModeLOCAL)	Cntrl Authority	IntSP	ON OFF	*			LED					101	86	1	Yes
-	Breaker (Breaker)	Control Device	CF_D 12	on off	*						BO		240	160	20	
-	Breaker (Breaker)	Control Device	DP	on off	*				BI			CB	240	160	1	Yes

No.	Description	Function	Type of Information	Event Log ON/OFF	Log Buffers			Configurable in Matrix					IEC 60870-5-103			
					Trip (Fault) Log ON/OFF	Ground Fault Log ON/OFF	Marked in Oscill. Record	LED	Binary Input	Function Key	Relay	Chatter Suppression	Type	Information Number	Data Unit	General Interrogation
-	Disconnect Switch (Disc.Swit.)	Control Device	CF_D 2	on off	*						BO		240	161	20	
-	Disconnect Switch (Disc.Swit.)	Control Device	DP	on off	*				BI		CB		240	161	1	Yes
-	Earth Switch (EarthSwit)	Control Device	CF_D 2	on off	*						BO		240	164	20	
-	Earth Switch (EarthSwit)	Control Device	DP	on off	*				BI		CB		240	164	1	Yes
-	Interlocking: 52 Open (52 Open)	Control Device	IntSP	*	*		*									
-	Interlocking: 52 Close (52 Close)	Control Device	IntSP	*	*		*									
-	Interlocking: Disconnect switch Open (Disc.Open)	Control Device	IntSP	*	*		*									
-	Interlocking: Disconnect switch Close (Disc.Close)	Control Device	IntSP	*	*		*									
-	Interlocking: Earth switch Open (E Sw Open)	Control Device	IntSP	*	*		*									
-	Interlocking: Earth switch Close (E Sw Cl.)	Control Device	IntSP	*	*		*									
-	Q2 Open/Close (Q2 Op/Cl)	Control Device	CF_D 2	on off	*						BO		240	162	20	
-	Q2 Open/Close (Q2 Op/Cl)	Control Device	DP	on off	*				BI		CB		240	162	1	Yes
-	Q9 Open/Close (Q9 Op/Cl)	Control Device	CF_D 2	on off	*						BO		240	163	20	
-	Q9 Open/Close (Q9 Op/Cl)	Control Device	DP	on off	*				BI		CB		240	163	1	Yes
-	Fan ON/OFF (Fan ON/OFF)	Control Device	CF_D 2	on off	*						BO		240	175	20	
-	Fan ON/OFF (Fan ON/OFF)	Control Device	DP	on off	*				BI		CB		240	175	1	Yes
-	>Cabinet door open (>Door open)	Process Data	SP	on off	*		*	LED	BI		BO	CB	101	1	1	Yes
-	>CB waiting for Spring charged (>CB wait)	Process Data	SP	on off	*		*	LED	BI		BO	CB	101	2	1	Yes
-	>Error Motor Voltage (>Err.Mot U)	Process Data	SP	on off	*		*	LED	BI		BO	CB	240	181	1	Yes
-	>Error Control Voltage (>ErrCntrl-U)	Process Data	SP	on off	*		*	LED	BI		BO	CB	240	182	1	Yes
-	>SF6-Loss (>SF6-Loss)	Process Data	SP	on off	*		*	LED	BI		BO	CB	240	183	1	Yes
-	>Error Meter (>Err Meter)	Process Data	SP	on off	*		*	LED	BI		BO	CB	240	184	1	Yes
-	>Transformer Temperature (>Tx Temp.)	Process Data	SP	on off	*		*	LED	BI		BO	CB	240	185	1	Yes
-	>Transformer Danger (>Tx Danger)	Process Data	SP	on off	*		*	LED	BI		BO	CB	240	186	1	Yes
-	Reset meter (Meter res)	Energy	IntSP_Ev	ON	*											
-	Error Systeminterface (SysIntErr.)	Protocol	IntSP	on off				LED			BO					
-	Threshold Value 1 (ThreshVal1)	Thresh.-Switch	IntSP	ON OFF	*		*	LED	BI	FC TN	BO	CB				
3	>Synchronize Internal Real Time Clock (>Time Synch)	Device	SP	*	*		*	LED	BI		BO					
4	>Trigger Waveform Capture (>Trig.Wave.Cap.)	Osc. Fault Rec.	SP	ON	*		m	LED	BI		BO					

No.	Description	Function	Type of Information	Log Buffers				Configurable in Matrix					IEC 60870-5-103			
				Event Log ON/OFF	Trip (Fault) Log ON/OFF	Ground Fault Log ON/OFF	Marked in Oscill. Record	LED	Binary Input	Function Key	Relay	Chatter Suppression	Type	Information Number	Data Unit	General Interrogation
5	>Reset LED (>Reset LED)	Device	SP	*	*		*	LED	BI		BO					
7	>Setting Group Select Bit 0 (>Set Group Bit0)	Change Group	SP	*	*		*	LED	BI		BO					
8	>Setting Group Select Bit 1 (>Set Group Bit1)	Change Group	SP	*	*		*	LED	BI		BO					
11	>User defined annunciation 1 (>Annunc. 1)	Device	SP	*	*	*	*	LED	BI		BO		192	27	1	Yes
12	>User defined annunciation 2 (>Annunc. 2)	Device	SP	*	*	*	*	LED	BI		BO		192	28	1	Yes
13	>User defined annunciation 3 (>Annunc. 3)	Device	SP	*	*	*	*	LED	BI		BO		192	29	1	Yes
14	>User defined annunciation 4 (>Annunc. 4)	Device	SP	*	*	*	*	LED	BI		BO		192	30	1	Yes
15	>Test mode (>Test mode)	Device	SP	ON OFF	*		*	LED	BI		BO		135	53	1	Yes
16	>Stop data transmission (>DataStop)	Device	SP	*	*		*	LED	BI		BO		135	54	1	Yes
51	Device is Operational and Protecting (Device OK)	Device	OUT	ON OFF	*		*	LED			BO		135	81	1	Yes
52	At Least 1 Protection Funct. is Active (ProtActive)	Device	IntSP	ON OFF	*		*	LED			BO		192	18	1	Yes
55	Reset Device (Reset Device)	Device	OUT	*	*		*	LED			BO		192	4	1	No
56	Initial Start of Device (Initial Start)	Device	OUT	ON	*		*	LED			BO		192	5	1	No
60	Reset LED (Reset LED)	Device	OUT_Ev	ON	*		*	LED			BO		192	19	1	No
67	Resume (Resume)	Device	OUT	ON	*		*	LED			BO		135	97	1	No
68	Clock Synchronization Error (Clock SyncError)	Device	OUT	ON OFF	*		*	LED			BO					
69	Daylight Saving Time (DayLight-SavTime)	Device	OUT	ON OFF	*		*	LED			BO					
70	Setting calculation is running (Settings Calc.)	Device	OUT	ON OFF	*		*	LED			BO		192	22	1	Yes
71	Settings Check (Settings Check)	Device	OUT	*	*		*	LED			BO					
72	Level-2 change (Level-2 change)	Device	OUT	ON OFF	*		*	LED			BO					
73	Local setting change (Local change)	Device	OUT	*	*											
110	Event lost (Event Lost)	Device	OUT_Ev	ON	*		*	LED			BO		135	130	1	No
113	Flag Lost (Flag Lost)	Device	OUT	ON	*		m	LED			BO		135	136	1	Yes
125	Chatter ON (Chatter ON)	Device	OUT	ON OFF	*		*	LED			BO		135	145	1	Yes
126	Protection ON/OFF (via system port) (ProtON/OFF)	Device	IntSP	ON OFF	*		*	LED			BO					
127	Auto Reclose ON/OFF (via system port) (AR ON/OFF)	Auto Reclose	IntSP	ON OFF	*		*	LED			BO					
128	Teleprot. ON/OFF (via system port) (TelePONoff)	Device	IntSP	ON OFF	*		*	LED			BO					
140	Error with a summary alarm (Error Sum Alarm)	Device	OUT	ON OFF	*		*	LED			BO		192	47	1	Yes
144	Error 5V (Error 5V)	Device	OUT	ON OFF	*		*	LED			BO		135	164	1	Yes
160	Alarm Summary Event (Alarm Sum Event)	Device	OUT	*	*		*	LED			BO		192	46	1	Yes

No.	Description	Function	Type of Information	Log Buffers				Configurable in Matrix					IEC 60870-5-103			
				Event Log ON/OFF	Trip (Fault) Log ON/OFF	Ground Fault Log ON/OFF	Marked in Oscill. Record	LED	Binary Input	Function Key	Relay	Chatter Suppression	Type	Information Number	Data Unit	General Interrogation
161	Failure: General Current Supervision (Fail I Superv.)	Measurem.Superv	OUT	*	*	*	*	LED			BO		192	32	1	Yes
163	Failure: Current Balance (Fail I balance)	Measurem.Superv	OUT	ON OFF	*	*	*	LED			BO		135	183	1	Yes
164	Failure: General Voltage Supervision (Fail U Superv.)	Measurem.Superv	OUT	*	*	*	*	LED			BO		192	33	1	Yes
165	Failure: Voltage summation Phase-Earth (Fail Σ U Ph-E)	Measurem.Superv	OUT	ON OFF	*	*	*	LED			BO		135	184	1	Yes
167	Failure: Voltage Balance (Fail U balance)	Measurem.Superv	OUT	ON OFF	*	*	*	LED			BO		135	186	1	Yes
168	Failure: Voltage absent (Fail U absent)	Measurem.Superv	OUT	ON OFF	*	*	*	LED			BO		135	187	1	Yes
169	VT Fuse Failure (alarm >10s) (VT FuseFail>10s)	Measurem.Superv	OUT	ON OFF	*	*	*	LED			BO		135	188	1	Yes
170	VT Fuse Failure (alarm instantaneous) (VT FuseFail)	Measurem.Superv	OUT	ON OFF	*	*	*	LED			BO					
171	Failure: Phase Sequence (Fail Ph. Seq.)	Measurem.Superv	OUT	ON OFF	*	*	*	LED			BO		192	35	1	Yes
177	Failure: Battery empty (Fail Battery)	Device	OUT	ON OFF	*	*	*	LED			BO		135	193	1	Yes
181	Error: A/D converter (Error A/D-conv.)	Device	OUT	ON OFF	*	*	*	LED			BO		135	178	1	Yes
182	Alarm: Real Time Clock (Alarm Clock)	Device	OUT													
183	Error Board 1 (Error Board 1)	Device	OUT	ON OFF	*	*	*	LED			BO		135	171	1	Yes
184	Error Board 2 (Error Board 2)	Device	OUT	ON OFF	*	*	*	LED			BO		135	172	1	Yes
185	Error Board 3 (Error Board 3)	Device	OUT	ON OFF	*	*	*	LED			BO		135	173	1	Yes
186	Error Board 4 (Error Board 4)	Device	OUT	ON OFF	*	*	*	LED			BO		135	174	1	Yes
187	Error Board 5 (Error Board 5)	Device	OUT	ON OFF	*	*	*	LED			BO		135	175	1	Yes
188	Error Board 6 (Error Board 6)	Device	OUT	ON OFF	*	*	*	LED			BO		135	176	1	Yes
189	Error Board 7 (Error Board 7)	Device	OUT	ON OFF	*	*	*	LED			BO		135	177	1	Yes
190	Error Board 0 (Error Board 0)	Device	OUT	ON OFF	*	*	*	LED			BO		135	210	1	Yes
191	Error: Offset (Error Offset)	Device	OUT	ON OFF	*	*	*	LED			BO					
192	Error: 1A/5A jumper different from setting (Error 1A/5A wrong)	Device	OUT	ON OFF	*	*	*	LED			BO		135	169	1	Yes
193	Alarm: Analog input adjustment invalid (Alarm adjustm.)	Device	OUT	ON OFF	*	*	*	LED			BO		135	181	1	Yes
194	Error: Neutral CT different from MLFB (Error neutralCT)	Device	OUT	ON OFF	*	*	*	LED			BO		135	180	1	Yes
196	Fuse Fail Monitor is switched OFF (Fuse Fail M.OFF)	Measurem.Superv	OUT		*	*	*	LED			BO		135	196	1	Yes
197	Measurement Supervision is switched OFF (MeasSup OFF)	Measurem.Superv	OUT	ON OFF	*	*	*	LED			BO		135	197	1	Yes
203	Waveform data deleted (Wave. deleted)	Osc. Fault Rec.	OUT_Ev	ON	*	*	*	LED			BO		135	203	1	No
273	Set Point Phase L1 dmd> (SP. IL1 dmd>)	Set Points(MV)	OUT	on off	*	*	*	LED			BO					

No.	Description	Function	Type of Information	Log Buffers				Configurable in Matrix					IEC 60870-5-103			
				Event Log ON/OFF	Trip (Fault) Log ON/OFF	Ground Fault Log ON/OFF	Marked in Oscill. Record	LED	Binary Input	Function Key	Relay	Chatter Suppression	Type	Information Number	Data Unit	General Interrogation
274	Set Point Phase L2 dmd> (SP. IL2 dmd>)	Set Points(MV)	OUT	on off	*		*	LED			BO					
275	Set Point Phase L3 dmd> (SP. IL3 dmd>)	Set Points(MV)	OUT	on off	*		*	LED			BO					
276	Set Point positive sequence I1dmd> (SP. I1dmd>)	Set Points(MV)	OUT	on off	*		*	LED			BO					
277	Set Point Pdmd> (SP. Pdmd >)	Set Points(MV)	OUT	on off	*		*	LED			BO					
278	Set Point Qdmd> (SP. Qdmd >)	Set Points(MV)	OUT	on off	*		*	LED			BO					
279	Set Point Sdmd> (SP. Sdmd >)	Set Points(MV)	OUT	on off	*		*	LED			BO					
285	Power factor alarm (cosφ alarm)	Set Points(MV)	OUT	on off	*		*	LED			BO					
289	Alarm: Current summation supervision (Failure Σi)	Measurem.Superv	OUT	ON OFF	*		*	LED			BO		135	250	1	Yes
290	Alarm: Broken current-wire detected L1 (Broken lwire L1)	Measurem.Superv	OUT	ON	*		*	LED			BO		135	137	1	Yes
291	Alarm: Broken current-wire detected L2 (Broken lwire L2)	Measurem.Superv	OUT	ON	*		*	LED			BO		135	138	1	Yes
292	Alarm: Broken current-wire detected L3 (Broken lwire L3)	Measurem.Superv	OUT	ON	*		*	LED			BO		135	139	1	Yes
295	Broken wire supervision is switched OFF (Broken wire OFF)	Measurem.Superv	OUT	ON OFF	*		*	LED			BO					
296	Current summation superv is switched OFF (Σi superv. OFF)	Measurem.Superv	OUT	ON OFF	*		*	LED			BO					
301	Power System fault (Pow.Sys.Flt.)	P.System Data 2	VI	ON OFF	ON		*						135	231	2	Yes
302	Fault Event (Fault Event)	P.System Data 2	VI	*	ON		*						135	232	2	No
303	E/Fit.det. in isol/comp.netw. (E/F Det.)	P.System Data 2	VI	ON OFF	*	ON	*									
351	>Circuit breaker aux. contact: Pole L1 (>CB Aux. L1)	P.System Data 2	SP	*	*		*	LED	BI		BO		150	1	1	Yes
352	>Circuit breaker aux. contact: Pole L2 (>CB Aux. L2)	P.System Data 2	SP	*	*		*	LED	BI		BO		150	2	1	Yes
353	>Circuit breaker aux. contact: Pole L3 (>CB Aux. L3)	P.System Data 2	SP	*	*		*	LED	BI		BO		150	3	1	Yes
356	>Manual close signal (>Manual Close)	P.System Data 2	SP	*	*		*	LED	BI		BO		150	6	1	Yes
357	>Block all close commands from external (>CloseCmd.Blo)	P.System Data 2	SP	ON OFF	*		*	LED	BI		BO		150	7	1	Yes
361	>Failure: Feeder VT (MCB tripped) (>FAIL:Feeder VT)	P.System Data 2	SP	ON OFF	*		*	LED	BI		BO		192	38	1	Yes
362	>Failure: Busbar VT (MCB tripped) (>FAIL:Bus VT)	P.System Data 2	SP	ON OFF	*		*	LED	BI		BO		150	12	1	Yes
366	>CB1 Pole L1 (for AR,CB-Test) (>CB1 Pole L1)	P.System Data 2	SP	*	*		*	LED	BI		BO		150	66	1	Yes
367	>CB1 Pole L2 (for AR,CB-Test) (>CB1 Pole L2)	P.System Data 2	SP	*	*		*	LED	BI		BO		150	67	1	Yes
368	>CB1 Pole L3 (for AR,CB-Test) (>CB1 Pole L3)	P.System Data 2	SP	*	*		*	LED	BI		BO		150	68	1	Yes
371	>CB1 READY (for AR,CB-Test) (>CB1 Ready)	P.System Data 2	SP	*	*		*	LED	BI		BO		150	71	1	Yes
378	>CB faulty (>CB faulty)	P.System Data 2	SP	*	*		*	LED	BI		BO					
379	>CB aux. contact 3pole Closed (>CB 3p Closed)	P.System Data 2	SP	*	*		*	LED	BI		BO		150	78	1	Yes

No.	Description	Function	Type of Information	Log Buffers				Configurable in Matrix					IEC 60870-5-103			
				Event Log ON/OFF	Trip (Fault) Log ON/OFF	Ground Fault Log ON/OFF	Marked in Oscill. Record	LED	Binary Input	Function Key	Relay	Chatter Suppression	Type	Information Number	Data Unit	General Interrogation
380	>CB aux. contact 3pole Open (>CB 3p Open)	P.System Data 2	SP	*	*		*	LED	BI		BO		150	79	1	Yes
381	>Single-phase trip permitted from ext.AR (>1p Trip Perm)	P.System Data 2	SP	ON OFF	*		*	LED	BI		BO					
382	>External AR programmed for 1phase only (>Only 1ph AR)	P.System Data 2	SP	ON OFF	*		*	LED	BI		BO					
383	>Enable all AR Zones / Stages (>Enable ARzones)	P.System Data 2	SP	ON OFF	ON OFF		*	LED	BI		BO					
385	>Lockout SET (>Lockout SET)	P.System Data 2	SP	ON OFF	*		*	LED	BI		BO		150	35	1	Yes
386	>Lockout RESET (>Lockout RESET)	P.System Data 2	SP	ON OFF	*		*	LED	BI		BO		150	36	1	Yes
395	>I MIN/MAX Buffer Reset (>I MinMax Reset)	Min/Max meter	SP	ON	*		*	LED	BI		BO					
396	>I1 MIN/MAX Buffer Reset (>I1 MiMaReset)	Min/Max meter	SP	ON	*		*	LED	BI		BO					
397	>U MIN/MAX Buffer Reset (>U MiMaReset)	Min/Max meter	SP	ON	*		*	LED	BI		BO					
398	>Uphph MIN/MAX Buffer Reset (>UphphMiMaRes)	Min/Max meter	SP	ON	*		*	LED	BI		BO					
399	>U1 MIN/MAX Buffer Reset (>U1 MiMa Reset)	Min/Max meter	SP	ON	*		*	LED	BI		BO					
400	>P MIN/MAX Buffer Reset (>P MiMa Reset)	Min/Max meter	SP	ON	*		*	LED	BI		BO					
401	>S MIN/MAX Buffer Reset (>S MiMa Reset)	Min/Max meter	SP	ON	*		*	LED	BI		BO					
402	>Q MIN/MAX Buffer Reset (>Q MiMa Reset)	Min/Max meter	SP	ON	*		*	LED	BI		BO					
403	>Idmd MIN/MAX Buffer Reset (>Idmd MiMaReset)	Min/Max meter	SP	ON	*		*	LED	BI		BO					
404	>Pdmd MIN/MAX Buffer Reset (>Pdmd MiMaReset)	Min/Max meter	SP	ON	*		*	LED	BI		BO					
405	>Qdmd MIN/MAX Buffer Reset (>Qdmd MiMaReset)	Min/Max meter	SP	ON	*		*	LED	BI		BO					
406	>Sdmd MIN/MAX Buffer Reset (>Sdmd MiMaReset)	Min/Max meter	SP	ON	*		*	LED	BI		BO					
407	>Frq. MIN/MAX Buffer Reset (>Frq MiMa Reset)	Min/Max meter	SP	ON	*		*	LED	BI		BO					
408	>Power Factor MIN/MAX Buffer Reset (>PF MiMaReset)	Min/Max meter	SP	ON	*		*	LED	BI		BO					
410	>CB1 aux. 3p Closed (for AR, CB-Test) (>CB1 3p Closed)	P.System Data 2	SP	*	*		*	LED	BI		BO		150	80	1	Yes
411	>CB1 aux. 3p Open (for AR, CB-Test) (>CB1 3p Open)	P.System Data 2	SP	*	*		*	LED	BI		BO		150	81	1	Yes
501	Relay PICKUP (Relay PICKUP)	P.System Data 2	OUT	*	*		M	LED			BO		192	84	2	Yes
502	Relay Drop Out (Relay Drop Out)	P.System Data 2	OUT													
503	Relay PICKUP Phase L1 (Relay PICKUP L1)	P.System Data 2	OUT	*	*		m	LED			BO		192	64	2	Yes
504	Relay PICKUP Phase L2 (Relay PICKUP L2)	P.System Data 2	OUT	*	*		m	LED			BO		192	65	2	Yes
505	Relay PICKUP Phase L3 (Relay PICKUP L3)	P.System Data 2	OUT	*	*		m	LED			BO		192	66	2	Yes
506	Relay PICKUP Earth (Relay PICKUP E)	P.System Data 2	OUT	*	*		m	LED			BO		192	67	2	Yes
507	Relay TRIP command Phase L1 (Relay TRIP L1)	P.System Data 2	OUT	*	*		m	LED			BO		192	69	2	No

No.	Description	Function	Type of Information	Log Buffers				Configurable in Matrix					IEC 60870-5-103			
				Event Log ON/OFF	Trip (Fault) Log ON/OFF	Ground Fault Log ON/OFF	Marked in Oscill. Record	LED	Binary Input	Function Key	Relay	Chatter Suppression	Type	Information Number	Data Unit	General Interrogation
508	Relay TRIP command Phase L2 (Relay TRIP L2)	P.System Data 2	OUT	*	*		m	LED			BO		192	70	2	No
509	Relay TRIP command Phase L3 (Relay TRIP L3)	P.System Data 2	OUT	*	*		m	LED			BO		192	71	2	No
510	General CLOSE of relay (Relay CLOSE)	P.System Data 2	OUT	*	*		*	LED			BO					
511	Relay GENERAL TRIP command (Relay TRIP)	P.System Data 2	OUT	*	OFF		M	LED			BO		192	68	2	No
512	Relay TRIP command - Only Phase L1 (Relay TRIP 1pL1)	P.System Data 2	OUT	*	*		*	LED			BO					
513	Relay TRIP command - Only Phase L2 (Relay TRIP 1pL2)	P.System Data 2	OUT	*	*		*	LED			BO					
514	Relay TRIP command - Only Phase L3 (Relay TRIP 1pL3)	P.System Data 2	OUT	*	*		*	LED			BO					
515	Relay TRIP command Phases L123 (Relay TRIP 3ph.)	P.System Data 2	OUT	*	*		*	LED			BO					
530	LOCKOUT is active (LOCKOUT)	P.System Data 2	IntSP	ON OFF	*		*	LED			BO					
533	Primary fault current IL1 (IL1 =)	P.System Data 2	VI	*	ON OFF								150	177	4	No
534	Primary fault current IL2 (IL2 =)	P.System Data 2	VI	*	ON OFF								150	178	4	No
535	Primary fault current IL3 (IL3 =)	P.System Data 2	VI	*	ON OFF								150	179	4	No
536	Final Trip (Final Trip)	P.System Data 2	OUT	ON	ON			LED			BO		150	180	2	Yes
545	Time from Pickup to drop out (PU Time)	P.System Data 2	VI													
546	Time from Pickup to TRIP (TRIP Time)	P.System Data 2	VI													
560	Single-phase trip was coupled 3phase (Trip Coupled 3p)	P.System Data 2	OUT	*	ON		*	LED			BO		150	210	2	No
561	Manual close signal detected (Man.Clos.Detect)	P.System Data 2	OUT	ON	*		*	LED			BO		150	211	1	No
562	CB CLOSE command for manual closing (Man.Close Cmd)	P.System Data 2	OUT	*	*		*	LED			BO		150	212	1	No
563	CB alarm suppressed (CB Alarm Supp)	P.System Data 2	OUT	*	*		*	LED			BO					
590	Line closure detected (Line closure)	P.System Data 2	OUT	ON OFF	ON OFF		*	LED			BO					
591	Single pole open detected in L1 (1pole open L1)	P.System Data 2	OUT	ON OFF	ON OFF		*	LED			BO					
592	Single pole open detected in L2 (1pole open L2)	P.System Data 2	OUT	ON OFF	ON OFF		*	LED			BO					
593	Single pole open detected in L3 (1pole open L3)	P.System Data 2	OUT	ON OFF	ON OFF		*	LED			BO					
916	Increment of active energy (WpΔ=)	Energy	-													
917	Increment of reactive energy (WqΔ=)	Energy	-													
1000	Number of breaker TRIP commands (# TRIPs=)	Statistics	VI													
1001	Number of breaker TRIP commands L1 (TripNo L1=)	Statistics	VI													
1002	Number of breaker TRIP commands L2 (TripNo L2=)	Statistics	VI													

No.	Description	Function	Type of Information	Log Buffers				Configurable in Matrix					IEC 60870-5-103			
				Event Log ON/OFF	Trip (Fault) Log ON/OFF	Ground Fault Log ON/OFF	Marked in Oscill. Record	LED	Binary Input	Function Key	Relay	Chatter Suppression	Type	Information Number	Data Unit	General Interrogation
1003	Number of breaker TRIP commands L3 (TripNo L3=)	Statistics	VI													
1027	Accumulation of interrupted current L1 (Σ IL1 =)	Statistics	VI													
1028	Accumulation of interrupted current L2 (Σ IL2 =)	Statistics	VI													
1029	Accumulation of interrupted current L3 (Σ IL3 =)	Statistics	VI													
1030	Max. fault current Phase L1 (Max IL1 =)	Statistics	VI													
1031	Max. fault current Phase L2 (Max IL2 =)	Statistics	VI													
1032	Max. fault current Phase L3 (Max IL3 =)	Statistics	VI													
1111	Fault locator active (FL active)	Fault Locator	OUT	ON OFF	*		*	LED			BO					
1113	Quality of the fault location (quality=)	Fault Locator	VI		on off											
1114	Flt Locator: primary RESISTANCE (Rpri =)	Fault Locator	VI		ON OFF							151	14	4	No	
1115	Flt Locator: primary REACTANCE (Xpri =)	Fault Locator	VI		ON OFF							151	15	4	No	
1117	Flt Locator: secondary RESISTANCE (Rsec =)	Fault Locator	VI		ON OFF							151	17	4	No	
1118	Flt Locator: secondary REACTANCE (Xsec =)	Fault Locator	VI		ON OFF							151	18	4	No	
1119	Flt Locator: Distance to fault (dist =)	Fault Locator	VI		ON OFF							151	19	4	No	
1120	Flt Locator: Distance [%] to fault (d[%] =)	Fault Locator	VI		ON OFF							151	20	4	No	
1122	Flt Locator: Distance to fault (dist =)	Fault Locator	VI		ON OFF							151	22	4	No	
1123	Fault Locator Loop L1E (FL Loop L1E)	Fault Locator	OUT_Ev		ON											
1124	Fault Locator Loop L2E (FL Loop L2E)	Fault Locator	OUT_Ev		ON											
1125	Fault Locator Loop L3E (FL Loop L3E)	Fault Locator	OUT_Ev		ON											
1126	Fault Locator Loop L1L2 (FL Loop L1L2)	Fault Locator	OUT_Ev		ON											
1127	Fault Locator Loop L2L3 (FL Loop L2L3)	Fault Locator	OUT_Ev		ON											
1128	Fault Locator Loop L3L1 (FL Loop L3L1)	Fault Locator	OUT_Ev		ON											
1131	Flt Locator: primary FAULT RESISTANCE (RFpri=)	Fault Locator	VI		ON OFF							151	31	4	No	
1132	Fault location invalid (Flt.Loc.invalid)	Fault Locator	OUT	*	ON		*	LED			BO					
1133	Fault locator setting error K0,angle(K0) (Flt.Loc.ErrorK0)	Fault Locator	OUT	*	ON		*	LED			BO					
1134	Two ended fault location (two ended FO)	Fault Locator	OUT_Ev		on											
1135	R (primary, single ended) (Rpri single. =)	Fault Locator	VI		on off											
1136	X (primary, single ended) (Xpri single. =)	Fault Locator	VI		on off											

No.	Description	Function	Type of Information	Log Buffers				Configurable in Matrix					IEC 60870-5-103			
				Event Log ON/OFF	Trip (Fault) Log ON/OFF	Ground Fault Log ON/OFF	Marked in Oscill. Record	LED	Binary Input	Function Key	Relay	Chatter Suppression	Type	Information Number	Data Unit	General Interrogation
1137	R (secondary single ended) (Rsec single. =)	Fault Locator	VI		on off											
1138	X (secondary single ended) (Xsec single. =)	Fault Locator	VI	*	on off											
1143	BCD Fault location [1%] (BCD d[1%])	Fault Locator	OUT	*	*			LED			BO					
1144	BCD Fault location [2%] (BCD d[2%])	Fault Locator	OUT	*	*			LED			BO					
1145	BCD Fault location [4%] (BCD d[4%])	Fault Locator	OUT	*	*			LED			BO					
1146	BCD Fault location [8%] (BCD d[8%])	Fault Locator	OUT	*	*			LED			BO					
1147	BCD Fault location [10%] (BCD d[10%])	Fault Locator	OUT	*	*			LED			BO					
1148	BCD Fault location [20%] (BCD d[20%])	Fault Locator	OUT	*	*			LED			BO					
1149	BCD Fault location [40%] (BCD d[40%])	Fault Locator	OUT	*	*			LED			BO					
1150	BCD Fault location [80%] (BCD d[80%])	Fault Locator	OUT	*	*			LED			BO					
1151	BCD Fault location [100%] (BCD d[100%])	Fault Locator	OUT	*	*			LED			BO					
1152	BCD Fault location valid (BCD dist. VALID)	Fault Locator	OUT	*	*			LED			BO					
1305	>Earth Fault O/C Block 3I0>>> (>EF BLK 3I0>>>)	Earth Fault O/C	SP	ON OFF	*		*	LED	BI		BO		166	5	1	Yes
1307	>Earth Fault O/C Block 3I0>> (>EF BLOCK 3I0>>)	Earth Fault O/C	SP	ON OFF	*		*	LED	BI		BO		166	7	1	Yes
1308	>Earth Fault O/C Block 3I0> (>EF BLOCK 3I0>)	Earth Fault O/C	SP	ON OFF	*		*	LED	BI		BO		166	8	1	Yes
1309	>Earth Fault O/C Block 3I0p (>EF BLOCK 3I0p)	Earth Fault O/C	SP	ON OFF	*		*	LED	BI		BO		166	9	1	Yes
1310	>Earth Fault O/C Instantaneous trip (>EF InstTRIP)	Earth Fault O/C	SP	ON OFF	ON OFF		*	LED	BI		BO		166	10	1	Yes
1311	>E/F Teleprotection ON (>EF Teleprot.ON)	Teleprot. E/F	SP	*	*		*	LED	BI		BO					
1312	>E/F Teleprotection OFF (>EF Teleprot.OFF)	Teleprot. E/F	SP	*	*		*	LED	BI		BO					
1313	>E/F Teleprotection BLOCK (>EF Teleprot.BLK)	Teleprot. E/F	SP	ON OFF	*		*	LED	BI		BO		166	13	1	Yes
1318	>E/F Carrier RECEPTION, Channel 1 (>EF Rec.Ch1)	Teleprot. E/F	SP	on off	on		*	LED	BI		BO		166	18	1	Yes
1319	>E/F Carrier RECEPTION, Channel 2 (>EF Rec.Ch2)	Teleprot. E/F	SP	on off	on		*	LED	BI		BO		166	19	1	Yes
1320	>E/F Unblocking: UNBLOCK, Channel 1 (>EF UB ub 1)	Teleprot. E/F	SP	ON OFF	ON		*	LED	BI		BO		166	20	1	Yes
1321	>E/F Unblocking: BLOCK, Channel 1 (>EF UB bl 1)	Teleprot. E/F	SP	ON OFF	ON		*	LED	BI		BO		166	21	1	Yes
1322	>E/F Unblocking: UNBLOCK, Channel 2 (>EF UB ub 2)	Teleprot. E/F	SP	ON OFF	ON		*	LED	BI		BO		166	22	1	Yes
1323	>E/F Unblocking: BLOCK, Channel 2 (>EF UB bl 2)	Teleprot. E/F	SP	ON OFF	ON		*	LED	BI		BO		166	23	1	Yes
1324	>E/F BLOCK Echo Signal (>EF BlkEcho)	Teleprot. E/F	SP	ON OFF	ON		*	LED	BI		BO		166	24	1	Yes

No.	Description	Function	Type of Information	Event Log ON/OFF	Log Buffers			Configurable in Matrix					IEC 60870-5-103			
					Trip (Fault) Log ON/OFF	Ground Fault Log ON/OFF	Marked in Oscill. Record	LED	Binary Input	Function Key	Relay	Chatter Suppression	Type	Information Number	Data Unit	General Interrogation
1325	>E/F Carrier RECEPTION, Channel 1, Ph.L1 (>EF Rec.Ch1 L1)	Teleprot. E/F	SP	on off	on		*	LED	BI		BO		166	25	1	Yes
1326	>E/F Carrier RECEPTION, Channel 1, Ph.L2 (>EF Rec.Ch1 L2)	Teleprot. E/F	SP	on off	on		*	LED	BI		BO		166	26	1	Yes
1327	>E/F Carrier RECEPTION, Channel 1, Ph.L3 (>EF Rec.Ch1 L3)	Teleprot. E/F	SP	on off	on		*	LED	BI		BO		166	27	1	Yes
1328	>E/F Unblocking: UNBLOCK Chan. 1, Ph.L1 (>EF UB ub 1-L1)	Teleprot. E/F	SP	ON OFF	ON		*	LED	BI		BO		166	28	1	Yes
1329	>E/F Unblocking: UNBLOCK Chan. 1, Ph.L2 (>EF UB ub 1-L2)	Teleprot. E/F	SP	ON OFF	ON		*	LED	BI		BO		166	29	1	Yes
1330	>E/F Unblocking: UNBLOCK Chan. 1, Ph.L3 (>EF UB ub 1-L3)	Teleprot. E/F	SP	ON OFF	ON		*	LED	BI		BO		166	30	1	Yes
1331	Earth fault protection is switched OFF (E/F Prot. OFF)	Earth Fault O/C	OUT	ON OFF	*		*	LED			BO		166	31	1	Yes
1332	Earth fault protection is BLOCKED (E/F BLOCK)	Earth Fault O/C	OUT	ON OFF	ON OFF		*	LED			BO		166	32	1	Yes
1333	Earth fault protection is ACTIVE (E/F ACTIVE)	Earth Fault O/C	OUT	*	*		*	LED			BO		166	33	1	Yes
1335	Earth fault protection Trip is blocked (EF TRIP BLOCK)	Earth Fault O/C	OUT	ON OFF	ON OFF		*	LED			BO					
1336	E/F phase selector L1 selected (E/F L1 selec.)	Earth Fault O/C	OUT	*	ON OFF		*	LED			BO					
1337	E/F phase selector L2 selected (E/F L2 selec.)	Earth Fault O/C	OUT	*	ON OFF		*	LED			BO					
1338	E/F phase selector L3 selected (E/F L3 selec.)	Earth Fault O/C	OUT	*	ON OFF		*	LED			BO					
1345	Earth fault protection PICKED UP (EF Pickup)	Earth Fault O/C	OUT	*	off		*	LED			BO		166	45	2	Yes
1354	E/F 3I0>>> PICKED UP (EF 3I0>>>Pickup)	Earth Fault O/C	OUT	*	ON		*	LED			BO					
1355	E/F 3I0>> PICKED UP (EF 3I0>> Pickup)	Earth Fault O/C	OUT	*	ON		*	LED			BO					
1356	E/F 3I0> PICKED UP (EF 3I0> Pickup)	Earth Fault O/C	OUT	*	ON		*	LED			BO					
1357	E/F 3I0p PICKED UP (EF 3I0p Pickup)	Earth Fault O/C	OUT	*	ON		*	LED			BO					
1358	E/F picked up FORWARD (EF forward)	Earth Fault O/C	OUT	*	ON		*	LED			BO		166	58	2	No
1359	E/F picked up REVERSE (EF reverse)	Earth Fault O/C	OUT	*	ON		*	LED			BO		166	59	2	No
1361	E/F General TRIP command (EF Trip)	Earth Fault O/C	OUT	*	*		*	LED			BO		166	61	2	No
1362	Earth fault protection: Trip 1pole L1 (E/F Trip L1)	Earth Fault O/C	OUT	*	ON		*	LED			BO		166	62	2	Yes
1363	Earth fault protection: Trip 1pole L2 (E/F Trip L2)	Earth Fault O/C	OUT	*	ON		*	LED			BO		166	63	2	Yes
1364	Earth fault protection: Trip 1pole L3 (E/F Trip L3)	Earth Fault O/C	OUT	*	ON		*	LED			BO		166	64	2	Yes
1365	Earth fault protection: Trip 3pole (E/F Trip 3p)	Earth Fault O/C	OUT	*	ON		*	LED			BO		166	65	2	Yes
1366	E/F 3I0>>> TRIP (EF 3I0>>> TRIP)	Earth Fault O/C	OUT	*	ON		*	LED			BO		166	66	2	No
1367	E/F 3I0>> TRIP (EF 3I0>> TRIP)	Earth Fault O/C	OUT	*	ON		*	LED			BO		166	67	2	No

No.	Description	Function	Type of Information	Log Buffers				Configurable in Matrix					IEC 60870-5-103			
				Event Log ON/OFF	Trip (Fault) Log ON/OFF	Ground Fault Log ON/OFF	Marked in Oscill. Record	LED	Binary Input	Function Key	Relay	Chatter Suppression	Type	Information Number	Data Unit	General Interrogation
1368	E/F 3I0> TRIP (EF 3I0> TRIP)	Earth Fault O/C	OUT	*	ON		*	LED			BO		166	68	2	No
1369	E/F 3I0p TRIP (EF 3I0p TRIP)	Earth Fault O/C	OUT	*	ON		*	LED			BO		166	69	2	No
1370	E/F Inrush picked up (EF Inrush-PU)	Earth Fault O/C	OUT	*	ON OFF		*	LED			BO		166	70	2	No
1371	E/F Telep. Carrier SEND signal, Phase L1 (EF Tele SEND L1)	Teleprot. E/F	OUT	on	on		*	LED			BO		166	71	1	No
1372	E/F Telep. Carrier SEND signal, Phase L2 (EF Tele SEND L2)	Teleprot. E/F	OUT	on	on		*	LED			BO		166	72	1	No
1373	E/F Telep. Carrier SEND signal, Phase L3 (EF Tele SEND L3)	Teleprot. E/F	OUT	on	on		*	LED			BO		166	73	1	No
1374	E/F Telep. Block: carrier STOP signal L1 (EF Tele STOP L1)	Teleprot. E/F	OUT	*	on		*	LED			BO		166	74	2	No
1375	E/F Telep. Block: carrier STOP signal L2 (EF Tele STOP L2)	Teleprot. E/F	OUT	*	on		*	LED			BO		166	75	2	No
1376	E/F Telep. Block: carrier STOP signal L3 (EF Tele STOP L3)	Teleprot. E/F	OUT	*	on		*	LED			BO		166	76	2	No
1380	E/F Teleprot. ON/OFF via BI (EF TeleON/offBI)	Teleprot. E/F	IntSP	ON OFF	*		*	LED			BO					
1381	E/F Teleprotection is switched OFF (EF Telep. OFF)	Teleprot. E/F	OUT	ON OFF	*		*	LED			BO		166	81	1	Yes
1384	E/F Telep. Carrier SEND signal (EF Tele SEND)	Teleprot. E/F	OUT	on	on		*	LED			BO		166	84	2	No
1386	E/F Telep. Transient Blocking (EF TeleTransBlk)	Teleprot. E/F	OUT	*	ON		*	LED			BO		166	86	2	No
1387	E/F Telep. Unblocking: FAILURE Channel 1 (EF TeleUB Fail1)	Teleprot. E/F	OUT	ON OFF	*		*	LED			BO		166	87	1	Yes
1388	E/F Telep. Unblocking: FAILURE Channel 2 (EF TeleUB Fail2)	Teleprot. E/F	OUT	ON OFF	*		*	LED			BO		166	88	1	Yes
1389	E/F Telep. Blocking: carrier STOP signal (EF Tele BL STOP)	Teleprot. E/F	OUT	*	on		*	LED			BO		166	89	2	No
1390	E/F Telep. Blocking: Send signal with jump (EF Tele BL Jump)	Teleprot. E/F	OUT	*	*		*	LED			BO		166	90	2	No
1401	>BF: Switch on breaker fail protection (>BF on)	Breaker Failure	SP	*	*		*	LED	BI		BO					
1402	>BF: Switch off breaker fail protection (>BF off)	Breaker Failure	SP	*	*		*	LED	BI		BO					
1403	>BLOCK Breaker failure (>BLOCK BkrFail)	Breaker Failure	SP	ON OFF	*		*	LED	BI		BO		166	103	1	Yes
1415	>BF: External start 3pole (>BF Start 3pole)	Breaker Failure	SP	ON OFF	*		*	LED	BI		BO					
1432	>BF: External release (>BF release)	Breaker Failure	SP	ON OFF	*		*	LED	BI		BO					
1435	>BF: External start L1 (>BF Start L1)	Breaker Failure	SP	ON OFF	*		*	LED	BI		BO					
1436	>BF: External start L2 (>BF Start L2)	Breaker Failure	SP	ON OFF	*		*	LED	BI		BO					
1437	>BF: External start L3 (>BF Start L3)	Breaker Failure	SP	ON OFF	*		*	LED	BI		BO					
1439	>BF: External start 3pole (w/o current) (>BF Start w/o I)	Breaker Failure	SP	ON OFF	*		*	LED	BI		BO					
1440	Breaker failure prot. ON/OFF via BI (BkrFailON/offBI)	Breaker Failure	IntSP	ON OFF	*		*	LED			BO					
1451	Breaker failure is switched OFF (BkrFail OFF)	Breaker Failure	OUT	ON OFF	*		*	LED			BO		166	151	1	Yes
1452	Breaker failure is BLOCKED (BkrFail BLOCK)	Breaker Failure	OUT	ON OFF	ON OFF		*	LED			BO		166	152	1	Yes

No.	Description	Function	Type of Information	Log Buffers				Configurable in Matrix					IEC 60870-5-103			
				Event Log ON/OFF	Trip (Fault) Log ON/OFF	Ground Fault Log ON/OFF	Marked in Oscill. Record	LED	Binary Input	Function Key	Relay	Chatter Suppression	Type	Information Number	Data Unit	General Interrogation
1453	Breaker failure is ACTIVE (Bkr-Fail ACTIVE)	Breaker Failure	OUT	*	*		*	LED			BO		166	153	1	Yes
1461	Breaker failure protection started (BF Start)	Breaker Failure	OUT	*	ON OFF		*	LED			BO		166	161	2	Yes
1472	BF Trip T1 (local trip) - only phase L1 (BF T1-TRIP 1pL1)	Breaker Failure	OUT	*	ON		*	LED			BO					
1473	BF Trip T1 (local trip) - only phase L2 (BF T1-TRIP 1pL2)	Breaker Failure	OUT	*	ON		*	LED			BO					
1474	BF Trip T1 (local trip) - only phase L3 (BF T1-TRIP 1pL3)	Breaker Failure	OUT	*	ON		*	LED			BO					
1476	BF Trip T1 (local trip) - 3pole (BF T1-TRIP L123)	Breaker Failure	OUT	*	ON		*	LED			BO					
1493	BF Trip in case of defective CB (BF TRIP CBdefec)	Breaker Failure	OUT	*	ON		*	LED			BO					
1494	BF Trip T2 (busbar trip) (BF T2-TRIP(bus))	Breaker Failure	OUT	*	ON		*	LED			BO		192	85	2	No
1495	BF Trip End fault stage (BF EndFIt TRIP)	Breaker Failure	OUT	*	ON		*	LED			BO					
1496	BF Pole discrepancy pickup (BF CBdiscrSTART)	Breaker Failure	OUT	*	ON OFF		*	LED			BO					
1497	BF Pole discrepancy pickup L1 (BF CBdiscr L1)	Breaker Failure	OUT	*	ON OFF		*	LED			BO					
1498	BF Pole discrepancy pickup L2 (BF CBdiscr L2)	Breaker Failure	OUT	*	ON OFF		*	LED			BO					
1499	BF Pole discrepancy pickup L3 (BF CBdiscr L3)	Breaker Failure	OUT	*	ON OFF		*	LED			BO					
1500	BF Pole discrepancy Trip (BF CBdiscr TRIP)	Breaker Failure	OUT	*	ON		*	LED			BO					
1503	>BLOCK Thermal Overload Protection (>BLK ThOverload)	Therm. Overload	SP	*	*		*	LED	BI		BO		167	3	1	Yes
1511	Thermal Overload Protection OFF (Th.Overload OFF)	Therm. Overload	OUT	ON OFF	*		*	LED			BO		167	11	1	Yes
1512	Thermal Overload Protection BLOCKED (Th.Overload BLK)	Therm. Overload	OUT	ON OFF	ON OFF		*	LED			BO		167	12	1	Yes
1513	Thermal Overload Protection ACTIVE (Th.O/L ACTIVE)	Therm. Overload	OUT	ON OFF	*		*	LED			BO		167	13	1	Yes
1515	Th. Overload: Current Alarm (I alarm) (Th.O/L I Alarm)	Therm. Overload	OUT	ON OFF	*		*	LED			BO		167	15	1	Yes
1516	Th. Overload Alarm: Near Thermal Trip (Th.O/L Θ Alarm)	Therm. Overload	OUT	ON OFF	*		*	LED			BO		167	16	1	Yes
1517	Th. Overload Pickup before trip (Th.O/L Pickup)	Therm. Overload	OUT	ON OFF	*		*	LED			BO		167	17	1	Yes
1521	Th. Overload TRIP command (Th.O/L TRIP)	Therm. Overload	OUT	*	ON		*	LED			BO		167	21	2	Yes
2054	Emergency mode (Emer. mode)	Device	OUT	ON OFF	ON OFF		*	LED			BO		192	37	1	Yes
2701	>AR: Switch on auto-reclose function (>AR on)	Auto Reclose	SP	*	*		*	LED	BI		BO		40	1	1	Yes
2702	>AR: Switch off auto-reclose function (>AR off)	Auto Reclose	SP	*	*		*	LED	BI		BO		40	2	1	Yes
2703	>AR: Block auto-reclose function (>AR block)	Auto Reclose	SP	ON OFF	*		*	LED	BI		BO		40	3	1	Yes
2711	>External start of internal Auto reclose (>AR Start)	Auto Reclose	SP	*	ON		*	LED	BI		BO		40	11	2	Yes
2712	>AR: External trip L1 for AR start (>Trip L1 AR)	Auto Reclose	SP	*	ON		*	LED	BI		BO		40	12	2	Yes

No.	Description	Function	Type of Information	Log Buffers				Configurable in Matrix					IEC 60870-5-103			
				Event Log ON/OFF	Trip (Fault) Log ON/OFF	Ground Fault Log ON/OFF	Marked in Oscill. Record	LED	Binary Input	Function Key	Relay	Chatter Suppression	Type	Information Number	Data Unit	General Interrogation
2713	>AR: External trip L2 for AR start (>Trip L2 AR)	Auto Reclose	SP	*	ON		*	LED	BI		BO		40	13	2	Yes
2714	>AR: External trip L3 for AR start (>Trip L3 AR)	Auto Reclose	SP	*	ON		*	LED	BI		BO		40	14	2	Yes
2715	>AR: External 1pole trip for AR start (>Trip 1pole AR)	Auto Reclose	SP	*	ON		*	LED	BI		BO		40	15	2	Yes
2716	>AR: External 3pole trip for AR start (>Trip 3pole AR)	Auto Reclose	SP	*	ON		*	LED	BI		BO		40	16	2	Yes
2727	>AR: Remote Close signal (>AR RemoteClose)	Auto Reclose	SP	*	ON		*	LED	BI		BO		40	22	2	Yes
2731	>AR: Sync. release from ext. sync.-check (>Sync.release)	Auto Reclose	SP	*	*		*	LED	BI		BO		40	31	2	Yes
2737	>AR: Block 1pole AR-cycle (>BLOCK 1pole AR)	Auto Reclose	SP	ON OFF	*		*	LED	BI		BO		40	32	1	Yes
2738	>AR: Block 3pole AR-cycle (>BLOCK 3pole AR)	Auto Reclose	SP	ON OFF	*		*	LED	BI		BO		40	33	1	Yes
2739	>AR: Block 1phase-fault AR-cycle (>BLK 1phase AR)	Auto Reclose	SP	ON OFF	*		*	LED	BI		BO		40	34	1	Yes
2740	>AR: Block 2phase-fault AR-cycle (>BLK 2phase AR)	Auto Reclose	SP	ON OFF	*		*	LED	BI		BO		40	35	1	Yes
2741	>AR: Block 3phase-fault AR-cycle (>BLK 3phase AR)	Auto Reclose	SP	ON OFF	*		*	LED	BI		BO		40	36	1	Yes
2742	>AR: Block 1st AR-cycle (>BLK 1.AR-cycle)	Auto Reclose	SP	ON OFF	*		*	LED	BI		BO		40	37	1	Yes
2743	>AR: Block 2nd AR-cycle (>BLK 2.AR-cycle)	Auto Reclose	SP	ON OFF	*		*	LED	BI		BO		40	38	1	Yes
2744	>AR: Block 3rd AR-cycle (>BLK 3.AR-cycle)	Auto Reclose	SP	ON OFF	*		*	LED	BI		BO		40	39	1	Yes
2745	>AR: Block 4th and higher AR-cycles (>BLK 4.-n. AR)	Auto Reclose	SP	ON OFF	*		*	LED	BI		BO		40	40	1	Yes
2746	>AR: External Trip for AR start (>Trip for AR)	Auto Reclose	SP	*	ON		*	LED	BI		BO		40	41	2	Yes
2747	>AR: External pickup L1 for AR start (>Pickup L1 AR)	Auto Reclose	SP	*	ON		*	LED	BI		BO		40	42	2	Yes
2748	>AR: External pickup L2 for AR start (>Pickup L2 AR)	Auto Reclose	SP	*	ON		*	LED	BI		BO		40	43	2	Yes
2749	>AR: External pickup L3 for AR start (>Pickup L3 AR)	Auto Reclose	SP	*	ON		*	LED	BI		BO		40	44	2	Yes
2750	>AR: External pickup 1phase for AR start (>Pickup 1ph AR)	Auto Reclose	SP	*	ON		*	LED	BI		BO		40	45	2	Yes
2751	>AR: External pickup 2phase for AR start (>Pickup 2ph AR)	Auto Reclose	SP	*	ON		*	LED	BI		BO		40	46	2	Yes
2752	>AR: External pickup 3phase for AR start (>Pickup 3ph AR)	Auto Reclose	SP	*	ON		*	LED	BI		BO		40	47	2	Yes
2781	AR: Auto-reclose is switched off (AR off)	Auto Reclose	OUT	ON OFF	*		*	LED			BO		40	81	1	Yes
2782	AR: Auto-reclose is switched on (AR on)	Auto Reclose	IntSP	*	*		*	LED			BO		192	16	1	Yes
2783	AR: Auto-reclose is blocked (AR is blocked)	Auto Reclose	OUT	ON OFF	*		*	LED			BO		40	83	1	Yes
2784	AR: Auto-reclose is not ready (AR not ready)	Auto Reclose	OUT	*	ON		*	LED			BO		192	130	2	Yes
2787	AR: Circuit breaker not ready (CB not ready)	Auto Reclose	OUT	*	*		*	LED			BO		40	87	1	Yes
2788	AR: CB ready monitoring window expired (AR T-CBreadyExp)	Auto Reclose	OUT	*	ON		*	LED			BO		40	88	2	Yes

No.	Description	Function	Type of Information	Log Buffers				Configurable in Matrix					IEC 60870-5-103			
				Event Log ON/OFF	Trip (Fault) Log ON/OFF	Ground Fault Log ON/OFF	Marked in Oscill. Record	LED	Binary Input	Function Key	Relay	Chatter Suppression	Type	Information Number	Data Unit	General Interrogation
2796	AR: Auto-reclose ON/OFF via BI (AR on/off BI)	Auto Reclose	IntSP	*	*		*	LED			BO					
2801	AR: Auto-reclose in progress (AR in progress)	Auto Reclose	OUT	*	ON		*	LED			BO		40	101	2	Yes
2809	AR: Start-signal monitoring time expired (AR T-Start Exp)	Auto Reclose	OUT	*	ON		*	LED			BO		40	174	2	Yes
2810	AR: Maximum dead time expired (AR TdeadMax Exp)	Auto Reclose	OUT	*	ON		*	LED			BO		40	175	2	Yes
2818	AR: Evolving fault recognition (AR evolving Flt)	Auto Reclose	OUT	*	ON		*	LED			BO		40	118	2	Yes
2820	AR is set to operate after 1p trip only (AR Program1pole)	Auto Reclose	OUT	*	*		*	LED			BO		40	143	1	Yes
2821	AR dead time after evolving fault (AR Td. evol.Flt)	Auto Reclose	OUT	*	ON OFF		*	LED			BO		40	197	2	Yes
2839	AR dead time after 1pole trip running (AR Tdead 1pTrip)	Auto Reclose	OUT	*	ON		*	LED			BO		40	148	2	Yes
2840	AR dead time after 3pole trip running (AR Tdead 3pTrip)	Auto Reclose	OUT	*	ON		*	LED			BO		40	149	2	Yes
2841	AR dead time after 1phase fault running (AR Tdead 1pFlt)	Auto Reclose	OUT	*	ON		*	LED			BO		40	150	2	Yes
2842	AR dead time after 2phase fault running (AR Tdead 2pFlt)	Auto Reclose	OUT	*	ON		*	LED			BO		40	151	2	Yes
2843	AR dead time after 3phase fault running (AR Tdead 3pFlt)	Auto Reclose	OUT	*	ON		*	LED			BO		40	154	2	Yes
2844	AR 1st cycle running (AR 1stCyc. run.)	Auto Reclose	OUT	*	ON		*	LED			BO		40	155	2	Yes
2845	AR 2nd cycle running (AR 2ndCyc. run.)	Auto Reclose	OUT	*	ON		*	LED			BO		40	157	2	Yes
2846	AR 3rd cycle running (AR 3rdCyc. run.)	Auto Reclose	OUT	*	ON		*	LED			BO		40	158	2	Yes
2847	AR 4th or higher cycle running (AR 4thCyc. run.)	Auto Reclose	OUT	*	ON		*	LED			BO		40	159	2	Yes
2848	AR cycle is running in ADT mode (AR ADT run.)	Auto Reclose	OUT	*	ON		*	LED			BO		40	130	2	Yes
2851	AR: Close command (AR CLOSE Cmd.)	Auto Reclose	OUT	*	ON		m	LED			BO		192	128	2	No
2852	AR: Close command after 1pole, 1st cycle (AR Close1.Cyc1p)	Auto Reclose	OUT	*	*		*	LED			BO		40	152	1	Yes
2853	AR: Close command after 3pole, 1st cycle (AR Close1.Cyc3p)	Auto Reclose	OUT	*	*		*	LED			BO		40	153	1	Yes
2854	AR: Close command 2nd cycle (and higher) (AR Close 2.Cyc)	Auto Reclose	OUT	*	*		*	LED			BO		192	129	1	No
2861	AR: Reclaim time is running (AR T-Recl. run.)	Auto Reclose	OUT	*	*		*	LED			BO		40	161	1	Yes
2862	AR successful (AR successful)	Auto Reclose	OUT	*	*		*	LED			BO		40	162	1	Yes
2863	Definitive TRIP (Definitive Trip)	Auto Reclose	OUT	*	*		*	LED			BO		40	163	1	Yes
2864	AR: 1pole trip permitted by internal AR (AR 1p Trip Perm)	Auto Reclose	OUT	*	*		*	LED			BO		40	164	1	Yes
2865	AR: Synchro-check request (AR Sync.Request)	Auto Reclose	OUT	*	*		*	LED			BO		40	165	2	Yes
2871	AR: TRIP command 3pole (AR TRIP 3pole)	Auto Reclose	OUT	*	ON		*	LED			BO		40	171	2	Yes
2889	AR 1st cycle zone extension release (AR 1.CycZoneRel)	Auto Reclose	OUT	*	*		*	LED			BO		40	160	1	Yes
2890	AR 2nd cycle zone extension release (AR 2.CycZoneRel)	Auto Reclose	OUT	*	*		*	LED			BO		40	169	1	Yes

No.	Description	Function	Type of Information	Log Buffers				Configurable in Matrix					IEC 60870-5-103			
				Event Log ON/OFF	Trip (Fault) Log ON/OFF	Ground Fault Log ON/OFF	Marked in Oscill. Record	LED	Binary Input	Function Key	Relay	Chatter Suppression	Type	Information Number	Data Unit	General Interrogation
2891	AR 3rd cycle zone extension release (AR 3.CycZoneRel)	Auto Reclose	OUT	*	*		*	LED			BO		40	170	1	Yes
2892	AR 4th cycle zone extension release (AR 4.CycZoneRel)	Auto Reclose	OUT	*	*		*	LED			BO		40	172	1	Yes
2893	AR zone extension (general) (AR Zone Release)	Auto Reclose	OUT	*	*		*	LED			BO		40	173	1	Yes
2894	AR Remote close signal send (AR Remote Close)	Auto Reclose	OUT	*	ON		*	LED			BO		40	129	2	Yes
2895	No. of 1st AR-cycle CLOSE commands, 1pole (AR #Close1./1p=)	Statistics	VI													
2896	No. of 1st AR-cycle CLOSE commands, 3pole (AR #Close1./3p=)	Statistics	VI													
2897	No. of higher AR-cycle CLOSE commands, 1p (AR #Close2./1p=)	Statistics	VI													
2898	No. of higher AR-cycle CLOSE commands, 3p (AR #Close2./3p=)	Statistics	VI													
2901	>Switch on synchro-check function (>Sync. on)	Sync. Check	SP	*	*		*	LED	BI		BO					
2902	>Switch off synchro-check function (>Sync. off)	Sync. Check	SP	*	*		*	LED	BI		BO					
2903	>BLOCK synchro-check function (>BLOCK Sync.)	Sync. Check	SP	*	*		*	LED	BI		BO					
2905	>Start synchro-check for Manual Close (>Sync. Start MC)	Sync. Check	SP	on off	*		*	LED	BI		BO					
2906	>Start synchro-check for AR (>Sync. Start AR)	Sync. Check	SP	on off	*		*	LED	BI		BO					
2907	>Sync-Prog. Live bus / live line / Sync (>Sync. synch)	Sync. Check	SP	*	*		*	LED	BI		BO					
2908	>Sync-Prog. Dead bus / live line (> Usyn< U-line>)	Sync. Check	SP	*	*		*	LED	BI		BO					
2909	>Sync-Prog. Live bus / dead line (> Usyn> U-line<)	Sync. Check	SP	*	*		*	LED	BI		BO					
2910	>Sync-Prog. Dead bus / dead line (> Usyn< U-line<)	Sync. Check	SP	*	*		*	LED	BI		BO					
2911	>Sync-Prog. Override (bypass) (>Sync. o/ride)	Sync. Check	SP	*	*		*	LED	BI		BO					
2930	Synchro-check ON/OFF via BI (Sync. on/off BI)	Sync. Check	IntSP	ON OFF	*		*	LED			BO					
2931	Synchro-check is switched OFF (Sync. OFF)	Sync. Check	OUT	ON OFF	*		*	LED			BO		41	31	1	Yes
2932	Synchro-check is BLOCKED (Sync. BLOCK)	Sync. Check	OUT	ON OFF	ON OFF		*	LED			BO		41	32	1	Yes
2934	Synchro-check function faulty (Sync. faulty)	Sync. Check	OUT	ON OFF	*		*	LED			BO		41	34	1	Yes
2935	Synchro-check supervision time expired (Sync.Tsup.Exp)	Sync. Check	OUT	ON	ON		*	LED			BO		41	35	1	No
2936	Synchro-check request by control (Sync. req.CNTRL)	Sync. Check	OUT	ON	ON		*	LED			BO		41	36	1	No
2941	Synchronization is running (Sync. running)	Sync. Check	OUT	ON OFF	ON		*	LED			BO		41	41	1	Yes
2942	Synchro-check override/bypass (Sync.Override)	Sync. Check	OUT	ON OFF	ON		*	LED			BO		41	42	1	Yes
2943	Synchronism detected (Synchronism)	Sync. Check	OUT	ON OFF	*		*	LED			BO		41	43	1	Yes
2944	Sync. dead bus / live line detected (Usyn< U-line>)	Sync. Check	OUT	ON OFF	*		*	LED			BO		41	44	1	Yes

No.	Description	Function	Type of Information	Log Buffers				Configurable in Matrix					IEC 60870-5-103			
				Event Log ON/OFF	Trip (Fault) Log ON/OFF	Ground Fault Log ON/OFF	Marked in Oscill. Record	LED	Binary Input	Function Key	Relay	Chatter Suppression	Type	Information Number	Data Unit	General Interrogation
2945	Sync. live bus / dead line detected (Usyn> U-line<)	Sync. Check	OUT	ON OFF	*		*	LED			BO		41	45	1	Yes
2946	Sync. dead bus / dead line detected (Usyn< U-line<)	Sync. Check	OUT	ON OFF	*		*	LED			BO		41	46	1	Yes
2947	Sync. Voltage diff. greater than limit (Sync. Udiff>)	Sync. Check	OUT	ON OFF	ON OFF		*	LED			BO		41	47	1	Yes
2948	Sync. Freq. diff. greater than limit (Sync. fdiff>)	Sync. Check	OUT	ON OFF	ON OFF		*	LED			BO		41	48	1	Yes
2949	Sync. Angle diff. greater than limit (Sync. φ-diff>)	Sync. Check	OUT	ON OFF	ON OFF		*	LED			BO		41	49	1	Yes
2951	Synchronism release (to ext. AR) (Sync. release)	Sync. Check	OUT	*	*		*	LED			BO		41	51	1	Yes
2961	Close command from synchro-check (Sync.CloseCmd)	Sync. Check	OUT	*	*		*	LED			BO		41	61	1	Yes
2970	Sync. Bus frequency > (fn + 3Hz) (Sync. f-bus>>)	Sync. Check	OUT	ON OFF	ON OFF		*	LED			BO					
2971	Sync. Bus frequency < (fn - 3Hz) (Sync. f-bus<<)	Sync. Check	OUT	ON OFF	ON OFF		*	LED			BO					
2972	Sync. Line frequency > (fn + 3Hz) (Sync. f-line>>)	Sync. Check	OUT	ON OFF	ON OFF		*	LED			BO					
2973	Sync. Line frequency < (fn - 3Hz) (Sync. f-line<<)	Sync. Check	OUT	ON OFF	ON OFF		*	LED			BO					
2974	Sync. Bus voltage > Umax (P.3504) (Sync. U-syn>>)	Sync. Check	OUT	ON OFF	ON OFF		*	LED			BO					
2975	Sync. Bus voltage < U> (P.3503) (Sync. U-syn<<)	Sync. Check	OUT	ON OFF	ON OFF		*	LED			BO					
2976	Sync. Line voltage > Umax (P.3504) (Sync. U-line>>)	Sync. Check	OUT	ON OFF	ON OFF		*	LED			BO					
2977	Sync. Line voltage < U> (P.3503) (Sync. U-line<<)	Sync. Check	OUT	ON OFF	ON OFF		*	LED			BO					
3101	IC compensation active (IC comp. active)	Diff. Prot	OUT	on off	*		*	LED			BO					
3102	Diff: 2nd Harmonic detected in phase L1 (2nd Harmonic L1)	Diff. Prot	OUT	*	*		*	LED			BO		92	89	1	Yes
3103	Diff: 2nd Harmonic detected in phase L2 (2nd Harmonic L2)	Diff. Prot	OUT	*	*		*	LED			BO		92	90	1	Yes
3104	Diff: 2nd Harmonic detected in phase L3 (2nd Harmonic L3)	Diff. Prot	OUT	*	*		*	LED			BO		92	91	1	Yes
3120	Diff: Active (Diff active)	Diff. Prot	OUT	ON OFF	*		m	LED			BO		92	92	1	Yes
3132	Diff: Fault detection (Diff. Gen. Flt.)	Diff. Prot	OUT	*	ON OFF		m	LED			BO					
3133	Diff: Fault detection in phase L1 (Diff. Flt. L1)	Diff. Prot	OUT	*	ON OFF		m	LED			BO		92	93	2	Yes
3134	Diff: Fault detection in phase L2 (Diff. Flt. L2)	Diff. Prot	OUT	*	ON OFF		m	LED			BO		92	94	2	Yes
3135	Diff: Fault detection in phase L3 (Diff. Flt. L3)	Diff. Prot	OUT	*	ON OFF		m	LED			BO		92	95	2	Yes
3136	Diff: Earth fault detection (Diff. Flt. E)	Diff. Prot	OUT	*	ON OFF		m	LED			BO		92	96	2	Yes
3137	Diff: Fault detection of I-Diff>> (I-Diff>> Flt.)	Diff. Prot	OUT	*	ON OFF		m	LED			BO		92	97	2	Yes
3139	Diff: Fault detection of I-Diff> (I-Diff> Flt.)	Diff. Prot	OUT	*	ON OFF		m	LED			BO		92	98	2	Yes
3141	Diff: General TRIP (Diff. Gen. TRIP)	Diff. Prot	OUT	*	ON OFF		m	LED			BO		92	99	2	Yes

No.	Description	Function	Type of Information	Log Buffers				Configurable in Matrix					IEC 60870-5-103			
				Event Log ON/OFF	Trip (Fault) Log ON/OFF	Ground Fault Log ON/OFF	Marked in Oscill. Record	LED	Binary Input	Function Key	Relay	Chatter Suppression	Type	Information Number	Data Unit	General Interrogation
3142	Diff: TRIP - Only L1 (Diff TRIP 1p L1)	Diff. Prot	OUT	*	ON OFF		m	LED			BO		92	100	2	Yes
3143	Diff: TRIP - Only L2 (Diff TRIP 1p L2)	Diff. Prot	OUT	*	ON OFF		m	LED			BO		92	101	2	Yes
3144	Diff: TRIP - Only L3 (Diff TRIP 1p L3)	Diff. Prot	OUT	*	ON OFF		m	LED			BO		92	102	2	Yes
3145	Diff: TRIP L123 (Diff TRIP L123)	Diff. Prot	OUT	*	ON OFF		m	LED			BO		92	103	2	Yes
3146	Diff: TRIP 1pole (Diff TRIP 1pole)	Diff. Prot	OUT	*	ON OFF		*	LED			BO					
3147	Diff: TRIP 3pole (Diff TRIP 3pole)	Diff. Prot	OUT	*	ON OFF		*	LED			BO					
3148	Diff: Differential protection is blocked (Diff block)	Diff. Prot	OUT	ON OFF	*		*	LED			BO		92	104	1	Yes
3149	Diff: Diff. protection is switched off (Diff OFF)	Diff. Prot	OUT	ON OFF	*		*	LED			BO		92	105	1	Yes
3176	Diff: Fault detection L1 (only) (Diff Flt. 1p.L1)	Diff. Prot	OUT	*	*		*	LED			BO					
3177	Diff: Fault detection L1E (Diff Flt. L1E)	Diff. Prot	OUT	*	*		*	LED			BO					
3178	Diff: Fault detection L2 (only) (Diff Flt. 1p.L2)	Diff. Prot	OUT	*	*		*	LED			BO					
3179	Diff: Fault detection L2E (Diff Flt. L2E)	Diff. Prot	OUT	*	*		*	LED			BO					
3180	Diff: Fault detection L12 (Diff Flt. L12)	Diff. Prot	OUT	*	*		*	LED			BO					
3181	Diff: Fault detection L12E (Diff Flt. L12E)	Diff. Prot	OUT	*	*		*	LED			BO					
3182	Diff: Fault detection L3 (only) (Diff Flt. 1p.L3)	Diff. Prot	OUT	*	*		*	LED			BO					
3183	Diff: Fault detection L3E (Diff Flt. L3E)	Diff. Prot	OUT	*	*		*	LED			BO					
3184	Diff: Fault detection L31 (Diff Flt. L31)	Diff. Prot	OUT	*	*		*	LED			BO					
3185	Diff: Fault detection L31E (Diff Flt. L31E)	Diff. Prot	OUT	*	*		*	LED			BO					
3186	Diff: Fault detection L23 (Diff Flt. L23)	Diff. Prot	OUT	*	*		*	LED			BO					
3187	Diff: Fault detection L23E (Diff Flt. L23E)	Diff. Prot	OUT	*	*		*	LED			BO					
3188	Diff: Fault detection L123 (Diff Flt. L123)	Diff. Prot	OUT	*	*		*	LED			BO					
3189	Diff: Fault detection L123E (Diff Flt. L123E)	Diff. Prot	OUT	*	*		*	LED			BO					
3190	Diff: Set Teststate of Diff. protection (Test Diff.)	Diff. Prot	IntSP	ON OFF	*		*	LED		FC TN	BO		92	106	1	Yes
3191	Diff: Set Commissioning state of Diff. (Comm. Diff)	Diff. Prot	IntSP	ON OFF	*		*	LED		FC TN	BO		92	107	1	Yes
3192	Diff: Remote relay in Teststate (TestDiff.remote)	Diff. Prot	OUT	ON OFF	*		*	LED			BO		92	108	1	Yes
3193	Diff: Commissioning state is active (Comm.Diff act.)	Diff. Prot	OUT	ON OFF	*		*	LED			BO		92	109	1	Yes
3194	Diff: >Test Diff. (>Test Diff.)	Diff. Prot	SP	ON OFF	*		*	LED	BI		BO					
3195	Diff: >Comm. Diff (>Comm. Diff)	Diff. Prot	SP	ON OFF	*		*	LED	BI		BO					

No.	Description	Function	Type of Information	Event Log ON/OFF	Log Buffers			Configurable in Matrix					IEC 60870-5-103			
					Trip (Fault) Log ON/OFF	Ground Fault Log ON/OFF	Marked in Oscill. Record	LED	Binary Input	Function Key	Relay	Chatter Suppression	Type	Information Number	Data Unit	General Interrogation
3215	Incompatible Firmware Versions (Wrong Firmware)	Prot. Interface	OUT	ON	*			LED			BO					
3217	Prot Int 1: Own Datas received (PI1 Data reflec)	Prot. Interface	OUT	ON OFF	*			LED			BO					
3218	Prot Int 2: Own Datas received (PI2 Data reflec)	Prot. Interface	OUT	ON OFF	*			LED			BO					
3227	>Prot Int 1: Transmitter is switched off (>PI1 light off)	Prot. Interface	SP	ON OFF	*		*	LED	BI		BO					
3228	>Prot Int 2: Transmitter is switched off (>PI2 light off)	Prot. Interface	SP	ON OFF	*		*	LED	BI		BO					
3229	Prot Int 1: Reception of faulty data (PI1 Data fault)	Prot. Interface	OUT	ON OFF	*		*	LED			BO		93	135	1	Yes
3230	Prot Int 1: Total reception failure (PI1 Datafailure)	Prot. Interface	OUT	ON OFF	*		*	LED			BO		93	136	1	Yes
3231	Prot Int 2: Reception of faulty data (PI2 Data fault)	Prot. Interface	OUT	ON OFF	*		*	LED			BO		93	137	1	Yes
3232	Prot Int 2: Total reception failure (PI2 Datafailure)	Prot. Interface	OUT	ON OFF	*		*	LED			BO		93	138	1	Yes
3233	Device table has inconsistent numbers (DT inconsistent)	Prot. Interface	OUT	ON OFF	*			LED			BO					
3234	Device tables are unequal (DT unequal)	Prot. Interface	OUT	ON OFF	*			LED			BO					
3235	Differences between common parameters (Par. different)	Prot. Interface	OUT	ON OFF	*			LED			BO					
3236	Different PI for transmit and receive (PI1<->PI2 error)	Prot. Interface	OUT	ON OFF	*			LED			BO					
3239	Prot Int 1: Transmission delay too high (PI1 TD alarm)	Prot. Interface	OUT	ON OFF	*			LED			BO		93	139	1	Yes
3240	Prot Int 2: Transmission delay too high (PI2 TD alarm)	Prot. Interface	OUT	ON OFF	*			LED			BO		93	140	1	Yes
3243	Prot Int 1: Connected with relay ID (PI1 with)	Prot. Interface	VI	ON OFF	*											
3244	Prot Int 2: Connected with relay ID (PI2 with)	Prot. Interface	VI	ON OFF	*											
3245	> GPS failure from external (>GPS failure)	Prot. Interface	SP	ON OFF	*		*	LED	BI		BO					
3247	GPS: local pulse loss (GPS loss)	Prot. Interface	OUT	ON OFF	*		*	LED			BO					
3248	GPS: Prot Int 1 is GPS synchronized (PI 1 GPS sync.)	Prot. Interface	OUT	ON OFF	*		*	LED			BO					
3249	GPS: Prot Int 2 is GPS synchronized (PI 2 GPS sync.)	Prot. Interface	OUT	ON OFF	*		*	LED			BO					
3250	GPS:PI1 unsym.propagation delay too high (PI 1 PD unsym.)	Prot. Interface	OUT	ON OFF	*		*	LED			BO					
3251	GPS:PI2 unsym.propagation delay too high (PI 2 PD unsym.)	Prot. Interface	OUT	ON OFF	*		*	LED			BO					
3252	> PI1 Synchronization RESET (>SYNC PI1 RESET)	Prot. Interface	SP	on off	*		*	LED	BI		BO					
3253	> PI2 Synchronization RESET (>SYNC PI2 RESET)	Prot. Interface	SP	on off	*		*	LED	BI		BO					
3254	Prot.1: Delay time change recognized (PI1 jump)	Prot. Interface	OUT	on off	*		*	LED			BO					
3255	Prot.2: Delay time change recognized (PI2 jump)	Prot. Interface	OUT	on off	*		*	LED			BO					
3256	Prot.1: Delay time unsymmetry to large (PI1 unsym.)	Prot. Interface	IntSP	ON OFF	*			LED			BO					

No.	Description	Function	Type of Information	Log Buffers				Configurable in Matrix					IEC 60870-5-103			
				Event Log ON/OFF	Trip (Fault) Log ON/OFF	Ground Fault Log ON/OFF	Marked in Oscill. Record	LED	Binary Input	Function Key	Relay	Chatter Suppression	Type	Information Number	Data Unit	General Interrogation
3257	Prot.2: Delay time unsymmetry to large (PI2 unsym.)	Prot. Interface	IntSP	ON OFF	*			LED			BO					
3258	ProtInt1:Permissible error rate exceeded (PI1 Error)	Prot. Interface	OUT	on off	*		*	LED			BO					
3259	ProtInt2:Permissible error rate exceeded (PI2 Error)	Prot. Interface	OUT	on off	*		*	LED			BO					
3451	> Logout input signal (>Logout)	Diff.-Topo	SP	ON OFF	*		*	LED	BI		BO					
3457	System operates in a closed Ringtopology (Ringtopology)	Diff.-Topo	OUT	ON OFF	*		*	LED			BO		93	141	1	Yes
3458	System operates in a open Chaintopology (Chaintopology)	Diff.-Topo	OUT	ON OFF	*		*	LED			BO		93	142	1	Yes
3464	Communication topology is complete (Topol complete)	Diff.-Topo	OUT	ON OFF	*		*	LED			BO					
3475	Relay 1 in Logout state (Rel1Logout)	Diff.-Topo	IntSP	ON OFF	*		*	LED		FC TN	BO		93	143	1	Yes
3476	Relay 2 in Logout state (Rel2Logout)	Diff.-Topo	IntSP	ON OFF	*		*	LED		FC TN	BO		93	144	1	Yes
3477	Relay 3 in Logout state (Rel3Logout)	Diff.-Topo	IntSP	ON OFF	*		*	LED		FC TN	BO		93	145	1	Yes
3478	Relay 4 in Logout state (Rel4Logout)	Diff.-Topo	IntSP	ON OFF	*		*	LED		FC TN	BO		93	146	1	Yes
3479	Relay 5 in Logout state (Rel5Logout)	Diff.-Topo	IntSP	ON OFF	*		*	LED		FC TN	BO		93	147	1	Yes
3480	Relay 6 in Logout state (Rel6Logout)	Diff.-Topo	IntSP	ON OFF	*		*	LED		FC TN	BO		93	148	1	Yes
3484	Local activation of Logout state (Logout)	Diff.-Topo	IntSP	ON OFF	*		*	LED		FC TN	BO		93	149	1	Yes
3487	Equal IDs in constellation (Equal IDs)	Diff.-Topo	OUT	ON OFF	*		*	LED			BO					
3491	Relay 1 in Login state (Rel1 Login)	Diff.-Topo	OUT	ON OFF	*		*	LED			BO		93	191	1	Yes
3492	Relay 2 in Login state (Rel2 Login)	Diff.-Topo	OUT	ON OFF	*		*	LED			BO		93	192	1	Yes
3493	Relay 3 in Login state (Rel3 Login)	Diff.-Topo	OUT	ON OFF	*		*	LED			BO		93	193	1	Yes
3494	Relay 4 in Login state (Rel4 Login)	Diff.-Topo	OUT	ON OFF	*		*	LED			BO		93	194	1	Yes
3495	Relay 5 in Login state (Rel5 Login)	Diff.-Topo	OUT	ON OFF	*		*	LED			BO		93	195	1	Yes
3496	Relay 6 in Login state (Rel6 Login)	Diff.-Topo	OUT	ON OFF	*		*	LED			BO		93	196	1	Yes
3501	I.Trip: >Intertrip L1 signal input (>Intertrip L1)	Intertrip	SP	ON OFF	*		*	LED	BI		BO					
3502	I.Trip: >Intertrip L2 signal input (>Intertrip L2)	Intertrip	SP	ON OFF	*		*	LED	BI		BO					
3503	I.Trip: >Intertrip L3 signal input (>Intertrip L3)	Intertrip	SP	ON OFF	*		*	LED	BI		BO					
3504	I.Trip: >Intertrip 3 pole signal input (>Intertrip 3pol)	Intertrip	SP	ON OFF	*		*	LED	BI		BO					
3505	I.Trip: Received at Prot.Interface 1 L1 (ITrp.rec.PI1.L1)	Intertrip	OUT	on off	*		*	LED			BO					
3506	I.Trip: Received at Prot.Interface 1 L2 (ITrp.rec.PI1.L2)	Intertrip	OUT	on off	*		*	LED			BO					
3507	I.Trip: Received at Prot.Interface 1 L3 (ITrp.rec.PI1.L3)	Intertrip	OUT	on off	*		*	LED			BO					

No.	Description	Function	Type of Information	Event Log ON/OFF	Log Buffers			Configurable in Matrix					IEC 60870-5-103			
					Trip (Fault) Log ON/OFF	Ground Fault Log ON/OFF	Marked in Oscill. Record	LED	Binary Input	Function Key	Relay	Chatter Suppression	Type	Information Number	Data Unit	General Interrogation
3508	I.Trip: Received at Prot.Interface 2 L1 (ITrp.rec.PI2.L1)	Intertrip	OUT	on off	*		*	LED			BO					
3509	I.Trip: Received at Prot.Interface 2 L2 (ITrp.rec.PI2.L2)	Intertrip	OUT	on off	*		*	LED			BO					
3510	I.Trip: Received at Prot.Interface 2 L3 (ITrp.rec.PI2.L3)	Intertrip	OUT	on off	*		*	LED			BO					
3511	I.Trip: Sending at Prot.Interface 1 L1 (ITrp.sen.PI1.L1)	Intertrip	OUT	ON OFF	*		*	LED			BO					
3512	I.Trip: Sending at Prot.Interface 1 L2 (ITrp.sen.PI1.L2)	Intertrip	OUT	ON OFF	*		*	LED			BO					
3513	I.Trip: Sending at Prot.Interface 1 L3 (ITrp.sen.PI1.L3)	Intertrip	OUT	ON OFF	*		*	LED			BO					
3514	I.Trip: Sending at Prot.Interface 2 L1 (ITrp.sen.PI2.L1)	Intertrip	OUT	ON OFF	*		*	LED			BO					
3515	I.Trip: Sending at Prot.Interface 2 L2 (ITrp.sen.PI2.L2)	Intertrip	OUT	ON OFF	*		*	LED			BO					
3516	I.Trip: Sending at Prot.Interface 2 L3 (ITrp.sen.PI2.L3)	Intertrip	OUT	ON OFF	*		*	LED			BO					
3517	I.Trip: General TRIP (ITrp. Gen. TRIP)	Intertrip	OUT	*	ON OFF		m	LED			BO					
3518	I.Trip: TRIP - Only L1 (ITrp.TRIP 1p L1)	Intertrip	OUT	*	ON OFF		m	LED			BO		93	150	2	Yes
3519	I.Trip: TRIP - Only L2 (ITrp.TRIP 1p L2)	Intertrip	OUT	*	ON OFF		m	LED			BO		93	151	2	Yes
3520	I.Trip: TRIP - Only L3 (ITrp.TRIP 1p L3)	Intertrip	OUT	*	ON OFF		m	LED			BO		93	152	2	Yes
3521	I.Trip: TRIP L123 (ITrp.TRIP L123)	Intertrip	OUT	*	ON OFF		m	LED			BO		93	153	2	Yes
3522	I.Trip: TRIP 1pole (Diff TRIP 1pole)	Intertrip	OUT	*	ON OFF		*	LED			BO					
3523	I.Trip: TRIP 3pole (Diff TRIP 3pole)	Intertrip	OUT	*	ON OFF		*	LED			BO					
3525	>Differential protection blocking signal (> Diff block)	Diff. Prot	SP	ON OFF	*		*	LED	BI		BO					
3526	Differential blocking received at PI1 (Diffblk.rec PI1)	Diff. Prot	OUT	ON OFF	*		*	LED			BO					
3527	Differential blocking received at PI2 (Diffblk.rec PI2)	Diff. Prot	OUT	ON OFF	*		*	LED			BO					
3528	Differential blocking sending via PI1 (Diffblk.sen PI1)	Diff. Prot	OUT	ON OFF	*		*	LED			BO					
3529	Differential blocking sending via PI2 (Diffblk.sen PI2)	Diff. Prot	OUT	ON OFF	*		*	LED			BO					
3541	>Remote Trip 1 signal input (>Remote Trip1)	Remote Signals	SP	on off	*		*	LED	BI		BO					
3542	>Remote Trip 2 signal input (>Remote Trip2)	Remote Signals	SP	on off	*		*	LED	BI		BO					
3543	>Remote Trip 3 signal input (>Remote Trip3)	Remote Signals	SP	on off	*		*	LED	BI		BO					
3544	>Remote Trip 4 signal input (>Remote Trip4)	Remote Signals	SP	on off	*		*	LED	BI		BO					
3545	Remote Trip 1 received (RemoteTrip1 rec)	Remote Signals	OUT	on off	*		*	LED			BO		93	154	1	Yes
3546	Remote Trip 2 received (RemoteTrip2 rec)	Remote Signals	OUT	on off	*		*	LED			BO		93	155	1	Yes
3547	Remote Trip 3 received (RemoteTrip3 rec)	Remote Signals	OUT	on off	*		*	LED			BO		93	156	1	Yes

No.	Description	Function	Type of Information	Log Buffers				Configurable in Matrix					IEC 60870-5-103			
				Event Log ON/OFF	Trip (Fault) Log ON/OFF	Ground Fault Log ON/OFF	Marked in Oscill. Record	LED	Binary Input	Function Key	Relay	Chatter Suppression	Type	Information Number	Data Unit	General Interrogation
3548	Remote Trip 4 received (RemoteTrip4 rec)	Remote Signals	OUT	on off	*		*	LED			BO		93	157	1	Yes
3549	>Remote Signal 1 input (>Rem.Signal 1)	Remote Signals	SP	on off	*		*	LED	BI		BO					
3550	>Remote Signal 2 input (>Rem.Signal 2)	Remote Signals	SP	on off	*		*	LED	BI		BO					
3551	>Remote Signal 3 input (>Rem.Signal 3)	Remote Signals	SP	on off	*		*	LED	BI		BO					
3552	>Remote Signal 4 input (>Rem.Signal 4)	Remote Signals	SP	on off	*		*	LED	BI		BO					
3553	>Remote Signal 5 input (>Rem.Signal 5)	Remote Signals	SP	on off	*		*	LED	BI		BO					
3554	>Remote Signal 6 input (>Rem.Signal 6)	Remote Signals	SP	on off	*		*	LED	BI		BO					
3555	>Remote Signal 7 input (>Rem.Signal 7)	Remote Signals	SP	on off	*		*	LED	BI		BO					
3556	>Remote Signal 8 input (>Rem.Signal 8)	Remote Signals	SP	on off	*		*	LED	BI		BO					
3557	>Remote Signal 9 input (>Rem.Signal 9)	Remote Signals	SP	on off	*		*	LED	BI		BO					
3558	>Remote Signal 10 input (>Rem.Signal10)	Remote Signals	SP	on off	*		*	LED	BI		BO					
3559	>Remote Signal 11 input (>Rem.Signal11)	Remote Signals	SP	on off	*		*	LED	BI		BO					
3560	>Remote Signal 12 input (>Rem.Signal12)	Remote Signals	SP	on off	*		*	LED	BI		BO					
3561	>Remote Signal 13 input (>Rem.Signal13)	Remote Signals	SP	on off	*		*	LED	BI		BO					
3562	>Remote Signal 14 input (>Rem.Signal14)	Remote Signals	SP	on off	*		*	LED	BI		BO					
3563	>Remote Signal 15 input (>Rem.Signal15)	Remote Signals	SP	on off	*		*	LED	BI		BO					
3564	>Remote Signal 16 input (>Rem.Signal16)	Remote Signals	SP	on off	*		*	LED	BI		BO					
3565	>Remote Signal 17 input (>Rem.Signal17)	Remote Signals	SP	on off	*		*	LED	BI		BO					
3566	>Remote Signal 18 input (>Rem.Signal18)	Remote Signals	SP	on off	*		*	LED	BI		BO					
3567	>Remote Signal 19 input (>Rem.Signal19)	Remote Signals	SP	on off	*		*	LED	BI		BO					
3568	>Remote Signal 20 input (>Rem.Signal20)	Remote Signals	SP	on off	*		*	LED	BI		BO					
3569	>Remote Signal 21 input (>Rem.Signal21)	Remote Signals	SP	on off	*		*	LED	BI		BO					
3570	>Remote Signal 22 input (>Rem.Signal22)	Remote Signals	SP	on off	*		*	LED	BI		BO					
3571	>Remote Signal 23 input (>Rem.Signal23)	Remote Signals	SP	on off	*		*	LED	BI		BO					
3572	>Remote Signal 24 input (>Rem.Signal24)	Remote Signals	SP	on off	*		*	LED	BI		BO					
3573	Remote signal 1 received (Rem.Sig 1rcv)	Remote Signals	OUT	on off	*		*	LED			BO		93	158	1	Yes
3574	Remote signal 2 received (Rem.Sig 2rcv)	Remote Signals	OUT	on off	*		*	LED			BO		93	159	1	Yes
3575	Remote signal 3 received (Rem.Sig 3rcv)	Remote Signals	OUT	on off	*		*	LED			BO		93	160	1	Yes

No.	Description	Function	Type of Information	Event Log ON/OFF	Log Buffers			Configurable in Matrix					IEC 60870-5-103			
					Trip (Fault) Log ON/OFF	Ground Fault Log ON/OFF	Marked in Oscill. Record	LED	Binary Input	Function Key	Relay	Chatter Suppression	Type	Information Number	Data Unit	General Interrogation
3576	Remote signal 4 received (Rem.Sig 4recv)	Remote Signals	OUT	on off	*		*	LED			BO	93	161	1	Yes	
3577	Remote signal 5 received (Rem.Sig 5recv)	Remote Signals	OUT	on off	*		*	LED			BO	93	162	1	Yes	
3578	Remote signal 6 received (Rem.Sig 6recv)	Remote Signals	OUT	on off	*		*	LED			BO	93	163	1	Yes	
3579	Remote signal 7 received (Rem.Sig 7recv)	Remote Signals	OUT	on off	*		*	LED			BO	93	164	1	Yes	
3580	Remote signal 8 received (Rem.Sig 8recv)	Remote Signals	OUT	on off	*		*	LED			BO	93	165	1	Yes	
3581	Remote signal 9 received (Rem.Sig 9recv)	Remote Signals	OUT	on off	*		*	LED			BO	93	166	1	Yes	
3582	Remote signal 10 received (Rem.Sig10recv)	Remote Signals	OUT	on off	*		*	LED			BO	93	167	1	Yes	
3583	Remote signal 11 received (Rem.Sig11recv)	Remote Signals	OUT	on off	*		*	LED			BO	93	168	1	Yes	
3584	Remote signal 12 received (Rem.Sig12recv)	Remote Signals	OUT	on off	*		*	LED			BO	93	169	1	Yes	
3585	Remote signal 13 received (Rem.Sig13recv)	Remote Signals	OUT	on off	*		*	LED			BO	93	170	1	Yes	
3586	Remote signal 14 received (Rem.Sig14recv)	Remote Signals	OUT	on off	*		*	LED			BO	93	171	1	Yes	
3587	Remote signal 15 received (Rem.Sig15recv)	Remote Signals	OUT	on off	*		*	LED			BO	93	172	1	Yes	
3588	Remote signal 16 received (Rem.Sig16recv)	Remote Signals	OUT	on off	*		*	LED			BO	93	173	1	Yes	
3589	Remote signal 17 received (Rem.Sig17recv)	Remote Signals	OUT	on off	*		*	LED			BO	93	174	1	Yes	
3590	Remote signal 18 received (Rem.Sig18recv)	Remote Signals	OUT	on off	*		*	LED			BO	93	175	1	Yes	
3591	Remote signal 19 received (Rem.Sig19recv)	Remote Signals	OUT	on off	*		*	LED			BO	93	176	1	Yes	
3592	Remote signal 20 received (Rem.Sig20recv)	Remote Signals	OUT	on off	*		*	LED			BO	93	177	1	Yes	
3593	Remote signal 21 received (Rem.Sig21recv)	Remote Signals	OUT	on off	*		*	LED			BO	93	178	1	Yes	
3594	Remote signal 22 received (Rem.Sig22recv)	Remote Signals	OUT	on off	*		*	LED			BO	93	179	1	Yes	
3595	Remote signal 23 received (Rem.Sig23recv)	Remote Signals	OUT	on off	*		*	LED			BO	93	180	1	Yes	
3596	Remote signal 24 received (Rem.Sig24recv)	Remote Signals	OUT	on off	*		*	LED			BO	93	181	1	Yes	
3603	>BLOCK Z1-Distance (>BLOCK Z1-Dist.)	Dis. General	SP	*	*		*	LED	BI		BO					
3610	>BLOCK Z1-Trip (>BLOCK Z1-Trip)	Dis. General	SP	on off	*		*	LED	BI		BO	28	10	1	Yes	
3611	>ENABLE Z1B (with setted Time Delay) (>ENABLE Z1B)	Dis. General	SP	ON OFF	*		*	LED	BI		BO	28	11	1	Yes	
3613	>ENABLE Z1B instantaneous (w/o T-Delay) (>ENABLE Z1Binst)	Dis. General	SP	ON OFF	*		*	LED	BI		BO	28	13	1	Yes	
3617	>BLOCK Z4-Trip (>BLOCK Z4-Trip)	Dis. General	SP	ON OFF	*		*	LED	BI		BO	28	17	1	Yes	
3618	>BLOCK Z5-Trip (>BLOCK Z5-Trip)	Dis. General	SP	ON OFF	*		*	LED	BI		BO	28	18	1	Yes	
3619	>BLOCK Z4 for ph-e loops (>BLOCK Z4 Ph-E)	Dis. General	SP	ON OFF	*		*	LED	BI		BO	28	19	1	Yes	

No.	Description	Function	Type of Information	Log Buffers				Configurable in Matrix					IEC 60870-5-103			
				Event Log ON/OFF	Trip (Fault) Log ON/OFF	Ground Fault Log ON/OFF	Marked in Oscill. Record	LED	Binary Input	Function Key	Relay	Chatter Suppression	Type	Information Number	Data Unit	General Interrogation
3620	>BLOCK Z5 for ph-e loops (>BLOCK Z5 Ph-E)	Dis. General	SP	ON OFF	*		*	LED	BI		BO		28	20	1	Yes
3651	Distance is switched off (Dist. OFF)	Dis. General	OUT	ON OFF	*		*	LED			BO		28	51	1	Yes
3652	Distance is BLOCKED (Dist. BLOCK)	Dis. General	OUT	ON OFF	ON OFF		*	LED			BO		28	52	1	Yes
3653	Distance is ACTIVE (Dist. ACTIVE)	Dis. General	OUT	*	*		*	LED			BO		28	53	1	Yes
3654	Setting error K0(Z1) or Angle K0(Z1) (Dis.ErrorK0(Z1))	Dis. General	OUT	ON OFF	*		*	LED			BO					
3655	Setting error K0(>Z1) or Angle K0(>Z1) (DisErrorK0(>Z1))	Dis. General	OUT	ON OFF	*		*	LED			BO					
3671	Distance PICKED UP (Dis. PICKUP)	Dis. General	OUT	*	OFF		*	LED			BO		28	71	2	Yes
3672	Distance PICKUP L1 (Dis.Pickup L1)	Dis. General	OUT	*	*		m	LED			BO		28	72	2	Yes
3673	Distance PICKUP L2 (Dis.Pickup L2)	Dis. General	OUT	*	*		m	LED			BO		28	73	2	Yes
3674	Distance PICKUP L3 (Dis.Pickup L3)	Dis. General	OUT	*	*		m	LED			BO		28	74	2	Yes
3675	Distance PICKUP Earth (Dis.Pickup E)	Dis. General	OUT	*	*		*	LED			BO		28	75	2	Yes
3681	Distance Pickup Phase L1 (only) (Dis.Pickup 1pL1)	Dis. General	OUT	*	ON		*	LED			BO		28	81	2	No
3682	Distance Pickup L1E (Dis.Pickup L1E)	Dis. General	OUT	*	ON		*	LED			BO		28	82	2	No
3683	Distance Pickup Phase L2 (only) (Dis.Pickup 1pL2)	Dis. General	OUT	*	ON		*	LED			BO		28	83	2	No
3684	Distance Pickup L2E (Dis.Pickup L2E)	Dis. General	OUT	*	ON		*	LED			BO		28	84	2	No
3685	Distance Pickup L12 (Dis.Pickup L12)	Dis. General	OUT	*	ON		*	LED			BO		28	85	2	No
3686	Distance Pickup L12E (Dis.Pickup L12E)	Dis. General	OUT	*	ON		*	LED			BO		28	86	2	No
3687	Distance Pickup Phase L3 (only) (Dis.Pickup 1pL3)	Dis. General	OUT	*	ON		*	LED			BO		28	87	2	No
3688	Distance Pickup L3E (Dis.Pickup L3E)	Dis. General	OUT	*	ON		*	LED			BO		28	88	2	No
3689	Distance Pickup L31 (Dis.Pickup L31)	Dis. General	OUT	*	ON		*	LED			BO		28	89	2	No
3690	Distance Pickup L31E (Dis.Pickup L31E)	Dis. General	OUT	*	ON		*	LED			BO		28	90	2	No
3691	Distance Pickup L23 (Dis.Pickup L23)	Dis. General	OUT	*	ON		*	LED			BO		28	91	2	No
3692	Distance Pickup L23E (Dis.Pickup L23E)	Dis. General	OUT	*	ON		*	LED			BO		28	92	2	No
3693	Distance Pickup L123 (Dis.Pickup L123)	Dis. General	OUT	*	ON		*	LED			BO		28	93	2	No
3694	Distance Pickup123E (Dis.Pickup123E)	Dis. General	OUT	*	ON		*	LED			BO		28	94	2	No
3695	Dist.: Phi phase L1 Pickup (Dis.Pickup ϕ L1)	Dis. General	OUT	*	*		*	LED			BO					
3696	Dist.: Phi phase L2 Pickup (Dis.Pickup ϕ L2)	Dis. General	OUT	*	*		*	LED			BO					
3697	Dist.: Phi phase L3 Pickup (Dis.Pickup ϕ L3)	Dis. General	OUT	*	*		*	LED			BO					

No.	Description	Function	Type of Information	Event Log ON/OFF	Log Buffers			Configurable in Matrix					IEC 60870-5-103			
					Trip (Fault) Log ON/OFF	Ground Fault Log ON/OFF	Marked in Oscill. Record	LED	Binary Input	Function Key	Relay	Chatter Suppression	Type	Information Number	Data Unit	General Interrogation
3701	Distance Loop L1E selected forward (Dis. Loop L1-E f)	Dis. General	OUT	*	ON OFF		*	LED			BO					
3702	Distance Loop L2E selected forward (Dis. Loop L2-E f)	Dis. General	OUT	*	ON OFF		*	LED			BO					
3703	Distance Loop L3E selected forward (Dis. Loop L3-E f)	Dis. General	OUT	*	ON OFF		*	LED			BO					
3704	Distance Loop L12 selected forward (Dis. Loop L1-2 f)	Dis. General	OUT	*	ON OFF		*	LED			BO					
3705	Distance Loop L23 selected forward (Dis. Loop L2-3 f)	Dis. General	OUT	*	ON OFF		*	LED			BO					
3706	Distance Loop L31 selected forward (Dis. Loop L3-1 f)	Dis. General	OUT	*	ON OFF		*	LED			BO					
3707	Distance Loop L1E selected reverse (Dis. Loop L1-E r)	Dis. General	OUT	*	ON OFF		*	LED			BO					
3708	Distance Loop L2E selected reverse (Dis. Loop L2-E r)	Dis. General	OUT	*	ON OFF		*	LED			BO					
3709	Distance Loop L3E selected reverse (Dis. Loop L3-E r)	Dis. General	OUT	*	ON OFF		*	LED			BO					
3710	Distance Loop L12 selected reverse (Dis. Loop L1-2 r)	Dis. General	OUT	*	ON OFF		*	LED			BO					
3711	Distance Loop L23 selected reverse (Dis. Loop L2-3 r)	Dis. General	OUT	*	ON OFF		*	LED			BO					
3712	Distance Loop L31 selected reverse (Dis. Loop L3-1 r)	Dis. General	OUT	*	ON OFF		*	LED			BO					
3713	Distance Loop L1E selected non-direct. (Dis. Loop L1E<->)	Dis. General	OUT	*	ON OFF		*	LED			BO					
3714	Distance Loop L2E selected non-direct. (Dis. Loop L2E<->)	Dis. General	OUT	*	ON OFF		*	LED			BO					
3715	Distance Loop L3E selected non-direct. (Dis. Loop L3E<->)	Dis. General	OUT	*	ON OFF		*	LED			BO					
3716	Distance Loop L12 selected non-direct. (Dis. Loop L12<->)	Dis. General	OUT	*	ON OFF		*	LED			BO					
3717	Distance Loop L23 selected non-direct. (Dis. Loop L23<->)	Dis. General	OUT	*	ON OFF		*	LED			BO					
3718	Distance Loop L31 selected non-direct. (Dis. Loop L31<->)	Dis. General	OUT	*	ON OFF		*	LED			BO					
3719	Distance Pickup FORWARD (Dis. forward)	Dis. General	OUT	*	*		*	LED			BO		28	121	2	No
3720	Distance Pickup REVERSE (Dis. reverse)	Dis. General	OUT	*	*		*	LED			BO		28	120	2	No
3741	Distance Pickup Z1, Loop L1E (Dis. Z1 L1E)	Dis. General	OUT	*	*		*	LED			BO					
3742	Distance Pickup Z1, Loop L2E (Dis. Z1 L2E)	Dis. General	OUT	*	*		*	LED			BO					
3743	Distance Pickup Z1, Loop L3E (Dis. Z1 L3E)	Dis. General	OUT	*	*		*	LED			BO					
3744	Distance Pickup Z1, Loop L12 (Dis. Z1 L12)	Dis. General	OUT	*	*		*	LED			BO					
3745	Distance Pickup Z1, Loop L23 (Dis. Z1 L23)	Dis. General	OUT	*	*		*	LED			BO					
3746	Distance Pickup Z1, Loop L31 (Dis. Z1 L31)	Dis. General	OUT	*	*		*	LED			BO					
3747	Distance Pickup Z1B, Loop L1E (Dis. Z1B L1E)	Dis. General	OUT	*	*		*	LED			BO					
3748	Distance Pickup Z1B, Loop L2E (Dis. Z1B L2E)	Dis. General	OUT	*	*		*	LED			BO					

No.	Description	Function	Type of Information	Log Buffers				Configurable in Matrix					IEC 60870-5-103			
				Event Log ON/OFF	Trip (Fault) Log ON/OFF	Ground Fault Log ON/OFF	Marked in Oscill. Record	LED	Binary Input	Function Key	Relay	Chatter Suppression	Type	Information Number	Data Unit	General Interrogation
3749	Distance Pickup Z1B, Loop L3E (Dis. Z1B L3E)	Dis. General	OUT	*	*		*	LED			BO					
3750	Distance Pickup Z1B, Loop L12 (Dis. Z1B L12)	Dis. General	OUT	*	*		*	LED			BO					
3751	Distance Pickup Z1B, Loop L23 (Dis. Z1B L23)	Dis. General	OUT	*	*		*	LED			BO					
3752	Distance Pickup Z1B, Loop L31 (Dis. Z1B L31)	Dis. General	OUT	*	*		*	LED			BO					
3755	Distance Pickup Z2 (Dis. Pickup Z2)	Dis. General	OUT	*	*		*	LED			BO					
3758	Distance Pickup Z3 (Dis. Pickup Z3)	Dis. General	OUT	*	*		*	LED			BO					
3759	Distance Pickup Z4 (Dis. Pickup Z4)	Dis. General	OUT	*	*		*	LED			BO					
3760	Distance Pickup Z5 (Dis. Pickup Z5)	Dis. General	OUT	*	*		*	LED			BO					
3771	DistanceTime Out T1 (Dis.Time Out T1)	Dis. General	OUT	*	*		*	LED			BO		28	171	2	No
3774	DistanceTime Out T2 (Dis.Time Out T2)	Dis. General	OUT	*	*		*	LED			BO		28	172	2	No
3777	DistanceTime Out T3 (Dis.Time Out T3)	Dis. General	OUT	*	*		*	LED			BO		28	173	2	No
3778	DistanceTime Out T4 (Dis.Time Out T4)	Dis. General	OUT	*	*		*	LED			BO		28	174	2	No
3779	DistanceTime Out T5 (Dis.Time Out T5)	Dis. General	OUT	*	*		*	LED			BO		28	175	2	No
3780	DistanceTime Out T1B (Dis.TimeOut T1B)	Dis. General	OUT	*	*		*	LED			BO		28	180	2	No
3781	DistanceTime Out Forward PICKUP (Dis.TimeOut Tfw)	Dis. General	OUT	*	*		*	LED			BO		28	160	2	No
3782	DistanceTime Out Non-directional PICKUP (Dis.TimeOut Tnd)	Dis. General	OUT	*	*		*	LED			BO		28	161	2	No
3801	Distance protection: General trip (Dis.Gen. Trip)	Dis. General	OUT	*	*		*	LED			BO		28	201	2	No
3802	Distance TRIP command - Only Phase L1 (Dis.Trip 1pL1)	Dis. General	OUT	*	ON		*	LED			BO		28	202	2	No
3803	Distance TRIP command - Only Phase L2 (Dis.Trip 1pL2)	Dis. General	OUT	*	ON		*	LED			BO		28	203	2	No
3804	Distance TRIP command - Only Phase L3 (Dis.Trip 1pL3)	Dis. General	OUT	*	ON		*	LED			BO		28	204	2	No
3805	Distance TRIP command Phases L123 (Dis.Trip 3p)	Dis. General	OUT	*	ON		*	LED			BO		28	205	2	No
3811	Distance TRIP single-phase Z1 (Dis.TripZ1/1p)	Dis. General	OUT	*	*		*	LED			BO		28	211	2	No
3813	Distance TRIP single-phase Z1B (Dis.TripZ1B1p)	Dis. General	OUT	*	*		*	LED			BO		28	213	2	No
3816	Distance TRIP single-phase Z2 (Dis.TripZ2/1p)	Dis. General	OUT	*	*		*	LED			BO		28	216	2	No
3817	Distance TRIP 3phase in Z2 (Dis.TripZ2/3p)	Dis. General	OUT	*	*		*	LED			BO		28	217	2	No
3818	Distance TRIP 3phase in Z3 (Dis.TripZ3/T3)	Dis. General	OUT	*	*		*	LED			BO		28	218	2	No
3819	Dist.: Trip by fault detection, forward (Dis.Trip FD->)	Dis. General	OUT	*	*		*	LED			BO		28	219	2	No
3820	Dist.: Trip by fault detec, rev/non-dir. (Dis.Trip <->)	Dis. General	OUT	*	*		*	LED			BO		28	220	2	No

No.	Description	Function	Type of Information	Log Buffers				Configurable in Matrix					IEC 60870-5-103			
				Event Log ON/OFF	Trip (Fault) Log ON/OFF	Ground Fault Log ON/OFF	Marked in Oscill. Record	LED	Binary Input	Function Key	Relay	Chatter Suppression	Type	Information Number	Data Unit	General Interrogation
3821	Distance TRIP 3phase in Z4 (Dis.TRIP 3p. Z4)	Dis. General	OUT	*	*		*	LED			BO		28	209	2	No
3822	Distance TRIP 3phase in Z5 (Dis.TRIP 3p. Z5)	Dis. General	OUT	*	*		*	LED			BO		28	210	2	No
3823	DisTRIP 3phase in Z1 with single-ph Flt. (DisTRIP3p. Z1sf)	Dis. General	OUT	*	*		*	LED			BO		28	224	2	No
3824	DisTRIP 3phase in Z1 with multi-ph Flt. (DisTRIP3p. Z1mf)	Dis. General	OUT	*	*		*	LED			BO		28	225	2	No
3825	DisTRIP 3phase in Z1B with single-ph Flt (DisTRIP3p.Z1Bsf)	Dis. General	OUT	*	*		*	LED			BO		28	244	2	No
3826	DisTRIP 3phase in Z1B with multi-ph Flt. (DisTRIP3p Z1Bmf)	Dis. General	OUT	*	*		*	LED			BO		28	245	2	No
3850	DisTRIP Z1B with Teleprotection scheme (DisTRIP Z1B Tel)	Dis. General	OUT	*	*		*	LED			BO		28	251	2	No
4001	>Distance Teleprotection ON (>Dis.Telep. ON)	Teleprot. Dist.	SP	*	*		*	LED	BI		BO					
4002	>Distance Teleprotection OFF (>Dis.Telep.OFF)	Teleprot. Dist.	SP	*	*		*	LED	BI		BO					
4003	>Distance Teleprotection BLOCK (>Dis.Telep. Blk)	Teleprot. Dist.	SP	ON OFF	ON OFF		*	LED	BI		BO		29	3	1	Yes
4005	>Dist. teleprotection: Carrier faulty (>Dis.RecFail)	Teleprot. Dist.	SP	on off	*		*	LED	BI		BO					
4006	>Dis.Tele. Carrier RECEPTION Channel 1 (>Dis.Tel Rec.Ch1)	Teleprot. Dist.	SP	on off	on		*	LED	BI		BO		29	6	1	Yes
4007	>Dis.Tele.Carrier RECEPTION Channel 1,L1 (>Dis.T.RecCh1L1)	Teleprot. Dist.	SP	on off	on		*	LED	BI		BO		29	7	1	Yes
4008	>Dis.Tele.Carrier RECEPTION Channel 1,L2 (>Dis.T.RecCh1L2)	Teleprot. Dist.	SP	on off	on		*	LED	BI		BO		29	8	1	Yes
4009	>Dis.Tele.Carrier RECEPTION Channel 1,L3 (>Dis.T.RecCh1L3)	Teleprot. Dist.	SP	on off	on		*	LED	BI		BO		29	9	1	Yes
4010	>Dis.Tele. Carrier RECEPTION Channel 2 (>Dis.T.Rec.Ch2)	Teleprot. Dist.	SP	on off	on		*	LED	BI		BO		29	10	1	Yes
4030	>Dis.Tele. Unblocking: UNBLOCK Channel 1 (>Dis.T.UB ub 1)	Teleprot. Dist.	SP	on off	on		*	LED	BI		BO		29	30	1	Yes
4031	>Dis.Tele. Unblocking: BLOCK Channel 1 (>Dis.T.UB bl 1)	Teleprot. Dist.	SP	on off	on		*	LED	BI		BO		29	31	1	Yes
4032	>Dis.Tele. Unblocking: UNBLOCK Ch. 1, L1 (>Dis.T.UB ub1L1)	Teleprot. Dist.	SP	on off	on		*	LED	BI		BO		29	32	1	Yes
4033	>Dis.Tele. Unblocking: UNBLOCK Ch. 1, L2 (>Dis.T.UB ub1L2)	Teleprot. Dist.	SP	on off	on		*	LED	BI		BO		29	33	1	Yes
4034	>Dis.Tele. Unblocking: UNBLOCK Ch. 1, L3 (>Dis.T.UB ub1L3)	Teleprot. Dist.	SP	on off	on		*	LED	BI		BO		29	34	1	Yes
4035	>Dis.Tele. Unblocking: UNBLOCK Channel 2 (>Dis.T.UB ub 2)	Teleprot. Dist.	SP	on off	on		*	LED	BI		BO		29	35	1	Yes
4036	>Dis.Tele. Unblocking: BLOCK Channel 2 (>Dis.T.UB bl 2)	Teleprot. Dist.	SP	on off	on		*	LED	BI		BO		29	36	1	Yes
4040	>Dis.Tele. BLOCK Echo Signal (>Dis.T.BlkEcho)	Teleprot. Dist.	SP	on off	on		*	LED	BI		BO		29	40	1	Yes
4050	Dis. Teleprotection ON/OFF via BI (Dis.T.on/off BI)	Teleprot. Dist.	IntSP	ON OFF	*		*	LED			BO					
4051	Teleprotection is switched ON (Telep. ON)	Device	IntSP	*	*		*	LED			BO		29	51	1	Yes

No.	Description	Function	Type of Information	Log Buffers				Configurable in Matrix					IEC 60870-5-103			
				Event Log ON/OFF	Trip (Fault) Log ON/OFF	Ground Fault Log ON/OFF	Marked in Oscill. Record	LED	Binary Input	Function Key	Relay	Chatter Suppression	Type	Information Number	Data Unit	General Interrogation
4052	Dis. Teleprotection is switched OFF (Dis.Telep. OFF)	Teleprot. Dist.	OUT	ON OFF	*		*	LED			BO					
4054	Dis. Telep. Carrier signal received (Dis.T.Carr.rec.)	Teleprot. Dist.	OUT	*	*		*	LED			BO		29	54	2	No
4055	Dis. Telep. Carrier CHANNEL FAILURE (Dis.T.Carr.Fail)	Teleprot. Dist.	OUT	*	*		*	LED			BO		29	55	1	Yes
4056	Dis. Telep. Carrier SEND signal (Dis.T.SEND)	Teleprot. Dist.	OUT	on	on		*	LED			BO		29	56	2	No
4057	Dis. Telep. Carrier SEND signal, L1 (Dis.T.SEND L1)	Teleprot. Dist.	OUT	*	*		*	LED			BO					
4058	Dis. Telep. Carrier SEND signal, L2 (Dis.T.SEND L2)	Teleprot. Dist.	OUT	*	*		*	LED			BO					
4059	Dis. Telep. Carrier SEND signal, L3 (Dis.T.SEND L3)	Teleprot. Dist.	OUT	*	*		*	LED			BO					
4060	Dis. Tele.Blocking: Send signal with jump (DisJumpBlocking)	Teleprot. Dist.	OUT	*	*		*	LED			BO		29	60	2	No
4068	Dis. Telep. Transient Blocking (Dis.T.Trans.Blk)	Teleprot. Dist.	OUT	*	ON		*	LED			BO		29	68	2	No
4070	Dis. Tele.Blocking: carrier STOP signal (Dis.T.BL STOP)	Teleprot. Dist.	OUT	*	ON		*	LED			BO		29	70	2	No
4080	Dis. Tele.Unblocking: FAILURE Channel 1 (Dis.T.UB Fail1)	Teleprot. Dist.	OUT	on off	*		*	LED			BO		29	80	1	Yes
4081	Dis. Tele.Unblocking: FAILURE Channel 2 (Dis.T.UB Fail2)	Teleprot. Dist.	OUT	on off	*		*	LED			BO		29	81	1	Yes
4082	DisTel Blocking: carrier STOP signal, L1 (Dis.T.BL STOPL1)	Teleprot. Dist.	OUT	*	*		*	LED			BO					
4083	DisTel Blocking: carrier STOP signal, L2 (Dis.T.BL STOPL2)	Teleprot. Dist.	OUT	*	*		*	LED			BO					
4084	DisTel Blocking: carrier STOP signal, L3 (Dis.T.BL STOPL3)	Teleprot. Dist.	OUT	*	*		*	LED			BO					
4160	>BLOCK Power Swing detection (>Pow. Swing BLK)	Power Swing	SP	ON OFF	ON OFF		*	LED	BI		BO					
4163	Power Swing unstable (P.Swing unstab.)	Power Swing	OUT	ON	ON		*	LED			BO					
4164	Power Swing detected (Power Swing)	Power Swing	OUT	ON OFF	ON OFF		*	LED			BO		29	164	1	Yes
4166	Power Swing TRIP command (Pow. Swing TRIP)	Power Swing	OUT	ON	ON		*	LED			BO		29	166	1	No
4167	Power Swing detected in L1 (Pow. Swing L1)	Power Swing	OUT	ON OFF	ON OFF		*	LED			BO					
4168	Power Swing detected in L2 (Pow. Swing L2)	Power Swing	OUT	ON OFF	ON OFF		*	LED			BO					
4169	Power Swing detected in L3 (Pow. Swing L3)	Power Swing	OUT	ON OFF	ON OFF		*	LED			BO					
4203	>BLOCK Weak Infeed (>BLOCK Weak Inf)	Weak Infeed	SP	*	*		*	LED	BI		BO					
4204	>BLOCK delayed Weak Infeed stage (>BLOCK del. WI)	Weak Infeed	SP	ON OFF	ON OFF		*	LED	BI		BO					
4205	>Reception (channel) for Weak Infeed OK (>WI rec. OK)	Weak Infeed	SP	ON OFF	ON OFF		*	LED	BI		BO					
4206	>Receive signal for Weak Infeed (>WI reception)	Weak Infeed	SP	ON OFF	ON OFF		*	LED	BI		BO					
4221	Weak Infeed is switched OFF (WeakInf. OFF)	Weak Infeed	OUT	ON OFF	*		*	LED			BO		25	21	1	Yes
4222	Weak Infeed is BLOCKED (Weak Inf. BLOCK)	Weak Infeed	OUT	ON OFF	ON OFF		*	LED			BO		25	22	1	Yes

No.	Description	Function	Type of Information	Log Buffers				Configurable in Matrix					IEC 60870-5-103			
				Event Log ON/OFF	Trip (Fault) Log ON/OFF	Ground Fault Log ON/OFF	Marked in Oscill. Record	LED	Binary Input	Function Key	Relay	Chatter Suppression	Type	Information Number	Data Unit	General Interrogation
4223	Weak Infeed is ACTIVE (Weak Inf ACTIVE)	Weak Infeed	OUT	*	*		*	LED			BO		25	23	1	Yes
4225	Weak Infeed Zero seq. current detected (3I0 detected)	Weak Infeed	OUT	ON OFF	ON OFF		*	LED			BO					
4226	Weak Infeed Undervoltg. L1 (WI U L1<)	Weak Infeed	OUT	ON OFF	ON OFF		*	LED			BO					
4227	Weak Infeed Undervoltg. L2 (WI U L2<)	Weak Infeed	OUT	ON OFF	ON OFF		*	LED			BO					
4228	Weak Infeed Undervoltg. L3 (WI U L3<)	Weak Infeed	OUT	ON OFF	ON OFF		*	LED			BO					
4229	WI TRIP with zero sequence current (WI TRIP 3I0)	Weak Infeed	OUT	*	*		*	LED			BO					
4231	Weak Infeed PICKED UP (Weak-Inf. PICKUP)	Weak Infeed	OUT	*	OFF		*	LED			BO		25	31	2	Yes
4232	Weak Infeed PICKUP L1 (W/I Pickup L1)	Weak Infeed	OUT	*	ON		*	LED			BO					
4233	Weak Infeed PICKUP L2 (W/I Pickup L2)	Weak Infeed	OUT	*	ON		*	LED			BO					
4234	Weak Infeed PICKUP L3 (W/I Pickup L3)	Weak Infeed	OUT	*	ON		*	LED			BO					
4241	Weak Infeed General TRIP command (WeakInfeed TRIP)	Weak Infeed	OUT	*	*		*	LED			BO		25	41	2	No
4242	Weak Infeed TRIP command - Only L1 (Weak TRIP 1p.L1)	Weak Infeed	OUT	*	ON		*	LED			BO		25	42	2	No
4243	Weak Infeed TRIP command - Only L2 (Weak TRIP 1p.L2)	Weak Infeed	OUT	*	ON		*	LED			BO		25	43	2	No
4244	Weak Infeed TRIP command - Only L3 (Weak TRIP 1p.L3)	Weak Infeed	OUT	*	ON		*	LED			BO		25	44	2	No
4245	Weak Infeed TRIP command L123 (Weak TRIP L123)	Weak Infeed	OUT	*	ON		*	LED			BO		25	45	2	No
4246	ECHO Send SIGNAL (ECHO SIGNAL)	Weak Infeed	OUT	ON	ON		*	LED			BO		25	46	2	Yes
4253	>BLOCK Instantaneous SOTF Overcurrent (>BLOCK SOTF-O/C)	SOTF Overcurr.	SP	*	*		*	LED	BI		BO					
4271	SOTF-O/C is switched OFF (SOTF-O/C OFF)	SOTF Overcurr.	OUT	ON OFF	*		*	LED			BO		25	71	1	Yes
4272	SOTF-O/C is BLOCKED (SOTF-O/C BLOCK)	SOTF Overcurr.	OUT	ON OFF	ON OFF		*	LED			BO		25	72	1	Yes
4273	SOTF-O/C is ACTIVE (SOTF-O/C ACTIVE)	SOTF Overcurr.	OUT	*	*		*	LED			BO		25	73	1	Yes
4281	SOTF-O/C PICKED UP (SOTF-O/C PICKUP)	SOTF Overcurr.	OUT	*	OFF		m	LED			BO		25	81	2	Yes
4282	SOTF-O/C Pickup L1 (SOF O/CpickupL1)	SOTF Overcurr.	OUT	*	ON		*	LED			BO		25	82	2	Yes
4283	SOTF-O/C Pickup L2 (SOF O/CpickupL2)	SOTF Overcurr.	OUT	*	ON		*	LED			BO		25	83	2	Yes
4284	SOTF-O/C Pickup L3 (SOF O/CpickupL3)	SOTF Overcurr.	OUT	*	ON		*	LED			BO		25	84	2	Yes
4285	High Speed-O/C Pickup I>>>> L1 (I>>>>O/C p.upL1)	SOTF Overcurr.	OUT	*	ON		*	LED			BO		25	85	2	Yes
4286	High Speed-O/C Pickup I>>>> L2 (I>>>>O/C p.upL2)	SOTF Overcurr.	OUT	*	ON		*	LED			BO		25	86	2	Yes
4287	High Speed-O/C Pickup I>>>> L3 (I>>>>O/C p.upL3)	SOTF Overcurr.	OUT	*	ON		*	LED			BO		25	87	2	Yes

No.	Description	Function	Type of Information	Log Buffers				Configurable in Matrix					IEC 60870-5-103			
				Event Log ON/OFF	Trip (Fault) Log ON/OFF	Ground Fault Log ON/OFF	Marked in Oscill. Record	LED	Binary Input	Function Key	Relay	Chatter Suppression	Type	Information Number	Data Unit	General Interrogation
4289	High Speed/SOTF-O/C TRIP - Only L1 (HS/SOF TRIP1pL1)	SOTF Overcurr.	OUT	*	ON		*	LED			BO		25	89	2	Yes
4290	High Speed/SOTF-O/C TRIP - Only L2 (HS/SOF TRIP1pL2)	SOTF Overcurr.	OUT	*	ON		*	LED			BO		25	90	2	Yes
4291	High Speed/SOTF-O/C TRIP - Only L3 (HS/SOF TRIP1pL3)	SOTF Overcurr.	OUT	*	ON		*	LED			BO		25	91	2	Yes
4292	High Speed/SOTF-O/C TRIP 1pole (HS/SOF TRIP 1p)	SOTF Overcurr.	OUT	*	ON		*	LED			BO		25	94	2	No
4293	High Speed/SOTF-O/C General TRIP (HS/SOF Gen.TRIP)	SOTF Overcurr.	OUT	*	ON		*	LED			BO					
4294	High Speed/SOTF-O/C TRIP 3pole (HS/SOF TRIP 3p)	SOTF Overcurr.	OUT	*	ON		*	LED			BO					
4295	High Speed/SOTF-O/C TRIP command L123 (HS/SOF TRIPL123)	SOTF Overcurr.	OUT	*	ON		*	LED			BO		25	95	2	Yes
4403	>BLOCK Direct Transfer Trip function (>BLOCK DTT)	DTT Direct Trip	SP	*	*		*	LED	BI		BO					
4412	>Direct Transfer Trip INPUT Phase L1 (>DTT Trip L1)	DTT Direct Trip	SP	ON OFF	*		*	LED	BI		BO					
4413	>Direct Transfer Trip INPUT Phase L2 (>DTT Trip L2)	DTT Direct Trip	SP	ON OFF	*		*	LED	BI		BO					
4414	>Direct Transfer Trip INPUT Phase L3 (>DTT Trip L3)	DTT Direct Trip	SP	ON OFF	*		*	LED	BI		BO					
4417	>Direct Transfer Trip INPUT 3ph L123 (>DTT Trip L123)	DTT Direct Trip	SP	ON OFF	*		*	LED	BI		BO					
4421	Direct Transfer Trip is switched OFF (DTT OFF)	DTT Direct Trip	OUT	ON OFF	*		*	LED			BO		51	21	1	Yes
4422	Direct Transfer Trip is BLOCKED (DTT BLOCK)	DTT Direct Trip	OUT	ON OFF	ON OFF		*	LED			BO		51	22	1	Yes
4432	DTT TRIP command - Only L1 (DTT TRIP 1p. L1)	DTT Direct Trip	OUT	*	ON		*	LED			BO		51	32	2	No
4433	DTT TRIP command - Only L2 (DTT TRIP 1p. L2)	DTT Direct Trip	OUT	*	ON		*	LED			BO		51	33	2	No
4434	DTT TRIP command - Only L3 (DTT TRIP 1p. L3)	DTT Direct Trip	OUT	*	ON		*	LED			BO		51	34	2	No
4435	DTT TRIP command L123 (DTT TRIP L123)	DTT Direct Trip	OUT	*	ON		*	LED			BO		51	35	2	No
5203	>BLOCK frequency protection (>BLOCK Freq.)	Frequency Prot.	SP	ON OFF	*		*	LED	BI		BO		70	176	1	Yes
5206	>BLOCK frequency protection stage f1 (>BLOCK f1)	Frequency Prot.	SP	ON OFF	*		*	LED	BI		BO		70	177	1	Yes
5207	>BLOCK frequency protection stage f2 (>BLOCK f2)	Frequency Prot.	SP	ON OFF	*		*	LED	BI		BO		70	178	1	Yes
5208	>BLOCK frequency protection stage f3 (>BLOCK f3)	Frequency Prot.	SP	ON OFF	*		*	LED	BI		BO		70	179	1	Yes
5209	>BLOCK frequency protection stage f4 (>BLOCK f4)	Frequency Prot.	SP	ON OFF	*		*	LED	BI		BO		70	180	1	Yes
5211	Frequency protection is switched OFF (Freq. OFF)	Frequency Prot.	OUT	ON OFF	*		*	LED			BO		70	181	1	Yes
5212	Frequency protection is BLOCKED (Freq. BLOCKED)	Frequency Prot.	OUT	ON OFF	ON OFF		*	LED			BO		70	182	1	Yes
5213	Frequency protection is ACTIVE (Freq. ACTIVE)	Frequency Prot.	OUT	ON OFF	*		*	LED			BO		70	183	1	Yes
5232	Frequency protection: f1 picked up (f1 picked up)	Frequency Prot.	OUT	*	ON OFF		*	LED			BO		70	230	2	Yes

No.	Description	Function	Type of Information	Log Buffers				Configurable in Matrix					IEC 60870-5-103			
				Event Log ON/OFF	Trip (Fault) Log ON/OFF	Ground Fault Log ON/OFF	Marked in Oscill. Record	LED	Binary Input	Function Key	Relay	Chatter Suppression	Type	Information Number	Data Unit	General Interrogation
5233	Frequency protection: f2 picked up (f2 picked up)	Frequency Prot.	OUT	*	ON OFF		*	LED			BO	70	231	2	Yes	
5234	Frequency protection: f3 picked up (f3 picked up)	Frequency Prot.	OUT	*	ON OFF		*	LED			BO	70	232	2	Yes	
5235	Frequency protection: f4 picked up (f4 picked up)	Frequency Prot.	OUT	*	ON OFF		*	LED			BO	70	233	2	Yes	
5236	Frequency protection: f1 TRIP (f1 TRIP)	Frequency Prot.	OUT	*	ON		*	LED			BO	70	234	2	Yes	
5237	Frequency protection: f2 TRIP (f2 TRIP)	Frequency Prot.	OUT	*	ON		*	LED			BO	70	235	2	Yes	
5238	Frequency protection: f3 TRIP (f3 TRIP)	Frequency Prot.	OUT	*	ON		*	LED			BO	70	236	2	Yes	
5239	Frequency protection: f4 TRIP (f4 TRIP)	Frequency Prot.	OUT	*	ON		*	LED			BO	70	237	2	Yes	
5240	Frequency protection: TimeOut Stage f1 (Time Out f1)	Frequency Prot.	OUT	*	*		*	LED			BO					
5241	Frequency protection: TimeOut Stage f2 (Time Out f2)	Frequency Prot.	OUT	*	*		*	LED			BO					
5242	Frequency protection: TimeOut Stage f3 (Time Out f3)	Frequency Prot.	OUT	*	*		*	LED			BO					
5243	Frequency protection: TimeOut Stage f4 (Time Out f4)	Frequency Prot.	OUT	*	*		*	LED			BO					
6854	>Trip circuit superv. 1: Trip Relay (>TripC1 TripRel)	TripCirc.Superv	SP	ON OFF	*		*	LED	BI		BO					
6855	>Trip circuit superv. 1: Breaker Relay (>TripC1 Bkr.Rel)	TripCirc.Superv	SP	ON OFF	*		*	LED	BI		BO					
6856	>Trip circuit superv. 2: Trip Relay (>TripC2 TripRel)	TripCirc.Superv	SP	ON OFF	*		*	LED	BI		BO					
6857	>Trip circuit superv. 2: Breaker Relay (>TripC2 Bkr.Rel)	TripCirc.Superv	SP	ON OFF	*		*	LED	BI		BO					
6858	>Trip circuit superv. 3: Trip Relay (>TripC3 TripRel)	TripCirc.Superv	SP	ON OFF	*		*	LED	BI		BO					
6859	>Trip circuit superv. 3: Breaker Relay (>TripC3 Bkr.Rel)	TripCirc.Superv	SP	ON OFF	*		*	LED	BI		BO					
6861	Trip circuit supervision OFF (TripC OFF)	TripCirc.Superv	OUT	ON OFF	*		*	LED			BO	170	53	1	Yes	
6865	Failure Trip Circuit (FAIL: Trip cir.)	TripCirc.Superv	OUT	ON OFF	*		*	LED			BO	192	36	1	Yes	
6866	TripC1 blocked: Binary input is not set (TripC1 ProgFAIL)	TripCirc.Superv	OUT	ON OFF	*		*	LED			BO					
6867	TripC2 blocked: Binary input is not set (TripC2 ProgFAIL)	TripCirc.Superv	OUT	ON OFF	*		*	LED			BO					
6868	TripC3 blocked: Binary input is not set (TripC3 ProgFAIL)	TripCirc.Superv	OUT	ON OFF	*		*	LED			BO					
7104	>BLOCK Backup OverCurrent I>> (>BLOCK O/C I>>)	Back-Up O/C	SP	ON OFF	*		*	LED	BI		BO	64	4	1	Yes	
7105	>BLOCK Backup OverCurrent I> (>BLOCK O/C I>)	Back-Up O/C	SP	ON OFF	*		*	LED	BI		BO	64	5	1	Yes	
7106	>BLOCK Backup OverCurrent Ip (>BLOCK O/C Ip)	Back-Up O/C	SP	ON OFF	*		*	LED	BI		BO	64	6	1	Yes	
7107	>BLOCK Backup OverCurrent Ie>> (>BLOCK O/C Ie>>)	Back-Up O/C	SP	ON OFF	*		*	LED	BI		BO	64	7	1	Yes	
7108	>BLOCK Backup OverCurrent Ie> (>BLOCK O/C Ie>)	Back-Up O/C	SP	ON OFF	*		*	LED	BI		BO	64	8	1	Yes	
7109	>BLOCK Backup OverCurrent Iep (>BLOCK O/C Iep)	Back-Up O/C	SP	ON OFF	*		*	LED	BI		BO	64	9	1	Yes	

No.	Description	Function	Type of Information	Log Buffers				Configurable in Matrix					IEC 60870-5-103			
				Event Log ON/OFF	Trip (Fault) Log ON/OFF	Ground Fault Log ON/OFF	Marked in Oscill. Record	LED	Binary Input	Function Key	Relay	Chatter Suppression	Type	Information Number	Data Unit	General Interrogation
7110	>Backup OverCurrent Instantaneous Trip (>O/C InstTRIP)	Back-Up O/C	SP	ON OFF	ON OFF		*	LED	BI		BO		64	10	1	Yes
7130	>BLOCK I-STUB (>BLOCK I-STUB)	Back-Up O/C	SP	ON OFF	*		*	LED	BI		BO		64	30	1	Yes
7131	>Enable I-STUB-Bus function (>I-STUB ENABLE)	Back-Up O/C	SP	ON OFF	ON OFF		*	LED	BI		BO		64	31	1	Yes
7132	>BLOCK Backup OverCurrent le>>> (>BLOCK O/Cle>>>)	Back-Up O/C	SP	ON OFF	*		*	LED	BI		BO		64	32	1	Yes
7151	Backup O/C is switched OFF (O/C OFF)	Back-Up O/C	OUT	ON OFF	*		*	LED			BO		64	51	1	Yes
7152	Backup O/C is BLOCKED (O/C BLOCK)	Back-Up O/C	OUT	ON OFF	ON OFF		*	LED			BO		64	52	1	Yes
7153	Backup O/C is ACTIVE (O/C ACTIVE)	Back-Up O/C	OUT	*	*		*	LED			BO		64	53	1	Yes
7161	Backup O/C PICKED UP (O/C PICKUP)	Back-Up O/C	OUT	*	OFF		m	LED			BO		64	61	2	Yes
7162	Backup O/C PICKUP L1 (O/C Pickup L1)	Back-Up O/C	OUT	*	ON		*	LED			BO		64	62	2	Yes
7163	Backup O/C PICKUP L2 (O/C Pickup L2)	Back-Up O/C	OUT	*	ON		*	LED			BO		64	63	2	Yes
7164	Backup O/C PICKUP L3 (O/C Pickup L3)	Back-Up O/C	OUT	*	ON		*	LED			BO		64	64	2	Yes
7165	Backup O/C PICKUP EARTH (O/C Pickup E)	Back-Up O/C	OUT	*	ON		*	LED			BO		64	65	2	Yes
7171	Backup O/C Pickup - Only EARTH (O/C PU only E)	Back-Up O/C	OUT	*	ON		*	LED			BO		64	71	2	No
7172	Backup O/C Pickup - Only L1 (O/C PU 1p. L1)	Back-Up O/C	OUT	*	ON		*	LED			BO		64	72	2	No
7173	Backup O/C Pickup L1E (O/C Pickup L1E)	Back-Up O/C	OUT	*	ON		*	LED			BO		64	73	2	No
7174	Backup O/C Pickup - Only L2 (O/C PU 1p. L2)	Back-Up O/C	OUT	*	ON		*	LED			BO		64	74	2	No
7175	Backup O/C Pickup L2E (O/C Pickup L2E)	Back-Up O/C	OUT	*	ON		*	LED			BO		64	75	2	No
7176	Backup O/C Pickup L12 (O/C Pickup L12)	Back-Up O/C	OUT	*	ON		*	LED			BO		64	76	2	No
7177	Backup O/C Pickup L12E (O/C Pickup L12E)	Back-Up O/C	OUT	*	ON		*	LED			BO		64	77	2	No
7178	Backup O/C Pickup - Only L3 (O/C PU 1p. L3)	Back-Up O/C	OUT	*	ON		*	LED			BO		64	78	2	No
7179	Backup O/C Pickup L3E (O/C Pickup L3E)	Back-Up O/C	OUT	*	ON		*	LED			BO		64	79	2	No
7180	Backup O/C Pickup L31 (O/C Pickup L31)	Back-Up O/C	OUT	*	ON		*	LED			BO		64	80	2	No
7181	Backup O/C Pickup L31E (O/C Pickup L31E)	Back-Up O/C	OUT	*	ON		*	LED			BO		64	81	2	No
7182	Backup O/C Pickup L23 (O/C Pickup L23)	Back-Up O/C	OUT	*	ON		*	LED			BO		64	82	2	No
7183	Backup O/C Pickup L23E (O/C Pickup L23E)	Back-Up O/C	OUT	*	ON		*	LED			BO		64	83	2	No
7184	Backup O/C Pickup L123 (O/C Pickup L123)	Back-Up O/C	OUT	*	ON		*	LED			BO		64	84	2	No
7185	Backup O/C Pickup L123E (O/C Pickup L123E)	Back-Up O/C	OUT	*	ON		*	LED			BO		64	85	2	No
7191	Backup O/C Pickup l>> (O/C PICKUP l>>)	Back-Up O/C	OUT	*	ON		m	LED			BO		64	91	2	Yes

No.	Description	Function	Type of Information	Log Buffers				Configurable in Matrix					IEC 60870-5-103			
				Event Log ON/OFF	Trip (Fault) Log ON/OFF	Ground Fault Log ON/OFF	Marked in Oscill. Record	LED	Binary Input	Function Key	Relay	Chatter Suppression	Type	Information Number	Data Unit	General Interrogation
7192	Backup O/C Pickup I> (O/C PICKUP I>)	Back-Up O/C	OUT	*	ON		m	LED			BO		64	92	2	Yes
7193	Backup O/C Pickup Ip (O/C PICKUP Ip)	Back-Up O/C	OUT	*	ON		m	LED			BO		64	93	2	Yes
7201	O/C I-STUB Pickup (I-STUB PICKUP)	Back-Up O/C	OUT	*	ON OFF		m	LED			BO		64	101	2	Yes
7211	Backup O/C General TRIP command (O/C TRIP)	Back-Up O/C	OUT	*	*		*	LED			BO		64	111	2	No
7212	Backup O/C TRIP - Only L1 (O/C TRIP 1p.L1)	Back-Up O/C	OUT	*	ON		*	LED			BO		64	112	2	No
7213	Backup O/C TRIP - Only L2 (O/C TRIP 1p.L2)	Back-Up O/C	OUT	*	ON		*	LED			BO		64	113	2	No
7214	Backup O/C TRIP - Only L3 (O/C TRIP 1p.L3)	Back-Up O/C	OUT	*	ON		*	LED			BO		64	114	2	No
7215	Backup O/C TRIP Phases L123 (O/C TRIP L123)	Back-Up O/C	OUT	*	ON		*	LED			BO		64	115	2	No
7221	Backup O/C TRIP I>> (O/C TRIP I>>)	Back-Up O/C	OUT	*	ON		*	LED			BO		64	121	2	No
7222	Backup O/C TRIP I> (O/C TRIP I>)	Back-Up O/C	OUT	*	ON		*	LED			BO		64	122	2	No
7223	Backup O/C TRIP Ip (O/C TRIP Ip)	Back-Up O/C	OUT	*	ON		*	LED			BO		64	123	2	No
7235	O/C I-STUB TRIP (I-STUB TRIP)	Back-Up O/C	OUT	*	ON		*	LED			BO		64	135	2	No
7325	CB1-TEST TRIP command - Only L1 (CB1-TESTtrip L1)	Testing	OUT	ON OFF	*		*	LED			BO		153	25	1	Yes
7326	CB1-TEST TRIP command - Only L2 (CB1-TESTtrip L2)	Testing	OUT	ON OFF	*		*	LED			BO		153	26	1	Yes
7327	CB1-TEST TRIP command - Only L3 (CB1-TESTtrip L3)	Testing	OUT	ON OFF	*		*	LED			BO		153	27	1	Yes
7328	CB1-TEST TRIP command L123 (CB1-TESTtrip123)	Testing	OUT	ON OFF	*		*	LED			BO		153	28	1	Yes
7329	CB1-TEST CLOSE command (CB1-TEST close)	Testing	OUT	ON OFF	*		*	LED			BO		153	29	1	Yes
7345	CB-TEST is in progress (CB-TEST running)	Testing	OUT	ON OFF	*		*	LED			BO		153	45	1	Yes
7346	CB-TEST canceled due to Power Sys. Fault (CB-TSTstop FLT.)	Testing	OUT_Ev	ON	*											
7347	CB-TEST canceled due to CB already OPEN (CB-TSTstop OPEN)	Testing	OUT_Ev	ON	*											
7348	CB-TEST canceled due to CB was NOT READY (CB-TSTstop NOTr)	Testing	OUT_Ev	ON	*											
7349	CB-TEST canceled due to CB stayed CLOSED (CB-TSTstop CLOS)	Testing	OUT_Ev	ON	*											
7350	CB-TEST was successful (CB-TST .OK.)	Testing	OUT_Ev	ON	*											
10201	>BLOCK Uph-e>(>) Overvolt. (phase-earth) (>Uph-e>) BLK)	Voltage Prot.	SP	*	*		*	LED	BI		BO					
10202	>BLOCK Uph-ph>(>) Overvolt (phase-phase) (>Uph-ph>) BLK)	Voltage Prot.	SP	*	*		*	LED	BI		BO					
10203	>BLOCK 3U0>(>) Overvolt. (zero sequence) (>3U0>) BLK)	Voltage Prot.	SP	*	*		*	LED	BI		BO					
10204	>BLOCK U1>(>) Overvolt. (positive seq.) (>U1>) BLK)	Voltage Prot.	SP	*	*		*	LED	BI		BO					

No.	Description	Function	Type of Information	Log Buffers				Configurable in Matrix					IEC 60870-5-103			
				Event Log ON/OFF	Trip (Fault) Log ON/OFF	Ground Fault Log ON/OFF	Marked in Oscill. Record	LED	Binary Input	Function Key	Relay	Chatter Suppression	Type	Information Number	Data Unit	General Interrogation
10205	>BLOCK U2>(>) Overvolt. (negative seq.) (>U2>(>) BLK)	Voltage Prot.	SP	*	*		*	LED	BI		BO					
10206	>BLOCK Uph-e<(<) Undervolt (phase-earth) (>Uph-e<(<) BLK)	Voltage Prot.	SP	*	*		*	LED	BI		BO					
10207	>BLOCK Uphph<(<) Undervolt (phase-phase) (>Uphph<(<) BLK)	Voltage Prot.	SP	*	*		*	LED	BI		BO					
10208	>BLOCK U1<(<) Undervolt (positive seq.) (>U1<(<) BLK)	Voltage Prot.	SP	*	*		*	LED	BI		BO					
10215	Uph-e>(>) Overvolt. is switched OFF (Uph-e>(>) OFF)	Voltage Prot.	OUT	ON OFF	*		*	LED			BO		73	15	1	Yes
10216	Uph-e>(>) Overvolt. is BLOCKED (Uph-e>(>) BLK)	Voltage Prot.	OUT	ON OFF	ON OFF		*	LED			BO		73	16	1	Yes
10217	Uph-ph>(>) Overvolt. is switched OFF (Uph-ph>(>) OFF)	Voltage Prot.	OUT	ON OFF	*		*	LED			BO		73	17	1	Yes
10218	Uph-ph>(>) Overvolt. is BLOCKED (Uph-ph>(>) BLK)	Voltage Prot.	OUT	ON OFF	ON OFF		*	LED			BO		73	18	1	Yes
10219	3U0>(>) Overvolt. is switched OFF (3U0>(>) OFF)	Voltage Prot.	OUT	ON OFF	*		*	LED			BO		73	19	1	Yes
10220	3U0>(>) Overvolt. is BLOCKED (3U0>(>) BLK)	Voltage Prot.	OUT	ON OFF	ON OFF		*	LED			BO		73	20	1	Yes
10221	U1>(>) Overvolt. is switched OFF (U1>(>) OFF)	Voltage Prot.	OUT	ON OFF	*		*	LED			BO		73	21	1	Yes
10222	U1>(>) Overvolt. is BLOCKED (U1>(>) BLK)	Voltage Prot.	OUT	ON OFF	ON OFF		*	LED			BO		73	22	1	Yes
10223	U2>(>) Overvolt. is switched OFF (U2>(>) OFF)	Voltage Prot.	OUT	ON OFF	*		*	LED			BO		73	23	1	Yes
10224	U2>(>) Overvolt. is BLOCKED (U2>(>) BLK)	Voltage Prot.	OUT	ON OFF	ON OFF		*	LED			BO		73	24	1	Yes
10225	Uph-e<(<) Undervolt. is switched OFF (Uph-e<(<) OFF)	Voltage Prot.	OUT	ON OFF	*		*	LED			BO		73	25	1	Yes
10226	Uph-e<(<) Undervolt. is BLOCKED (Uph-e<(<) BLK)	Voltage Prot.	OUT	ON OFF	ON OFF		*	LED			BO		73	26	1	Yes
10227	Uph-ph<(<) Undervolt. is switched OFF (Uph-ph<(<) OFF)	Voltage Prot.	OUT	ON OFF	*		*	LED			BO		73	27	1	Yes
10228	Uphph<(<) Undervolt. is BLOCKED (Uphph<(<) BLK)	Voltage Prot.	OUT	ON OFF	ON OFF		*	LED			BO		73	28	1	Yes
10229	U1<(<) Undervolt. is switched OFF (U1<(<) OFF)	Voltage Prot.	OUT	ON OFF	*		*	LED			BO		73	29	1	Yes
10230	U1<(<) Undervolt. is BLOCKED (U1<(<) BLK)	Voltage Prot.	OUT	ON OFF	ON OFF		*	LED			BO		73	30	1	Yes
10231	Over-/Under-Voltage protection is ACTIVE (U</> ACTIVE)	Voltage Prot.	OUT	ON OFF	*		*	LED			BO		73	31	1	Yes
10240	Uph-e> Pickup (Uph-e> Pickup)	Voltage Prot.	OUT	*	ON OFF		*	LED			BO		73	40	2	Yes
10241	Uph-e>> Pickup (Uph-e>> Pickup)	Voltage Prot.	OUT	*	ON OFF		*	LED			BO		73	41	2	Yes
10242	Uph-e>(>) Pickup L1 (Uph-e>(>) PU L1)	Voltage Prot.	OUT	*	ON OFF		*	LED			BO		73	42	2	Yes
10243	Uph-e>(>) Pickup L2 (Uph-e>(>) PU L2)	Voltage Prot.	OUT	*	ON OFF		*	LED			BO		73	43	2	Yes
10244	Uph-e>(>) Pickup L3 (Uph-e>(>) PU L3)	Voltage Prot.	OUT	*	ON OFF		*	LED			BO		73	44	2	Yes
10245	Uph-e> TimeOut (Uph-e> Time-Out)	Voltage Prot.	OUT	*	*		*	LED			BO					

No.	Description	Function	Type of Information	Log Buffers				Configurable in Matrix					IEC 60870-5-103			
				Event Log ON/OFF	Trip (Fault) Log ON/OFF	Ground Fault Log ON/OFF	Marked in Oscill. Record	LED	Binary Input	Function Key	Relay	Chatter Suppression	Type	Information Number	Data Unit	General Interrogation
10246	Uph-e>> TimeOut (Uph-e>> TimeOut)	Voltage Prot.	OUT	*	*		*	LED			BO					
10247	Uph-e>(>) TRIP command (Uph-e>(>) TRIP)	Voltage Prot.	OUT	*	ON		*	LED			BO		73	47	2	Yes
10255	Uph-ph> Pickup (Uphph> Pickup)	Voltage Prot.	OUT	*	ON OFF		*	LED			BO		73	55	2	Yes
10256	Uph-ph>> Pickup (Uphph>> Pickup)	Voltage Prot.	OUT	*	ON OFF		*	LED			BO		73	56	2	Yes
10257	Uph-ph>(>) Pickup L1-L2 (Uph-ph>(>)PU L12)	Voltage Prot.	OUT	*	ON OFF		*	LED			BO		73	57	2	Yes
10258	Uph-ph>(>) Pickup L2-L3 (Uph-ph>(>)PU L23)	Voltage Prot.	OUT	*	ON OFF		*	LED			BO		73	58	2	Yes
10259	Uph-ph>(>) Pickup L3-L1 (Uph-ph>(>)PU L31)	Voltage Prot.	OUT	*	ON OFF		*	LED			BO		73	59	2	Yes
10260	Uph-ph> TimeOut (Uphph> TimeOut)	Voltage Prot.	OUT	*	*		*	LED			BO					
10261	Uph-ph>> TimeOut (Uphph>> TimeOut)	Voltage Prot.	OUT	*	*		*	LED			BO					
10262	Uph-ph>(>) TRIP command (Uphph>(>) TRIP)	Voltage Prot.	OUT	*	ON		*	LED			BO		73	62	2	Yes
10270	3U0> Pickup (3U0> Pickup)	Voltage Prot.	OUT	*	ON OFF		*	LED			BO		73	70	2	Yes
10271	3U0>> Pickup (3U0>> Pickup)	Voltage Prot.	OUT	*	ON OFF		*	LED			BO		73	71	2	Yes
10272	3U0> TimeOut (3U0> TimeOut)	Voltage Prot.	OUT	*	*		*	LED			BO					
10273	3U0>> TimeOut (3U0>> TimeOut)	Voltage Prot.	OUT	*	*		*	LED			BO					
10274	3U0>(>) TRIP command (3U0>(>) TRIP)	Voltage Prot.	OUT	*	ON		*	LED			BO		73	74	2	Yes
10280	U1> Pickup (U1> Pickup)	Voltage Prot.	OUT	*	ON OFF		*	LED			BO		73	80	2	Yes
10281	U1>> Pickup (U1>> Pickup)	Voltage Prot.	OUT	*	ON OFF		*	LED			BO		73	81	2	Yes
10282	U1> TimeOut (U1> TimeOut)	Voltage Prot.	OUT	*	*		*	LED			BO					
10283	U1>> TimeOut (U1>> TimeOut)	Voltage Prot.	OUT	*	*		*	LED			BO					
10284	U1>(>) TRIP command (U1>(>) TRIP)	Voltage Prot.	OUT	*	ON		*	LED			BO		73	84	2	Yes
10290	U2> Pickup (U2> Pickup)	Voltage Prot.	OUT	*	ON OFF		*	LED			BO		73	90	2	Yes
10291	U2>> Pickup (U2>> Pickup)	Voltage Prot.	OUT	*	ON OFF		*	LED			BO		73	91	2	Yes
10292	U2> TimeOut (U2> TimeOut)	Voltage Prot.	OUT	*	*		*	LED			BO					
10293	U2>> TimeOut (U2>> TimeOut)	Voltage Prot.	OUT	*	*		*	LED			BO					
10294	U2>(>) TRIP command (U2>(>) TRIP)	Voltage Prot.	OUT	*	ON		*	LED			BO		73	94	2	Yes
10300	U1< Pickup (U1< Pickup)	Voltage Prot.	OUT	*	ON OFF		*	LED			BO		73	100	2	Yes
10301	U1<< Pickup (U1<< Pickup)	Voltage Prot.	OUT	*	ON OFF		*	LED			BO		73	101	2	Yes
10302	U1< TimeOut (U1< TimeOut)	Voltage Prot.	OUT	*	*		*	LED			BO					
10303	U1<< TimeOut (U1<< TimeOut)	Voltage Prot.	OUT	*	*		*	LED			BO					
10304	U1<(<) TRIP command (U1<(<) TRIP)	Voltage Prot.	OUT	*	ON		*	LED			BO		73	104	2	Yes
10310	Uph-e< Pickup (Uph-e< Pickup)	Voltage Prot.	OUT	*	ON OFF		*	LED			BO		73	110	2	Yes

No.	Description	Function	Type of Information	Log Buffers				Configurable in Matrix					IEC 60870-5-103			
				Event Log ON/OFF	Trip (Fault) Log ON/OFF	Ground Fault Log ON/OFF	Marked in Oscill. Record	LED	Binary Input	Function Key	Relay	Chatter Suppression	Type	Information Number	Data Unit	General Interrogation
10311	Uph-e<< Pickup (Uph-e<< Pickup)	Voltage Prot.	OUT	*	ON OFF		*	LED			BO		73	111	2	Yes
10312	Uph-e<(<) Pickup L1 (Uph-e<(<) PU L1)	Voltage Prot.	OUT	*	ON OFF		*	LED			BO		73	112	2	Yes
10313	Uph-e<(<) Pickup L2 (Uph-e<(<) PU L2)	Voltage Prot.	OUT	*	ON OFF		*	LED			BO		73	113	2	Yes
10314	Uph-e<(<) Pickup L3 (Uph-e<(<) PU L3)	Voltage Prot.	OUT	*	ON OFF		*	LED			BO		73	114	2	Yes
10315	Uph-e< TimeOut (Uph-e< Time-Out)	Voltage Prot.	OUT	*	*		*	LED			BO					
10316	Uph-e<< TimeOut (Uph-e<< Time-Out)	Voltage Prot.	OUT	*	*		*	LED			BO					
10317	Uph-e<(<) TRIP command (Uph-e<(<) TRIP)	Voltage Prot.	OUT	*	ON		*	LED			BO		73	117	2	Yes
10325	Uph-ph< Pickup (Uph-ph< Pickup)	Voltage Prot.	OUT	*	ON OFF		*	LED			BO		73	125	2	Yes
10326	Uph-ph<< Pickup (Uph-ph<< Pickup)	Voltage Prot.	OUT	*	ON OFF		*	LED			BO		73	126	2	Yes
10327	Uphph<(<) Pickup L1-L2 (Uph-ph<(<) PU L12)	Voltage Prot.	OUT	*	ON OFF		*	LED			BO		73	127	2	Yes
10328	Uphph<(<) Pickup L2-L3 (Uph-ph<(<) PU L23)	Voltage Prot.	OUT	*	ON OFF		*	LED			BO		73	128	2	Yes
10329	Uphph<(<) Pickup L3-L1 (Uph-ph<(<) PU L31)	Voltage Prot.	OUT	*	ON OFF		*	LED			BO		73	129	2	Yes
10330	Uphph< TimeOut (Uphph< Time-Out)	Voltage Prot.	OUT	*	*		*	LED			BO					
10331	Uphph<< TimeOut (Uphph<< TimeOut)	Voltage Prot.	OUT	*	*		*	LED			BO					
10332	Uphph<(<) TRIP command (Uph-ph<(<) TRIP)	Voltage Prot.	OUT	*	ON		*	LED			BO		73	132	2	Yes

A.9 Group Alarms

No.	Description	Function No.	Description
140	Error Sum Alarm	144 181 192 194	Error 5V Error A/D-conv. Error 1A/5A wrong Error neutral CT
160	Alarm Sum Event	289 163 165 167 168 169 170 171 177 183 184 185 186 187 188 189 190 191 193 361	Failure Σ i Fail I balance Fail Σ U Ph-E Fail U balance Fail U absent VT Fuse Fail >10s VT Fuse Fail Fail Ph. Seq. Fail Battery Error Board 1 Error Board 2 Error Board 3 Error Board 4 Error Board 5 Error Board 6 Error Board 7 Error Board 0 Error Offset Alarm adjustm. >FAIL:Feeder VT
161	Fail I Superv.	289 163	Failure Σ i Fail I balance
164	Fail U Superv.	165 167 168	Fail Σ U Ph-E Fail U balance Fail U absent

A.10 Measured Values

No.	Description	Function	IEC 60870-5-103					Configurable in Matrix		
			Type	Information Number	Compatibility	Data Unit	Position	CFC	Control Display	Default Display
-	Upper setting limit for IL1dmd (IL1dmd>)	Set Points(MV)	-	-	-	-	-	CFC	CD	DD
-	Upper setting limit for IL2dmd (IL2dmd>)	Set Points(MV)	-	-	-	-	-	CFC	CD	DD
-	Upper setting limit for IL3dmd (IL3dmd>)	Set Points(MV)	-	-	-	-	-	CFC	CD	DD
-	Upper setting limit for I1dmd (I1dmd>)	Set Points(MV)	-	-	-	-	-	CFC	CD	DD
-	Upper setting limit for Pdmd (Pdmd >)	Set Points(MV)	-	-	-	-	-	CFC	CD	DD
-	Upper setting limit for Qdmd (Qdmd >)	Set Points(MV)	-	-	-	-	-	CFC	CD	DD
-	Upper setting limit for Sdmd (Sdmd>)	Set Points(MV)	-	-	-	-	-	CFC	CD	DD
-	Lower setting limit for Power Factor (PF<)	Set Points(MV)	-	-	-	-	-	CFC	CD	DD
601	I L1 (IL1 =)	Measurement	134	129	No	9	1	CFC	CD	DD
602	I L2 (IL2 =)	Measurement	134	129	No	9	2	CFC	CD	DD
603	I L3 (IL3 =)	Measurement	134	129	No	9	3	CFC	CD	DD
610	3I0 (zero sequence) (3I0 =)	Measurement	-	-	-	-	-	CFC	CD	DD
611	3I0sen (sensitive zero sequence) (3I0sen=)	Measurement	-	-	-	-	-	CFC	CD	DD
612	IY (star point of transformer) (IY =)	Measurement	-	-	-	-	-	CFC	CD	DD
613	3I0par (parallel line neutral) (3I0par=)	Measurement	-	-	-	-	-	CFC	CD	DD
619	I1 (positive sequence) (I1 =)	Measurement	-	-	-	-	-	CFC	CD	DD
620	I2 (negative sequence) (I2 =)	Measurement	-	-	-	-	-	CFC	CD	DD
621	U L1-E (UL1E=)	Measurement	134	129	No	9	4	CFC	CD	DD
622	U L2-E (UL2E=)	Measurement	134	129	No	9	5	CFC	CD	DD
623	U L3-E (UL3E=)	Measurement	134	129	No	9	6	CFC	CD	DD
624	U L12 (UL12=)	Measurement	134	129	No	9	10	CFC	CD	DD
625	U L23 (UL23=)	Measurement	134	129	No	9	11	CFC	CD	DD
626	U L31 (UL31=)	Measurement	134	129	No	9	12	CFC	CD	DD
627	Uen (Uen =)	Measurement	-	-	-	-	-	CFC	CD	DD
631	3U0 (zero sequence) (3U0 =)	Measurement	-	-	-	-	-	CFC	CD	DD
632	Usync (synchronism) (Usync =)	Measurement	-	-	-	-	-	CFC	CD	DD
633	Ux (separate VT) (Ux =)	Measurement	-	-	-	-	-	CFC	CD	DD
634	U1 (positive sequence) (U1 =)	Measurement	-	-	-	-	-	CFC	CD	DD
635	U2 (negative sequence) (U2 =)	Measurement	-	-	-	-	-	CFC	CD	DD
636	U-diff (line-bus) (Udiff =)	Measurement	130	1	No	9	2	CFC	CD	DD
637	U-line (Uline =)	Measurement	130	1	No	9	3	CFC	CD	DD
638	U-bus (Ubus =)	Measurement	130	1	No	9	1	CFC	CD	DD
641	P (active power) (P =)	Measurement	134	129	No	9	7	CFC	CD	DD
642	Q (reactive power) (Q =)	Measurement	134	129	No	9	8	CFC	CD	DD
643	Power Factor (PF =)	Measurement	-	-	-	-	-	CFC	CD	DD
644	Frequency (Freq=)	Measurement	134	129	No	9	9	CFC	CD	DD
645	S (apparent power) (S =)	Measurement	-	-	-	-	-	CFC	CD	DD
646	Frequency (busbar) (F-bus =)	Measurement	130	1	No	9	4	CFC	CD	DD
647	Frequency (difference line-bus) (F-diff=)	Measurement	130	1	No	9	5	CFC	CD	DD
648	Angle (difference line-bus) (ϕ -diff=)	Measurement	130	1	No	9	6	CFC	CD	DD
649	Frequency (line) (F-line=)	Measurement	130	1	No	9	7	CFC	CD	DD
679	U1co (positive sequence, compounding) (U1co=)	Measurement	-	-	-	-	-	CFC	CD	DD
684	U0 (zero sequence) (U0 =)	Measurement	-	-	-	-	-	CFC	CD	DD

No.	Description	Function	IEC 60870-5-103					Configurable in Matrix		
			Type	Information Number	Compatibility	Data Unit	Position	CFC	Control Display	Default Display
801	Temperat. rise for warning and trip (Θ/Θ_{trip} =)	Measurement	-	-	-	-	-	CFC	CD	DD
802	Temperature rise for phase L1 (Θ/Θ_{tripL1} =)	Measurement	-	-	-	-	-	CFC	CD	DD
803	Temperature rise for phase L2 (Θ/Θ_{tripL2} =)	Measurement	-	-	-	-	-	CFC	CD	DD
804	Temperature rise for phase L3 (Θ/Θ_{tripL3} =)	Measurement	-	-	-	-	-	CFC	CD	DD
833	I1 (positive sequence) Demand (I1dmd =)	Demand meter	-	-	-	-	-	CFC	CD	DD
834	Active Power Demand (Pdmd =)	Demand meter	-	-	-	-	-	CFC	CD	DD
835	Reactive Power Demand (Qdmd =)	Demand meter	-	-	-	-	-	CFC	CD	DD
836	Apparent Power Demand (Sdmd =)	Demand meter	-	-	-	-	-	CFC	CD	DD
837	I L1 Demand Minimum (IL1d Min)	Min/Max meter	-	-	-	-	-	CFC	CD	DD
838	I L1 Demand Maximum (IL1d Max)	Min/Max meter	-	-	-	-	-	CFC	CD	DD
839	I L2 Demand Minimum (IL2d Min)	Min/Max meter	-	-	-	-	-	CFC	CD	DD
840	I L2 Demand Maximum (IL2d Max)	Min/Max meter	-	-	-	-	-	CFC	CD	DD
841	I L3 Demand Minimum (IL3d Min)	Min/Max meter	-	-	-	-	-	CFC	CD	DD
842	I L3 Demand Maximum (IL3d Max)	Min/Max meter	-	-	-	-	-	CFC	CD	DD
843	I1 (positive sequence) Demand Minimum (I1dmdMin)	Min/Max meter	-	-	-	-	-	CFC	CD	DD
844	I1 (positive sequence) Demand Maximum (I1dmdMax)	Min/Max meter	-	-	-	-	-	CFC	CD	DD
845	Active Power Demand Minimum (PdMin=)	Min/Max meter	-	-	-	-	-	CFC	CD	DD
846	Active Power Demand Maximum (PdMax=)	Min/Max meter	-	-	-	-	-	CFC	CD	DD
847	Reactive Power Demand Minimum (QdMin=)	Min/Max meter	-	-	-	-	-	CFC	CD	DD
848	Reactive Power Demand Maximum (QdMax=)	Min/Max meter	-	-	-	-	-	CFC	CD	DD
849	Apparent Power Demand Minimum (SdMin=)	Min/Max meter	-	-	-	-	-	CFC	CD	DD
850	Apparent Power Demand Maximum (SdMax=)	Min/Max meter	-	-	-	-	-	CFC	CD	DD
851	I L1 Minimum (IL1Min=)	Min/Max meter	-	-	-	-	-	CFC	CD	DD
852	I L1 Maximum (IL1Max=)	Min/Max meter	-	-	-	-	-	CFC	CD	DD
853	I L2 Minimum (IL2Min=)	Min/Max meter	-	-	-	-	-	CFC	CD	DD
854	I L2 Maximum (IL2Max=)	Min/Max meter	-	-	-	-	-	CFC	CD	DD
855	I L3 Minimum (IL3Min=)	Min/Max meter	-	-	-	-	-	CFC	CD	DD
856	I L3 Maximum (IL3Max=)	Min/Max meter	-	-	-	-	-	CFC	CD	DD
857	Positive Sequence Minimum (I1 Min=)	Min/Max meter	-	-	-	-	-	CFC	CD	DD
858	Positive Sequence Maximum (I1 Max=)	Min/Max meter	-	-	-	-	-	CFC	CD	DD
859	U L1E Minimum (UL1EMin=)	Min/Max meter	-	-	-	-	-	CFC	CD	DD
860	U L1E Maximum (UL1EMax=)	Min/Max meter	-	-	-	-	-	CFC	CD	DD
861	U L2E Minimum (UL2EMin=)	Min/Max meter	-	-	-	-	-	CFC	CD	DD
862	U L2E Maximum (UL2EMax=)	Min/Max meter	-	-	-	-	-	CFC	CD	DD
863	U L3E Minimum (UL3EMin=)	Min/Max meter	-	-	-	-	-	CFC	CD	DD
864	U L3E Maximum (UL3EMax=)	Min/Max meter	-	-	-	-	-	CFC	CD	DD
865	U L12 Minimum (UL12Min=)	Min/Max meter	-	-	-	-	-	CFC	CD	DD
867	U L12 Maximum (UL12Max=)	Min/Max meter	-	-	-	-	-	CFC	CD	DD
868	U L23 Minimum (UL23Min=)	Min/Max meter	-	-	-	-	-	CFC	CD	DD
869	U L23 Maximum (UL23Max=)	Min/Max meter	-	-	-	-	-	CFC	CD	DD
870	U L31 Minimum (UL31Min=)	Min/Max meter	-	-	-	-	-	CFC	CD	DD
871	U L31 Maximum (UL31Max=)	Min/Max meter	-	-	-	-	-	CFC	CD	DD
874	U1 (positive sequence) Voltage Minimum (U1 Min =)	Min/Max meter	-	-	-	-	-	CFC	CD	DD
875	U1 (positive sequence) Voltage Maximum (U1 Max =)	Min/Max meter	-	-	-	-	-	CFC	CD	DD

No.	Description	Function	IEC 60870-5-103					Configurable in Matrix		
			Type	Information Number	Compatibility	Data Unit	Position	CFC	Control Display	Default Display
880	Apparent Power Minimum (SMin=)	Min/Max meter	-	-	-	-	-	CFC	CD	DD
881	Apparent Power Maximum (SMax=)	Min/Max meter	-	-	-	-	-	CFC	CD	DD
882	Frequency Minimum (fMin=)	Min/Max meter	-	-	-	-	-	CFC	CD	DD
883	Frequency Maximum (fMax=)	Min/Max meter	-	-	-	-	-	CFC	CD	DD
888	Pulsed Energy Wp (active) (Wp(puls))	Energy	133	55	No	205	-		CD	DD
889	Pulsed Energy Wq (reactive) (Wq(puls))	Energy	133	56	No	205	-		CD	DD
924	Wp Forward (Wp+=)	Energy	133	51	No	205	-		CD	DD
925	Wq Forward (Wq+=)	Energy	133	52	No	205	-		CD	DD
928	Wp Reverse (Wp-=)	Energy	133	53	No	205	-		CD	DD
929	Wq Reverse (Wq-=)	Energy	133	54	No	205	-		CD	DD
963	I L1 demand (IL1dmd=)	Demand meter	-	-	-	-	-	CFC	CD	DD
964	I L2 demand (IL2dmd=)	Demand meter	-	-	-	-	-	CFC	CD	DD
965	I L3 demand (IL3dmd=)	Demand meter	-	-	-	-	-	CFC	CD	DD
966	R L1E (R L1E=)	Measurement	-	-	-	-	-	CFC	CD	DD
967	R L2E (R L2E=)	Measurement	-	-	-	-	-	CFC	CD	DD
970	R L3E (R L3E=)	Measurement	-	-	-	-	-	CFC	CD	DD
971	R L12 (R L12=)	Measurement	-	-	-	-	-	CFC	CD	DD
972	R L23 (R L23=)	Measurement	-	-	-	-	-	CFC	CD	DD
973	R L31 (R L31=)	Measurement	-	-	-	-	-	CFC	CD	DD
974	X L1E (X L1E=)	Measurement	-	-	-	-	-	CFC	CD	DD
975	X L2E (X L2E=)	Measurement	-	-	-	-	-	CFC	CD	DD
976	X L3E (X L3E=)	Measurement	-	-	-	-	-	CFC	CD	DD
977	X L12 (X L12=)	Measurement	-	-	-	-	-	CFC	CD	DD
978	X L23 (X L23=)	Measurement	-	-	-	-	-	CFC	CD	DD
979	X L31 (X L31=)	Measurement	-	-	-	-	-	CFC	CD	DD
1040	Active Power Minimum Forward (Pmin Forw=)	Min/Max meter	-	-	-	-	-	CFC	CD	DD
1041	Active Power Maximum Forward (Pmax Forw=)	Min/Max meter	-	-	-	-	-	CFC	CD	DD
1042	Active Power Minimum Reverse (Pmin Rev=)	Min/Max meter	-	-	-	-	-	CFC	CD	DD
1043	Active Power Maximum Reverse (Pmax Rev=)	Min/Max meter	-	-	-	-	-	CFC	CD	DD
1044	Reactive Power Minimum Forward (Qmin Forw=)	Min/Max meter	-	-	-	-	-	CFC	CD	DD
1045	Reactive Power Maximum Forward (Qmax Forw=)	Min/Max meter	-	-	-	-	-	CFC	CD	DD
1046	Reactive Power Minimum Reverse (Qmin Rev=)	Min/Max meter	-	-	-	-	-	CFC	CD	DD
1047	Reactive Power Maximum Reverse (Qmax Rev=)	Min/Max meter	-	-	-	-	-	CFC	CD	DD
1048	Power Factor Minimum Forward (PFmin-Forw=)	Min/Max meter	-	-	-	-	-	CFC	CD	DD
1049	Power Factor Maximum Forward (PFmax-Forw=)	Min/Max meter	-	-	-	-	-	CFC	CD	DD
1050	Power Factor Minimum Reverse (PFmin Rev=)	Min/Max meter	-	-	-	-	-	CFC	CD	DD
1051	Power Factor Maximum Reverse (PFmax Rev=)	Min/Max meter	-	-	-	-	-	CFC	CD	DD
1052	Active Power Demand Forward (Pdmd Forw=)	Demand meter	-	-	-	-	-	CFC	CD	DD
1053	Active Power Demand Reverse (Pdmd Rev=)	Demand meter	-	-	-	-	-	CFC	CD	DD

No.	Description	Function	IEC 60870-5-103					Configurable in Matrix		
			Type	Information Number	Compatibility	Data Unit	Position	CFC	Control Display	Default Display
1054	Reactive Power Demand Forward (Qdmd Forw=)	Demand meter	-	-	-	-	-	CFC	CD	DD
1055	Reactive Power Demand Reverse (Qdmd Rev =)	Demand meter	-	-	-	-	-	CFC	CD	DD
7731	PHI IL1L2 (local) (Φ IL1L2=)	Measurement	-	-	-	-	-	CFC	CD	DD
7732	PHI IL2L3 (local) (Φ IL2L3=)	Measurement	-	-	-	-	-	CFC	CD	DD
7733	PHI IL3L1 (local) (Φ IL3L1=)	Measurement	-	-	-	-	-	CFC	CD	DD
7734	PHI UL1L2 (local) (Φ UL1L2=)	Measurement	-	-	-	-	-	CFC	CD	DD
7735	PHI UL2L3 (local) (Φ UL2L3=)	Measurement	-	-	-	-	-	CFC	CD	DD
7736	PHI UL3L1 (local) (Φ UL3L1=)	Measurement	-	-	-	-	-	CFC	CD	DD
7737	PHI UIL1 (local) (Φ UIL1=)	Measurement	-	-	-	-	-	CFC	CD	DD
7738	PHI UIL2 (local) (Φ UIL2=)	Measurement	-	-	-	-	-	CFC	CD	DD
7739	PHI UIL3 (local) (Φ UIL3=)	Measurement	-	-	-	-	-	CFC	CD	DD
7742	IDiffL1(% Operational nominal current) (IDiffL1=)	IDiff/IRest	134	122	No	9	1	CFC	CD	DD
7743	IDiffL2(% Operational nominal current) (IDiffL2=)	IDiff/IRest	134	122	No	9	2	CFC	CD	DD
7744	IDiffL3(% Operational nominal current) (IDiffL3=)	IDiff/IRest	134	122	No	9	3	CFC	CD	DD
7745	IRestL1(% Operational nominal current) (IRestL1=)	IDiff/IRest	134	122	No	9	4	CFC	CD	DD
7746	IRestL2(% Operational nominal current) (IRestL2=)	IDiff/IRest	134	122	No	9	5	CFC	CD	DD
7747	IRestL3(% Operational nominal current) (IRestL3=)	IDiff/IRest	134	122	No	9	6	CFC	CD	DD
7748	Diff3I0 (Differential current 3I0) (Diff3I0=)	IDiff/IRest	-	-	-	-	-	CFC	CD	DD
7751	Prot.Interface 1:Transmission delay (PI1 TD)	Statistics	134	122	No	9	7	CFC	CD	DD
7752	Prot.Interface 2:Transmission delay (PI2 TD)	Statistics	134	122	No	9	9	CFC	CD	DD
7753	Prot.Interface 1: Availability per min. (PI1A/m)	Statistics	-	-	-	-	-	CFC	CD	DD
7754	Prot.Interface 1: Availability per hour (PI1A/h)	Statistics	134	122	No	9	8	CFC	CD	DD
			134	121	No	9	3			
7755	Prot.Interface 2: Availability per min. (PI2A/m)	Statistics	-	-	-	-	-	CFC	CD	DD
7756	Prot.Interface 2: Availability per hour (PI2A/h)	Statistics	134	122	No	9	10	CFC	CD	DD
			134	121	No	9	6			
7761	Relay ID of 1. relay (Relay ID)	Measure relay1	-	-	-	-	-	CFC	CD	DD
7762	IL1(% of Operational nominal current) (IL1_opN=)	Measure relay1	-	-	-	-	-	CFC	CD	DD
7763	Angle IL1_rem <-> IL1_loc (Φ L1=)	Measure relay1	-	-	-	-	-	CFC	CD	DD
7764	IL2(% of Operational nominal current) (IL2_opN=)	Measure relay1	-	-	-	-	-	CFC	CD	DD
7765	Angle IL2_rem <-> IL2_loc (Φ L2=)	Measure relay1	-	-	-	-	-	CFC	CD	DD
7766	IL3(% of Operational nominal current) (IL3_opN=)	Measure relay1	-	-	-	-	-	CFC	CD	DD
7767	Angle IL3_rem <-> IL3_loc (Φ L3=)	Measure relay1	-	-	-	-	-	CFC	CD	DD
7769	UL1(% of Operational nominal voltage) (UL1_opN=)	Measure relay1	-	-	-	-	-	CFC	CD	DD
7770	Angle UL1_rem <-> UL1_loc (Φ U L1=)	Measure relay1	-	-	-	-	-	CFC	CD	DD
7771	UL2(% of Operational nominal voltage) (UL2_opN=)	Measure relay1	-	-	-	-	-	CFC	CD	DD
7772	Angle UL2_rem <-> UL2_loc (Φ U L2=)	Measure relay1	-	-	-	-	-	CFC	CD	DD
7773	UL3(% of Operational nominal voltage) (UL3_opN=)	Measure relay1	-	-	-	-	-	CFC	CD	DD

No.	Description	Function	Type	IEC 60870-5-103				Configurable in Matrix		
				Information Number	Compatibility	Data Unit	Position	CFC	Control Display	Default Display
7774	Angle UL3_rem <-> UL3_loc (ΦU L3=)	Measure relay1	-	-	-	-	-	CFC	CD	DD
7781	Relay ID of 2. relay (Relay ID)	Measure relay2	-	-	-	-	-	CFC	CD	DD
7782	IL1(% of Operational nominal current) (IL1_opN=)	Measure relay2	-	-	-	-	-	CFC	CD	DD
7783	Angle IL1_rem <-> IL1_loc (ΦI L1=)	Measure relay2	-	-	-	-	-	CFC	CD	DD
7784	IL2(% of Operational nominal current) (IL2_opN=)	Measure relay2	-	-	-	-	-	CFC	CD	DD
7785	Angle IL2_rem <-> IL2_loc (ΦI L2=)	Measure relay2	-	-	-	-	-	CFC	CD	DD
7786	IL3(% of Operational nominal current) (IL3_opN=)	Measure relay2	-	-	-	-	-	CFC	CD	DD
7787	Angle IL3_rem <-> IL3_loc (ΦI L3=)	Measure relay2	-	-	-	-	-	CFC	CD	DD
7789	UL1(% of Operational nominal voltage) (UL1_opN=)	Measure relay2	-	-	-	-	-	CFC	CD	DD
7790	Angle UL1_rem <-> UL1_loc (ΦU L1=)	Measure relay2	-	-	-	-	-	CFC	CD	DD
7791	UL2(% of Operational nominal voltage) (UL2_opN=)	Measure relay2	-	-	-	-	-	CFC	CD	DD
7792	Angle UL2_rem <-> UL2_loc (ΦU L2=)	Measure relay2	-	-	-	-	-	CFC	CD	DD
7793	UL3(% of Operational nominal voltage) (UL3_opN=)	Measure relay2	-	-	-	-	-	CFC	CD	DD
7794	Angle UL3_rem <-> UL3_loc (ΦU L3=)	Measure relay2	-	-	-	-	-	CFC	CD	DD
7801	Relay ID of 3. relay (Relay ID)	Measure relay3	-	-	-	-	-	CFC	CD	DD
7802	IL1(% of Operational nominal current) (IL1_opN=)	Measure relay3	-	-	-	-	-	CFC	CD	DD
7803	Angle IL1_rem <-> IL1_loc (ΦI L1=)	Measure relay3	-	-	-	-	-	CFC	CD	DD
7804	IL2(% of Operational nominal current) (IL2_opN=)	Measure relay3	-	-	-	-	-	CFC	CD	DD
7805	Angle IL2_rem <-> IL2_loc (ΦI L2=)	Measure relay3	-	-	-	-	-	CFC	CD	DD
7806	IL3(% of Operational nominal current) (IL3_opN=)	Measure relay3	-	-	-	-	-	CFC	CD	DD
7807	Angle IL3_rem <-> IL3_loc (ΦI L3=)	Measure relay3	-	-	-	-	-	CFC	CD	DD
7809	UL1(% of Operational nominal voltage) (UL1_opN=)	Measure relay3	-	-	-	-	-	CFC	CD	DD
7810	Angle UL1_rem <-> UL1_loc (ΦU L1=)	Measure relay3	-	-	-	-	-	CFC	CD	DD
7811	UL2(% of Operational nominal voltage) (UL2_opN=)	Measure relay3	-	-	-	-	-	CFC	CD	DD
7812	Angle UL2_rem <-> UL2_loc (ΦU L2=)	Measure relay3	-	-	-	-	-	CFC	CD	DD
7813	UL3(% of Operational nominal voltage) (UL3_opN=)	Measure relay3	-	-	-	-	-	CFC	CD	DD
7814	Angle UL3_rem <-> UL3_loc (ΦU L3=)	Measure relay3	-	-	-	-	-	CFC	CD	DD
7821	Relay ID of 4. relay (Relay ID)	Measure relay4	-	-	-	-	-	CFC	CD	DD
7822	IL1(% of Operational nominal current) (IL1_opN=)	Measure relay4	-	-	-	-	-	CFC	CD	DD
7823	Angle IL1_rem <-> IL1_loc (ΦI L1=)	Measure relay4	-	-	-	-	-	CFC	CD	DD
7824	IL2(% of Operational nominal current) (IL2_opN=)	Measure relay4	-	-	-	-	-	CFC	CD	DD
7825	Angle IL2_rem <-> IL2_loc (ΦI L2=)	Measure relay4	-	-	-	-	-	CFC	CD	DD
7826	IL3(% of Operational nominal current) (IL3_opN=)	Measure relay4	-	-	-	-	-	CFC	CD	DD
7827	Angle IL3_rem <-> IL3_loc (ΦI L3=)	Measure relay4	-	-	-	-	-	CFC	CD	DD
7829	UL1(% of Operational nominal voltage) (UL1_opN=)	Measure relay4	-	-	-	-	-	CFC	CD	DD
7830	Angle UL1_rem <-> UL1_loc (ΦU L1=)	Measure relay4	-	-	-	-	-	CFC	CD	DD
7831	UL2(% of Operational nominal voltage) (UL2_opN=)	Measure relay4	-	-	-	-	-	CFC	CD	DD

No.	Description	Function	IEC 60870-5-103					Configurable in Matrix		
			Type	Information Number	Compatibility	Data Unit	Position	CFC	Control Display	Default Display
7832	Angle UL2_rem <-> UL2_loc (ΦU L2=)	Measure relay4	-	-	-	-	-	CFC	CD	DD
7833	UL3(% of Operational nominal voltage) (UL3_opN=)	Measure relay4	-	-	-	-	-	CFC	CD	DD
7834	Angle UL3_rem <-> UL3_loc (ΦU L3=)	Measure relay4	-	-	-	-	-	CFC	CD	DD
7841	Relay ID of 5. relay (Relay ID)	Measure relay5	-	-	-	-	-	CFC	CD	DD
7842	IL1(% of Operational nominal current) (IL1_opN=)	Measure relay5	-	-	-	-	-	CFC	CD	DD
7843	Angle IL1_rem <-> IL1_loc (ΦI L1=)	Measure relay5	-	-	-	-	-	CFC	CD	DD
7844	IL2(% of Operational nominal current) (IL2_opN=)	Measure relay5	-	-	-	-	-	CFC	CD	DD
7845	Angle IL2_rem <-> IL2_loc (ΦI L2=)	Measure relay5	-	-	-	-	-	CFC	CD	DD
7846	IL3(% of Operational nominal current) (IL3_opN=)	Measure relay5	-	-	-	-	-	CFC	CD	DD
7847	Angle IL3_rem <-> IL3_loc (ΦI L3=)	Measure relay5	-	-	-	-	-	CFC	CD	DD
7849	UL1(% of Operational nominal voltage) (UL1_opN=)	Measure relay5	-	-	-	-	-	CFC	CD	DD
7850	Angle UL1_rem <-> UL1_loc (ΦU L1=)	Measure relay5	-	-	-	-	-	CFC	CD	DD
7851	UL2(% of Operational nominal voltage) (UL2_opN=)	Measure relay5	-	-	-	-	-	CFC	CD	DD
7852	Angle UL2_rem <-> UL2_loc (ΦU L2=)	Measure relay5	-	-	-	-	-	CFC	CD	DD
7853	UL3(% of Operational nominal voltage) (UL3_opN=)	Measure relay5	-	-	-	-	-	CFC	CD	DD
7854	Angle UL3_rem <-> UL3_loc (ΦU L3=)	Measure relay5	-	-	-	-	-	CFC	CD	DD
7861	Relay ID of 6. relay (Relay ID)	Measure relay6	-	-	-	-	-	CFC	CD	DD
7862	IL1(% of Operational nominal current) (IL1_opN=)	Measure relay6	-	-	-	-	-	CFC	CD	DD
7863	Angle IL1_rem <-> IL1_loc (ΦI L1=)	Measure relay6	-	-	-	-	-	CFC	CD	DD
7864	IL2(% of Operational nominal current) (IL2_opN=)	Measure relay6	-	-	-	-	-	CFC	CD	DD
7865	Angle IL2_rem <-> IL2_loc (ΦI L2=)	Measure relay6	-	-	-	-	-	CFC	CD	DD
7866	IL3(% of Operational nominal current) (IL3_opN=)	Measure relay6	-	-	-	-	-	CFC	CD	DD
7867	Angle IL3_rem <-> IL3_loc (ΦI L3=)	Measure relay6	-	-	-	-	-	CFC	CD	DD
7869	UL1(% of Operational nominal voltage) (UL1_opN=)	Measure relay6	-	-	-	-	-	CFC	CD	DD
7870	Angle UL1_rem <-> UL1_loc (ΦU L1=)	Measure relay6	-	-	-	-	-	CFC	CD	DD
7871	UL2(% of Operational nominal voltage) (UL2_opN=)	Measure relay6	-	-	-	-	-	CFC	CD	DD
7872	Angle UL2_rem <-> UL2_loc (ΦU L2=)	Measure relay6	-	-	-	-	-	CFC	CD	DD
7873	UL3(% of Operational nominal voltage) (UL3_opN=)	Measure relay6	-	-	-	-	-	CFC	CD	DD
7874	Angle UL3_rem <-> UL3_loc (ΦU L3=)	Measure relay6	-	-	-	-	-	CFC	CD	DD
7875	Prot.Interface 1:Transmission delay rec. (PI1 TD R)	Statistics	134	121	No	9	1	CFC	CD	DD
7876	Prot.Interface 1:Transmission delay send (PI1 TD S)	Statistics	134	121	No	9	2	CFC	CD	DD
7877	Prot.Interface 2:Transmission delay rec. (PI2 TD R)	Statistics	134	121	No	9	4	CFC	CD	DD
7878	Prot.Interface 2:Transmission delay send (PI2 TD S)	Statistics	134	121	No	9	5	CFC	CD	DD
7880	Measured value charging current L1 (Ic L1 =)	IDiff/IRest	-	-	-	-	-	CFC	CD	DD
7881	Measured value charging current L2 (Ic L2 =)	IDiff/IRest	-	-	-	-	-	CFC	CD	DD
7882	Measured value charging current L3 (Ic L3 =)	IDiff/IRest	-	-	-	-	-	CFC	CD	DD

No.	Description	Function	IEC 60870-5-103					Configurable in Matrix		
			Type	Information Number	Compatibility	Data Unit	Position	CFC	Control Display	Default Display
10102	Min. Zero Sequence Voltage 3U0 (3U0min =)	Min/Max meter	-	-	-	-	-	CFC	CD	DD
10103	Max. Zero Sequence Voltage 3U0 (3U0max =)	Min/Max meter	-	-	-	-	-	CFC	CD	DD



Literature

- /1/ SIPROTEC 4 System Description; E50417-H1176-C151-A2
- /2/ SIPROTEC DIGSI, Start Up; E50417-G1176-C152-A2
- /3/ DIGSI CFC, Manual; E50417-H1176-C098-A4
- /4/ SIPROTEC SIGRA 4, Manual; E50417-H1176-C070-A2

www.ElectricalPartManuals.com

Glossary

Battery	The buffer battery ensures that specified data areas, flags, timers and counters are retained retentively.
Bay controllers	Bay controllers are devices with control and monitoring functions without protective functions.
Bit pattern indication	Bit pattern indication is a processing function by means of which items of digital process information applying across several inputs can be detected together in parallel and processed further. The bit pattern length can be specified as 1, 2, 3 or 4 bytes.
BP_xx	→ Bit pattern indication (Bitstring Of x Bit), x designates the length in bits (8, 16, 24 or 32 bits).
C_xx	Command without feedback
CF_xx	Command with feedback
CFC	Continuous Function Chart. CFC is a graphics editor with which a program can be created and configured by using ready-made blocks.
CFC blocks	Blocks are parts of the user program delimited by their function, their structure or their purpose.
Chatter blocking	A rapidly intermittent input (for example, due to a relay contact fault) is switched off after a configurable monitoring time and can thus not generate any further signal changes. The function prevents overloading of the system when a fault arises.
Combination devices	Combination devices are bay devices with protection functions and a control display.
Combination matrix	From DIGSI V4.5 onward, up to 32 compatible SIPROTEC 4 devices can communicate with one another in an Inter Relay Communication combination (IRC combination). Which device exchanges which information is defined with the help of the combination matrix.
Communication branch	A communications branch corresponds to the configuration of 1 to n users which communicate by means of a common bus.
Communication reference CR	The communication reference describes the type and version of a station in communication by PROFIBUS.

Component view	In addition to a topological view, SIMATIC Manager offers you a component view. The component view does not offer any overview of the hierarchy of a project. It does, however, provide an overview of all the SIPROTEC 4 devices within a project.
COMTRADE	Common Format for Transient Data Exchange, format for fault records.
Container	If an object can contain other objects, it is called a container. The object Folder is an example of such a container.
Control display	The display which is displayed on devices with a large (graphic) display after you have pressed the control key is called the control display. It contains the switchgear that can be controlled in the feeder with status display. It is used to perform switching operations. Defining this display is part of the configuration.
Data pane	→ The right-hand area of the project window displays the contents of the area selected in the → navigation window, for example indications, measured values, etc. of the information lists or the function selection for the device configuration.
DCF77	The extremely precise official time is determined in Germany by the "Physikalisch-Technischen-Bundesanstalt PTB" in Braunschweig. The atomic clock unit of the PTB transmits this time via the long-wave time-signal transmitter in Mainflingen near Frankfurt/Main. The emitted time signal can be received within a radius of approx. 1,500 km from Frankfurt/Main.
Device container	In the Component View, all SIPROTEC 4 devices are assigned to an object of type Device container. This object is a special object of DIGSI Manager. However, since there is no component view in DIGSI Manager, this object only becomes visible in conjunction with STEP 7.
Double command	Double commands are process outputs which indicate 4 process states at 2 outputs: 2 defined (for example ON/OFF) and 2 undefined states (for example intermediate positions)
Double-point indication	Double-point indications are items of process information which indicate 4 process states at 2 inputs: 2 defined (for example ON/OFF) and 2 undefined states (for example intermediate positions).
DP	→ Double-point indication
DP_I	→ Double point indication, intermediate position 00
Drag-and-drop	Copying, moving and linking function, used at graphics user interfaces. Objects are selected with the mouse, held and moved from one data area to another.
Earth	The conductive earth whose electric potential can be set equal to zero at every point. In the area of earth electrodes the earth can have a potential deviating from zero. The term "Earth reference plane" is often used for this state.

Earth (verb)	This term means that a conductive part is connected via an earthing system to the → earth.
Earthing	Earthing is the total of all means and measures used for earthing.
Electromagnetic compatibility	Electromagnetic compatibility (EMC) is the ability of an electrical apparatus to function fault-free in a specified environment without influencing the environment unduly.
EMC	→ Electromagnetic compatibility
ESD protection	ESD protection is the total of all the means and measures used to protect electrostatic sensitive devices.
ExBPxx	External bit pattern indication via an ETHERNET connection, device-specific → Bit pattern indication
ExC	External command without feedback via an ETHERNET connection, device-specific
ExCF	External command with feedback via an ETHERNET connection, device-specific
ExDP	External double point indication via an ETHERNET connection, device-specific → Double-point indication
ExDP_I	External double point indication via an ETHERNET connection, intermediate position 00, device-specific → Double-point indication
ExMV	External metered value via an ETHERNET connection, device-specific
ExSI	External single point indication via an ETHERNET connection, device-specific → Single point indication
ExSI_F	External single point indication via an ETHERNET connection, device-specific → Transient information, → Single point indication
Field devices	Generic term for all devices assigned to the field level: Protection devices, combination devices, bay controllers.
Floating	→ Without electrical connection to the → Earth.
FMS communication branch	Within an FMS communication branch the users communicate on the basis of the PROFIBUS FMS protocol via a PROFIBUS FMS network.
Folder	This object type is used to create the hierarchical structure of a project.
General interrogation (GI)	During the system start-up the state of all the process inputs, of the status and of the fault image is sampled. This information is used to update the system-end process

image. The current process state can also be sampled after a data loss by means of a GI.

GOOSE messages	The GOOSE messages (Generic Object Oriented Substation Event) are data packages which are transmitted event-controlled via the Ethernet communication system. They are used for a direct information exchange between devices. This mechanism enables the cross-communication between bay units.
GPS	Global Positioning System. Satellites with atomic clocks on board orbit the earth twice a day in different parts in approx. 20,000 km. They transmit signals which also contain the GPS universal time. The GPS receiver determines its own position from the signals received. From its position it can derive the running time of a satellite and thus correct the transmitted GPS universal time.
Hierarchy level	Within a structure with higher-level and lower-level objects a hierarchy level is a container of equivalent objects.
HV field description	The HV project description file contains details of fields which exist in a ModPara-project. The actual field information of each field is memorized in a HV field description file. Within the HV project description file, each field is allocated such a HV field description file by a reference to the file name.
HV project description	All the data is exported once the configuration and parameterisation of PCUs and sub-modules using ModPara has been completed. This data is split up into several files. One file contains details about the fundamental project structure. This also includes, for example, information detailing which fields exist in this project. This file is called a HV project description file.
ID	Internal double point indication → Double-point indication
ID_S	Internal double point indication intermediate position 00, → Double-point indication
IEC	International Electrotechnical Commission
IEC address	Within an IEC bus a unique IEC address has to be assigned to each SIPROTEC 4 device. A total of 254 IEC addresses are available for each IEC bus.
IEC communication branch	Within an IEC communication branch the users communicate on the basis of the IEC60-870-5-103 protocol via an IEC bus.
IEC61850	International communication standard for communication in substations. The objective of this standard is the interoperability of devices from different manufacturers on the station bus. An Ethernet network is used for data transfer.
Initialization string	An initialization string comprises a range of modem-specific commands. These are transmitted to the modem within the framework of modem initialization. The commands can, for example, force specific settings for the modem.

Inter relay communication	→ IRC combination
IRC combination	Inter Relay Communication, IRC, is used for directly exchanging process information between SIPROTEC 4 devices. You require an object of type IRC combination to configure an Inter Relay Communication. Each user of the combination and all the necessary communication parameters are defined in this object. The type and scope of the information exchanged among the users is also stored in this object.
IRIG-B	Time signal code of the Inter-Range Instrumentation Group
IS	Internal single point indication → Single point indication
IS_F	Single-point indication fleeting → Transient information, → Single point indication
ISO 9001	The ISO 9000 ff range of standards defines measures used to ensure the quality of a product from the development stage to the manufacturing stage.
Link address	The link address gives the address of a V3/V2 device.
List view	The right pane of the project window displays the names and icons of objects which represent the contents of a container selected in the tree view. Because they are displayed in the form of a list, this area is called the list view.
LV	Limit value
LVU	Limit value, user-defined
Master	Masters may send data to other users and request data from other users. DIGSI operates as a master.
Metered value	Metered values are a processing function with which the total number of discrete similar events (counting pulses) is determined for a period, usually as an integrated value. In power supply companies the electrical work is usually recorded as a metered value (energy purchase/supply, energy transportation).
MLFB	MLFB is the abbreviation for "MaschinenLesbare FabrikateBezeichnung" (machine-readable product designation). This is the equivalent of an order number. The type and version of a SIPROTEC 4 device are coded in the order number.
Modem connection	This object type contains information on both partners of a modem connection, the local modem and the remote modem.
Modem profile	A modem profile consists of the name of the profile, a modem driver and may also comprise several initialization commands and a user address. You can create several modem profiles for one physical modem. To do so you need to link various initialization commands or user addresses to a modem driver and its properties and save them under different names.

Modems	Modem profiles for a modem connection are saved in this object type.
MV	Measured value
MVMV	Metered value which is formed from the measured value
MVT	Measured value with time
MVU	Measured value, user-defined
Navigation pane	The left pane of the project window displays the names and symbols of all containers of a project in the form of a folder tree.
Object	Each element of a project structure is called an object in DIGSI.
Object properties	Each object has properties. These might be general properties that are common to several objects. An object can also have specific properties.
Off-line	In Off-line mode a link with the SIPROTEC 4 device is not necessary. You work with data which are stored in files.
OI_F	Output indication fleeting → Transient information
On-line	When working in On-line mode, there is a physical link to a SIPROTEC 4 device which can be implemented in various ways. This link can be implemented as a direct connection, as a modem connection or as a PROFIBUS FMS connection.
OUT	Output indication
Parameter set	The parameter set is the set of all parameters that can be set for a SIPROTEC 4 device.
Phone book	User addresses for a modem connection are saved in this object type.
PMV	Pulse metered value
Process bus	Devices with a process bus interface allow direct communication with SICAM HV modules. The process bus interface is equipped with an Ethernet module.
PROFIBUS	PROcess Field BUS, the German process and field bus standard, as specified in the standard EN 50170, Volume 2, PROFIBUS. It defines the functional, electrical, and mechanical properties for a bit-serial field bus.
PROFIBUS address	Within a PROFIBUS network a unique PROFIBUS address has to be assigned to each SIPROTEC 4 device. A total of 254 PROFIBUS addresses are available for each PROFIBUS network.

Project	Content-wise, a project is the image of a real power supply system. Graphically, a project is represented by a number of objects which are integrated in a hierarchical structure. Physically, a project consists of a series of folders and files containing project data.
Protection devices	All devices with a protective function and no control display.
Reorganizing	Frequent addition and deletion of objects gives rise to memory areas that can no longer be used. By cleaning up projects, you can release these memory areas again. However, a clean up also reassigns the VD addresses. The consequence of that is that all SIPROTEC 4 devices have to be reinitialised.
RIO file	Relay data Interchange format by Omicron.
RSxxx-interface	Serial interfaces RS232, RS422/485
SCADA Interface	Rear serial interface on the devices for connecting to a control system via IEC or PROFIBUS.
Service port	Rear serial interface on the devices for connecting DIGSI (for example, via modem).
Setting parameters	General term for all adjustments made to the device. Parameterization jobs are executed by means of DIGSI or, in some cases, directly on the device.
SI	→ Single point indication
SI_F	→ Single-point indication fleeting → Transient information, → Single point indication
SICAM SAS	Modularly structured station control system, based on the substation controller → SICAM SC and the SICAM WinCC operator control and monitoring system.
SICAM SC	Substation Controller. Modularly structured substation control system, based on the SIMATIC M7 automation system.
SICAM WinCC	The SICAM WinCC operator control and monitoring system displays the state of your network graphically, visualizes alarms, interrupts and indications, archives the network data, offers the possibility of intervening manually in the process and manages the system rights of the individual employee.
Single command	Single commands are process outputs which indicate 2 process states (for example, ON/OFF) at one output.
Single point indication	Single indications are items of process information which indicate 2 process states (for example, ON/OFF) at one output.
SIPROTEC	The registered trademark SIPROTEC is used for devices implemented on system base V4.

SIPROTEC 4 device	This object type represents a real SIPROTEC 4 device with all the setting values and process data it contains.
SIPROTEC 4 variant	This object type represents a variant of an object of type SIPROTEC 4 device. The device data of this variant may well differ from the device data of the source object. However, all variants derived from the source object have the same VD address as the source object. For this reason they always correspond to the same real SIPROTEC 4 device as the source object. Objects of type SIPROTEC 4 variant have a variety of uses, such as documenting different operating states when entering parameter settings of a SIPROTEC 4 device.
Slave	A slave may only exchange data with a master after being prompted to do so by the master. SIPROTEC 4 devices operate as slaves.
Time stamp	Time stamp is the assignment of the real time to a process event.
Topological view	DIGSI Manager always displays a project in the topological view. This shows the hierarchical structure of a project with all available objects.
Transformer Tap Indication	Transformer tap indication is a processing function on the DI by means of which the tap of the transformer tap changer can be detected together in parallel and processed further.
Transient information	A transient information is a brief transient → single-point indication at which only the coming of the process signal is detected and processed immediately.
Tree view	The left pane of the project window displays the names and symbols of all containers of a project in the form of a folder tree. This area is called the tree view.
TxTap	→ Transformer Tap Indication
User address	A user address comprises the name of the station, the national code, the area code and the user-specific phone number.
Users	From DIGSI V4.5 onward , up to 32 compatible SIPROTEC 4 devices can communicate with one another in an Inter Relay Communication combination. The individual participating devices are called users.
VD	A VD (Virtual Device) includes all communication objects and their properties and states that are used by a communication user through services. A VD can be a physical device, a module of a device or a software module.
VD address	The VD address is assigned automatically by DIGSI Manager. It exists only once in the entire project and thus serves to identify unambiguously a real SIPROTEC 4 device. The VD address assigned by DIGSI Manager must be transferred to the SIPROTEC 4 device in order to allow communication with DIGSI Device Editor.
VFD	A VFD (Virtual Field Device) includes all communication objects and their properties and states that are used by a communication user through services.

Index

A

AC voltage 520
 Acknowledgement of Commands 442
 Adaptive dead time (ADT) 304
 Additional functions 574
 Analog inputs 20
 Analog inputs and outputs 519
 Analog/digital converters 21
 Ancillary functions 414
 Angle of inclination of the tripping characteristics 127
 Angular Dependence 131
 Assignment to the polygons 142
 Asymmetrical Measuring Voltage Failure 389
 Automatic reclosing
 Action times 287
 External automatic reclosing device 296
 Automatic Reclosure
 Circuit breaker auxiliary contacts 290
 Automatic reclosure 285
 Blocking 289
 Circuit breaker test 401
 Control 297
 Control mode 288
 Initiation 287
 Multi-shot 292
 Selectivity 286
 Single-pole reclose cycle 291
 Single-pole/three-pole reclose cycle 292
 Three-pole reclose cycle 291
 Automatic reclosure function 24, 558
 Auxiliary contacts of the CB 360
 Auxiliary voltage 451, 520

B

Binary Inputs 520
 Binary Outputs 416
 Blocking 218
 Blocking 219
 Blocking of Zone Z1 124
 Breaker Failure Protection 368
 Breaker Intertrip
 Receiving Circuit 107
 Remote Tripping 107
 Transmission Circuit 106
 Broken-wire monitoring 382
 Buffer battery 378
 Busbar tripping 491

C

Calculation of the Impedances 118
 Certifications 530
 Chain topology 75
 Characteristics
 Definite-time 24
 Inverse-time 24
 Charge comparison stage
 Pickup value 101
 Charging current values 427
 Check:
 Blocking scheme 510
 Blocking scheme (earth fault protection) 512
 Data connection of serial interfaces 471
 Instrument transformer connections for more than two ends 506
 Operator interface 471
 Permissive (release) schemes 509
 Permissive schemes (earth fault protection) 511
 Permissive underreach transfer trip 510
 Phase rotation 492
 Pilot wire comparison 508
 Polarity check for the voltage input U_4 498
 Polarity for the current measuring input I_4 500
 Power plant connections 474
 Protection data communication 473
 Reverse interlocking 508
 Service interface 471
 Signal transmission (breaker failure protection/stub fault protection) 513
 Signal transmission (int., ext. remote tripping) 513
 System interface 471
 Teleprotection scheme (distance protection) 508
 Termination 472
 Time synchronization interface 472, 478
 Trip and close with the circuit breaker 514
 Voltage connections 492
 Checking:
 Switching Configured Operating Devices 514
 Checking the States of the Binary Inputs/Outputs 481
 System Interface 479
 Checks:
 Instrument transformer connections of two line ends 494
 Polarity 496
 Circuit breaker

- Closing time 50
- External local trip 260
- Measuring the operating time 507
- Position detection 399
- Position logic 400
- Test 50
- Test programs 409
- Changing Setting Groups
 - Changing 447
- Circuit Breaker Failure Protection
 - Circuit Breaker Monitoring 566
 - End Fault Protection 566
 - Initiation Conditions 566
 - Pole Discrepancy Supervision 566
 - Times 566
- Circuit Breaker
 - Trip Test 514
 - Device Fault 366
- Circuit breaker failure protection 358
- Circuit breaker failure protection 566
- Circuit breaker for voltage transformers 390
- Circuit Breaker not Operational 370
- Circuit breaker status 64
- Climatic Stress Tests 529
- Climatic tests 529
- Clock Time Synchronization 576
- CLOSE-command transmission 295
- Closing check 559
- Closing Check Operating Modes 316
- Closing under asynchronous system conditions 317
- Closing under Synchronous System
 - Conditions 317
- Command 437
- Command Execution 438
- Command Output 442
- Command Path 437
- Command Processing 436
- Command Types 436
- Commissioning aids 33
- Commissioning mode 80
- Commissioning Tools 576
- Commissioning tools 414
- Communication 24
 - Monitoring 78
 - Operating mode 79
- Communication Chain 75
- Communication connection 85
- Communication converter 76, 485, 485
- Communication Media 76
- Comparison Schemes
 - Earth Fault Protection 550
- Comparison schemes
 - Earth fault protection 233
- Configuration of auto-reclosure 303
- Configuration of Function Scope 38

- Contact mode for binary outputs 452
- Control Logic 441
- Control voltage for binary inputs 452
- Controlled Zone 160
- Controlled zone 147
- Cross polarization 153
- CT error characteristic 52
- Cubicle Mounting 577, 578
- Cubicle mounting 468
- Current Flow Monitoring 359
- Current Inputs 519
- Current pickup
 - Voltage and angle-dependent $U/I/\phi$ 116
 - Voltage-dependent U/I 114
- Current transformer characteristic 50
- Current Transformer Saturation 64

D

- DC voltage 520
- DCF 77 33
- Dead line check (DLC) 304
- Dead-line Closing 317
- Default displays 417
- Delay Times for Single-stage/two-stage Circuit Breaker Protection 364
 - Definite time high-set current stage $3I_0 >>$ 209
 - Definite time overcurrent stage $3I_0 >$ 209
- Definite Time Stages 220
 - Definite time very high-set current stage $3I_0 >>>$ 208
- Dependent zone 143
- Determination of direction 138
 - MHO characteristic 150
 - Negative sequence system 216
 - Series-compensated lines 141, 154
 - Zero sequence system power (compensated) 216
- Device identification 85
- Differential current
 - Pickup value 99
- Differential current values 427
- Differential Protection
 - Basic Principle with Multiple Ends 89
 - Basic Principle with Two Ends 89
 - Charge Comparison 96
 - Communication Chain 91
 - Current Transformers Errors 93
 - Inrush Restraint 94
 - Measurement Quantities 95
 - Operating Times 533
 - Pickup 98
 - Pickup Values 533
 - Transmission of Measured Value 90
 - Tripping Logic 98

Differential protection 27
 Blocking 97
 Charging current compensation 92, 101
 Delay times 534
 Delays 101
 Emergency operation 534
 Further influences 93
 Inrush restraint 102, 534
 Interblocking 97
 Measured value synchronization 91
 Pickup values 99, 101, 101
 Protection data interfaces 531
 Restraint 92
 Self-restraint 534
 Special features 39
 Tolerances 93
 Topology 531
 Zone Z1 124
 Direct connection 76
 Direct Transfer Trip 181
 Direction determination
 Zero sequence system 215
 Directional Blocking Scheme 192
 Directional characteristic 140
 Directional Comparison Pickup 185
 Directional comparison pickup 233
 Directional Unblocking Scheme 187
 Display panel 417
 Distance Protection
 Earth Fault Detection 536
 Earth Impedance Ratio 536
 Mutual Impedance Ratio 536
 Phase References 536
 Times 538
 Distance protection 28, 110
 Distance measurement 537
 Earth impedance ratio 50
 Emergency operation 538
 Fault detection 113
 Pickup 536
 Special features 40
 Teleprotection schemes 540
 Zone Z1 124
 Double Earth Faults in Effectively Earthed Systems 127
 Double Earth Faults in Non-earthed Systems 122
 Double earth faults in non-earthed systems 127
 Double Faults in Effectively Earthed Systems 121

E

Earth Fault Detection 110
 Earth fault detection 125
 Earth Fault Protection
 Characteristics 541, 541

 Determination of Direction 544
 High Current Stage 541
 Zero Sequence Power Protection Stage 543
 Zero Sequence Voltage Time Protection Stage (U0-inverse) 543
 Earth fault protection 541
 Determination of direction 225
 Inrush restraint 543
 Inverse time overcurrent stage with logarithmic inverse characteristic 542
 Inverse-time stage with ANSI characteristic 542
 Inverse-time stage with IEC characteristic 542
 Teleprotection schemes 550
 Zero sequence power stage 224
 Earth Fault Protection Definite Time Overcurrent Stage 541
 Earth Impedance (Residual) Compensation 60
 Echo Function 200
 Echo function 204
 Echo function (EF) 247
 Electrical tests 526
 EMC Tests for Interference Immunity (type tests) 527
 EMC Tests for Noise Emission (type test) 527
 Emergency operation 24
 End Fault Protection 370
 Event buffer 418
 Exchanging interfaces 452
 External trip of the local tripping 535

F

Fast tripping zone (MHO) 157
 Fast tripping zone (polygon) 143
 Fault Annunciations 412
 Fault direction 138
 Fault locating
 Single-ended 349
 Fault location
 Earth impedance ratio 50
 Fault location options 420
 Fault locator 565
 Double earth fault 348
 Double-ended 349
 Single/double-ended 348
 Fault loops 138
 Fault Protocol 575
 Fault Recording 575
 Fault recording 25, 418, 429
 Feedback Monitoring 442
 Fernmesswerte 428
 Fibre-optic cables 76, 473
 Final Preparation of the Device 516
 Flush Mounting 577, 578

Forced three-pole trip 304
 Frequency 534
 Frequency Protection 342
 Operating Ranges 564
 Pickup Values 564
 Times 564
 Tolerances 564
 Frequency protection 564
 Delay 345
 Frequency measurement 342
 Frequency stages 342
 Operating ranges 343
 Overfrequency protection 342
 Pickup values 345
 Pickup/tripping 343
 Power swings 343
 Underfrequency protection 342
 Function Control 396
 Function Modules 571
 Functional scope 37
 Fuse Failure Monitor 389
 Fuse-Failure-Monitor 383

G

General 37
 General interrogation 420
 General Pickup 162
 GPS 33
 GPS Synchronization 82
 GPS synchronization 81
 Grading Coordination Chart 143, 157

H

High-set stages $I_{ph}>>, 3I_0>>$ 275
 Humidity 529

I

IBS-Tool 33
 Impedance pickup
 Implicit 113
 Independent zones 143, 145, 157, 158
 Indications 419
 Information exchange 85
 Information to a Control Centre 418
 Initiation breaker failure protection 361
 Input/output board C-I/O-1
 Input/output board C-I/O-10 455
 Input/Output board
 C-I/O-2 460

Inrush restraint 227
 Inrush stabilization 215
 Instantaneous High-current Switch-onto-Fault Protection 265
 Instantaneous High-set current Switch-onto-Fault Protection 554
 Instantaneous trip
 $I>>>$ stage 265
 $I>>>>$ stage 265
 Instantaneous tripping
 Before automatic reclosure 273
 Instrument transformer connections
 Check with more than two ends 506
 Differential currents 505
 Polarity check 496
 Polarity check for the current input I_4 500
 Polarity check for the voltage input U_4 498
 Restraint currents 505
 Insulation Test 526
 Interfaces 85
 Exchange 462
 RS232 463
 RS485 464
 Termination 465
 Intertrip 108
 Inverse Time Overcurrent Stage 211
 Inverse time overcurrent stage (Earth fault protection)
 Logarithmic inverse characteristic 222, 542
 Inverse time overcurrent stage (earth fault protection)
 ANSI characteristic 221, 542
 IEC characteristic 221, 542
 Inverse time overcurrent stage (overcurrent protection)
 ANSI characteristic 556
 IEC characteristic 556
Inverse time overcurrent stage $3I_{0P}$ 209
 IRIG B 33

K

K- Factor 374

L

Life contact 451
 Limit Value Monitoring 434
 Limits for CFC Blocks 572
 Limits for User-defined Functions 572
 Line energization recognition 396
 Line sections 348, 351
 Line symmetry (double-ended fault locator) 351

Load Range (only for Impedance Pickup) 128
 Log buffer 33
 Long-term Average Values 431

M

Measured value correction
 Double-end fed lines 352
 Parallel line 351
 Measured Values 569
 Measured values constellation 429
 Measured voltage failure monitoring 385
 Measured voltage failure supervision 389
 Measurement value acquisition
 Currents 379
 Measures for Weak and Zero Infeed 200
 Measuring voltage failure 384
 Mechanical design 530
 Mechanical Tests 528
 Memory modules 378
 MHO characteristic 150
 Pickup 156
 Minimum Current 125
 Modem 76
 Monitoring 78
 Monitoring Function 569
 Monitoring functions 32
 Mounting: Panel Surface Mounting 470

N

Nominal accuracy limit factor 51
 Nominal currents 451
 Nominal frequency 49
 Non-delayed Tripping 256

O

Open Pole Detector 402
 Operating Interface 522
 Operating polygon 137
 Operating polygons 137
 Operating time of the circuit breaker 507
 Operational accuracy limit factor 51
 Operational Event Log Buffer 575
 Operational indications 419
 Operational measured values 423, 574
 Operator interface
 Check 471
 Optical fibres 473
 Ordering Data 582
 Oscillographic recording for test 515

Output Relay 416
 Overcurrent Pickup 113
 Overcurrent pickup
 $U/I/\phi$ pickup 129
 U/I pickup 129
 Overcurrent Stage
 I_P (inverse-time) 271
 Overcurrent stage
 $3I_0 >$ (Definite-time O/C protection) 277
 $3I_{OP}$ (Inverse-time O/C protection with ANSI characteristics) 279
 $3I_{OP}$ (Inverse-time O/C protection with IEC characteristics) 278
 $I >$ (definite-time) 271
 I_P (Inverse-time O/C protection with ANSI characteristics) 279
 I_P (Inverse-time O/C protection with IEC characteristics) 278
 $I_{ph} >$ (Definite-time O/C protection) 277
 Overreach Schemes
 Distance Protection 182, 540
 Overtemperature 376
 Overvoltage protection 325
 Any single-phase voltage 562
 Compounding 327
 Negative sequence system U_2 328, 335, 561
 Phase-earth 334, 561
 Phase-phase 326, 334, 561
 Positive sequence system U_1 326, 334, 561
 Zero sequence system 335
 Zero sequence system $3U_0$ 329, 562

P

Panel flush mounting 466
 Parallel Line Measured Value Correction 123, 127
 Parallel Line Mutual Impedance 63
 Parallel protection functions 38
 Permissive Overreach Transfer Trip (POTT)
 Distance Protection 182
 Permissive Underreach Transfer Trip with Zone Acceleration Z1B (PUTT) 179
 Phase current restraint 227
 Phase current stabilization 214
 Phase Selection 256
 Phase Selector 217
 Phase-segregated initiation of the circuit breaker failure protection 362
 Pickup Logic 274
 Pickup Logic for the Entire Device 403
 Pickup Modes 115
 Pilot Wire Comparison 195
 Polarity
 Current transformers 45
 Polarity check 496

Polarity check for the current measuring input
 I_4 500

Polarity check for the voltage input U_4 498

Polarized MHO characteristic 151

Pole Discrepancy Supervision 371

Pole Discrepancy Supervision 367

Polygonal characteristic 137

Power plant connections

Check 474

Power Supply 520

Power system data 1 45

Power System Data 2 56

Printed circuit boards 453

Protection Data Communication 78, 531

Protection data communication

Check 473

Protection Data Interfaces 81, 82

Protection data interfaces 22, 74, 85, 262, 522

Protection Data Topology 74

Protection data topology

Availability of the protection data interfaces 488

Check 484

Check: Communication converter 485

Check: Direct link (topology) 485

Checking further links 488

Configuration 487

Consistency 487

Protection function mode 38

Protection functions 24

PUTT (Pickup) 177

Q

Quality index 348

R

Rack mounting 468

Real Time Clock and Buffer Battery 575

Reclosing Cycle 307

Reclosure cycle 305, 308

Reference Voltages 378

Remote Commands 553

Remote commands 262

Remote Indications 553

Remote indications 262

Remote transmission 30

Remote Tripping 535

Remote tripping 108

Remote-CLOSE 295

Requirements for current transformers 519

Reset 432

Resistance Tolerance 144

Restraint current values 427

Retrievable indications 420

Reverse Interlocking 197

Ring topology 76, 85

S

Series-compensated lines 126

Service / modem interface 522

Service Conditions 529

Service interface

Check 471

Setting group change option 55

Setting groups 55

Single-pole Dead Time 403

Single-stage Breaker Failure Protection 369

Specifications 526

Spontaneous indications 419, 420

Spontaneous Indications on the Display 411

Standard Interlocking 439

Start Triggering Oscillographic Recording 515

Statistics 33, 575, 575

Stromsymmetrie 381

Summation Monitoring 389

Supervision with binary input 395

Switchgear Interlocking 438

Switching

Onto a fault 125, 128

Onto an earth fault 219

Pickup Value 101

Switching onto an Earth Fault 227

Switching (Interlocked/Non-Interlocked) 438

Symmetry Monitoring 389

Synchro-check 314, 559

Synchronism 33

Synchronism Check

Asynchronous Power Conditions 559

Operating Modes 559

Synchronous Power Conditions 559

Voltages 559

ΔU -measurement 559

Synchronism Check Conditions before Automatic

Reclosure 319

Synchronism Check Conditions before Manual

Closing 320

Synchronization 28

System interface

Check 471

System Power Swing 539

System starpoint 49

T

- Teleprotection 175
 - With earth fault protection 226
- Teleprotection Schemes 175
- Termination 465, 472
- Termination of serial interfaces 452
- Test for the Configured Operating Devices 514
- Test Mode 478
- Test mode 80
- Test:
 - Circuit breaker failure protection 490
 - Signal transmission (earth fault protection) 511
 - User-defined functions 513
- Thermal Overload Protection 567
 - Tripping Characteristic 567
- Three-phase measuring voltage failure 389
- Three-pole coupling 66
- Time Constant τ 375
- Time Overcurrent Protection
 - Characteristics 555
 - Definite Time High Set Current Stage 555
 - Definite Time Overcurrent Stage 555
- Time overcurrent protection 24, 30
- Time synchronization 85
- Time synchronization interface 472, 478, 526
- Topology Exploration 262
- Transformer data 45
- Transformers
 - Current matching 534
- Transient Blocking 199, 204, 242
- Transient Blocking (E/F) 246
- Transmission Block 478
- Transmission Channels 175
- Trip Circuit Monitoring 570
- Trip Circuit Supervision 448
- Trip command duration 50
- Trip with Delay 257
- Trip-dependent messages 411
- Tripping characteristic 150
- Tripping Logic 167, 274
- Tripping Logic of the Entire Device 404
- Tripping zones 155
- Two-stage Breaker Failure Protection 368

U

- Umschaltung von Einstellgruppen 447
- Underreach Schemes
 - Distance Protection 540
- Undervoltage protection
 - Phase-earth 330, 336, 562
 - Phase-phase 332, 337, 562
 - Positive sequence system U_1 333, 337, 563
- User Defined Functions 571

V

- Vibration and Shock Stress during Stationary Operation 528
- Vibration and Shock Stress During Transport 528
- Voltage inputs 519
- Voltage Jump 253
- Voltage measuring inputs 47
- Voltage Phase Sequence 382
- Voltage protection 325
- Voltage symmetry 381

W

- Warning Temperature Levels 376
- Watchdog 380
- Weak infeed 243
- Weak-Infeed Tripping
 - Operation Mode 551
 - Times 551
 - Undervoltage 551
- Weak-infeed tripping
 - Classic 551
 - French specification 552
- WEB-Monitor 489, 494, 505
- Web-Monitor 22
- WI Transmission Scheme 250
- WI Undervoltage 250
- Work on the plug connectors 454

Z

- Zero infeed 243
- Zero Sequence Power Protection 213
- Zero sequence voltage stages for single-phase voltage 330
- Zero voltage time protection 212
- Zero Sequence Voltage Stage with Inverse Characteristic 223
- Zone Logic 162
- Zone pickup 155

www.ElectricalPartManuals.com