



Supplemental Instructions for 575 Volt Control Power Transformers

Issued: October 2000

1. The information contained in this Supplemental Literature (SL) supersedes the Control Power Transformer (CPT) selection and installation procedures contained in **all** Cutler-Hammer Digitrip Retrofit Instruction Literature manuals (ILs).
2. A 600 volt CPT is not available for Digitrip Retrofit Kits. However, a 575 volt CPT is available as a special order item. To order a 575 volt CPT, contact Cutler-Hammer at 1-800-973-5487.

Table 1 Voltage Taps for Special Order CPTs

Special Order 575 Volt CPT

575 Volt Circuit	H1 & H4
460 Volt Circuit	H2 & H4
230 Volt Circuit	H3 & H4

3. Changes to the Digitrip Retrofit Installation Components Lists when a 575 volt CPT is special ordered from Cutler-Hammer.

Step	Description	Style No.	Qty.	Comment
Step (Varies)	Breaker Mounted CPT Kit	8259A91G07	1	CPT Only
	CPT (575 Volt)	C0050E3C	1	CPT Only
	Ring Terminals (.138, .190, .250, .312, .375, .500 - Each Size)		2	CPT Only